



Standard of Performance data for the month of Feb'2021

Name of Transmission Licensee : **POWER GRID CORPORATION OF INDIA LTD., EASTERN REGION-I**


Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		DURATION OF OUTAGE					Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified
			DATE	TIME	DATE	TIME	TOTAL	ISTS Licensee	OTHERS	System constraint / Natural	Deemed Availab				
1	ERIL1	132kV ARA-ARA	18/02/21	09:47:00	18/02/21	22:26:00	12.65	0	12.65	0	0	OMSU	SHUTDOWN TAKEN FOR RETROFITTING OF NUMERICAL BACKUP OVER CURRENT AND EARTH FAULT RELAY AT ARA(PG)	ERPC	100
	TOTAL					12.65	0.00	12.65	0.00	0.00					
2	ERIL2	132kV DEHRI - KUDRA						0	0	0	0			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
3	ERIL3	132kV KUDRA - SASARAM						0.00	0.00	0.00	0.00			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
4	ERIL4	132kV Dehri-SASARAM						0.00	0.00	0.00	0.00			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
5	ERIL5	132kV SASARAM- KARAMNASA						0.00	0.00	0.00	0.00			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
6	ERIL6	132kV SASARAM-MOHANIA						0.00	0.00	0.00	0.00			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
7	ERIL7	132kV MOHANIA - KARMASA						0.00	0.00	0.00	0.00			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
8	ERIL8	132kV DUMRAON-ARA	27/02/21	10:17:00	27/02/21	17:00:00	6.72	0	0	0	6.72	OSPD	SHUTDOWN TAKEN FOR POWER LINE CROSSING OF NEWLY CONSTRUCTED 132 KV DUMRAON NEW BGCL-BUXAR TRANS LINE BY BSPTCL.	ERPC	98.32
			11/02/21	09:32:00	11/02/21	20:47:00	11.25	11.25	0	0	0	0	OSPT		
	TOTAL					17.97	11.25	0.00	0.00	6.72					
9	ERIL9	132kV PURNEA-DALKHOLA (LILO PART)						0.00	0.00	0.00	0.00			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
10	ERIL10	132kV PNR-PRN(LILO PART)						0.00	0.00	0.00	0.00			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
11	ERIL11	220kV DALKHOLA-PURNEA I						0	0	0	0			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
12	ERIL12	220kV DALKHOLA-PURNEA II						0	0	0	0			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
13	ERIL13	220 kV PURNEA - NEW PURNEA-I						0.00	0.00	0.00	0.00			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
14	ERIL14	220 kV PURNEA - NEW PURNEA-II						0	0	0	0			ERPC	100
	TOTAL						0	0	0	0					
15	ERIL15	220kV SASARAM-NADOKHAR I	27/02/21	11:42:00	27/02/21	19:05:00	7.38	0	0	0	7.38	OSPD	SHUTDOWN TAKEN FOR WINTER MAINTENANCE WORK BY BSPTCL.	ERPC	100
	TOTAL						7.38	0.00	0.00	0.00	7.38				
16	ERIL16	220kV NADOKHAR -ARRAH II						0.00	0.00	0.00	0.00			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
17	ERIL17	220kV NADOKHAR-ARRAH I						0	0	0	0			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
18	ERIL18	220kV ARA-KHAGOL I						0	0	0	0			ERPC	100
	TOTAL						0	0	0	0					
19	ERIL19	220kV ARA-KHAGOL II						0	0	0	0			ERPC	100
	TOTAL						0	0	0	0					
20	ERIL20	220kV DEHRI-SASARAM						0.00	0.00	0.00	0.00			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					
21	ERIL21	220kV SASARAM-SAHUPURI						0	0	0	0			ERPC	100
	TOTAL						0	0	0	0					
22	ERIL22	220kV RANCHI-CHANDIL I						0	0	0	0			ERPC	100
	TOTAL						0.00	0.00	0.00	0.00					



Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		DURATION OF OUTAGE					Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified
			DATE	TIME	DATE	TIME	TOTAL	ISTS Licensee	OTHERS	System constraint / Natural	Deemed Availab				
23	ERIL23 TOTAL	220kV RANCHI-CHANDIL-II (LILO)												ERPC	100
24	ERIL24 TOTAL	220kV RANCHI-HATIA-I (LILO)	29/01/21	10:29:00	31/01/21	14:50:00	14.83	0	0	0	14.83	OSPD	FOR REPLACEMENT OF ISOLATORS AT HATIA END UNDER PSDF SCHEME. SHUTDOWN BY JUSNL	ERPC	100
25	ERIL25 TOTAL	220kV RANCHI-HATIA-II(LILO)	01/02/21	00:00:00	03/02/21	16:41:00	73.75	0	0	0	73.75	OSPD	SHUTDOWN TAKEN FOR COMPLETE MAINTANANCE OF ISOLATORS AT HATIA END UNDER PSDF SCHEME. SHUTDOWN TAKEN BY HATIA.	ERPC	100
26	ERIL26 TOTAL	220kV GAYA-DEHRI -I(LILO PART)	01/02/21	10:30:00	01/02/21	18:04:00	7.57	0	0	0	7.57	OSPD	FOR REMOVAL OF HANGING BURNT PILOT ROPE USED FOR INSTALLATION OF OPGW BETWEEN LOC-269-273.SHUTDOWN TAKEN BY BSPTCL.	ERPC	100
			02/02/21	10:47:00	02/02/21	16:17:00	5.5	0	0	0	5.5	OSPD	FOR REMOVAL OF HANGING BURNT PILOT ROPE USED FOR INSTALLATION OF OPGW BETWEEN LOC-269-273.SHUTDOWN TAKEN BY BSPTCL.	ERPC	100
27	ERIL27 TOTAL	220kV GAYA-BODHGAYA(BSEB) I	07/02/21	11:09:00	07/02/21	13:14:00	2.08	0	0	0	2.08	OSPD	SHUTDOWN TAKEN BY BSPTCL FOR BUS MAINTENANCE AT BODH GAYA.	ERPC	100
28	ERIL28 TOTAL	220kV GAYA-DEHRI-II (LILO PART)	01/02/21	10:31:00	01/02/21	18:05:00	7.57	0	0	0	7.57	OSPD	FOR REMOVAL OF HANGING BURNT PILOT ROPE USED FOR INSTALLATION OF OPGW BETWEEN LOC-269-273.SHUTDOWN TAKEN BY BSPTCL.	ERPC	99.71
			02/02/21	10:48:00	02/02/21	16:18:00	5.5	0	0	0	5.5	OSPD	FOR REMOVAL OF HANGING BURNT PILOT ROPE USED FOR INSTALLATION OF OPGW BETWEEN LOC-269-273.SHUTDOWN TAKEN BY BSPTCL.	ERPC	
			25/02/21	14:41:00	25/02/21	16:38:00	1.95	1.95	0	0	0	OSPT	FOR ATTENDING SF6 LOSS ALARM IN Y-PHASE LINE CT AT GAYA.	ERPC	
29	ERIL29 TOTAL	220kV GAYA-BODHGAYA(BSEB) II					0	0	0	0	0			ERPC	100
30	ERIL30 TOTAL	200KV RANCHI- HATIA-III(LILO)	04/02/21	11:11:00	06/02/21	17:04:00	53.88	0	0	0	53.88	OSPD	SHUTDOWN TAKEN FOR COMPLETE MAINTANANCE OF ISOLATORS AT HATIA END UNDER PSDF SCHEME. SHUTDOWN TAKEN BY HATIA.	ERPC	99.46
			26/02/21	15:18:00	26/02/21	18:54:00	3.6	3.6	0	0	0	OSPT	SHUTDOWN TAKEN TO ATTEND HOT SPOT IN Y-PH LINE ISOLATOR AT RANCHI.	ERPC	
31	ERIL31 TOTAL	220kV SASARAM-NADOKHAR II					0	0	0	0	0			ERPC	100
32	ERIL32 TOTAL	400kV FARAKKA-KAHALGAON I					0	0	0	0	0			ERPC	100
33	ERIL33 TOTAL	400kV FARAKKA-KAHALGAON II					0	0	0	0	0			ERPC	100
34	ERIL34 TOTAL	400kV KAHALGAON-FARAKKA III	06/02/21	10:36:00	06/02/21	19:30:00	8.9	0	0	0	8.9	OSPD	SHUTDOWN TAKEN FOR PROTECTION CHECKING OF MAIN AND TIE BAY CB AT FSTPP. SHUTDOWN TAKEN BY FSTPP.	ERPC	100
35	ERIL35 TOTAL	400kV KAHALGAON-FARAKKA IV					0	0	0	0	0			ERPC	100
36	ERIL36 TOTAL	400kV KAHALGAON-LAKHISARAI I					0	0	0	0	0			ERPC	100
37	ERIL37 TOTAL	400kV BIHARSHARIFF-LAKHISARAI I					0	0	0	0	0			ERPC	100
38	ERIL38 TOTAL	400kV KAHALGAON-LAKHISARAI II					0	0	0	0	0			ERPC	100
39	ERIL39 TOTAL	400kV BIHARSHARIF-LAKHISARAI II	02/02/21	11:23:00	02/02/21	19:05:00	7.7	7.7	0	0	0	OSPT	SHUTDOWN TAKEN FOR ATTENDING HOT SPOT IN B PH WAVE TRAP AT LAKHISARAI END.	ERPC	98.85
40	ERIL40 TOTAL	400kV KAHALGAON-BANKA-I					0	0	0	0	0			ERPC	100
41	ERIL41	400kV BIHARSHARIF-BANKA I					0	0	0	0	0			ERPC	100



Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		TOTAL	DURATION OF OUTAGE				Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified
			DATE	TIME	DATE	TIME		ISTS Licensee	OTHERS	System constraint / Natural	Deemed Availab				
	TOTAL							0.00	0.00	0.00	0.00				
42	ERIL42	400kV KAHALGAON-BANKA-II						0	0	0	0			ERPC	100
	TOTAL							0.00	0.00	0.00	0.00				
43	ERIL43	400KV BIHARSHARIF-BANKA II						0	0	0	0			ERPC	100
	TOTAL							0.00	0.00	0.00	0.00				
44	ERIL44	400kV JAMSHEDPUR-CHAIBASA I						0	0	0	0			ERPC	100
	TOTAL							0.00	0.00	0.00	0.00				
45	ERIL45	400kV JAMSHEDPUR-CHAIBASA II	26/02/21	12:59:00	26/02/21	15:53:00	2.9	0	0	2.9	0	GOVC	400KV CHAIBASA-JAMSHEDPUR-II TRIPPED IN OVER VOLTAGE.	ERPC	100
	TOTAL						2.9	0.00	0.00	2.90	0.00				
46	ERIL46	400kV CHAIBASA-ROURKELA I						0	0	0	0			ERPC	100
	TOTAL							0.00	0.00	0.00	0.00				
47	ERIL47	400kV CHAIBASA-ROURKELA II	26/02/21	12:59:00	26/02/21	17:14:00	4.25	0	0	4.25	0	GOVC	400KV CHAIBASA-ROURKELA-II TRIPPED IN OVER VOLTAGE.	ERPC	100
	TOTAL						4.25	0.00	0.00	4.25	0.00				
48	ERIL48	400kV MAITHON-KAHALGAON I						0	0	0	0			ERPC	100
	TOTAL							0	0	0	0				
49	ERIL49	400kV MAITHON-KAHALGAON II	11/02/21	09:36:00	12/02/21	19:19:00	33.72	0	0	0	33.72	OSPD	SHUTDOWN TAKEN FOR ANNUAL BAY MAINTENANCE AND RELAY TESTING AT KAHALGAON. SHUTDOWN TAKEN BY NTPC KAHALGAON.	ERPC	99.38
			06/02/21	13:03:00	06/02/21	17:13:00	4.17	4.17	0	0	0	OSPT	SHUTDOWN TAKEN TO ATTEND HOTSPOT IN LINE ISOLATOR AT MAITHON SS. SHUTDOWN TAKEN BY ER-II.		
	TOTAL						37.89	4.17	0	0	33.72				
50	ERIL50	400kV BIHARSHARIF-SASARAM-I	20/02/21	16:23:00	21/02/21	01:39:00	9.27	0	0	9.27	0	LNCC	SHUTDOWN TAKEN FOR REPLACEMENT OF INSULATOR AT LOC 401 DECAPPED DUE TO DENSE FOG.	ERPC	100
	TOTAL						9.27	0.00	0.00	9.27	0.00				
51	ERIL51	400kV SASARAM - VARANASI						0	0	0	0			ERPC	100
	TOTAL							0	0	0	0				
52	ERIL52	400kV SASARAM - ALLAHABAD - I						0.00	0.00	0.00	0.00			ERPC	100
	TOTAL							0.00	0.00	0.00	0.00				
53	ERIL53	400kV SASARAM - ALLAHABAD - II						0	0	0	0			ERPC	100
	TOTAL							0	0	0	0				
54	ERIL54	400kV BIHARSHARIF - BALIA - I						0	0	0	0			ERPC	100
	TOTAL							0	0	0	0				
55	ERIL55	400kV BIHARSHARIF - BALIA - II	25/02/21	10:30:00	25/02/21	10:30:00	0	0	0	0	0	LART	SUCCESSFULLY A/R FROM BOTH ENDS DUE TO Y-N FAULT. BSF-M1-200.5 KM, F.C.=1.575 KA. BALIA-M1-49.9 KM,9.1 KA.	ERPC	100
	TOTAL						0.00	0.00	0.00	0.00	0.00				
56	ERIL56	400kV PATNA - BALIA - I						0	0	0	0			ERPC	100




Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		DURATION OF OUTAGE				Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified	
			DATE	TIME	DATE	TIME	TOTAL	ISTS Licensee	OTHERS	System constraint / Natural					Deemed Availab
56								0	0	0	0				
	TOTAL							0	0	0	0				
57	ER1L57	400kV PATNA - BALIA -II						0	0	0	0		ERPC	100	
	TOTAL							0	0	0	0				
58	ER1L58	400kV PATNA - BALIA -III	26/02/21	07:48:00	26/02/21	19:34:00	11.77	0	11.77	0	0	OMSU	LINE WAS UNDER SHUTDOWN FOR REPLACEMENT OF PORCELAIN INSULATOR WITH POLYMER INSULATOR.	ERPC	100
	TOTAL						11.77	0	11.77	0	0				
59	ER1L59	400kV PATNA - BALIA -IV	27/02/21	07:57:00	27/02/21	19:34:00	11.62	0	11.62	0	0	OMSU	SHUTDOWN TAKEN FOR REPLACEMENT OF PORCELAIN INSULATOR WITH POLYMER INSULATOR.	ERPC	100
	TOTAL						11.62	0.00	11.62	0.00	0.00				
60	ER1L60	400kV BIHARSHARIF-SASARAM-II						0	0	0	0		ERPC	100	
	TOTAL							0	0	0	0			100	
61	ER1L61	400KV PATNA-BARH III						0	0	0	0		ERPC	100	
	TOTAL							0.00	0.00	0.00	0.00			100	
62	ER1L62	400KV PATNA-BARH IV						0	0	0	0		ERPC	100	
	TOTAL							0.00	0.00	0.00	0.00			100	
63	ER1L63	400KV MUZAFFARPUR-BIHARSHARIF I						0.00	0.00	0.00	0.00		ERPC	100	
	TOTAL							0.00	0.00	0.00	0.00			100	
64	ER1L64	400KV MUZAFFARPUR-BIHARSHARIF II						0	0	0	0		ERPC	100	
	TOTAL							0.00	0.00	0.00	0.00			100	
65	ER1L65	400kV KAHALGAON-BARH I						0	0	0	0		ERPC	100	
	TOTAL							0.00	0.00	0.00	0.00			100	
66	ER1L66	400kV KAHALGAON-BARH II	13/02/21	00:02:00	13/02/21	01:19:00	1.28	0	0	1.28	0	LNCC	TRIPPED ON R-N FAULT DUE TO DENSE FOG AROUND THE FAULT AREA. FD-122.34KM FROM KAHALGAON AND FC-4.01KA	ERPC	100
	TOTAL		13/02/21	01:19:00	13/02/21	08:00:00	6.68	0	0	0	6.68	LVRD	HAND TRIPPED DUE TO HIGH VOLTAGE AS PER ERLDC INSTRUCTION.		
	TOTAL						7.96	0.00	0.00	1.28	6.68				
67	ER1L67	400kV PATNA-BARH I						0	0	0	0		ERPC	100	
	TOTAL							0	0	0	0				
	TOTAL							0.00	0.00	0.00	0.00				
68	ER1L68	400kV PATNA-BARH II	13/02/21	09:25:00	13/02/21	18:55:00	9.5	0	0	9.5	0	LNCC	SHUTDOWN TAKEN FOR REPLACEMENT OF DECAPPED INSULATOR STRING AT LOC. LILO-12 (DA+0, MIDDLE PHASE) DUE TO DENSE FOG AROUND THE FAULT AREA	ERPC	100
	TOTAL						9.50	0.00	0.00	9.50	0.00				
69	ER1L69	400kV MAITHON-RANCHI I						0	0	0	0		ERPC	100	
	TOTAL							0.00	0.00	0.00	0.00				
70	ER1L70	400kV RAGHUNATHPUR-MAITHON						0	0	0	0		ERPC	100	
	TOTAL							0.00	0.00	0.00	0.00				
71	ER1L71	400kV RANCHI-RAGHUNATHPUR I(LILO of Maithon-						0	0	0	0		ERPC	100	
	TOTAL							0	0	0	0				
72	ER1L72	400kV MAITHON RB-RANCHI I	14/02/21	08:09:00	15/02/21	20:22:00	36.22	0	36.22	0	0	OMSU	POWER LINE CROSSING DURING RE-CONDUCTORING WORK OF 400KV MAITHON – RIGHT BANK-CKT-I (LOC.NO. 91-92).SHUTDOWN BY ER-2	ERPC	100
	TOTAL		18/02/21	08:20:00	19/02/21	18:25:00	34.08	0	34.08	0	0	OMSU	POWER LINE CROSSING DURING RE-CONDUCTORING WORK OF 400KV MAITHON – RIGHT BANK-CKT-II (LOC.NO. 91-92).SHUTDOWN BY ER-2		
	TOTAL						70.3	0	70.3	0	0				



Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		DURATION OF OUTAGE				Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified	
			DATE	TIME	DATE	TIME	TOTAL	ISTS Licensee	OTHERS	System constraint / Natural					Deemed Availab
73	ER1L73	400kV MAITHON RB-RANCHI II	14/02/21	08:16:00	15/02/21	20:23:00	36.12	0	36.12	0	0	OMSU	POWER LINE CROSSING DURING RE-CONDUCTORING WORK OF 400KV MAITHON – RIGHT BANK-CKT-I (LOC.NO. 91-92).SHUTDOWN BY ER-2	ERPC	100
			18/02/21	09:10:00	19/02/21	18:27:00	33.28	0	33.28	0	0	OMSU			
	TOTAL						69.40	0.00	69.40	0.00	0.00				
74	ER1L74	400kV RANCHI-ROURKELA I						0	0	0	0			ERPC	100
								0	0	0	0				
								0	0	0	0				
								0	0	0	0				
			TOTAL						0.00	0.00	0.00	0.00			
75	ER1L75	400kV RANCHI-ROURKELA II	19/02/21	14:55:00	19/02/21	14:55:00	0	0	0	0	0	LART	AUTORECLOSED SUCCESSFULLY FROM BOTH ENDS ON B-N FAULT (TOP PHASE). RANCHI(AFAS DOUBLE END)- M1- F.C-14.646KA F.D.-6.915KM	ERPC	100
			TOTAL					0.00	0.00	0.00	0.00	0.00			
76	ER1L76	400kV BIHARSHARIF-KODERMA I	23/02/21	14:23:00	23/02/21	21:13:00	6.83	0	0	6.83	0	LNCC	SHUTDOWN TAKEN FOR REPLACEMENT OF DECAPPED INSULATOR AT LOC NO.140 DUE TO DENSE FOG.	ERPC	99.03
			12/02/21	11:25:00	12/02/21	17:51:00	6.43	6.43	0	0	0	OSPT			
	TOTAL						13.26	6.43	0.00	6.83	0.00				
77	ER1L77	400kV BIHARSHARIF-KODERMA II						0	0	0	0			ERPC	100
								0	0	0	0				
			TOTAL						0	0	0	0			
78	ER1L78	400kV BIHARSHARIF-VARANASI - I	01/02/21	10:02:00	01/02/21	19:20:00	9.3	0	0	0	9.3	LCSD	FOR OVERHEAD CROSSING WORK OF 765 KV VINCHYACHAL-VARANASI LINE. SHUTDOWN TAKEN BY NR3	ERPC	100
			TOTAL					9.3	0	0	0	9.3			
	ER1L79	400kV BIHARSHARIF-VARANASI - II	01/02/21	10:04:00	01/02/21	19:24:00	9.33	0	0	0	9.33	LCSD	FOR OVERHEAD CROSSING WORK OF 765 KV VINCHYACHAL-VARANASI LINE. SHUTDOWN ATKEN BY NR3	ERPC	100
TOTAL						9.33	0.00	0.00	0.00	9.33					
80	ER1L80	765kV GAYA-BALLIA					0	0	0	0	0			ERPC	100
81	ER1L81	400kV JAMSHEDPUR(DVC)-BARIPADA					0	0	0	0	0			ERPC	100
TOTAL							0.00	0.00	0.00	0.00					
82	ER1L82	400kV BARIPADA-JAMSHEDPUR II	28/02/21	08:00:00	28/02/21	17:58:00	9.97	9.97	0	0	0	OSPT	SHUTDOWN TAKEN FOR LINE ISOLATOR RECTIFICATION WORK AT BARIPADA.	ERPC	98.51
			TOTAL					9.97	9.97	0	0	0			
83	ER1L83	400kV JAMSHEDPUR-JAMSHEDPUR(DVC)					0	0	0	0	0			ERPC	100
TOTAL							0.00	0.00	0.00	0.00					
84	ER1L84	SASARAM - NABINAGAR I						0	0	0	0			ERPC	100
			TOTAL						0	0	0	0			
85	ER1L85	SASARAM - NABINAGAR II						0	0	0	0			ERPC	100
								0	0	0	0				
			TOTAL						0.00	0.00	0.00	0.00			
86	ER1L86	400kV MOTIHARI - GORAKHPUR - I (LIL0 BARH-GK)						0	0	0	0			ERPC	100
								0	0	0	0				
								0	0	0	0				
			TOTAL						0.00	0.00	0.00	0.00			




Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		DURATION OF OUTAGE					Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified	
			DATE	TIME	DATE	TIME	TOTAL	ISTS Licensee	OTHERS	System constraint / Natural	Deemed Availab					
87	ERIL87	400kV MOTIHARI - GORAKHPUR - II (LIL0 BARH-G)	01/02/21	00:00:00	01/03/21	00:00:00	720	0	720	0	0	0	OMSU	LINE KEPT OPEN DUE TO PROBLEM AT DMTCL END. TOWER/ERS TOWER NOT READY BY DMTCL IN LIL0 PORTION.	ERPC	100
	TOTAL					720.00	0.00	720.00	0.00	0.00						
88	ERIL88	400kV BARH-MOTIHARI-I (LIL0 BARH-GKP-1)						0	0	0	0				ERPC	100
	TOTAL							0.00	0.00	0.00	0.00					
89	ERIL89	400kV BARH-MOTIHARI- II (LIL0 BARH-GKP-2)	14/02/21	10:51:00	14/02/21	13:56:00	3.08	0	3.08	0	0	OMSU	SHUTDOWN TAKEN BY MOTIHARI (DMTCL) FOR CONDUCTOR PAYING OUT ACTIVITY IN 400kV BARH-MOTIHARI CIRCUIT-1 BETWEEN SPAN NO.-26/0 TO 26/1.	ERPC	100	
			18/02/21	08:33:00	18/02/21	18:09:00	9.6	0	0	0	9.6	OSPD	SHUTDOWN TAKEN BY DMCTL MOTIHARI FOR STRINGING WORK OF 400KV MOTIHARI-GORAKHPUR-II ON THE SAME TOWER BETWEEN 27/0 TO 27/1 OF MOTIHARI-GORAKHPUR LINE.			
	TOTAL					12.68	0.00	3.08	0.00	9.60						
90	ERIL90	400KV GAYA - KODERMA - II					0	0	0	0	0				ERPC	100
	TOTAL						0.00	0.00	0.00	0.00	0.00					
91	ERIL91	400kV GAYA-MAITHON II					0	0	0	0	0				ERPC	100
	TOTAL						0.00	0.00	0.00	0.00	0.00					
92	ERIL92	400kV GAYA-KODERMA-I					0	0	0	0	0				ERPC	100
	TOTAL						0.00	0.00	0.00	0.00	0.00					
93	ERIL93	400kV GAYA-MAITHON-I					0	0	0	0	0				ERPC	100
	TOTAL						0.00	0.00	0.00	0.00	0.00					
94	ERIL94	400kV RANCHI-NEW RANCHI II					0	0	0	0	0				ERPC	100
	TOTAL						0.00	0.00	0.00	0.00	0.00					
95	ERIL95	400kV RANCHI-NEW RANCHI I					0	0	0	0	0				ERPC	100
	TOTAL						0	0	0	0	0					
96	ERIL96	400kV RANCHI-NEW RANCHI III	13/02/21	07:02:00	13/02/21	18:56:00	11.9	0	11.9	0	0	OMSU	SHUTDOWN TAKEN FOR INSULATOR CLEANING WORKS.	ERPC	100	
	TOTAL					11.9	0	11.9	0	0						
97	ERIL97	400kV RANCHI-NEW RANCHI IV	22/02/21	07:38:00	22/02/21	19:01:00	11.38	0	11.38	0	0	OMSU	SHUTDOWN TAKEN FOR INSULATOR CLEANING WORK.	ERPC	100	
	TOTAL					11.38	0.00	11.38	0.00	0.00						
98	ERIL98	400 KV BOKARO-KODERMA-I					0	0	0	0	0				ERPC	100
							0	0	0	0	0					
							0	0	0	0	0					
							0	0	0	0	0					
							0	0	0	0	0					
							0	0	0	0	0					
	TOTAL						0.00	0.00	0.00	0.00	0.00					
99	ERIL99	400 KV BOKARO-KODERMA-II					0	0	0	0	0				ERPC	100
	TOTAL						0.00	0.00	0.00	0.00	0.00					
100	ERIL100	400 KV PATNA - KISHANGANJ -I	05/02/21	11:41:00	05/02/21	13:49:00	2.13	2.13	0	0	0	OSPT	SHUTDOWN TAKEN FOR SF6 GAS FILLING AT OUTDOOR GIS SECTION TOWARDS GIS TO AIS BUSHING IN Y PHASE SECTION OF 416 GP 6 AT KISHANGANJ	ERPC	99.68	
	TOTAL					2.13	2.13	0	0	0						
101	ERIL101	400 KV PATNA - KISHANGANJ -II					0	0	0	0	0				ERPC	100
	TOTAL						0.00	0.00	0.00	0.00	0.00					
102	ERIL102	765 KV GAYA - VARANASI - II					0	0	0	0	0				ERPC	100
	TOTAL						0.00	0.00	0.00	0.00	0.00					
103	ERIL103	400 KV GAYA - CHANDAWA - I					0	0	0	0	0				ERPC	100




Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		TOTAL	DURATION OF OUTAGE				Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified
			DATE	TIME	DATE	TIME		ISTS Licensee	OTHERS	System constraint / Natural	Deemed Availab				
	TOTAL							0.00	0.00	0.00	0.00				
104	ERIL104 TOTAL	400 KV GAYA - CHANDAWA - II					0	0.00	0.00	0.00	0.00			ERPC	100
105	ERIL105 TOTAL	400 KV NEW RANCHI - CHANDAWA - I					0	0.00	0.00	0.00	0.00			ERPC	100
106	ERIL106 TOTAL	400 KV NEW RANCHI - CHANDAWA - II					0	0.00	0.00	0.00	0.00			ERPC	100
107	ERIL107 TOTAL	765KV SASARAM - FATEHPUR					0	0.00	0.00	0.00	0.00			ERPC	100
108	ERIL108 TOTAL	765KV GAYA - VARANASI -I					0	0.00	0.00	0.00	0.00			ERPC	100
109	ERIL109 TOTAL	400 KVSASARAM - DALTONGANJ - I					0	0.00	0.00	0.00	0.00			ERPC	100
110	ERIL110 TOTAL	400 KV SASARAM - DALTONGANJ - II					0	0.00	0.00	0.00	0.00			ERPC	100
111	ERIL111 TOTAL	400KV GAYA NABINAGAR-1					0	0.00	0.00	0.00	0.00			ERPC	100
112	ERIL112 TOTAL	400KV GAYA NABINAGAR-2					0	0.00	0.00	0.00	0.00			ERPC	100
113	ERIL113 TOTAL	400KV PATNA NABINAGAR-1					0	0.00	0.00	0.00	0.00			ERPC	100
114	ERIL114 TOTAL	400KV PATNA NABINAGAR-1I					0	0.00	0.00	0.00	0.00			ERPC	100
115	ER1T1 TOTAL	400/220kV ICT1 BIHARSHARIFF	17/02/21	11:10:00	17/02/21	17:52:00	6.7	0	0	0	6.7	OSPD	SHUTDOWN TAKEN FOR DC EARTH FAULT RECTIFICATION WORK AT 220 KV SIDE BSPTCL END.SHUTDOWN TAKEN BY BSPTCL.	ERPC	100
116	ER1T2 TOTAL	400/220kV ICT2 BIHARSHARIFF	02/02/21	11:00:00	02/02/21	21:20:00	10.33	0	0	0	10.33	OSPD	SHUTDOWN TAKEN BY BSPTCL FOR PROTECTION TESTING AT 220KV SIDE (BSPTCL END)	ERPC	100
117	ER1T3 TOTAL	400/220kV ICT3 BIHARSHARIFF	08/02/21	11:21:00	08/02/21	15:13:00	3.87	0	0	0	3.87	OSPD	SHUTDOWN TAKEN BY BSEB FOR DISMANTLING OF BUSBAR PROTECTION CABLE FROM OLD BUSBAR (DISABLED) PANELS AND FROM CT JUNCTION BOX AT 220KVSIDE.	ERPC	100
118	ER1T4	400/220kV ICT4 BIHARSHARIFF					0	0.00	0.00	0.00	0.00			ERPC	100
119	ER1T5 TOTAL	400/220kV ICT1 JAMSHEDPUR	18/02/21	15:58:00	18/02/21	16:31:00	0.55	0	0	0	0.55	OSPD	SHUTDOWN TAKEN BY JUNSL FOR RECTIFICATION OF ENERGY METER CONNECTION AT RAMCHANDRAPUR END.	ERPC	100
120	ER1T6 TOTAL	400/220kV ICT2 JAMSHEDPUR					0	0.00	0.00	0.00	0.00			ERPC	100
121	ER1T7 TOTAL	400/220kV ICT1 NEW PURNEA					0	0.00	0.00	0.00	0.00			ERPC	100
122	ER1T8 TOTAL	400/220kV ICT2 NEW PURNEA					0	0.00	0.00	0.00	0.00			ERPC	100
123	ER1T9	400/220kV ICT1 SASARAM					0	0.00	0.00	0.00	0.00			ERPC	100




Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		DURATION OF OUTAGE					Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified
			DATE	TIME	DATE	TIME	TOTAL	ISTS Licensee	OTHERS	System constraint / Natural	Deemed Availab				
	TOTAL						0.00	0.00	0.00	0.00					
124	ERIT10 TOTAL	400/220kV ICT2 SASARAM	28/02/21	09:13:00	28/02/21	19:46:00	10.55	10.55	0	0	0	OSPT	SHUTDOWN TAKEN FOR AMP WORK.	ERPC	98.43
125	ERIT11 TOTAL	400/220kV ICT1 MUZ					0.00	0.00	0.00	0.00				ERPC	100
126	ERIT12 TOTAL	400/220kV ICT2 MUZ					0.00	0.00	0.00	0.00				ERPC	100
127	ERIT13 TOTAL	400/220kV ICT1 PATNA					0	0	0	0				ERPC	100
128	ERIT14 TOTAL	400/220kV ICT2 PATNA	02/02/21	10:45:00	02/02/21	20:15:00	9.5	9.5	0	0	0	OSPT	SHUTDOWN TAKEN FOR ATTENDING HOT SPOT IN 220KV SIDE Y PH CT.	ERPC	98.58
129	ERIT15 TOTAL	400/220kV ICT1 RNC	02/02/21	10:10:00	02/02/21	14:32:00	4.37	4.37	0	0	0	OSPT	SHUTDOWN TAKEN FOR ATTENDING DC EARTH FAULT IN OLTC R-PHASE OSR CONNECTING WIRE.	ERPC	99.35
130	ERIT16 TOTAL	400/220kV ICT2 RNC					0.00	0.00	0.00	0.00				ERPC	100
131	ERIT17 TOTAL	400/220kV ICT1 GAYA					0	0	0	0				ERPC	100
132	ERIT18 TOTAL	400/220kV ICT2 GAYA					0	0	0	0				ERPC	100
133	ERIT19 TOTAL	400/220kV ICT3 GAYA					0	0	0	0				ERPC	100
134	ERIT20 TOTAL	400/132kV ICT1 BANKA					0.00	0.00	0.00	0.00				ERPC	100
135	ERIT21 TOTAL	400/132kV ICT 2 BANKA					0.00	0.00	0.00	0.00				ERPC	100
136	ERIT22 TOTAL	765/400kV ICT1 GAYA					0.00	0.00	0.00	0.00				ERPC	100
137	ERIT23 TOTAL	765/400kV ICT2 GAYA					0.00	0.00	0.00	0.00				ERPC	100
138	ERIT24 TOTAL	765/400kV ICT3 GAYA					0.00	0.00	0.00	0.00				ERPC	100
139	ERIT25 TOTAL	765/400kV ICT2 GAYA					0.00	0.00	0.00	0.00				ERPC	100
140	ERIT26 TOTAL	220/132kV ICT1 PRN					0.00	0.00	0.00	0.00				ERPC	100
141	ERIT27 TOTAL	220/132kV ICT2 PRN					0.00	0.00	0.00	0.00				ERPC	100
142	ERIT28 TOTAL	220/132kV ICT3 PRN					0.00	0.00	0.00	0.00				ERPC	100
143	ERIT29 TOTAL	220/132kV ICT1 ARRAH	20/02/21	18:10:00	20/02/21	18:31:00	0.35	0.35	0	0	0	OSPT	SHUTDOWN TAKEN TO ATTEND SPARKING PROBLEM IN 132 KV MAIN BAY BUS SIDE ISOLATOR	ERPC	99.95
144	ERIT30 TOTAL	220/132kV ICT2 ARRAH					0.00	0.00	0.00	0.00				ERPC	100
145	ERIT31 TOTAL	765/400/220 kV ICT 1 SASARAM					0.00	0.00	0.00	0.00				ERPC	100
146	ERIT32 TOTAL	765/400kV ICT1 RANCHI(NEW)					0.00	0.00	0.00	0.00				ERPC	100
147	ERIT33 TOTAL	765/400kV ICT2 RANCHI(NEW)					0.00	0.00	0.00	0.00				ERPC	100
148	ERIT34 TOTAL	400/132kV ICT1 LAKHISARAI					0.00	0.00	0.00	0.00				ERPC	100
149	ERIT35 TOTAL	400/132kV ICT 2 LAKHISARAI					0.00	0.00	0.00	0.00				ERPC	100
150	ERIT36 TOTAL	400/220kV ICT 2 CHAIBASA					0.00	0.00	0.00	0.00				ERPC	100
151	ERIT37 TOTAL	400/220kV ICT 1 CHAIBASA					0.00	0.00	0.00	0.00				ERPC	100




Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		DURATION OF OUTAGE					Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified
			DATE	TIME	DATE	TIME	TOTAL	ISTS Licensee	OTHERS	System constraint / Natural	Deemed Availab				
	TOTAL							0.00	0.00	0.00	0.00				
152	ERIT38 TOTAL	220/132kV ICT3 ARRAH						0.00	0.00	0.00	0.00			ERPC	100
153	ERIT39 TOTAL	400/220kV ICT3 MUZZAFERPUR						0.00	0.00	0.00	0.00			ERPC	100
154	ERIT40 TOTAL	400/220kV ICT2 KISHANGANJ						0.00	0.00	0.00	0.00			ERPC	100
155	ERIT41 TOTAL	400/220 kV ICT1 AT KISHANGANJ						0.00	0.00	0.00	0.00			ERPC	100
156	ERIT42 TOTAL	400/220kV ICT3 JAMSHEDPUR						0.0	0.0	0.0	0.0			ERPC	100
157	ERIT43 TOTAL	400/220kV ICT3 PATNA	03/02/21	16:03:00	03/02/21	17:09:00	1.1	1.1	0	0	0	OSPT	SHUTDOWN TAKEN FOR ATTENDING OIL LEAKAGE.	ERPC	99.83
158	ERIT44 TOTAL	400/220kV ICT1 DALTONGANJ						0.00	0.00	0.00	0.00			ERPC	100
159	ERIT45 TOTAL	220/132 kV ICT1 DALTONGANJ						0.00	0.00	0.00	0.00			ERPC	100
160	ERIT46 TOTAL	220/132 kV ICT2 DALTONGANJ						0.00	0.00	0.00	0.00			ERPC	100
161	ERIT47 TOTAL	400/220kV ICT2 DALTONGANJ						0.00	0.00	0.00	0.00			ERPC	100
162	ERIT48 TOTAL	400/132kV ICT 3 BANKA						0.0	0.0	0.0	0.0			ERPC	100
163	ERIT49 TOTAL	400/132kV ICT 3 LAKHISARAI						0.00	0.00	0.00	0.00			ERPC	100
164	ERIR1 TOTAL	50 MVAR B/R-1 AT BIHARSHARIF						0.00	0.00	0.00	0.00			ERPC	100
165	ERIR2 TOTAL	50 MVAR B/R-1 AT JMASHEDPUR						0.00	0.00	0.00	0.00			ERPC	100
166	ERIR3 TOTAL	50 MVAR BUS REACTOR-II, JAMSHEDPUR II						0.00	0.00	0.00	0.00			ERPC	100
167	ERIR4 TOTAL	400kV BUS REACTOR MUZZAFERPUR						0.00	0.00	0.00	0.00			ERPC	100
168	ERIR5 TOTAL	80 MVAR BARH-I LR AT PATNA						0.0	0.0	0.0	0.0			ERPC	100
169	ERIR6 TOTAL	400kV BUS REACTOR RANCHI						0.00	0.00	0.00	0.00			ERPC	100
170	ERIR7 TOTAL	80 MVAR B/R AT BIHARSHARIF						0.00	0.00	0.00	0.00			ERPC	100
171	ERIR8 TOTAL	125 MVAR B/R - I AT NEW PURNEA						0.00	0.00	0.00	0.00			ERPC	100
172	ERIR9 TOTAL	125 MVAR B/R - II AT NEW PURNEA						0.00	0.00	0.00	0.00			ERPC	100
173	ERIR10 TOTAL	3*80 B/R AT GAYA						0.00	0.00	0.00	0.00			ERPC	100
174	ERIR11 TOTAL	3*80 B/R II AT GAYA						0.00	0.00	0.00	0.00			ERPC	100
175	ERIR12 TOTAL	50 MVAR MTN RB-2 L/R AT RANCHI						0.00	0.00	0.00	0.00			ERPC	100
176	ERIR13 TOTAL	50 MVAR GAYA L/R AT BIHARSHARIF						0.00	0.00	0.00	0.00			ERPC	100
177	ERIR14 TOTAL	50 MVAR SSRM-III L/R AT BIHARSHARIF						0.00	0.00	0.00	0.00			ERPC	100



Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		TOTAL	DURATION OF OUTAGE				Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified
			DATE	TIME	DATE	TIME		ISTS Licensee	OTHERS	System constraint / Natural	Deemed Availab				
178	ER1R15 TOTAL	400kV BUS REACTOR-I, GAYA 125MVAR						0.00	0.00	0.00	0.00			ERPC	100
179	ER1R16 TOTAL	400kV BUS REACTOR II,GAYA 125MVAR						0.00	0.00	0.00	0.00			ERPC	100
180	ER1R17 TOTAL	765kV BUS REACTOR II, GAYA						0.00	0.00	0.00	0.00			ERPC	100
181	ER1R18 TOTAL	765kV BUS REACTOR1-GAYA						0.00	0.00	0.00	0.00			ERPC	100
182	ER1R19 TOTAL	125 MVAR B/R - I AT PSL						0.00	0.00	0.00	0.00			ERPC	100
183	ER1R20 TOTAL	125 MVAR B/R - II AT PASAULI						0.00	0.00	0.00	0.00			ERPC	100
184	ER1R21 TOTAL	63 MVAR GKP - I L/R AT MUZZAFERPUR						0.00	0.00	0.00	0.00			ERPC	100
185	ER1R22 TOTAL	63 MVAR GKP - II L/R AT MUZZAFERPUR						0.00	0.00	0.00	0.00			ERPC	100
186	ER1R23 TOTAL	63 MVAR NPRN - I L/R AT MUZZAFERPUR						0.00	0.00	0.00	0.00			ERPC	100
187	ER1R24 TOTAL	63 MVAR NPRN - II L/R AT MUZZAFERPUR						0.00	0.00	0.00	0.00			ERPC	100
188	ER1R25 TOTAL	63 MVAR MUZ - I L/R AT NPRN						0.00	0.00	0.00	0.00			ERPC	100
189	ER1R26 TOTAL	63 MVAR MUZ- II L/R AT NPRN						0.00	0.00	0.00	0.00			ERPC	100
190	ER1R27 TOTAL	63 MVAR BSF- I L/R AT PSL						0.00	0.00	0.00	0.00			ERPC	100
191	ER1R28 TOTAL	63 MVAR BSF- II L/R AT PSL						0.00	0.00	0.00	0.00			ERPC	100
192	ER1R29 TOTAL	50 MVAR BSF- III L/R AT PSL						0.00	0.00	0.00	0.00			ERPC	100
193	ER1R30 TOTAL	50 MVAR BALIA L/R AT PSL						0.00	0.00	0.00	0.00			ERPC	100
194	ER1R31 TOTAL	63 MVAR ALLAHABAD-1 L/R AT PSL						0.00	0.00	0.00	0.00			ERPC	100
195	ER1R32 TOTAL	63 MVAR SARNATH-1 L/R AT PSL						0.00	0.00	0.00	0.00			ERPC	100
196	ER1R33 TOTAL	50 MVAR B/R - I AT GAYA						0.00	0.00	0.00	0.00			ERPC	100
197	ER1R34 TOTAL	50 MVAR B/R - II AT GAYA						0.00	0.00	0.00	0.00			ERPC	100
198	ER1R35 TOTAL	50 MVAR L/R - I AT BANKA						0.00	0.00	0.00	0.00			ERPC	100
199	ER1R36 TOTAL	50 MVAR L/R - 2 AT BANKA						0.00	0.00	0.00	0.00			ERPC	100
200	ER1R37 TOTAL	80 MVAR B/R - I AT BANKA						0.00	0.00	0.00	0.00			ERPC	100
201	ER1R38 TOTAL	125 3Ph B/R I AT SASARAM						0.00	0.00	0.00	0.00			ERPC	100
202	ER1R39 TOTAL	125 3Ph B/R II AT SASARAM						0.00	0.00	0.00	0.00			ERPC	100
203	ER1R40 TOTAL	3*110 MVAR 1 PH B/R - I AT SASARAM						0.00	0.00	0.00	0.00			ERPC	100
204	ER1R41 TOTAL	3*110 MVAR 1 PH L/R - I AT SASARAM (AS B/R)						0.00	0.00	0.00	0.00			ERPC	100
205	ER1R42	125 MVAR BUS REACTOR-1 RANCHI												ERPC	100



Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		TOTAL	DURATION OF OUTAGE				Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified	
			DATE	TIME	DATE	TIME		ISTS Licensee	OTHERS	System constraint / Natural	Deemed Availab					
205	TOTAL	125 MVAR BUS REACTOR-1 PATNA						0.00	0.00	0.00	0.00			ERPC	100	
206	ERIR43 TOTAL	125 MVAR BUS REACTOR-1 PATNA						0.00	0.00	0.00	0.00			ERPC	100	
207	ERIR44 TOTAL	80 MVAR PURNEA-1 L/R at Biharsharif						0.00	0.00	0.00	0.00			ERPC	100	
208	ERIR45 TOTAL	80 MVAR PURNEA-2 L/R at Biharsharif						0.00	0.00	0.00	0.00			ERPC	100	
209	ERIR46 TOTAL	125 MVAR BARH-2 LR PATNA						0.0	0.0	0.0	0.0			ERPC	100	
210	ERIR47 TOTAL	125 MVAR BUS REACTOR-1 NEW RANCHI						0.00	0.00	0.00	0.00			ERPC	100	
211	ERIR48 TOTAL	125 MVAR BUS REACTOR-2 NEW RANCHI						0.00	0.00	0.00	0.00			ERPC	100	
212	ERIR49 TOTAL	3*80MVAR 1 PH L/R - I AT NEW RANCHI						0.00	0.00	0.00	0.00			ERPC	100	
213	ERIR50 TOTAL	3*80MVAR 1 PH B/R - II AT NEW RANCHI						0	0	0	0			ERPC	100	
214	ERIR51 TOTAL	80 MVAR B/R - I AT LAKHISARAI						0.00	0.00	0.00	0.00			ERPC	100	
215	ERIR52 TOTAL	3*80MVAR 1 PH B/R - I AT NEW RANCHI						0.00	0.00	0.00	0.00			ERPC	100	
216	ERIR53 TOTAL	80MVAR NABINAGAR LR-I AT PATNA						0.00	0.00	0.00	0.00			ERPC	100	
217	ERIR54 TOTAL	80MVAR NABINAGAR LR-II AT PATNA						0.00	0.00	0.00	0.00			ERPC	100	
218	ERIR55 TOTAL	3*80 MVAR DHRAMJAYGARH LR-II AS BR AT NEW						0.00	0.00	0.00	0.00			ERPC	100	
219	ERIR56 TOTAL	125 MVAR BR-II AT MUZAFFERPUR						0.00	0.00	0.00	0.00			ERPC	100	
220	ERIR57 TOTAL	125 MVAR BR-I AT MUZAFFERPUR						0.00	0.00	0.00	0.00			ERPC	100	
221	ERIR58 TOTAL	125 MVAR BR-III AT Biharsharif						0	0	0	0			ERPC	100	
222	ERIR59 TOTAL	125 MVAR BR-I AT Kishanganj						0	0	0	0			ERPC	100	
223	ERIR60 TOTAL	125 MVAR BR-I AT Chandawa						0.00	0.00	0.00	0.00			ERPC	100	
224	ERIR61 TOTAL	125 MVAR BR-II AT Chandawa						0	0	0	0			ERPC	100	
225	ERIR62 TOTAL	80 MVAR B/R AT CHAIBASA	26/02/21	12:59:00	27/02/21	01:23:00	12.4	12.4	0	0	0	0	OMST	400KV 80MVAR BUS REACTOR-I AT CHAIBASA TRIPPED DUE TO JACK BUS JUMPER AT TIE BAY OF CHAIBASA-ROURKELA-2 AND 80MVAR BUS-REACTOR-1 BROKE OFF.	ERPC	98.15
226	ERIR63 TOTAL	3*80 1ph VARANASI L/R-II at Gaya						0.00	0.00	0.00	0.00			ERPC	100	
227	ERIR64 TOTAL	125 MVAR B/R - II AT KISHENGANJ						0	0	0	0			ERPC	100	
228	ERIR65 TOTAL	80 MVAR PATNA LR - I AT KISHENGANJ						0.00	0.00	0.00	0.00			ERPC	100	
229	ERIR66 TOTAL	80 MVAR PATNA LR - II AT KISHENGANJ						0.00	0.00	0.00	0.00			ERPC	100	



Sr. No.	Unique ID of transmission	Element Name	OUTAGE		RESTORATION		DURATION OF OUTAGE				Category	Detailed Reason(s) for Outage	Outage Certifying Agency and	% Availability as certified	
			DATE	TIME	DATE	TIME	TOTAL	ISTS Licensee	OTHERS	System constraint / Natural					Deemed Availab
230	ER1R67 TOTAL	80 MVAR L/R OF 400 kV BARH - GORAKHPUR - I AT						0.00	0.00	0.00	0.00		ERPC	100	
231	ER1R68 TOTAL	80 MVAR L/R OF 400 kV BARH - GORAKHPUR - II AT						0.00	0.00	0.00	0.00		ERPC	100	
232	ER1R69 TOTAL	240 MVAR L/R OF 765 kV GAYA - BALIA LINE AT BA						0.00	0.00	0.00	0.00		ERPC	100	
233	ER1R70 TOTAL	330 MVAR L/R OF 765 kV SASARAM - FATEHPUR LI						0.00	0.00	0.00	0.00		ERPC	100	
234	ER1R71 TOTAL	330 MVAR L/R OF 765 kV SASARAM - FATEHPUR LI						0.00	0.00	0.00	0.00		ERPC	100	
235	ER1R72 TOTAL	240 MVAR L/R OF 765 kV GAYA - VARANASI - I LIN						0.00	0.00	0.00	0.00		ERPC	100	
236	ER1R73 TOTAL	240 MVAR L/R OF 765 kV GAYA - VARANASI - I LIN						0.00	0.00	0.00	0.00		ERPC	100	
237	ER1R74 TOTAL	240 MVAR L/R OF 765 kV GAYA - VARANASI - II LIN						0.00	0.00	0.00	0.00		ERPC	100	
238	ER1R75 TOTAL	240 MVAR L/R OF 765 kV GAYA - VARANASI - II LIN						0.00	0.00	0.00	0.00		ERPC	100	
239	ER1R76 TOTAL	125MVAR, 400kV BUS REACTOR-III, AT JAMSHEDP						0.00	0.00	0.00	0.00		ERPC	100	
240	ER1R77 TOTAL	80 MVAR BUS REACTOR AT DALTONGANJ	01/02/21	00:00:00	01/03/21	00:00:00	720	0	0	0	720	SVRD	S/OFF FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION	ERPC	100
241	ER1R78 TOTAL	125 MVAR BR-IV AT Biharsharif						0	0	0	0		ERPC	100	
242	ER1R79 TOTAL	125 MVAR BR-II AT Lakhisarai						0.00	0.00	0.00	0.00		ERPC	100	
243	ER1R80 TOTAL	50 MVAR L/R of 400 kV Biharsarif - Sasaram - I AT Bih						0.00	0.00	0.00	0.00		ERPC	100	
244	ER1R81 TOTAL	50 MVAR L/R of 400 kV Biharsarif - Lakhisarai - II AT B						0.00	0.00	0.00	0.00		ERPC	100	
245	ER1R82 TOTAL	80 MVAR L/R of 400 kV Kishanganj- Darbhanga - II AT						0.00	0.00	0.00	0.00		ERPC	100	
246	ER1 ST01 TOTAL	STATCOM AT New ranchi						0.00	0.00	0.00	0.00		ERPC	100	
247	ER1 ST02 TOTAL	STATCOM AT Kishanganj						0	0	0	0		ERPC	100	
248	ER1R82 TOTAL	BANKA-BUS REACTOR-2						0	0	0	0		ERPC	100	
249	ER1R84 TOTAL	63 MVAR KISHANGANJ-1 L/R AT PURNEA						0.00	0.00	0.00	0.00		ERPC	100	

