

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., EASTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR,BUS REACTOR-1 AT BANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT BANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR,BUS REACTOR-1 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-2 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-4 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125 MVAR BUS REACTOR-5 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT CHAIBASA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT CHAIBASA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT CHANDWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT CHANDWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT DALTANGANJ	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* HAND TRIPPED FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION
							28.00	0.00	0.00	0.00	672.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	49MVAR,BUS REACTOR-1 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	175MVAR,BUS REACTOR-2 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-4 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT LAKHISARAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT LAKHISARAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT MUZAFFARPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT MUZAFFARPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT NEW PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT NEW PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT RANCHI 400			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT RANCHI 400			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT RANCHI 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT RANCHI 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT RANCHI 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., EASTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT RANCHI 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT SASARAM	SVRD	17-02-2025	09:14:00	28-02-2025	23:59:59	11.62	0.00	0.00	0.00	278.77		* HAND TRIPPED FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION
							11.62	0.00	0.00	0.00	278.77	100.00	
BSR	330MVAR,BUS REACTOR-1 AT SASARAM	SVRD	10-02-2025	10:12:00	14-02-2025	13:43:00	4.15	0.00	0.00	0.00	99.52		* HAND TRIPPED FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION
BSR	330MVAR,BUS REACTOR-1 AT SASARAM	SVRD	28-02-2025	04:58:00	28-02-2025	05:04:00	0.00	0.00	0.00	0.00	0.10		* H/T FOR VOL REGULATION AS PER ERLDC* VOL CHANGE-->742 TO 796KV, 411 TO 414KV (AFTER OPENING)* VOL CHANGE-->798 TO 767KV, 414 TO 410KV (AFTER CHARGING)
							4.15	0.00	0.00	0.00	99.62	100.00	
BSR	125MVAR,BUS REACTOR-2 AT SASARAM	SVRD	17-02-2025	09:21:00	28-02-2025	23:59:59	11.61	0.00	0.00	0.00	278.65		* HAND TRIPPED FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION
							11.61	0.00	0.00	0.00	278.65	100.00	
CKT	132kV ARA-ARA(BSPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kVARA-DUMRAON(BSPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV DEHRI(BSPTCL)-KUDRA(BSPTCL)-1	OMSU	07-02-2025	14:20:00	07-02-2025	19:10:00	0.20	0.00	4.83	0.00	0.00		* TO FACILITATE THE RECTIFICATION WORK OF 400KV SASARAM-NABINAGAR-1
							0.20	0.00	4.83	0.00	0.00	100.00	
CKT	132kV KUDRA(BSPTCL)-SASARAM-1	OSPT	05-02-2025	10:28:00	05-02-2025	16:49:00	0.27	6.35	0.00	0.00	0.00		* SHUTDOWN TAKEN FOR BAY AMP WORK AT SASARAM
							0.27	6.35	0.00	0.00	0.00	99.06	
CKT	132kV MOHANIA(BSPTCL)-KARMANASHA(BSPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV PURNEA-PURNEA(BSEB)-1 (LILO PART)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV PRN-PRN(BSEB)-2(PRN-DALKHOLA LILO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV SASARAM-MOHANIA(BSPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV ARA-DUMRAON(BSPTCL)-1	OMSU	13-02-2025	10:03:00	13-02-2025	18:59:00	0.37	0.00	8.93	0.00	0.00		* FOR BUS BAR RELAY RETROFITTING WORK AT ARRACH.REPLACEMENT OF ELECTROMECHANICAL RELAY WITH NUMERICAL RELAY FOR PROTECTION SYSTEM PERFO=RMANCE IMPROVEMENT.
CKT	220kV ARA-DUMRAON(BSPTCL)-1	OMSU	05-02-2025	13:33:00	05-02-2025	17:18:00	0.16	0.00	3.75	0.00	0.00		* SHUTDOWN TAKEN FOR REMOVAL OF KITE(ALONG WITH LONG THREAD) HANGING AT BOTTOM PHASE CONDUCTOR (SPAN NO. 342-343) TO AVOID TRIPPING OF LINE.
							0.53	0.00	12.68	0.00	0.00	100.00	
CKT	220kV ARA-DUMRAON(BSPTCL)-2	OMSU	12-02-2025	09:56:00	13-02-2025	02:03:00	0.67	0.00	16.12	0.00	0.00		* FOR BUS BAR RELAY RETROFITTING WORK AT ARRACH. REPLACEMENT OF ELECTROMECHANICAL RELAY WITH NUMERICAL RELAY FOR PROTECTION SYSTEM PERF=ORMANCE IMPROVEMENT.
							0.67	0.00	16.12	0.00	0.00	100.00	
CKT	220kV ARA-NAUBATPUR(BGCL) CKT-1	OMSU	15-02-2025	09:55:00	15-02-2025	15:30:00	0.23	0.00	5.58	0.00	0.00		* FOR BUS BAR RELAY RETROFITTING WORK AT ARRACH. REPLACEMENT OF ELECTROMECHANICAL RELAY WITH NUMERICAL RELAY FOR PROTECTION SYSTEM PE=RFORMANCE IMPROVEMENT.
							0.23	0.00	5.58	0.00	0.00	100.00	
CKT	220kV ARA-NAUBATPUR(BGCL) CKT-2	OMSU	14-02-2025	10:12:00	14-02-2025	17:46:00	0.32	0.00	7.57	0.00	0.00		* FOR BUS BAR RELAY RETROFITTING WORK AT ARRACH.REPLACEMENT OF ELECTROMECHANICAL RELAY WITH NUMERICAL RELAY FOR PROTECTION SYSTEM PERFO=RMANCE IMPROVEMENT.
							0.32	0.00	7.57	0.00	0.00	100.00	
CKT	220kV DEHRI(BSPTCL)-SASARAM-1	OSPD	06-02-2025	12:44:00	06-02-2025	17:09:00	0.18	0.00	0.00	0.00	4.42		* SHUTDOWN TAKEN TO FACILITATE THE BUS SHUTDOWN AT DEHRI BY BSPTCL
CKT	220kV DEHRI(BSPTCL)-SASARAM-1	LART	23-02-2025	17:33:00	23-02-2025	17:33:00	0.00	0.00	0.00	0.00	0.00		* LINE A/R SUCCESSFUL FROM BOTH END DUE TO B-N FAULT UNDER BSPTCL JURISDICTION. (SASARAM SITE):- M1: Z1, FD- 14.42KM, FC- 7.228KA.
							0.18	0.00	0.00	0.00	4.42	100.00	
CKT	220kV GAYA-BODHGAYA(BSPTCL)-1	OSPD	04-02-2025	09:45:00	04-02-2025	16:23:00	0.28	0.00	0.00	0.00	6.63		* SHUTDOWN TAKEN TO FACILITATE THE BUS SHUTDOWN AT BODHGAYA BY BSPTCL
CKT	220kV GAYA-BODHGAYA(BSPTCL)-1	OSPD	05-02-2025	10:04:00	05-02-2025	14:19:00	0.18	0.00	0.00	0.00	4.25		* SHUTDOWN TAKEN TO FACILITATE THE BUS SHUTDOWN AT BODHGAYA BY BSPTCL
							0.46	0.00	0.00	0.00	10.88	100.00	
CKT	220kV GAYA-BODHGAYA(BSPTCL)-2	OSPD	04-02-2025	09:46:00	04-02-2025	16:24:00	0.28	0.00	0.00	0.00	6.63		* SHUTDOWN TAKEN TO FACILITATE THE BUS SHUTDOWN AT BODHGAYA BY BSPTCL
CKT	220kV GAYA-BODHGAYA(BSPTCL)-2	OSPD	05-02-2025	10:04:00	05-02-2025	14:21:00	0.18	0.00	0.00	0.00	4.28		* SHUTDOWN TAKEN TO FACILITATE THE BUS SHUTDOWN AT BODHGAYA BY BSPTCL
							0.46	0.00	0.00	0.00	10.91	100.00	
CKT	220kV GAYA-DEHRI(BSPTCL)-1(LILO PART.)	OSPD	06-02-2025	12:46:00	06-02-2025	18:00:00	0.22	0.00	0.00	0.00	5.23		* SHUTDOWN TAKEN TO FACILITATE THE BUS SHUTDOWN AT DEHRI BY BSPTCL
							0.22	0.00	0.00	0.00	5.23	100.00	
CKT	220kV GAYA-DEHRI(BSPTCL)-2(LILO PART.)	OSPD	06-02-2025	12:46:00	06-02-2025	17:07:00	0.18	0.00	0.00	0.00	4.35		* SHUTDOWN TAKEN TO FACILITATE THE BUS SHUTDOWN AT DEHRI BY BSPTCL
							0.18	0.00	0.00	0.00	4.35	100.00	
CKT	220kV NAUBATPUR(BGCL) -KHGAUL CKT-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV NAUBATPUR(BGCL) -KHGAUL CKT-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV NADOKHAR DUMRAON CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV NADOKHAR DUMRAON CKT2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., EASTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	220 kV DALKHOLA-PURNEA -1	LNCC	23-02-2025	02:58:00	23-02-2025	03:34:00	0.03	0.00	0.00	0.60	0.00		* TRIPPED ON B-N FAULT DUE TO LIGHTENING <(>&<)> THUNDERSTORM. INSULATOR FLASHOVER B-PH ERS TOWER NO. 1 UNDER TEMPORARY ARRANGEMENT (DALKHOLA-PG BYPASS) BY ER-2.* PURNEA(SITE)- M1-FC-3.34KA,FD-31.96KM
CKT	220 kV DALKHOLA-PURNEA -1	LCSD	01-02-2025	00:00:01	04-02-2025	17:58:00	3.75	0.00	0.00	0.00	89.97		* SHUTDOWN TAKEN BY ER-2 FOR 220KVDALKHOLA(PG) BY-PASS ARRANGEMENT AND NEW CONFIGURATION SHALL BE 220KV PURNEA-DALKHOLA (W.B)-I* 31.01.2025 12:33:05 INDIA (60003811)* SHUTDOWN TAKEN TO FACILITATE ISOLATOR RETROFITTING WORK UNDER ADD CAP
CKT	220 kV DALKHOLA-PURNEA -1	LNCC	27-02-2025	06:23:00	27-02-2025	13:57:00	0.32	0.00	0.00	7.57	0.00		* LINE TRIPPED ON B-N FAULT DUE TO LIGHTENING <(>&<)> INSULATOR FLASHOVER AT ERS TOWER NO. 1 NEAR BY DALKHOLA(PG).
							4.10	0.00	0.00	8.17	89.97	100.00	
CKT	220 kV DALKHOLA-PURNEA -2	LCSD	01-02-2025	00:00:01	03-02-2025	16:01:00	2.67	0.00	0.00	0.00	64.02		* SHUTDOWN TAKEN BY ER-2 FOR 220KVDALKHOLA(PG) BY-PASS ARRANGEMENT AND NEW CONFIGURATION SHALL BE 220KV PURNEA-DALKHOLA (W.B)-I* 31.01.2025 12:36:00 INDIA (60003811)* SHUTDOWN TAKEN TO FACILITATE ISOLATOR RETROFITTING WORK UNDER ADD CAP*
							2.67	0.00	0.00	0.00	64.02	100.00	
CKT	220kV PURNEA-NEW PURNEA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV PURNEA-NEW PURNEA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RANCHI-CHANDIL(JUSNL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RANCHI-HATIA(JSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RANCHI-HATIA(JSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RANCHI-HATIA(JSEB)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SASARAM-NADOKHAR(BSPTCL)-1	OSPD	08-02-2025	12:02:00	08-02-2025	16:21:00	0.18	0.00	0.00	0.00	4.32		* LINE <(>&<)> BAY MAINTENANCE WORK AT NADHOKAR. SHUTDOWN TAKEN BY BSPTCL
							0.18	0.00	0.00	0.00	4.32	100.00	
CKT	220kV SASARAM-NADOKHAR(BSPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SASARAM-NEW KARMNASA(BSPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANKA BIHARSARIF-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANKA BIHARSARIF-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BARH(NTPC)-MOTIHARI(DMTCL)-1	OSPD	11-02-2025	09:33:00	11-02-2025	11:46:00	0.09	0.00	0.00	0.00	2.22		* FOR B-PH BUSHING JUMPER RECTIFICATION AT MOTIHARI END (SHUTDOWN TAKEN BY DMTCL MOTIHARI)
CKT	400kV BARH(NTPC)-MOTIHARI(DMTCL)-1	OSPD	24-02-2025	09:59:00	24-02-2025	18:51:00	0.37	0.00	0.00	0.00	8.87		* S/D TAKEN BY MOTIHARI FOR AMP WORK
CKT	400kV BARH(NTPC)-MOTIHARI(DMTCL)-1	OSPT	01-02-2025	09:38:00	01-02-2025	13:33:00	0.16	3.92	0.00	0.00	0.00	0.00	* FOR RECTIFICATION OF BENT MIDSPAN JOINT BETWEEN LOC-142-143.
							0.62	3.92	0.00	0.00	11.09	99.42	
CKT	400kV BARH(NTPC)-MOTIHARI(DMTCL)-2	OSPD	26-02-2025	08:14:00	26-02-2025	19:09:00	0.46	0.00	0.00	0.00	10.92		* LINE SHUTDOWN AVAILED FOR AMP WORK AT MOTIHARI END BY DMTCL
							0.46	0.00	0.00	0.00	10.92	100.00	
CKT	400kV BARH(NTPC)-PATNA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BARH(NTPC)-PATNA-2	OSPD	01-02-2025	00:00:01	01-02-2025	12:54:00	0.54	0.00	0.00	0.00	12.90		* JUMPERING WORK IN LILO PORTION AT GSS BAKHTIYARPUR BY BSPTCL.* SHUTDOWN TAKEN BY BSPTCL
							0.54	0.00	0.00	0.00	12.90	100.00	
CKT	400kV BARH(NTPC)-PATNA-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BARH(NTPC)-PATNA-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV BIHARSHARIF-BALIA-1	LART	08-02-2025	23:21:00	08-02-2025	23:21:00	0.00	0.00	0.00	0.00	0.00		* A/R SUCCESSFUL FROM BOTH END DUE TO B-GROUND FAULT.* BIHARSHARIFF SITE DETAILS-* M1, Z1, FD- 24.6KM, FC- 10.13KA** M2, Z1, FD- 25.8KM, FC- 10.14KA
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV BIHARSHARIF-BALIA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BIHARSHARIF-MUZAFFARPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BIHARSHARIF-MUZAFFARPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BIHARSHARIF-SASARAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BIHARSHARIF-SASARAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BIHARSHARIF-SAHUPURI-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., EASTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400KV-BIHARSHARIF-SAHUPURI-ACL-CKT2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV CHAIBASA-ROURKELA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV CHAIBASA-ROURKELA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHANDAUTI NABINAGAR 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHANDAUTI NABINAGAR 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHANDWA-GAYA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHANDWA-GAYA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DHANBAD- MAITHON RB 1(MRB LILO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DHANBAD- MAITHON RB 2(MRB LILO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GAYA CHANDAUTI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GAYA CHANDAUTI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GAYA MAITHON-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GAYA MAITHON-2	OMSU	13-02-2025	09:31:00	13-02-2025	13:20:00	0.16	0.00	3.82	0.00	0.00		* SHUTDOWN TAKEN FOR REMOVAL OF KITE THREAD AT LOC NO- 587 TO AVOID TRIPPING OF LINE.
							0.16	0.00	3.82	0.00	0.00	100.00	
CKT	400 kV TATA DVC-BARIPADA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JAMSHEDPUR-BARIPADA-2	LNCC	18-02-2025	18:42:00	18-02-2025	20:04:00	0.06	0.00	0.00	1.37	0.00		* LINE TRIPPED ON R-N FAULT DUE TO LIGHTENING <(>&<)> HEAVY STORM. FLASHOVER MARK FOUND ON TOWER BODY AND JUMPER AT LOCATION 384* FAULT DETAILS:* JAMSHEDPUR SITE: (R-N): M2: FC=2.41KA, FD=141KM
							0.06	0.00	0.00	1.37	0.00	100.00	
CKT	400 kV JAMSHEDPUR-CHAIBASA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV JAMSHEDPUR-CHAIBASA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV JAMSHEDPUR-TATA DVC-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV JAKKANPUR NABINAGAR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV JAKKANPUR NABINAGAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAHALGAON(NTPC)-BANKA-1	OMSU	14-02-2025	11:29:00	14-02-2025	18:21:00	0.29	0.00	6.87	0.00	0.00		* TO FACILITATE THE SD OF 400KV BARH-KAHALGAON-1 (BARH 1 AND BANKA CKT 1 IS IN SAME DIA AT KAHALGAON END. MAIN BAY OF BANKA 1 IS IN BREAKDOWN AT KAHALGAON).
CKT	400kV KAHALGAON(NTPC)-BANKA-1	OSFD	25-02-2025	10:13:00	25-02-2025	18:47:00	0.36	0.00	0.00	0.00	8.57		* EMERGENCY S/D TAKEN BY KAHALGAON NTPC TO FACILITATE THE BUS SHUTDOWN
							0.65	0.00	6.87	0.00	8.57	100.00	
CKT	400kV KAHALGAON(NTPC)-BANKA-2	OSFD	28-02-2025	07:40:00	28-02-2025	09:15:00	0.07	0.00	0.00	0.00	1.58		* EMERGENCY SHUTDOWN AVAILED BY NTPC KAHALGAON TO FACILITATE THE SHUTDOWN OF BUS-1 <(>&<)> 3 AT KHSTPP
CKT	400kV KAHALGAON(NTPC)-BANKA-2	OSFD	22-02-2025	07:24:00	22-02-2025	09:38:00	0.09	0.00	0.00	0.00	2.23		* EMERGENCY S/D TAKEN BY KAHALGAON NTPC TO FACILITATE THE BUS SHUTDOWN
							0.16	0.00	0.00	0.00	3.81	100.00	
CKT	400kV KAHALGAON(NTPC)-BARH(NTPC)-1	OSFD	25-02-2025	10:17:00	25-02-2025	18:44:00	0.35	0.00	0.00	0.00	8.45		* EMERGENCY S/D TAKEN BY KAHALGAON NTPC TO FACILITATE THE BUS SHUTDOWN
CKT	400kV KAHALGAON(NTPC)-BARH(NTPC)-1	OSPD	14-02-2025	11:29:00	14-02-2025	18:10:00	0.28	0.00	0.00	0.00	6.68		* FOR RECTIFICATION OF BROKEN CONTACT FINGERS OF BARH-KAHALGAON-1 LINE ISOLATOR (3089L-R PHASE) AT NTPC BARH END. SHUTDOWN TAKEN BY NTPC BARH.
							0.63	0.00	0.00	0.00	15.13	100.00	
CKT	400kV KAHALGAON(NTPC)-BARH(NTPC)-2	OSPD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* UPRATING OF BAY <(>&<)> LINE EQUIPMENTS AT NTPC KAHALGAON END* SHUTDOWN TAKEN BY NTPC KAHALGAON
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	400kV FARAKKA(NTPC)-KAHALGAON(NTPC)-1	OSFD	25-02-2025	08:30:00	25-02-2025	19:01:00	0.44	0.00	0.00	0.00	10.52		* EMERGENCY S/D TAKEN BY KAHALGAON NTPC TO FACILITATE THE BUS SHUTDOWN
							0.44	0.00	0.00	0.00	10.52	100.00	
CKT	400kV FARAKKA(NTPC)-KAHALGAON(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAHALGAON(NTPC)-LAKHISARAI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAHALGAON(NTPC)-LAKHISARAI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAHALGAON(NTPC)-MAITHON-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., EASTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAHALGAON(NTPC)-MAITHON-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KODERMA(DVC)-BIHARSHARIF-1	LNCC	26-02-2025	09:03:00	26-02-2025	19:36:00	0.44	0.00	0.00	10.55	0.00		* LINE SHUTDOWN AVAILED FOR FLASHOVER POLYMER INSULATOR REPLACEMENT AT LOC. 61 DAMAGED DUE TO LIGHTENING.
							0.44	0.00	0.00	10.55	0.00	100.00	
CKT	400kV KODERMA(DVC)-BIHARSHARIF-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KODERMA(DVC)-BOKARO(JBVNL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KODERMA(DVC)-BOKARO(JBVNL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KODERMA(DVC)-GAYA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KODERMA(DVC)-GAYA-2	OMSU	13-02-2025	14:53:00	13-02-2025	17:18:00	0.10	0.00	2.42	0.00	0.00		* TRIPPED FROM BOTH ENDS DUE TO Y-B FAULT DUE TO KITE THREAD.* FAULT DETAILS GAYA(SITE):- FD- 87.7KM, FC- 6.81 KA .** A KITE WITH THREADING FOUND HANGEOVER AT EW NEAR EVD (109-110).
							0.10	0.00	2.42	0.00	0.00	100.00	
CKT	400kV KISHANGANJ-SAHARSA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHANGANJ-SAHARSA-2	LART	03-02-2025	22:13:00	03-02-2025	22:13:00	0.00	0.00	0.00	0.00	0.00		* A/R SUCCESSFUL FROM BOTH ENDS DUE TO B-N FAULT.* SAHARSA(SITE):M1-FD-180KM, FC-1.934KA, M2-FD-190KM, FC-1.938KA* KSN(SITE):M1-FD-17.2KM, FC-11.53KA, M2-FD-17.2KM, FC-12.06KA
CKT	400kV KISHANGANJ-SAHARSA-2	LVRD	01-02-2025	00:00:01	03-02-2025	13:57:00	2.58	0.00	0.00	0.00	61.95		* HAND TRIPPED FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION
							2.58	0.00	0.00	0.00	61.95	100.00	
CKT	400kV KISHANGANJ-SAHARSA-3(LILO PORTION)	OSPT	18-02-2025	10:30:00	18-02-2025	18:56:00	0.35	8.43	0.00	0.00	0.00		* SHUTDOWN TAKEN FOR LINE BAY AND LINE REACTOR MAINTAINANCE WORK AT KISHANGANJ END.
							0.35	8.43	0.00	0.00	0.00	98.75	
CKT	400kV KISHANGANJ-SAHARSA-4(LILO PORTION)	OSPT	19-02-2025	09:12:00	19-02-2025	18:55:00	0.41	9.72	0.00	0.00	0.00		* SHUTDOWN TAKEN FOR LINE BAY AND LINE REATOR MAINTAINANCE WORK AT KISHANGANJ END
							0.41	9.72	0.00	0.00	0.00	98.55	
CKT	400kV LAKHISARAI-BIHARSHARIF-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LAKHISARAI-BIHARSHARIF-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MOTIHARI(DMTCL)-GORAKHPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MOTIHARI(DMTCL)-GORAKHPUR-2	LNCC	15-02-2025	18:04:00	15-02-2025	22:26:00	0.18	0.00	0.00	4.37	0.00		* FOR REPLACEMENT OF DE-CAPPED INSULATOR AT LOCATION NO-775 UNDER NR3 JURISDICTION.
CKT	400kV MOTIHARI(DMTCL)-GORAKHPUR-2	LART	15-02-2025	14:05:00	15-02-2025	14:05:00	0.00	0.00	0.00	0.00	0.00		* A/R SUCCESSFUL FROM BOTH ENDS DUE TO B-N FAULT DUE TO LOCALIZED CYCLONE , FAULT DETAILS-GORAKHPUR (SITE)-M1-FD-51.7 KM, FC-6.2 KA, M2-FD-51.58 KM, FC-6.16 KA* INSULATOR DE-CAPPED AT LOCATION NO-775** FAULT UNDER NR-3 JURISDICTION
							0.18	0.00	0.00	4.37	0.00	100.00	
CKT	400kV NABINAGAR(BRBCL)-SASARAM-1	LNCC	10-02-2025	11:13:00	10-02-2025	16:43:00	0.23	0.00	0.00	5.50	0.00		* SHUTDOWN TAKEN FOR EARTH WIRE CLEARANCE MAINTENANCE WORK DUE TO LOCALIZED CYCLONE BETWEEN LOCATION NO 83-84 <(> 84-85
CKT	400kV NABINAGAR(BRBCL)-SASARAM-1	LNCC	07-02-2025	10:23:00	07-02-2025	19:34:00	0.38	0.00	0.00	9.18	0.00		* TRIPPED ON R-N PERSISTENT FAULT* PSL(SITE):M1-FD-52.23KM, FC-7.538KA, M2-FD-53.1KM, FC-6.294KA
CKT	400kV NABINAGAR(BRBCL)-SASARAM-1	LNCC	07-02-2025	09:48:00	07-02-2025	10:16:00	0.02	0.00	0.00	0.47	0.00		* TRIPPED DUE TO R-N FULT.* PSL(SITE):M1-FD-54.28KM, FC-7.754KA, M2-FD-55.09KM, FC-6.17KA
							0.63	0.00	0.00	15.15	0.00	100.00	
CKT	400kV NABINAGAR(BRBCL)-SASARAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAUBATPUR BALIA CKT-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATNA-BALIA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATNA-BALIA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATNA-BALIA-3	OSPT	25-02-2025	10:33:00	25-02-2025	19:14:00	0.36	8.68	0.00	0.00	0.00		* FOR AMP WORK OF LINE BAY AND LINE REACTOR AT BALIA END BY NR-3
							0.36	8.68	0.00	0.00	0.00	98.71	
CKT	400kV PATNA-JAKKANPUR CKT-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATNA-JAKKANPUR CKT-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATNA-NAUBATPUR CKT-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATNA-SAHARSA-1	OMSU	14-02-2025	13:07:00	14-02-2025	15:46:00	0.11	0.00	2.65	0.00	0.00		* SHUTDOWN TAKEN FOR REMOVAL OF MIDDLE PHASE KITE THREAD AT LOC NO-453 TO AVOID TRIPPING OF LINE.

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., EASTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV PATNA-SAHARSA-2			00:00:00		00:00:00	0.11	0.00	2.65	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RANCHI-DHANBAD-1(MRB LILO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RANCHI-DHANBAD-2(MRB LILO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RANCHI-MAITHON-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RANCHI-RAGHUNATHPUR(DVC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RANCHI-NEW RANCHI-1	OMSU	18-02-2025	08:20:00	18-02-2025	20:15:00	0.50	0.00	11.92	0.00	0.00		* SHUTDOWN TAKEN FOR STRINGING OF MISSING EARTH WIRE AT MULTI-CIRCUIT TOWER (29-30 <[&<] 33-34) TO AVOID LINE TRIPPING DUE TO LIGHTENING
							0.50	0.00	11.92	0.00	0.00	100.00	
CKT	400kV RANCHI-NEW RANCHI-2	OMSU	19-02-2025	08:19:00	19-02-2025	20:49:00	0.52	0.00	12.50	0.00	0.00		* SHUTDOWN TAKEN FOR STRINGING OF MISSING EARTH WIRE AT MULTI-CIRCUIT TOWER (29-30 <[&<] 33-34) TO AVOID LINE TRIPPING DUE TO LIGHTENING
CKT	400kV RANCHI-NEW RANCHI-2	OMSU	18-02-2025	08:21:00	18-02-2025	20:13:00	0.49	0.00	11.87	0.00	0.00		* SHUTDOWN TAKEN FOR STRINGING OF MISSING EARTH WIRE AT MULTI-CIRCUIT TOWER (29-30 <[&<] 33-34) TO AVOID LINE TRIPPING DUE TO LIGHTENING
							1.01	0.00	24.37	0.00	0.00	100.00	
CKT	400kV RANCHI-NEW RANCHI-3	OMSU	18-02-2025	08:22:00	18-02-2025	20:12:00	0.49	0.00	11.83	0.00	0.00		* SHUTDOWN TAKEN FOR STRINGING OF MISSING EARTH WIRE AT MULTI-CIRCUIT TOWER (29-30 <[&<] 33-34) TO AVOID LINE TRIPPING DUE TO LIGHTENING
CKT	400kV RANCHI-NEW RANCHI-3	OMSU	19-02-2025	08:20:00	19-02-2025	20:51:00	0.52	0.00	12.52	0.00	0.00		* SHUTDOWN TAKEN FOR STRINGING OF MISSING EARTH WIRE AT MULTI-CIRCUIT TOWER (29-30 <[&<] 33-34) TO AVOID LINE TRIPPING DUE TO LIGHTENING
							1.01	0.00	24.35	0.00	0.00	100.00	
CKT	400kV RANCHI-NEW RANCHI 4	OMSU	19-02-2025	08:21:00	19-02-2025	20:54:00	0.52	0.00	12.55	0.00	0.00		* SHUTDOWN TAKEN FOR STRINGING OF MISSING EARTH WIRE AT MULTI-CIRCUIT TOWER (29-30 <[&<] 33-34) TO AVOID LINE TRIPPING DUE TO LIGHTENING
							0.52	0.00	12.55	0.00	0.00	100.00	
CKT	400kV RANCHI-ROURKELA-1	LCSD	01-02-2025	13:09:00	07-02-2025	21:06:00	6.33	0.00	0.00	0.00	151.95		* TO FACILITATE THE RECONDUCTORING WORK OF STRUNG BUS AT ROURKELA UNDER OH-02 PACKAGE (SHUTDOWN TAKEN BY ODISHA)
CKT	400kV RANCHI-ROURKELA-1	OSPT	28-02-2025	10:27:00	28-02-2025	14:07:00	0.15	3.67	0.00	0.00	0.00		* SHUTDOWN TAKEN TO ATTEND HOT SPOT IN LINE ISOLATOR AT ROURKELA END BY ODISHA-PG.
							6.48	3.67	0.00	0.00	151.95	99.45	
CKT	400kV RANCHI-ROURKELA-2	LCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BAY UPGRADING WORK AT ROURKELA BY ODISHA PROJECT (UNDER OH-02 PACKAGE)
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	400kV RAGHUNATHPUR(DVC)-MAITHON-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEW RANCHI-CHANDWA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEW RANCHI-CHANDWA-2	OSPT	07-02-2025	00:15:00	07-02-2025	01:54:00	0.07	1.65	0.00	0.00	0.00		* FOR RECTIFICATION OF SF6 ALRAM AT CHANDWA SS.
							0.07	1.65	0.00	0.00	0.00	99.75	
CKT	400kV SASARAM-ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DALTONGANJ- SASARAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DALTONGANJ-SASARAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SAHARSA-DARBHANGA-1(LILO PORTION)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SAHARSA-DARBHANGA-2(LILO PORTION)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SITAMARHI DHALKEBAR 1 (INDIA PORTI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SITAMARHI DHALKEBAR2 (INDIA PORTIO			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SASARAM-VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV GAYA-BALIA	LART	06-02-2025	11:39:00	06-02-2025	11:39:00	0.00	0.00	0.00	0.00	0.00		* A/R SUCCESSFUL FROM BOTH ENDS DUE TO R-N FAULT.* BALIA(SITE):M1-FD-130.5KM, FC-4.628KA, M2-FD-131KM, FC-4.675KA.** LONG KITE THREAD FOUND AT MIDDLE PHASE CONDUCTOR (R PHASE) <[&<] AT TOWER BODY OF LOC NO. 251.
CKT	765kV GAYA-BALIA	LNCC	20-02-2025	09:48:00	20-02-2025	19:57:00	0.42	0.00	0.00	10.15	0.00		* SHUTDOWN TAKEN FOR REPLACEMENT OF DE-CAPPED POLYMER INSULATOR AT LOCATION 454 <[&<] 462A BY NR3
CKT	765kV GAYA-BALIA	LART	06-02-2025	11:39:00	06-02-2025	11:39:00	0.00	0.00	0.00	0.00	0.00		* A/R SUCCESSFUL FROM BOTH ENDS DUE TO R-N FAULT.* GAYA(SITE):M1-FD-99.6KM, FC-5.50 kA, M2-99.2 kM, FC-5.58 kA
							0.42	0.00	0.00	10.15	0.00	100.00	
CKT	765kV GAYA-VARANASI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV GAYA-VARANASI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., EASTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	765kV SASARAM-FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SW LR OF BIHARSHARIFF-1 AT BANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SW LR OF BIHARSHARIFF-2 AT BANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SW LR OF PURNEA-2 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF LAKHISARAI-2 AT BIHARSHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SW LR OF SASARAM-1 AT BIHARSHARIF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SW LR OF VARANASI-2 AT BIHARSHARI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SW LR OF PURNEA-1 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SW LR OF VARANASI-1 AT BIHARSHARI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SW LR OF MAITHON-1 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SW LR OF MAITHON-2 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SW LR OF BALIA AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SW LR OF VARANASI-1 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SW LR OF VARANASI-2 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SW LR OF PATNA-1 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SW LR OF PATNA-2 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF DARBHANGA-1 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF DARBHANGA-2 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF PURNEA-2 AT MUZAFFARPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF GORAKHPUR-2 AT MUZAFFARPU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF PURNEA-1 AT MUZAFFARPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF GORAKHPUR-1 AT MUZAFFARPU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF JAKKANPUR-1 AT PATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF NABINAGAR-2 AT PATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	125MVAR,SWLR OF BARH-2 AT PATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF BARH-1 AT PATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF KISHANGANJ-1 AT N.PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF MUZAFFARPUR-2 AT N.PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF MUZAFFARPUR-1 AT N.PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF FARAKKA AT N.PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF GOKARNA AT N.PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., EASTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	50MVAR,SWLR OF DHANBAD-1 AT RANCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF DHANBAD-2 AT RANCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DHARAMJAYGARH-1 AT N.RAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DHARAMJAYGARH-2 AT N.RAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF MEDNIPUR-1 AT N.RANCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF MEDNIPUR-2 AT N.RANCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF VARANASI-1 AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	HVDC- PUSAULI SWITCHABLE LINE REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF FATEHPUR AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF ALLAHABAD AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	PUSAULI SARNATH_LINE_REACTOR_CWL39			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF BIHARSHARIFF-1 AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF BIHARSHARIFF-2 AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-200/+200 MVAR STATCOM AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT RANCHI 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	HVDC BTB SASARAM	OMSU	10-02-2025	10:51:00	14-02-2025	05:04:00	3.76	0.00	90.22	0.00	0.00		* FOR UPGRADATION WORK OF BIO-3_CARDS ALONG WITH ITS INSTALLATION AT SASARAM HVDC BY M/S SYNERGY_SYSTEMS_<(>&<)>_SOLUTIONS TO AVOID TRIPPING.
							3.76	0.00	90.22	0.00	0.00	100.00	
XMER	100MVA,220/132KV ICT-1 AT ARA	OMSU	12-02-2025	09:33:00	13-02-2025	01:46:00	0.68	0.00	16.22	0.00	0.00		* FOR BUS BAR RELAY RETROFITTING WORK AT ARRACH. REPLACEMENT OF ELECTROMECHANICAL RELAY WITH NUMERICAL RELAY FOR PROTECTION SYSTEM PERF=ORMANCE IMPROVEMENT.
							0.68	0.00	16.22	0.00	0.00	100.00	
XMER	100MVA,220/132KV ICT-2 AT ARA	OMSU	14-02-2025	09:55:00	14-02-2025	16:30:00	0.27	0.00	6.58	0.00	0.00		* FOR BUS BAR RELAY RETROFITTING WORK AT ARRACH. REPLACEMENT OF ELECTROMECHANICAL RELAY WITH NUMERICAL RELAY FOR PROTECTION SYSTEM PERF=ORMANCE IMPROVEMENT.
							0.27	0.00	6.58	0.00	0.00	100.00	
XMER	160MVA,220/132KV ICT-3 AT ARA	OMSU	15-02-2025	09:47:00	15-02-2025	19:42:00	0.41	0.00	9.92	0.00	0.00		* FOR BUS BAR RELAY RETROFITTING WORK AT ARRACH. REPLACEMENT OF ELECTROMECHANICAL RELAY WITH NUMERICAL RELAY FOR PROTECTION SYSTEM PE=RFORMANCE IMPROVEMENT.
							0.41	0.00	9.92	0.00	0.00	100.00	
XMER	200MVA,220/132KV ICT-4 AT ARA	OMSU	13-02-2025	09:59:00	13-02-2025	18:40:00	0.36	0.00	8.68	0.00	0.00		* FOR BUS BAR RELAY RETROFITTING WORK AT ARRACH. REPLACEMENT OF ELECTROMECHANICAL RELAY WITH NUMERICAL RELAY FOR PROTECTION SYSTEM PER=FORMANCE IMPROVEMENT.
							0.36	0.00	8.68	0.00	0.00	100.00	
XMER	200MVA,400/132KV ICT-1 AT BANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	200MVA,400/132KV ICT-2 AT BANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/132KV ICT-3 AT BANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-3 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-4 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT CHAIBASA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., EASTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220KV ICT-2 AT CHAIBASA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/132KV ICT-1 AT DALANGANJ	OMSU	23-02-2025	09:33:00	23-02-2025	13:24:00	0.16	0.00	3.85	0.00	0.00		* ICT WAS UNDER S/D TO FACILATE THE S/D OF 132KV MAIN BUS -1 AT DALTONGANJ (PG) END
							0.16	0.00	3.85	0.00	0.00	100.00	
XMER	160MVA,220/132KV ICT-2 AT DALANGANJ	OMSU	23-02-2025	09:33:00	23-02-2025	13:24:00	0.16	0.00	3.85	0.00	0.00		* ICT WAS UNDER S/D TO FACILATE THE S/D OF 132KV MAIN BUS -1 AT DALTONGANJ (PG) END
							0.16	0.00	3.85	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT DALANGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT DALANGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-1 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400KV ICT-1 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400KV ICT-2 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-3 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400KV ICT-3 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400KV ICT-4 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-3 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-1 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-2 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	200MVA,400/132KV ICT-1 AT LAKHISARAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	200MVA,400/132KV ICT-2 AT LAKHISARAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/132KV ICT-3 AT LAKHISARAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT MUZAFFARPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT MUZAFFARPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-3 AT MUZAFFARPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-4 AT MUZAFFARPUR	OSPT	27-02-2025	10:15:00	27-02-2025	18:22:00	0.34	8.12	0.00	0.00	0.00		* SHUTDOWN TAKEN FOR AMP WORK OF ICT-4 AT MUZAFFARPUR
							0.34	8.12	0.00	0.00	0.00	98.79	
XMER	500MVA,400/220KV ICT-1 AT PATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-2 AT PATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-3 AT PATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/132KV ICT-1 AT PURNEA	OSPT	10-02-2025	09:29:00	10-02-2025	18:23:00	0.37	8.90	0.00	0.00	0.00		* SHUTDOWN TAKEN FOR AMP WORK
							0.37	8.90	0.00	0.00	0.00	98.68	
XMER	160MVA,220/132KV ICT-2 AT PURNEA	OSPT	12-02-2025	09:25:00	12-02-2025	20:14:00	0.45	10.82	0.00	0.00	0.00		* SHUTDOWN TAKEN FOR AMP WORK
							0.45	10.82	0.00	0.00	0.00	98.39	
XMER	160MVA,220/132KV ICT-3 AT PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-1 AT NEW PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-2 AT NEW PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT RANCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., EASTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT RANCHI	OSPT	10-02-2025	09:19:00	11-02-2025	06:32:00	0.88	21.22	0.00	0.00	0.00		* SHUTDOWN TAKEN FOR AMP WORK AT RANCHI SS
							0.88	21.22	0.00	0.00	0.00	96.84	
XMER	500MVA,400/220KV ICT-3 AT RANCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400KV,ICT-1 AT RANCHI 765KV	OSPT	17-02-2025	13:49:00	17-02-2025	17:55:00	0.17	4.10	0.00	0.00	0.00		* FOR RECTIFICATION OF HV SIDE WTI METER AT NEW RANCHI SS
							0.17	4.10	0.00	0.00	0.00	99.39	
XMER	1500MVA,765/400KV,ICT-2 AT RANCHI 765KV			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400KV,ICT AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-1 AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-2 AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	