

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. EASTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR,BUS REACTOR-1 AT BANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT BANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR,BUS REACTOR-1 AT BIHARSHARIFF	SCSD	21-08-2023	09:42:00	21-08-2023	20:32:00	0.45	0.00	0.00	0.00	10.83	100.00	* S/D TAKEN FOR MAIN BAY LBB RETROFITTING WORK
BSR	80MVAR,BUS REACTOR-2 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-4 AT BIHARSHARIFF	SCSD	21-08-2023	09:42:00	21-08-2023	20:32:00	0.45	0.00	0.00	0.00	10.83	100.00	* S/D TAKEN FOR MAIN BAY LBB RETROFITTING WORK
BSR	80MVAR,BUS REACTOR-1 AT CHAIBASA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT CHAIBASA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT CHANDWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT CHANDWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT DALTANGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT GAYA	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* HAND TRIPPED FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT GAYA	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* H/T FOR VOLTAGE REGULATION.
BSR	125MVAR,BUS REACTOR-2 AT GAYA	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* HAND TRIPPED FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-2 AT GAYA	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* "H/T FOR V/R" 752/759,397/399,221/222"
BSR	49MVAR,BUS REACTOR-1 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	175MVAR,BUS REACTOR-2 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT LAKHISARAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT LAKHISARAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT MUZAFFARPUR	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* H/T FOR VOLTAGE REGULATION AS PER ERLDC. V/C-391/393
BSR	125MVAR,BUS REACTOR-2 AT MUZAFFARPUR	SVRD	03-08-2023	21:09:00	31-08-2023	23:59:59	28.12	0.00	0.00	0.00	674.85	100.00	* HAND TRIPPED FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION.
BSR	125MVAR,BUS REACTOR-2 AT MUZAFFARPUR	SVRD	01-08-2023	00:00:01	02-08-2023	11:10:00	1.47	0.00	0.00	0.00	35.17	100.00	* HANDTRIPPED UNDER VOLTAGE REGULATION
BSR	125MVAR,BUS REACTOR-1 AT PATNA	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	710.02	100.00	* HAND TRIPPED DUE TO VOLTAGE REGULATION, VOL CHANGE: 393/395 KV , 213/215KV
BSR	125MVAR,BUS REACTOR-1 AT NEW PURNEA	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* HAND TRIPPED DUE TO VOLTAGE REGULATION, VOL CHANGE: 398/398 KV , 218/218KV
BSR	125MVAR,BUS REACTOR-2 AT NEW PURNEA	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* HAND TRIPPED DUE TO VOLTAGE REGULATION, VOL CHANGE: 398/398 KV , 218/218KV
BSR	80MVAR,BUS REACTOR-1 AT RANCHI 400			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT RANCHI 400			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT RANCHI 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT RANCHI 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT RANCHI 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT RANCHI 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT SASARAM	SVRD	13-08-2023	19:04:00	31-08-2023	23:59:59	18.21	0.00	0.00	0.00	436.93	100.00	* HAND TRIPPED FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION.
BSR	330MVAR,BUS REACTOR-1 AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT SASARAM	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* HAND TRIPPED FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION.
CKT	132kV ARA-ARA(BSPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kVARA-DUMRAON(BSPTCL)-1	LCSD	28-08-2023	09:59:00	28-08-2023	17:49:00	0.33	0.00	0.00	0.00	7.83	100.00	* SAS UPGRADATION WORK AT ARA SS
CKT	132kVARA-DUMRAON(BSPTCL)-1	LPRD	24-08-2023	11:15:00	24-08-2023	20:41:00	0.39	0.00	0.00	0.00	9.43	100.00	* LINE HAND TRIPPED UNDER POWER REGULATION AS PER ERLDC INSTRUCTION
CKT	132kVARA-DUMRAON(BSPTCL)-1	OMSU	16-08-2023	14:35:00	16-08-2023	15:53:00	0.05	0.00	1.30	0.00	0.00	100.00	* LINE TRIPPED DUE TO Y-N FAULT UNDER ZONE-3.* ARA (AFAS) FC-1.085KA,FD-61.500KM

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. EASTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV BARH(NTPC)-PATNA-3	LCSD	01-08-2023	00:00:01	02-08-2023	22:47:00	1.95	0.00	0.00	0.00	46.78	100.00	* SHUTDOWN TAKEN FOR DIVERSION WORKS OF NHAI FROM LOC. 48-51.
CKT	400kV BARH(NTPC)-PATNA-4	LCSD	01-08-2023	00:00:01	02-08-2023	22:49:00	1.95	0.00	0.00	0.00	46.82	100.00	* SHUTDOWN TAKEN FOR DIVERSION WORKS OF NHAI FROM LOC. 48-51.
CKT	400 kV BIHARSHARIF-BALIA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV BIHARSHARIF-BALIA-2	LNCC	07-08-2023	10:03:00	07-08-2023	20:55:00	0.45	0.00	0.00	10.87	0.00	100.00	* FLASHED INSULATOR REPLACEMENT WORK.
CKT	400kV BIHARSHARIF-MUZAFFARPUR-1	LART	23-08-2023	15:48:00	23-08-2023	15:48:00	0.00	0.00	0.00	0.00	0.00	100.00	* AUTO RECLOSER SUCCESSFUL FROM BOTH END DUE TO Y-N FAULT.FD-51.6KM FROM BIHARSHARIF AND FC-5.77KA.
CKT	400kV BIHARSHARIF-MUZAFFARPUR-1	LCSD	01-08-2023	10:10:00	01-08-2023	20:08:00	0.42	0.00	0.00	0.00	9.97	100.00	* FOR LBB RETROFITTING WORK AT BIHARSHARIFF
CKT	400kV BIHARSHARIF-MUZAFFARPUR-1	LNCC	25-08-2023	08:25:00	25-08-2023	16:41:00	0.34	0.00	0.00	8.27	0.00	100.00	* SHUTDOWN TAKEN FOR REPLACEMENT OF DECAPPED INSULATOR AT LOC. 147 DUE TO LIGHTENING.
CKT	400kV BIHARSHARIF-MUZAFFARPUR-2	LNCC	01-08-2023	22:13:00	01-08-2023	23:03:00	0.04	0.00	0.00	0.83	0.00	100.00	* TRIPPED ON Y-N FAULT DUE TO SEVERE THUNDERSTORM AND LIGHTENUNG AROUND THE FAULT.FD-55.7KM FROM BIHARSHARIF AND FC-5.38KA.
CKT	400kV BIHARSHARIF-SASARAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BIHARSHARIF-SASARAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BIHARSHARIF-VARANASI-1	LNCC	26-08-2023	10:20:23	26-08-2023	20:05:00	0.41	0.00	0.00	9.74	0.00	100.00	* FLASHED INSULATOR REPLACEMENT WORK
CKT	400kV BIHARSHARIF-VARANASI-2	LNCC	25-08-2023	12:03:00	25-08-2023	20:20:00	0.35	0.00	0.00	8.28	0.00	100.00	* SHUTDOWN TAKEN FOR FLASHOVER AFFECTED INSULATOR REPLACEMENT WORK AT LOC. 181.
CKT	400 kV CHAIBASA-ROURKELA-1	OMST	06-08-2023	13:27:00	06-08-2023	14:03:00	0.03	0.60	0.00	0.00	0.00	99.92	* TRIPPED ONLY FROM ROURKELA END DUE TO DT RECEIVED AT ROURKELA END. NO EVENT RECORDED AT CHAIBASA
CKT	400 kV CHAIBASA-ROURKELA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHANDAUTI NABINAGAR 1	OMSU	09-08-2023	15:36:00	09-08-2023	16:49:00	0.05	0.00	1.22	0.00	0.00	100.00	* TRIPPED DUE TO DT RECEIVED AT CHANDAUTI END DUE TO PROBLEM AT NPGC END.
CKT	400kV CHANDAUTI NABINAGAR 1	OMSU	27-08-2023	09:28:00	27-08-2023	19:52:00	0.44	0.00	10.43	0.00	0.00	100.00	* REPLACEMENT OF PORCELAIN INSULATOR TO POLYMER AT MAJOR CROSSINGS
CKT	400kV CHANDAUTI NABINAGAR 2	OSPD	09-08-2023	15:36:00	09-08-2023	20:39:00	0.21	0.00	0.00	0.00	5.05	100.00	* SHUTDOWN TAKEN BY PMTL FOR ATTENDING HOTSPOT R-PHASE WAVE TRAP CONNECTOR TOWARDS AT CHANDAUTI
CKT	400kV CHANDAUTI NABINAGAR 2	OMSU	21-08-2023	11:16:00	21-08-2023	18:09:00	0.29	0.00	6.88	0.00	0.00	100.00	* FOR REPLACEMENT OF PORCELAIN INSULATOR AT LOC-199
CKT	400kV CHANDWA-GAYA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHANDWA-GAYA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DHANBAD- MAITHON RB 1(MRB LILO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DHANBAD- MAITHON RB 2(MRB LILO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GAYA CHANDAUTI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GAYA CHANDAUTI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GAYA MAITHON-1	OMSU	29-08-2023	09:24:00	29-08-2023	20:26:00	0.46	0.00	11.03	0.00	0.00	100.00	* TO INSTALL ADDITIONAL PILOT STRINGS TO CONTAIN JUMPER SWING DURING HEAVY WIND LIGHTENING CONDITION IN MULTI CIRCUIT AND OTHE RPORTIONS.
CKT	400kV GAYA MAITHON-2	OMSU	28-08-2023	09:29:00	28-08-2023	20:38:00	0.47	0.00	11.15	0.00	0.00	100.00	* TO INSTALL ADDITIONAL PILOT STRINGS IN MULTI CIRCUIT
CKT	400 kV TATA DVC-BARIPADA-1	LMAC	05-08-2023	09:04:00	05-08-2023	18:57:00	0.41	0.00	0.00	9.88	0.00	100.00	* SHUTDOWN TAKEN FOR REPLACEMENT OF INSULATOR BROKEN BY MISCREANTS.
CKT	400kV JAMSHEDPUR-BARIPADA-2	LNCC	21-08-2023	09:25:00	21-08-2023	21:41:00	0.51	0.00	0.00	12.27	0.00	100.00	* SHUTDOWN TAKEN FOR REPLACEMENT OF FLASHED INSULATOR DUE TO SEVERE THUNDERSTORM AND LIGHTENING AT LOC NO 182
CKT	400 kV JAMSHEDPUR-CHAIBASA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV JAMSHEDPUR-CHAIBASA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV JAMSHEDPUR-TATA DVC-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV JAKKANPUR NABINAGAR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV JAKKANPUR NABINAGAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAHALGAON(NTPC)-BANKA-1	OMSU	20-08-2023	10:17:00	20-08-2023	20:34:00	0.43	0.00	10.28	0.00	0.00	100.00	* TRIPPED FROM BOTH ENDS ON RECEIPT OF DT FROM KAHALGAON END.
CKT	400kV KAHALGAON(NTPC)-BANKA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAHALGAON(NTPC)-BARH(NTPC)-1	OSPD	04-08-2023	12:19:00	31-08-2023	23:59:59	27.49	0.00	0.00	0.00	659.68	100.00	* SHUTDOWN TAKEN BY NTPC KAHALGAON FOR UPGRADATION OF BAY EQUIPMENTS.
CKT	400kV KAHALGAON(NTPC)-BARH(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV FARAKKA(NTPC)-KAHALGAON(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV FARAKKA(NTPC)-KAHALGAON(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. EASTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE TO Others	OUTAGE ATTRIBU TABLE TO System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/132KV ICT-3 AT BANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220KV ICT-1 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-3 AT BIHARSHARIFF	OSPT	16-08-2023	09:16:00	17-08-2023	19:35:00	1.43	34.32	0.00	0.00	0.00	95.39	* REPLACEMENT OF PUMPSET-1 PUMP INDICATOR AT BIHARSHARIF SUBSTATION.
XMER	500MVA,400/220KV ICT-4 AT BIHARSHARIFF			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT CHAIBASA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT CHAIBASA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/132KV ICT-1 AT DALANGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/132KV ICT-2 AT DALANGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT DALANGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT DALANGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-1 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400KV ICT-1 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400KV ICT-2 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-3 AT GAYA	OSPT	31-08-2023	10:03:00	31-08-2023	23:29:00	0.56	13.43	0.00	0.00	0.00	98.19	* FOR AMP WORK AND OTIWTI AND PRV SCHEME MODIFICATION WORK.
XMER	1500MVA,765/400KV ICT-3 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400KV ICT-4 AT GAYA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-3 AT JAMSHEDPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-2 AT KISHENGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	200MVA,400/132KV ICT-1 AT LAKHISARAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	200MVA,400/132KV ICT-2 AT LAKHISARAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/132KV ICT-3 AT LAKHISARAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT MUZAFFARPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-2 AT MUZAFFARPUR	OMSU	09-08-2023	10:21:00	09-08-2023	20:42:00	0.43	0.00	10.35	0.00	0.00	100.00	* SHUTDOWN TAKEN FOR 220KV BAY LBB RELAY RETROFITTING WORK .
XMER	500MVA,400/220KV ICT-3 AT MUZAFFARPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-4 AT MUZAFFARPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-1 AT PATNA	OMSU	22-08-2023	09:11:00	22-08-2023	19:49:00	0.44	0.00	10.63	0.00	0.00	100.00	* LBB RELAY RETROFITMENT IN TIE BAY
XMER	500MVA,400/220KV ICT-2 AT PATNA	OMSU	16-08-2023	10:51:00	16-08-2023	20:16:00	0.39	0.00	9.42	0.00	0.00	100.00	* S/D TAKEN FOR 400KV TIE BAY (408) LBB RELAY RETROFITTING WORK.
XMER	500MVA,400/220KV ICT-3 AT PATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/132KV ICT-1 AT PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/132KV ICT-2 AT PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/132KV ICT-3 AT PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-1 AT NEW PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-2 AT NEW PURNEA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220KV ICT-1 AT RANCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. EASTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220KV ICT-2 AT RANCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-3 AT RANCHI	SCSD	25-08-2023	09:55:00	25-08-2023	16:21:00	0.27	0.00	0.00	0.00	6.43		* SHUTDOWN TAKEN FOR RECTIFICATION OF FIREFIGHTING EMULSIFIER SYSTEM.
							0.27	0.00	0.00	0.00	6.43	100.00	
XMER	1500MVA,765/400KV,ICT-1 AT RANCHI 765KV			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400KV,ICT-2 AT RANCHI 765KV			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400KV,ICT AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-1 AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220KV ICT-2 AT SASARAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	