

Standard of Performance data for the month of Apr-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. EASTERN REGION-II

Object Type	Element Name	Type	Outage Date	Outage Time	Restoration	Total Outage	OUTAGE ATTR1	OUTAGE ATTR2	OUTAGE ATTR3	OUTAGE ATTR4	% Availability as	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-2 AT ALIPURDUAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT ALIPURDUAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT ANGUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-1 AT ANGUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT ANGUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-2 AT ANGUL	SCSD	08-05-2023	09:09:00	08-05-2023	14:54:00	0.24	0.00	0.00	0.00	5.75	* 330 MVAR BR-2 SD for spare rotation <(>&<)> AMP
BSR	330MVAR,BUS REACTOR-2 AT ANGUL	SCSD	27-09-2023	09:18:00	27-09-2023	13:08:00	0.16	0.00	0.00	0.00	3.83	* Spare Rotation of BR # 2 at Angul SS
BSR	125MVAR,BUS REACTOR-3 AT ANGUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT BOLANGIR	SVRD	01-09-2023	18:28:00	30-09-2023	23:59:59	29.23	0.00	0.00	0.00	701.53	* H/T for Voltage reulation
BSR	80MVAR,BUS REACTOR-1 AT BOLANGIR	SVRD	09-07-2023	11:18:00	02-08-2023	11:44:00	24.02	0.00	0.00	0.00	576.43	* H/T as per instruction of ERLDC for voltage regulation.
BSR	80MVAR,BUS REACTOR-1 AT BOLANGIR	SVRD	01-07-2023	13:27:00	04-07-2023	21:07:00	3.32	0.00	0.00	0.00	79.67	* HT for voltage regulation
BSR	80MVAR,BUS REACTOR-1 AT BOLANGIR	SVRD	01-04-2023	00:00:01	21-04-2023	09:13:00	20.38	0.00	0.00	0.00	489.22	* H/T as per instruction of ERLDC for voltage regulation.
BSR	80MVAR,BUS REACTOR-1 AT BOLANGIR	SVRD	09-06-2023	10:08:00	12-06-2023	09:56:00	2.99	0.00	0.00	0.00	71.80	* 400KV, 80 MVAR BUS REACTOR AT BOLANGIR HAND TRIPPED FOR VOLTAGE REGULATION PURPOSE AT 10:08 HRS C
BSR	80MVAR,BUS REACTOR-1 AT BOLANGIR	SVRD	08-08-2023	17:15:00	26-08-2023	01:24:00	17.34	0.00	0.00	0.00	416.15	* H/T as per instruction of ERLDC for voltage regulation.
BSR	125MVAR,BUS REACTOR-2 AT BOLANGIR	SVRD	01-04-2023	00:00:01	26-06-2023	10:44:00	86.45	0.00	0.00	0.00	2,074.73	* 125MVAR,BUS REACTOR-2 AT BOLANGIR H/T for voltage regulation at 06:30Hrs* 26.06.2023 13:55:40 INDIA Abhishek Anand
BSR	125MVAR,BUS REACTOR-2 AT BOLANGIR	SVRD	09-08-2023	10:07:00	02-09-2023	18:41:00	24.36	0.00	0.00	0.00	584.57	* H/T FOR VOLTAGE REGULATION
BSR	125MVAR,BUS REACTOR-1 AT BINAGURI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT BINAGURI	OSPT	29-09-2023	10:19:00	29-09-2023	17:05:00	0.28	6.77	0.00	0.00	0.00	* AMP WORKS
BSR	125MVAR,BUS REACTOR-2 AT BINAGURI	OMSU	29-05-2023	09:56:00	29-05-2023	21:47:00	0.49	0.00	11.85	0.00	0.00	* S/D FOR CSD RETUNING
BSR	80MVAR,BUS REACTOR-1 AT BERHAMPORE	OSPT	20-08-2023	09:52:00	20-08-2023	16:20:00	0.27	6.47	0.00	0.00	0.00	* S/D FOR ATTENDING OIL LEAKAGE AT BUCHHOLZ RELAY POINT.
BSR	125MVAR,BUS REACTOR-2 AT BERHAMPORE	OSPT	27-09-2023	17:23:00	27-09-2023	18:50:00	0.06	1.45	0.00	0.00	0.00	* E/S/D TO ATTEND ALIGNMENT OF 40589A(Y PHASE).
BSR	125MVAR,BUS REACTOR-2 AT BERHAMPORE	OSPT	25-07-2023	12:33:00	25-07-2023	17:36:00	0.21	5.05	0.00	0.00	0.00	* S/D for checking of CSD alarm.
BSR	125MVAR,BUS REACTOR-1 AT BARIPADA	SVRD	15-08-2023	23:51:00	30-09-2023	23:59:59	46.01	0.00	0.00	0.00	1,104.15	* Handtripped for Voltage Regulation at 23:51 hrs on 15/08/2023. * Voltage Change: 398 kV to 402 kV
BSR	125MVAR,BUS REACTOR-1 AT BARIPADA	SVRD	08-04-2023	15:18:00	27-06-2023	02:58:00	79.49	0.00	0.00	0.00	1,907.67	* 125MVAR,BUS REACTOR-1 AT BARIPADA H/T for voltage regulation as per ERLDC instruction. at 15:18Hrs
BSR	125MVAR,BUS REACTOR-2 AT BARIPADA	SVRD	10-06-2023	14:31:00	27-06-2023	02:44:00	16.51	0.00	0.00	0.00	396.22	* H/T for voltage regulation at 14:31hrs
BSR	125MVAR,BUS REACTOR-2 AT BARIPADA	SVRD	01-04-2023	00:00:01	09-06-2023	17:54:00	69.75	0.00	0.00	0.00	1,673.90	* 400 KV, 125 MVAR BR # 2 at Baripada H/T at 09:46 Hrs on 03.02.2023 as per instruction of ERLDC for voltage regulation.
BSR	80MVAR,BUS REACTOR-1 AT DUBRI	OSPT	05-04-2023	11:07:00	05-04-2023	14:25:00	0.14	3.30	0.00	0.00	0.00	* For AMP work* 05.04.2023 17:44:53 INDIA Abhishek Anand (60003546)** Taken into service at 14:25 hrs on 05/04/2023 vide ER
BSR	50MVAR,BUS REACTOR-1 AT DURGAPUR	SCSD	18-07-2023	11:06:00	18-07-2023	21:32:00	0.44	0.00	0.00	0.00	10.43	* S/d for stability testing of 400KV Main Bus -I-new BB commissioning works at Durgapur end.
BSR	50MVAR,BUS REACTOR-1 AT DURGAPUR	SCSD	24-06-2023	10:13:00	24-06-2023	17:27:00	0.30	0.00	0.00	0.00	7.23	* S/D FOR TESTING OF NEW BUSBAR TRIPPING WITH LBB INITIATION FOR RETROFITTING OF 400 KV BUS BAR PROTE
BSR	50MVAR,BUS REACTOR-1 AT DURGAPUR	SCSD	07-07-2023	09:41:00	07-07-2023	20:33:00	0.45	0.00	0.00	0.00	10.87	* S/D FOR RETROFITTING OF BUS-BAR <(>&<)> LBB RELAY AND TRIP TEST AT DURGAPUR S/S.
BSR	50MVAR,BUS REACTOR-1 AT DURGAPUR	SCSD	13-07-2023	06:19:00	13-07-2023	16:27:00	0.42	0.00	0.00	0.00	10.13	* S/D FOR DT/TRIP TEST FOR LBB/BUS BAR RELAY RETOIFITTING WORK AT DURGAPUR S/S
BSR	50MVAR,BUS REACTOR-1 AT DURGAPUR	SCSD	12-07-2023	09:20:00	12-07-2023	18:20:00	0.38	0.00	0.00	0.00	9.00	* S/D FOR DT/TRIP TEST FOR LBB BUS BAR RELAY RETOIFITTING WORK AT DURGAPUR S/S
BSR	125MVAR,BUS REACTOR-2 AT DURGAPUR	SCSD	24-06-2023	10:13:00	24-06-2023	17:27:00	0.30	0.00	0.00	0.00	7.23	* S/D FOR TESTING OF NEW BUSBAR TRIPPING WITH LBB INITIATION FOR RETROFITTING OF 400 KV BUS BAR PROTE
BSR	125MVAR,BUS REACTOR-2 AT DURGAPUR	SCSD	12-07-2023	09:20:00	12-07-2023	18:20:00	0.38	0.00	0.00	0.00	9.00	* S/D FOR DT/TRIP TEST FOR LBB BUS BAR RELAY RETOIFITTING WORK AT DURGAPUR S/S
BSR	125MVAR,BUS REACTOR-2 AT DURGAPUR	SCSD	07-07-2023	09:41:00	07-07-2023	20:33:00	0.45	0.00	0.00	0.00	10.87	* S/D FOR RETROFITTING OF BUS-BAR <(>&<)> LBB RELAY AND TRIP TEST AT DURGAPUR S/S.
BSR	125MVAR,BUS REACTOR-2 AT DURGAPUR	SCSD	18-07-2023	11:06:00	18-07-2023	21:32:00	0.44	0.00	0.00	0.00	10.43	* S/d for stability testing of 400KV Main Bus -I-new BB commissioning works at Durgapur end.
BSR	125MVAR,BUS REACTOR-2 AT DURGAPUR	SCSD	13-07-2023	06:19:00	13-07-2023	15:27:00	0.38	0.00	0.00	0.00	9.13	* S/D FOR DT/TRIP TEST FOR LBB/BUS BAR RELAY RETOIFITTING WORK AT DURGAPUR S/S
BSR	125MVAR,BUS REACTOR-3 AT DURGAPUR	SVRD	12-05-2023	13:00:00	30-09-2023	23:59:59	141.46	0.00	0.00	0.00	3,395.00	* H/T ON V/R AS PER ERLDC INSTRUCTION
BSR	125MVAR,BUS REACTOR-3 AT DURGAPUR	SVRD	09-04-2023	21:20:00	23-04-2023	09:18:00	13.50	0.00	0.00	0.00	323.97	* H/T FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTION.
BSR	125MVAR,BUS REACTOR-4 AT DURGAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT GOKARNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR AT INDRAVATI	OSPT	07-08-2023	08:12:00	07-08-2023	19:52:00	0.49	11.67	0.00	0.00	0.00	* SD taken for AMP at08:12hrs on 07-08-2023
BSR	50*2 MVAR,BUSREACTOR-1 AT JEERAT WBS	OSPD	30-09-2023	09:53:00	30-09-2023	15:18:00	0.23	0.00	0.00	0.00	5.42	* 100MVA BUS REACTOR 1 MAINTENANCE WORK BY WBSSETCL AT JEERAT SS
BSR	63MVAR,BUS REACTOR-1 AT JEYPORE	SVRD	24-08-2023	10:50:00	24-08-2023	16:13:00	0.22	0.00	0.00	0.00	5.38	* H/T for Voltage reulation
BSR	63MVAR,BUS REACTOR-1 AT JEYPORE	SVRD	30-05-2023	10:04:00	30-05-2023	22:25:00	0.52	0.00	0.00	0.00	12.35	* H/T as per instruction of ERLDC for voltage regulation.* 30.05.2023 22:27:11 INDIA Pothuraju Rajasekhar (60065278)* Reactor te
BSR	125MVAR,BUS REACTOR-2 AT JEYPORE	SVRD	24-08-2023	10:30:00	24-08-2023	13:06:00	0.11	0.00	0.00	0.00	2.60	* H/T for Voltage reulation
BSR	125MVAR,BUS REACTOR-2 AT JEYPORE	SVRD	08-08-2023	12:33:00	13-08-2023	20:35:00	5.34	0.00	0.00	0.00	128.03	* H/T FOR VOLTAGE REGULATION AT 12:33 HRS ON 08/08/2023
BSR	125MVAR,BUS REACTOR-2 AT JEYPORE	SVRD	30-05-2023	09:12:00	30-05-2023	10:21:00	0.05	0.00	0.00	0.00	1.15	* H/T as per instruction of ERLDC for voltage regulation.
BSR	80MVAR,BUS REACTOR-1 AT KEONJHAR	SVRD	09-06-2023	14:34:00	12-06-2023	18:37:00	3.17	0.00	0.00	0.00	76.05	* 80 MVAR BR-1 H/T for voltage regulation* 12.06.2023 19:50:58 INDIA Sushil Kumar Pradhan (60001857)* Reactor taken into ser
BSR	125MVAR,BUS REACTOR-2 AT KEONJHAR	SVRD	01-09-2023	19:18:00	30-09-2023	23:59:59	29.20	0.00	0.00	0.00	700.70	* H/T for Voltage reulation
BSR	125MVAR,BUS REACTOR-2 AT KEONJHAR	SRET	05-04-2023	09:37:00	05-04-2023	12:05:00	0.10	2.47	0.00	0.00	0.00	* Tripped at 09:37 hrs on 05/04/2023 due to differential protection operation and restored at 12:05 hrs on 05/04/2023 vide ERLDC c
BSR	125MVAR,BUS REACTOR-2 AT KEONJHAR	SVRD	09-06-2023	13:16:00	01-09-2023	09:34:00	83.85	0.00	0.00	0.00	2,012.30	* 400KV, 125 MVAR BUS REACTOR AT BOLANGIR HAND TRIPPED FOR VOLTAGE REGULATION PURPOSE AT 13:16 HRS
BSR	125MVAR,BUS REACTOR-2 AT KEONJHAR	OSPT	01-09-2023	09:34:00	01-09-2023	19:18:00	0.41	9.73	0.00	0.00	0.00	* 125MVAR,BUS REACTOR-2 AT KEONJHAR SD TAKEN FOR AMP
BSR	125MVAR,BUS REACTOR-1 AT MAITHON	SVRD	10-04-2023	15:50:00	29-07-2023	12:32:00	109.86	0.00	0.00	0.00	2,636.70	* Hand tripped as per ERLDC instruction for voltage regulation
BSR	125MVAR,BUS REACTOR-2 AT MAITHON	SCSD	01-08-2023	09:09:00	04-08-2023	22:18:00	3.55	0.00	0.00	0.00	85.15	* S/D TAKEN TO FACILITATE SHUTDOWN OF BUS-3 <(>&<)> BUS-4 AT MAITHON S/S FOR CARRYING OUT JACK BUS RE
BSR	31.5MVAR,BUS REACTOR-1 AT NEW MELLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	
BSR	31.5MVAR,BUS REACTOR-2 AT NEW MELLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Apr-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. EASTERN REGION-II

Table with columns: Object Type, Element Name, Type, Outage Date, Outage Time, Restoration, Outage ATTRI, Total Outage ATTRI, % Availability as, Detailed Reasons for Outage. Rows contain outage records for various power lines like FARAKA, JEERAT, MAITHON, etc.

Standard of Performance data for the month of Apr-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. EASTERN REGION-II

Object Type	Element Name	Type	Outage Date	Outage Time	Restoration	Total Outage	Outage Attr	Outage Attr	Outage Attr	Outage Attr	% Availability	Detailed Reasons for Outage
LNR	50MVAR,SWLR OF GAYA-2 AT MAITHON			00:00:00		00:00:00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR SWLR OF BOLANGIR AT MERAMUN	OSPT	17-04-2023	08:00:00	17-04-2023	18:55:00	0.46	10.92	0.00	0.00	100.00	* For PRV leakage recification <(>&<)> AMP* 17.04.2023 20:36:28 INDIA Pothuraju Rajasekhar (60065278)* Reactor SD returned
LNR	63MVAR,SWLR OF BARIPADA AT PANDIABILI	SVRD	12-06-2023	12:26:00	12-06-2023	20:23:00	0.33	0.00	0.00	0.00	7.95	* HT FOR VOLTAGE REGULATION AS PER INSTRUCTION OF ERLDC AT 12:26 HRS ON 12/06/2023* 12.06.2023 20:29:08 IN
LNR	63MVAR,SWLR OF BARIPADA AT PANDIABILI	SVRD	15-06-2023	14:04:00	27-06-2023	02:17:00	11.51	0.00	0.00	0.00	278.22	* 63MVAR, 400KV BARIPADA LINE REACTOR AT PANDIABILI HT FOR VOLTAGE REGULATION AT 14:04HRS ON 15.06.2023
LNR	63MVAR,SWLR OF BARIPADA AT PANDIABILI	OSPT	08-06-2023	08:43:00	08-06-2023	21:31:00	0.53	12.80	0.00	0.00	0.00	* AMP and PRD scheme modification* 08.06.2023 22:04:04 INDIA Pothuraju Rajasekhar (60065278)* Reactor taken IN service at 2
LNR	63MVAR,SWLR OF BARIPADA AT PANDIABILI	SVRD	29-05-2023	15:07:00	08-06-2023	08:43:00	9.73	0.00	0.00	0.00	233.60	* HT as per instruction of ERLDC for voltage regulation.
LNR	63MVAR,SWLR OF DUBRI AT PANDIABILI	SVRD	24-05-2023	15:43:00	27-06-2023	02:19:00	22.10	12.80	0.00	0.00	517.77	99.71
LNR	50MVAR,SWLR OF CHAIBASA-1 AT ROURKELA	OSPT	12-09-2023	09:14:00	12-09-2023	21:43:00	0.52	12.48	0.00	0.00	0.00	* 50MVAR switchable LR AMP work* 12.09.2023 21:49:24 INDIA Pothuraju Rajasekhar (60065278)* Reactor taken IN service at 21
LNR	50MVAR,SWLR OF JEERAT AT SUBHASHGRAM	SVRD	01-04-2023	00:00:01	30-09-2023	23:59:59	183.00	0.00	0.00	0.00	4,392.00	* H/T FOR VOLTAGE REGULATION AS PER ERLDC INSTRUCTIONS.
LNR	240MVAR,SWLR OF RAIPUR-2 AT SUNDERGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
LNR	240MVAR,SWLR OF RAIPUR-1 AT SUNDERGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
STATCOM	~200+200 MVAR STATCOM AT JEYPORE	SCSD	29-08-2023	09:24:00	29-08-2023	18:51:00	0.39	0.00	0.00	0.00	9.45	* STATCOM coupling transformer changeover from SYB to RSB works.
STATCOM	~200+200 MVAR STATCOM AT JEYPORE	OSPT	30-05-2023	09:54:00	30-05-2023	21:49:00	0.50	11.92	0.00	0.00	0.00	* Coupling Transformer AMP work* 30.05.2023 22:12:32 INDIA Pothuraju Rajasekhar (60065278)* Transformer taken IN service at
STATCOM	~300+300 MVAR STATCOM AT ROURKELA	SCSD	04-07-2023	09:12:00	04-07-2023	13:00:00	0.16	0.00	0.00	0.00	3.80	* Switched off at 09:12 hrs on 04/07/2023.* Switched on at 13:00 hrs on 04/07/2023.** For spare rotation of Y-phase coupling transf
XMER	315MVA,400/220kV ICT-1 AT ALIPURDUAR	OSPT	03-05-2023	06:45:00	03-05-2023	17:26:00	0.45	10.68	0.00	0.00	0.00	* S/D TO ATTEND OIL LEAKAGE IN 220KV B-PH TURRET
XMER	315MVA,400/220kV ICT-2 AT ALIPURDUAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
XMER	1500MVA,765/400kV ICT-1 AT ANGUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
XMER	1500MVA,765/400kV ICT-2 AT ANGUL	OSPT	26-07-2023	23:30:00	27-07-2023	01:07:00	0.07	1.62	0.00	0.00	0.00	* Shutdown taken for For attending the alignment of 71389TA (Auxiliary bus side isolator which was charged by spare ICT connect
XMER	1500MVA,765/400kV ICT-2 AT ANGUL	SCSD	14-08-2023	10:49:00	14-08-2023	17:51:00	0.29	0.00	0.00	0.00	7.03	* SPARE ROTATION WORK WITH Y PHASE* 14.08.2023 18:47:34 INDIA Pothuraju Rajasekhar (60065278)* ICT -2 taken IN serv
XMER	1500MVA,765/400kV ICT-3 AT ANGUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
XMER	1500MVA,765/400kV ICT-4 AT ANGUL	OSPT	16-05-2023	13:08:00	16-05-2023	18:28:00	0.22	5.33	0.00	0.00	0.00	* ICT-4 E/S/D to attend oil leakage at angul ss
XMER	160MVA,220/132kV ICT-1 AT BIRPARA	SRMT	25-09-2023	18:18:00	25-09-2023	19:22:00	0.04	1.07	0.00	0.00	0.00	* 220 KV/132 KIV 100 MVA ICT - 1 TRIPPED ON DIFF RELAY MALOPERATION AT 18:18 HRS ON 25.09.2023
XMER	160MVA,220/132kV ICT-2 AT BIRPARA	SCSD	12-09-2023	07:03:00	12-09-2023	16:33:00	0.40	0.00	0.00	0.00	9.50	* S/D TO FACILITATE EXCAVATION WORK ON 220KV CB SIDE OF ICT-II AND 220KV SIDE BAY AMP WORK.* 12.09.2023 15
XMER	315MVA,400/220kV ICT-1 AT BOLANGIR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
XMER	315MVA,400/220kV ICT-2 AT BOLANGIR	OMSU	30-05-2023	15:51:00	30-05-2023	19:39:00	0.16	0.00	3.80	0.00	0.00	* 30.05.2023 13:26:21 INDIA MANAS KUMAR SETHY (60065094) Phone 9007077560* Emergency shutdown availed for replacem
XMER	315MVA,400/220kV ICT-2 AT BOLANGIR	OSPT	30-05-2023	12:14:00	30-05-2023	15:51:00	0.15	3.62	0.00	0.00	0.00	* Emergency shutdown availed for replacement of defective B ph IV side LA* 30.05.2023 20:59:32 INDIA Abhishek Anand (600035
XMER	315MVA,400/220kV ICT-1 AT BINAGURI	OMSU	11-09-2023	09:10:00	11-09-2023	20:22:00	0.31	3.62	3.80	0.00	0.00	99.92
XMER	315MVA,400/220kV ICT-2 AT BINAGURI	OSPT	05-04-2023	05:50:00	05-04-2023	18:10:00	0.47	0.00	11.20	0.00	0.00	* SD FOR PRV LOGIC MODIFICATION <(>&<)> CSD RETUNING.
XMER	315MVA,400/220kV ICT-2 AT BINAGURI	OMSU	13-09-2023	07:35:00	13-09-2023	18:36:00	0.47	0.00	11.20	0.00	0.00	100.00
XMER	160MVA,220/132kV ICT-1 AT BARIPADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
XMER	315MVA,400/220kV ICT-1 AT BARIPADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
XMER	160MVA,220/132kV ICT-2 AT BARIPADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
XMER	315MVA,400/220kV ICT-2 AT BARIPADA	OSPT	20-06-2023	22:01:00	21-06-2023	01:35:00	0.15	3.57	0.00	0.00	0.00	* Emergency SD availed to attend heavy sparking in 220 kV R-phase TBC connector of isolator** Switched off at 22:01 on 20/06/2
XMER	500MVA, 400/220kV ICT-3 AT BARIPADA	OSPT	22-05-2023	08:27:00	22-05-2023	20:20:00	0.50	11.88	0.00	0.00	0.00	* For AMP and CC Technical Circular Compliance work* 22.05.2023 20:59:49 INDIA Abhishek Anand (60003546)*** Taken into ser
XMER	315MVA,400/220kV ICT-1 AT DURGA PUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
XMER	315MVA,400/220kV ICT-2 AT DURGA PUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
XMER	315MVA,400/220kV ICT-3 AT DURGA PUR	OSPT	25-04-2023	12:20:00	25-04-2023	14:51:00	0.11	2.52	0.00	0.00	0.00	* SD For rectification of opened 427-89T -Bph Isolator of 315MVA ICT-3
XMER	315MVA,400/220kV ICT-3 AT DURGA PUR	OSPT	27-09-2023	10:09:00	27-09-2023	19:59:00	0.41	9.83	0.00	0.00	0.00	* S/D TAKEN FOR AMP WORK
XMER	315MVA,400/220kV ICT-1 AT FARA KKA	OSPD	18-09-2023	11:42:00	21-09-2023	17:24:00	0.52	12.35	0.00	0.00	0.00	99.72
XMER	50MVA,132/66kV ICT-1 AT GANGTOK	OSPT	06-07-2023	13:27:00	06-07-2023	16:26:00	0.12	2.98	0.00	0.00	0.00	* S/D for SF6 Pressure switch guage stuck up issue and restoration.
XMER	50MVA,132/66kV ICT-1 AT GANGTOK	OMSU	06-09-2023	09:31:00	06-09-2023	17:29:00	0.33	0.00	7.97	0.00	0.00	* S/D FOR RETROFITTING OF OVER FLUX RELAY AT GANGTOK SS
XMER	50MVA,132/66kV ICT-2 AT GANGTOK	OMSU	31-07-2023	11:47:00	31-07-2023	18:40:00	0.29	0.00	6.88	0.00	0.00	* S/D FOR STUCK UP DIFFENTIAL RELAY RECTIFICATION WORK.
XMER	50MVA,132/66kV ICT-2 AT GANGTOK	OMSU	07-09-2023	09:23:00	07-09-2023	17:20:00	0.33	0.00	7.95	0.00	0.00	* RETROFITTING OF OVERFLUX RELAY
XMER	315MVA, 400/220kV ICT-1&3 AT JEYPORE	OMSU	19-05-2023	08:09:00	19-05-2023	08:49:00	0.03	0.00	0.67	0.00	0.00	* ICT 1 <(>&<)> 3 stitched off at 08:09 Hrs for AMP works on ICT-3 at Jeypore* 19.05.2023 13:57:31 INDIA Prasad KVSHK (600
XMER	315MVA, 400/220kV ICT-1&3 AT JEYPORE	OMSU	19-05-2023	11:48:00	19-05-2023	13:35:00	0.07	0.00	1.78	0.00	0.00	* ICT-1 S/D to facilitate charging of ICT-3 at Jeypore at 11:48 Hrs* 19.05.2023 14:00:34 INDIA Prasad KVSHK (60030519) Phone 9
XMER	315MVA, 400/220kV ICT-1&3 AT JEYPORE	OMSU	25-05-2023	09:40:00	25-05-2023	11:59:00	0.10	0.00	2.32	0.00	0.00	* ICT#1 SD taken for AMP and ICT#3 SD taken to facilitate SD of ICT#1
XMER	315MVA, 400/220kV ICT-2&4 AT JEYPORE	OSPT	26-09-2023	11:14:00	26-09-2023	16:56:00	0.24	5.70	0.00	0.00	0.00	* 315MVA, 400/220kV ICT-2 AT JEYPORE SD TAKEN AT 11:14 HRS ON 26/09/2023 FOR AMP.ICT#4 FOR MADE OPEN TO F
XMER	315MVA, 400/220kV ICT-2&4 AT JEYPORE	OSPT	26-09-2023	15:28:00	26-09-2023	16:56:00	0.06	1.47	0.00	0.00	0.00	* 315MVA ICT#4 at Jeypore taken S/D at 15:28 on 26/09/2023 for facilitation of Charging of ICT#2, ICT#4 and ICT#2 taken into ser
XMER	315MVA,400/220kV ICT-1 AT KEONJHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
XMER	315MVA,400/220kV ICT-2 AT KEONJHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	

