

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN EASTERN REGION

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	20MVAR,BUS REACTOR-1 AT AIZAWL	SVRD	01-02-2024	00:00:01	02-02-2024	00:24:00	1.02	0.00	0.00	0.00	24.40	100.00	* BUS REACTOR HAND TRIPPRD FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC VIDE CODE 2123
							1.02	0.00	0.00	0.00	24.40	100.00	
BSR	63MVAR,BUS REACTOR-1 AT BALIPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-2 AT BALIPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT BALIPARA	SVRD	14-02-2024	09:56:00	14-02-2024	23:33:00	0.57	0.00	0.00	0.00	13.62	100.00	** BUS REACTOR HAND TRIPPRD FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC VIDE CODE 991
BSR	125MVAR,BUS REACTOR-3 AT BALIPARA	SVRD	29-02-2024	17:20:00	29-02-2024	23:59:59	0.28	0.00	0.00	0.00	6.67	100.00	* BUS REACTOR HAND TRIPPED FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC VIDE CODE 2077
							0.85	0.00	0.00	0.00	20.29	100.00	
BSR	80MVAR,BUS REACTOR-1 AT B'CHARIALI	SVRD	17-02-2024	16:24:00	17-02-2024	23:49:00	0.31	0.00	0.00	0.00	7.42	100.00	* BUS REACTOR HAND TRIPPRD FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC VIDE CODE 1199
BSR	80MVAR,BUS REACTOR-1 AT B'CHARIALI	SVRD	08-02-2024	08:49:00	08-02-2024	22:40:00	0.58	0.00	0.00	0.00	13.85	100.00	* H/T FOR VOLTAGE REGLATION
							0.89	0.00	0.00	0.00	21.27	100.00	
BSR	80MVAR,BUS REACTOR-2 AT B'CHARIALI	SVRD	09-02-2024	08:14:00	09-02-2024	23:55:00	0.65	0.00	0.00	0.00	15.68	100.00	* H/T FOR VOLTAGE REGLATION AS PER INSTRUCTION OF NELDC
							0.65	0.00	0.00	0.00	15.68	100.00	
BSR	50MVAR,BUS REACTOR-1 AT BONGAIGAON			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR,BUS REACTOR-2 AT BONGAIGAON			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-3 AT BONGAIGAON			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-4 AT BONGAIGAON			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-5 AT BONGAIGAON	SVRD	29-02-2024	17:03:00	29-02-2024	20:04:00	0.13	0.00	0.00	0.00	3.02	100.00	* BUS REACTOR HAND TRIPPED FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC VIDE CODE 2075
							0.13	0.00	0.00	0.00	3.02	100.00	
BSR	20MVAR,BUS REACTOR-1 AT IMPHAL	SCSD	24-02-2024	07:50:00	24-02-2024	16:24:00	0.36	0.00	0.00	0.00	8.57	100.00	* H/T FOR ERECTION OF GIB DUCT AT IMPHAL
							0.36	0.00	0.00	0.00	8.57	100.00	
BSR	80MVAR,BUS REACTOR-1 AT IMPHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT IMPHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	20MVAR,BUS REACTOR-1 AT KUMARGHAT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	15MVAR,BUS REACTOR-1 AT MELRIAT	SVRD	02-02-2024	10:33:00	29-02-2024	23:59:59	27.56	0.00	0.00	0.00	661.45	100.00	* BUS REACTOR HAND TRIPPRD FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC VIDE CODE 099
							27.56	0.00	0.00	0.00	661.45	100.00	
BSR	5MVAR_BUS-REACTOR_SPARE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80 MVAR BUS REACTOR 2 431	SCSD	05-02-2024	09:20:00	05-02-2024	18:54:00	0.40	0.00	0.00	0.00	9.57	100.00	* SHUTDOWN TAKEN FOR CSD TUNING AND COMMISSIONING WORK
							0.40	0.00	0.00	0.00	9.57	100.00	
BSR	50MVAR,BUS REACTOR-1 AT MISA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	31MVAR,BUS REACTOR-1 AT MOKUKCHONG			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	20MVAR,BUS REACTOR-1 AT MARIANI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	420KV,125MVAR_BR-1	SVRD	13-02-2024	08:55:00	14-02-2024	02:49:00	0.75	0.00	0.00	0.00	17.90	100.00	*** H/T FOR VOLTAGE REGULATION VIDE CODE 898
BSR	420KV,125MVAR_BR-1	SVRD	06-02-2024	09:52:00	07-02-2024	21:32:00	1.49	0.00	0.00	0.00	35.67	100.00	** E/S/D TAKEN FOR ATTENDING OIL LEAKAGE FROM RADIATOR TANK* 06.02.2024 15:52:54 INDIA (60050178)** H/T FOR VOLTAGE REGULATION VIDE CODE 393
							2.24	0.00	0.00	0.00	53.57	100.00	
BSR	125MVAR,BUS REACTOR-2 AT MARIANI	SVRD	05-02-2024	13:00:00	05-02-2024	17:24:00	0.18	0.00	0.00	0.00	4.40	100.00	* BUS REACTOR HAND TRIPPRD FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC VIDE CODE 314
							0.18	0.00	0.00	0.00	4.40	100.00	
BSR	20MVAR,BUS REACTOR-1 AT NAMSAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	20MVAR,BUS REACTOR-1 AT ROING	SVRD	01-02-2024	00:00:01	03-02-2024	00:38:00	2.03	0.00	0.00	0.00	48.63	100.00	** BUS REACTOR HAND TRIPPRD FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC VIDE CODE 2122
BSR	20MVAR,BUS REACTOR-1 AT ROING	SVRD	25-02-2024	10:51:00	29-02-2024	23:59:59	4.55	0.00	0.00	0.00	109.15	100.00	* B/R HAND TRIPPED FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC VIDE CODE 1768
							6.58	0.00	0.00	0.00	157.78	100.00	
BSR	63MVAR,BUS REACTOR-1 AT SILCHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN EASTERN REGION

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR,BUS REACTOR-2 AT SILCHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT SILCHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	20MVAR,BUS REACTOR-1 AT TEZU	SVRD	05-02-2024	07:42:00	05-02-2024	23:57:00	0.68	0.00	0.00	0.00	16.25		* H/T FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC
BSR	20MVAR,BUS REACTOR-1 AT TEZU	SVRD	14-02-2024	09:08:00	14-02-2024	23:22:00	0.59	0.00	0.00	0.00	14.23		** BUS REACTOR HAND TRIPPRD FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC VIDE CODE 989
BSR	20MVAR,BUS REACTOR-1 AT TEZU	SVRD	24-02-2024	11:10:00	24-02-2024	23:43:00	0.52	0.00	0.00	0.00	12.55		* HAND TRIPPED FOR VOLTAGE REGULATION
BSR	20MVAR,BUS REACTOR-1 AT TEZU	SVRD	13-02-2024	09:58:00	14-02-2024	00:30:00	0.61	0.00	0.00	0.00	14.53		* BUS REACTOR HAND TRIPPRD FOR VOLTAGE REGULATION AS PER INSTRUCTION OF NERLDC VIDE CODE 909
							2.40	0.00	0.00	0.00	57.56	100.00	
BSR	20MVAR,BUS REACTOR-1 AT ZIRO			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV AIZWAL-KOLASIB(MIZORAM)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV AIZWAL-TIPAIMUKH(MANIPUR)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV AIZWAL-MELRIAT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV BADARPUR-BADARPUR(ASSAM)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV BADARPUR-JIRIBAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV-BADARPUR-KARIMGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV BADARPUR-KHLIEHRIAT-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV BADARPUR-KOLASIB(MIZORAM)	OMSU	22-02-2024	13:47:00	22-02-2024	16:34:00	0.12	0.00	2.78	0.00	0.00		** BADARPUR: YB, Z3, 146.5KM, IY= 969A, IB= 924A ,KOLASIB N/T* LINE TRIPPED DUE TO DOWNSTREAM FAULT IN 132 KV KOLASIB TUTORIAL (STATE FEEDER)
CKT	132kV BADARPUR-KOLASIB(MIZORAM)	OSPT	02-02-2024	08:49:00	02-02-2024	16:59:00	0.34	8.17	0.00	0.00	0.00		* SHUTDOWN AVAILED FOR AMP WORKS AT KOLASIB END BY AIZAWL SS
CKT	132kV BADARPUR-KOLASIB(MIZORAM)	OSPT	03-02-2024	08:02:00	03-02-2024	15:43:00	0.32	7.68	0.00	0.00	0.00		* SHUTDOWN AVAILED FOR AMP WORKS AT KOLASIB END BY AIZAWL SS
							0.78	15.85	2.78	0.00	0.00	97.71	
CKT	132kV DIMAPUR-DIMAPUR(NAGALAND)-1	OSPD	26-02-2024	10:08:00	26-02-2024	12:29:00	0.10	0.00	0.00	0.00	2.35		* H/T, S/D TAKEN BY STATE (NAGALD)
							0.10	0.00	0.00	0.00	2.35	100.00	
CKT	132kV DIMAPUR-KOHIMA(NAGALAND)-1	OSPD	08-02-2024	09:14:00	08-02-2024	16:23:00	0.30	0.00	0.00	0.00	7.15		* H/T FOR SD TAKEN BY STATE
CKT	132kV DIMAPUR-KOHIMA(NAGALAND)-1	OSPD	10-02-2024	09:18:00	10-02-2024	15:33:00	0.26	0.00	0.00	0.00	6.25		* 0H/T FOR SD TAKEN BY STATE
CKT	132kV DIMAPUR-KOHIMA(NAGALAND)-1	OSPD	09-02-2024	09:53:00	09-02-2024	15:08:00	0.22	0.00	0.00	0.00	5.25		* H/T FOR SD TAKEN BY STATE
							0.78	0.00	0.00	0.00	18.65	100.00	
CKT	132kV DOYANG(NEEPCO)-DIMAPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV DOYANG(NEEPCO)-DIMAPUR-2	OSPD	02-02-2024	09:32:00	02-02-2024	15:58:00	0.27	0.00	0.00	0.00	6.43		* SHUTDOWN TAKEN BY NEEPCO INSPECTION OF CIRCUIT BREAKER TO CHECK FEASIBILITY AND MECHANICAL DRIVES BY SERVICE ENGINEER OF CGL
CKT	132kV DOYANG(NEEPCO)-DIMAPUR-2	OSPD	01-02-2024	09:04:00	01-02-2024	16:43:00	0.32	0.00	0.00	0.00	7.65		* H/T S/D TAKEN BY NEEPCO for inspection of CB to feasibility and mechanism drive by service engineer of CGL
							0.59	0.00	0.00	0.00	14.08	100.00	
CKT	132kV NIRJULI-GOHPUR(ASSAM)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV JIRIBAM-HAFLONG			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV Haflong-Umrangso	OSPD	20-02-2024	11:13:00	20-02-2024	13:25:00	0.09	0.00	0.00	0.00	2.20		* SHUTDOWN TAKEN BY ASSAM FOR REPLACEMENT OF FAULTY LIMIT SWITCH
							0.09	0.00	0.00	0.00	2.20	100.00	
CKT	132kV IMPHAL-DIMAPUR-1	SCSD	24-02-2024	08:03:00	24-02-2024	16:22:00	0.35	0.00	0.00	0.00	8.32		* H/T FOR ERECTION OF GIS DUCT AT IMPHAL
CKT	132kV IMPHAL-DIMAPUR-1	LHWT	06-02-2024	21:01:00	06-02-2024	21:48:00	0.03	0.78	0.00	0.00	0.00		* DIMAPUR: (SITE) Y-N PHASE, ZONE -1, 3.7KA. RECLAIMED TIME: Y-N, Z1, 17.17KM, 3.8KA* (AFAS) : Y-N, Z, 17.28KM, 3.9KA* IMPHAL: Y-N PHASE, ZONE -2, 149.5KM, 718AMP.* ATTEMPTED CHARGED MADE FROM DIMAPUR END AT 21:42HRS BUT TRIPPED INSTANTENOUSLY ON Y-N, Z1, 17.18KM, 3.88KA.* POST PATROLLING WAS CARRIED OUT AND FOUND CLR INSULATOR GOT PUNCTURED IN Y-PH AT LOC NO 463
CKT	132kV IMPHAL-DIMAPUR-1	OSFT	06-02-2024	21:49:00	07-02-2024	10:58:00	0.55	13.15	0.00	0.00	0.00		* AKEN FOR REPOLACEMNET OF DEFECTIVE INSULATORS AT Y-PH AT LOC NO 463
							0.93	13.93	0.00	0.00	8.32	98.00	
CKT	132kV IMPHAL-IMPHAL(MANIPUR)-1	SCSD	17-02-2024	07:58:00	17-02-2024	16:51:00	0.37	0.00	0.00	0.00	8.88		* S/D TAKEN FOR ERECTION OF GIB DUCT FOR 132KV GIS CONSTRUCTION WORK (SS-74 PACKAGE) - UNDER NERSS-XII <(>&<)> XIII
CKT	132kV IMPHAL-IMPHAL(MANIPUR)-1	SCSD	19-02-2024	08:00:00	19-02-2024	13:53:00	0.25	0.00	0.00	0.00	5.88		* ERECTION OF GIB DUCT FOR 132KV GIS CONSTRUCTION WORK (SS-74 PACKAGE) - UNDER NERSS-XII <(>&<)> XIII
CKT	132kV IMPHAL-IMPHAL(MANIPUR)-1	SCSD	18-02-2024	07:55:00	18-02-2024	16:44:00	0.37	0.00	0.00	0.00	8.82		* ERECTION OF GIB DUCT FOR 132KV GIS CONSTRUCTION WORK (SS-74 PACKAGE) - UNDER NERSS-XII <(>&<)> XIII

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN EASTERN REGION

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	132kV IMPHAL-IMPHAL(MANIPUR)-1	OMSU	27-02-2024	19:54:00	27-02-2024	20:26:00	0.02	0.00	0.53	0.00	0.00		* LINE TRIPPED= MPHAL (PG) : NOT TRIPPED IMPH= L (STATE): AWAITED
							1.01	0.00	0.53	0.00	23.58	100.00	
CKT	132kV IMPHAL-IMPHAL(MANIPUR)-2	SCSD	16-02-2024	10:31:00	16-02-2024	13:42:00	0.13	0.00	0.00	0.00	3.18		* SD FOR FOUNDATION WORK OF LINE ISOLATOR
							0.13	0.00	0.00	0.00	3.18	100.00	
CKT	132kV IMPHAL-NINGTHOUNGKONG(MANIPUR)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV JIRIBAM-TIPAIMUKH(MANIPUR)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV JIRIBAM-LOKTAK(NHPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV KHLIEHRIAT-KHLIEHRIAT(MePTCL)-1	OSPD	06-02-2024	13:25:00	06-02-2024	17:49:00	0.18	0.00	0.00	0.00	4.40		* SHUTDOWN TAKEN BY STATE FOR SPS RELATED WORK
							0.18	0.00	0.00	0.00	4.40	100.00	
CKT	132kV KHANDONG(NEPECO)-KHLIEHRIAT-1	LCSD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00		** CONTINUOUS SHUTDOWN TAKEN FOR HTLS RE CONDUCTORING WORK
							29.00	0.00	0.00	0.00	696.00	100.00	
CKT	132kV KHANDONG(NEPECO)-KHLIEHRIAT-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV KHANDONG(NEPECO)-KOPILI(NEPECO)-1	LCSD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00		** C/SD TAKEN FOR HTLS RE CONDUCTORING WORK
							29.00	0.00	0.00	0.00	696.00	100.00	
CKT	132kV KHANDONG(NEPECO)-KOPILI(NEPECO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV Khandong-Umranqso			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV KUMARGHAT-AIZWAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV-KUMARGHAT-KARIMGANJ-ACL-C1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV LOKTAK(NHPC)-IMPHAL-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV MELRIAT-SIHMUI(MIZORAM)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV MELRIAT-SIHMUI(MIZORAM)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV MELRIAT-ZEMABAWK(MIZORAM)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV MOKOKCHUNG-MOKOKCHUNG(NAGALAND)-1	OSPD	18-02-2024	13:16:00	18-02-2024	16:43:00	0.14	0.00	0.00	0.00	3.45		* SHUT DOWN TAKEN BY NAGALAND FOR ANNUAL MAINTANANCE BUS BAR AND BAYS
							0.14	0.00	0.00	0.00	3.45	99.02	
CKT	132kV MOKOKCHUNG-MOKOKCHUNG(NAGALAND)-1	OSPT	06-02-2024	07:49:00	06-02-2024	14:38:00	0.28	6.82	0.00	0.00	0.00		* SHUTDOWN TAKEN FOR AMP OF BAY EQUIPMENTS
CKT	132kV MOKOKCHUNG-MOKOKCHUNG(NAGALAND)-1	OSPD	17-02-2024	13:07:00	17-02-2024	17:16:00	0.17	0.00	0.00	0.00	4.15		* SHUT DOWN TAKEN BY NAGALAND FOR ANNUAL MAINTANANCE BUS BAR AND BAYS
							0.59	6.82	0.00	0.00	7.60	99.02	
CKT	132kV MOKOKCHUNG-MOKOKCHUNG(NAGALAND)-2	OSPD	17-02-2024	13:10:00	17-02-2024	17:18:00	0.17	0.00	0.00	0.00	4.13		* SHUT DOWN TAKEN BY NAGALAND FOR ANNUAL MAINTANANCE BUS BAR AND BAYS
							0.70	7.18	0.00	0.00	9.58	98.97	
CKT	132kV MOKOKCHUNG-MOKOKCHUNG(NAGALAND)-2	OSPT	07-02-2024	07:24:00	07-02-2024	14:35:00	0.30	7.18	0.00	0.00	0.00		* SD FOR AMP WORK
CKT	132kV MOKOKCHUNG-MOKOKCHUNG(NAGALAND)-2	OSPD	18-02-2024	13:18:00	18-02-2024	18:45:00	0.23	0.00	0.00	0.00	5.45		* SHUT DOWN TAKEN BY NAGALAND FOR ANNUAL MAINTANANCE BUS BAR AND BAYS
							0.70	7.18	0.00	0.00	9.58	98.97	
CKT	132kV NIRJULI-LEKHI(DOP-AP)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV PAVOI(ASSAM)-BISWANATH CHARIALI-1	OSFT	15-02-2024	09:16:00	15-02-2024	12:44:00	0.14	3.47	0.00	0.00	0.00		* E/S/D TAKEN TO RECTIFY THE JUMPER OF BOTTOM PHASE OF CKT-2 REQUIRES THE SHUTDOWN OF CKT-1 DUE TO THE SAFETY CLEARANCE ISSUE OF CHARGED CIRCUIT 1(BOTH CIRCUITS ARE IN MUTLI CIRCUIT TOWER ON ONE SIDE)
							0.86	3.47	0.00	0.00	17.18	99.50	
CKT	132kV PAVOI(ASSAM)-BISWANATH CHARIALI-1	LCSD	13-02-2024	09:01:00	13-02-2024	17:33:00	0.36	0.00	0.00	0.00	8.53		* SHUTDOWN TAKEN FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS
CKT	132kV PAVOI(ASSAM)-BISWANATH CHARIALI-1	LCSD	14-02-2024	07:44:00	14-02-2024	16:23:00	0.36	0.00	0.00	0.00	8.65		* SHUTDOWN TAKEN FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
							0.86	3.47	0.00	0.00	17.18	99.50	
CKT	132kV PAVOI(ASSAM)-BISWANATH CHARIALI-2	LCSD	16-02-2024	09:12:00	16-02-2024	16:30:00	0.30	0.00	0.00	0.00	7.30		** HT FOR REPLACEMENT OF PORCELAIN INSULATOR
CKT	132kV PAVOI(ASSAM)-BISWANATH CHARIALI-2	LCSD	15-02-2024	08:22:00	15-02-2024	15:51:00	0.31	0.00	0.00	0.00	7.48		* HT FOR REPLACEMENT OF PORCELAIN INSULATOR
							0.61	0.00	0.00	0.00	14.78	100.00	
CKT	132kV ROING-PASIGHAT(DOP-AP)	OMSU	21-02-2024	21:43:00	21-02-2024	22:42:00	0.04	0.00	0.98	0.00	0.00		* ROING: (CB RECLOSED) YB-PH, Z1, 9.69KM, 1.25KA* PASIGHAT: YB-PH, 95KM. INCREMENT WEATER CONDITION AT THE TIME OF TRIPPING.* TRIPPED DUE TO PLCC AT PASIGHAT END (DOP AP) OUT OF SERVICE DUE TO NON -AVAILABILITY OF 48V DC SERVICE.
CKT	132kV ROING-PASIGHAT(DOP-AP)	OSFT	27-02-2024	10:29:00	27-02-2024	12:49:00	0.10	2.33	0.00	0.00	0.00		* ESD TAKEN FOR CRITICAL TREE INFRINGEMENT WORK

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN EASTERN REGION

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	132kV ROING-PASIGHAT(DOP-AP)	LART	21-02-2024	21:43:00	21-02-2024	21:43:00	0.00	0.00	0.00	0.00	0.00	99.66	* ROING: (CB RECLOSED) YB-PH, Z1, 9.69KM, 1.25KA* PASIGHAT: YB-PH, 95KM. INCREMENT WEATER CONDITION AT THE TIME OF TRIPPING.
CKT	132kV RANGANADI(NEPCO)-ZIRO	OSPD	24-02-2024	09:07:00	24-02-2024	15:41:00	0.27	0.00	0.00	0.00	6.57		* 24.02.2024 17:15:16 INDIA (60020570)* SHUTDOWN TAKEN FOR CONSTRUCTION OF 132/33 KV D/C ZIRO (NEW)-ZIRO (PG) TL UNDER COMP.T<(>&<)>D PROJECT.
CKT	132kV RANGANADI(NEPCO)-ZIRO	LCSD	25-02-2024	08:10:00	25-02-2024	14:35:00	0.27	0.00	0.00	0.00	6.42		** SHUTDOWN TAKEN FOR CONSTRUCTION OF 132/33 KV D/C ZIRO (NEW)-ZIRO (PG) TL UNDER COMP.T<(>&<)>D PROJECT.
CKT	132kV KUMARGHAT-R C NAGAR(TRIPURA)-1			00:00:00		00:00:00	0.54	0.00	0.00	0.00	12.99	100.00	
CKT	132kV ROING-CHAPAKHOWA(AEGCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV ROING-CHAPAKHOWA(AEGCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV ROING-TEZU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV SILCHAR-BADARPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV SILCHAR-BADARPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV SILCHAR-HAILAKANDI(ASSAM)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV SILCHAR-HAILAKANDI(ASSAM)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV SILCHAR-SRIKONA(ASSAM)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV SILCHAR-SRIKONA(ASSAM)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV TEZU-NAMSAI-1	OSPT	06-02-2024	11:02:00	06-02-2024	11:42:00	0.03	0.67	0.00	0.00	0.00	99.90	* SHUTDOWN TAKEN FOR JUMPER CONNECTION OF 132KV MIAO BAY UNDER CTDS AT NAMSAI S/S
CKT	132kV RC NAGR(NEPCO)-AGARTLA(TRIPURA)-1			00:00:00		00:00:00	0.03	0.67	0.00	0.00	0.00	100.00	
CKT	132kV RC NAGR(NEPCO)-AGARTLA(TRIPURA)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV-BALIPARA-SONABIL(ASSAM)	SCSD	08-02-2024	10:13:00	08-02-2024	16:58:00	0.28	0.00	0.00	0.00	6.75		* For Alignment and rectification of Line isolator and Transfer Isolator
CKT	220kV BALIPARA-SONABIL(ASSAM)-2			00:00:00		00:00:00	0.28	0.00	0.00	0.00	6.75	100.00	
CKT	220kV BONGAIGAON-SALAKATI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV BONGAIGAON-SALAKATI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV MISA-DIMAPUR-1	SCSD	08-02-2024	08:48:00	17-02-2024	18:18:00	9.40	0.00	0.00	0.00	225.50		* Dismantling, Erection, Installation and Commissioning of 245 kV Isolator(04 Set) under ADDCAP
CKT	220kV MISA-DIMAPUR-2	SCSD	19-02-2024	08:53:00	29-02-2024	23:56:00	10.63	0.00	0.00	0.00	255.05		* C/S/D DISMANTLING, ERECTION, INSTALLATION AND COMMISSIONING OF 245 KV ISOLATOR(04 SET) UNDER O<(>&<)>M ADDCAP
CKT	220kV MISA-KOPILI(NEPCO)-1	LMAC	27-02-2024	12:09:00	27-02-2024	13:03:00	0.04	0.00	0.00	0.90	0.00		* 220KV MISA-KOPLI CKT-1, Relay Indication – TOR* MISA: MAIN-1# B-N, Z1, 53.14KM,2.16KA /MAIN-2# B-N, Z1, 69.9KM, 2.03KA* KOPLI (NEPCO): Z1
CKT	220kV MISA-KOPILI(NEPCO)-2			00:00:00		00:00:00	0.04	0.00	0.00	0.90	0.00	100.00	
CKT	220kV MISA-KOPILI(NEPCO)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV-NMRNI-MARIA-ACL-C1	OSPT	09-02-2024	09:53:00	09-02-2024	16:09:00	0.26	6.27	0.00	0.00	0.00		* SHUTDOWN TAKEN FOR AMP OF LINE BAY EQUIPMENT
CKT	220kV MARIANI-MOKOKCHUNG-1			00:00:00		00:00:00	0.26	6.27	0.00	0.00	0.00	99.10	
CKT	220kV MARIANI-MOKOKCHUNG-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SALAKATI-BTPS(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SALAKATI-BTPS(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN EASTERN REGION

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	220kV SAMAGURI(ASSAM)-MISA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SAMAGURI(ASSAM)-MISA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BALIPARA-BISWANATH CHARIALI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BALIPARA-BISWANATH CHARIALI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BALIPARA-BISWANATH CHARIALI-3	LCSD	17-02-2024	10:08:00	17-02-2024	17:49:00	0.32	0.00	0.00	0.00	7.68		* FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
							0.32	0.00	0.00	0.00	7.68	100.00	
CKT	400kV BALIPARA-BISWANATH CHARIALI-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BALIPARA-BONGAIGAON-1	OSFT	05-02-2024	11:30:00	05-02-2024	15:19:00	0.16	3.82	0.00	0.00	0.00		** LINE TRIPPED ON R PH FAULT, DUE TO EARTH WIRE BROKEN AT LOCATION NO 350 - 351
CKT	400kV BALIPARA-BONGAIGAON-1	LHWT	05-02-2024	10:42:00	05-02-2024	11:30:00	0.03	0.80	0.00	0.00	0.00		* LINE TRIPPED ON R PH FAULT, DUE TO EARTH WIRE BROKEN AT LOCATION NO 350 - 351
							0.19	4.62	0.00	0.00	0.00	99.34	
CKT	400kV BALIPARA-BONGAIGAON-2	LVRD	05-02-2024	03:15:00	05-02-2024	07:48:00	0.19	0.00	0.00	0.00	4.55		* LINE HAND TRIP FOR VOLTAGE REGULATION AS PER NERLDC VIDE CODE-287
							0.19	0.00	0.00	0.00	4.55	100.00	
CKT	400kV BALIPARA-BONGAIGAON-3	LART	28-02-2024	19:02:00	28-02-2024	19:02:00	0.00	0.00	0.00	0.00	0.00		* BALIPARA: YN, 261.6KM, 2.05KA* BONGAIGAON: YN, 40.39KM, 4.70KA* AUTO RECLOSE SUCCESSULL AT BOTH END
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BALIPARA-BONGAIGAON-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BALIPARA-KAMENG(NEPECO)-1	OSPD	28-02-2024	07:35:00	28-02-2024	15:27:00	0.33	0.00	0.00	0.00	7.87		* SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-1	OSPD	29-02-2024	07:35:00	29-02-2024	15:28:00	0.33	0.00	0.00	0.00	7.88		** SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-1	OSPD	25-02-2024	00:14:00	25-02-2024	15:17:00	0.63	0.00	0.00	0.00	15.05		*** SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-1	OSPD	24-02-2024	00:23:00	24-02-2024	15:45:00	0.64	0.00	0.00	0.00	15.37		** SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-1	OSPD	22-02-2024	00:22:00	22-02-2024	15:25:00	0.63	0.00	0.00	0.00	15.05		* SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-1	OSPD	27-02-2024	07:36:00	27-02-2024	15:41:00	0.34	0.00	0.00	0.00	8.08		** SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-1	OSPD	26-02-2024	00:16:00	26-02-2024	15:47:00	0.65	0.00	0.00	0.00	15.52		** SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-1	OSPD	23-02-2024	00:13:00	23-02-2024	15:43:00	0.65	0.00	0.00	0.00	15.50		* SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
							4.20	0.00	0.00	0.00	100.32	100.00	
CKT	400kV BALIPARA-KAMENG(NEPECO)-2	OSPD	28-02-2024	07:36:00	28-02-2024	15:30:00	0.33	0.00	0.00	0.00	7.90		* SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-2	OSPD	29-02-2024	07:35:00	29-02-2024	15:29:00	0.33	0.00	0.00	0.00	7.90		** SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-2	OSPD	24-02-2024	00:23:00	24-02-2024	15:47:00	0.64	0.00	0.00	0.00	15.40		** SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-2	OSPD	26-02-2024	00:16:00	26-02-2024	15:49:00	0.65	0.00	0.00	0.00	15.55		** SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-2	OSPD	27-02-2024	07:36:00	27-02-2024	15:44:00	0.34	0.00	0.00	0.00	8.13		** SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-2	OSPD	22-02-2024	00:23:00	22-02-2024	15:25:00	0.63	0.00	0.00	0.00	15.03		* SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-2	OSPD	23-02-2024	00:13:00	23-02-2024	15:38:00	0.64	0.00	0.00	0.00	15.42		* SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
CKT	400kV BALIPARA-KAMENG(NEPECO)-2	OSPD	25-02-2024	00:14:00	25-02-2024	15:48:00	0.65	0.00	0.00	0.00	15.57		*** SHUTDOWN AVAILED BY NEEPCO (KAMENG END) FOR OIL FILTRATION OF REACTOR AND CB PREVENTIVE MAINTENANCE.
							4.21	0.00	0.00	0.00	100.90	100.00	
CKT	400kV BONGAIGAON-BTPS(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BONGAIGAON-BTPS(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV MARIANI-KATHALGURI(ASSAM)-1	OSPD	13-02-2024	09:52:00	13-02-2024	09:59:00	0.01	0.00	0.00	0.00	0.12		* H/T AT KATHALGURI END TO FACILITATE BUS -2 SHIFTING AT KATHALGURI END
							0.01	0.00	0.00	0.00	0.12	100.00	

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN EASTERN REGION

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400KV-KATHALGURI-MARIANI-2	OSFD	19-02-2024	16:53:00	19-02-2024	17:07:00	0.01	0.00	0.00	0.00	0.23	100.00	** H/T AT KATHALGURI END TO FACILITATE BUS SHIFTING AT KATHALGURI END
							0.01	0.00	0.00	0.00	0.23	100.00	
CKT	400KV New Mariani - Misa 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV New Mariani - Misa 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV MISA-BALIPARA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV MISA-BALIPARA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PALATANA(TSECL)-SM.NAGAR(TSECL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PALATANA(TSECL)-SM.NAGAR(TSECL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-1	OSPD	19-02-2024	09:31:00	19-02-2024	10:00:00	0.02	0.00	0.00	0.00	0.48		* SHUTDOWN AVAILED BY NEEPCO FOR CARRYING OUT OIL FILTRATION OF LINE REACTOR
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-1	OSPD	22-02-2024	15:32:00	22-02-2024	15:46:00	0.01	0.00	0.00	0.00	0.23		* LINE H/T FOR TAKING LINE REACTOR AT RANGANADI END IN SERVICE
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-1	LCSD	01-02-2024	07:15:00	01-02-2024	17:09:00	0.41	0.00	0.00	0.00	9.90		** FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-1	LCSD	02-02-2024	08:00:00	02-02-2024	17:42:00	0.40	0.00	0.00	0.00	9.70		* FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-1	LCSD	03-02-2024	08:15:00	03-02-2024	16:34:00	0.35	0.00	0.00	0.00	8.32		* FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
							1.19	0.00	0.00	0.00	28.63	100.00	
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-2	LVRD	23-02-2024	09:19:00	23-02-2024	09:34:00	0.01	0.00	0.00	0.00	0.25		* LINE HAND TRIPPED FOR TAKING OUT THE L/R AT RANGANADI END FOR OIL FILTRATION
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-2	LCSD	09-02-2024	08:12:00	09-02-2024	16:25:00	0.34	0.00	0.00	0.00	8.22		** FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-2	LCSD	10-02-2024	07:39:00	10-02-2024	17:37:00	0.42	0.00	0.00	0.00	9.97		*** FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-2	LCSD	07-02-2024	08:09:00	07-02-2024	17:08:00	0.37	0.00	0.00	0.00	8.98		** FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-2	OSPD	01-02-2024	08:35:00	01-02-2024	13:57:00	0.22	0.00	0.00	0.00	5.37		* H/T S/D TAKEN BY RANGANADI FOR BUS-1 <(><)> 2 S/D AT RANGANADI (NEPCO) END
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-2	LCSD	06-02-2024	07:57:00	06-02-2024	17:14:00	0.39	0.00	0.00	0.00	9.28		* FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-2	LCSD	08-02-2024	08:49:00	08-02-2024	16:41:00	0.33	0.00	0.00	0.00	7.87		*** FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-2	LCSD	07-02-2024	08:09:00	07-02-2024	17:08:00	0.37	0.00	0.00	0.00	8.98		** FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-2	OSPD	26-02-2024	12:36:00	26-02-2024	12:53:00	0.01	0.00	0.00	0.00	0.28		* LINE HAND TRIPPED FOR LINE REACTOR TAKING IN TO SERVICE AT RANGANADI (NEPCO) END
CKT	400KV RANGANADI(NEPCO)-B'CHARIALI-2	LCSD	05-02-2024	07:43:00	05-02-2024	17:10:00	0.39	0.00	0.00	0.00	9.45		** FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS AT POWER/RAILWAY/RIVER/SH/NH CROSSING LOCATIONS
							2.85	0.00	0.00	0.00	68.65	100.00	
CKT	400KV-SILCHAR-IMPHAL-1	LCSD	16-02-2024	09:34:00	16-02-2024	18:22:00	0.37	0.00	0.00	0.00	8.80		* INSTALLATION AND COMMISSIONING OF CSD AT IMPHAL
							0.37	0.00	0.00	0.00	8.80	100.00	
CKT	400KV SILCHAR-IMPHAL-2	LCSD	11-02-2024	07:16:00	11-02-2024	17:47:00	0.44	0.00	0.00	0.00	10.52		**** FOR REPLACEMENT OF INSULATOR
CKT	400KV SILCHAR-IMPHAL-2	LCSD	10-02-2024	07:13:00	10-02-2024	16:05:00	0.37	0.00	0.00	0.00	8.87		*** FOR REPLACEMENT OF INSULATOR
CKT	400KV SILCHAR-IMPHAL-2	LCSD	09-02-2024	07:04:00	09-02-2024	17:27:00	0.43	0.00	0.00	0.00	10.38		** FOR REPLACEMENT OF INSULATOR
CKT	400KV SILCHAR-IMPHAL-2	LCSD	15-02-2024	07:32:00	15-02-2024	16:00:00	0.35	0.00	0.00	0.00	8.47		* SHUTDOWN TAKEN FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS
CKT	400KV SILCHAR-IMPHAL-2	LCSD	14-02-2024	07:44:00	14-02-2024	16:02:00	0.35	0.00	0.00	0.00	8.30		* SHUTDOWN TAKEN FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS
CKT	400KV SILCHAR-IMPHAL-2	LCSD	08-02-2024	07:22:00	08-02-2024	16:07:00	0.37	0.00	0.00	0.00	8.75		* FOR REPLACEMENT OF INSULATOR

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN EASTERN REGION

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV SILCHAR-IMPHAL-2	LCSD	13-02-2024	06:59:00	13-02-2024	16:25:00	0.39	0.00	0.00	0.00	9.43		* SHUTDOWN TAKEN FOR REPLACEMENT OF CONVENTIONAL PORCELAIN INSULATORS BY COMPOSITE LONG ROD POLYMER INSULATORS
CKT	400kV SILCHAR-IMPHAL-2	LCSD	12-02-2024	06:52:00	12-02-2024	16:04:00	0.38	0.00	0.00	0.00	9.20	100.00	* H/T FOR SD FOR INSULATOR REPLACEMENT
CKT	132kV SILCHAR-MELRIAT-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV SILCHAR-MELRIAT-2	LCSD	05-02-2024	08:42:00	05-02-2024	15:50:00	0.30	0.00	0.00	0.00	7.13		*** H/T S/D AVAILED FOR REPLACEMENT OF INSULATOR
CKT	132kV SILCHAR-MELRIAT-2	LCSD	02-02-2024	08:49:00	02-02-2024	16:47:00	0.33	0.00	0.00	0.00	7.97		* H/T S/D AVAILED FOR REPLACEMENT OF INSULATOR
CKT	132kV SILCHAR-MELRIAT-2	LCSD	01-02-2024	08:08:00	01-02-2024	16:31:00	0.35	0.00	0.00	0.00	8.38		* H/T S/D AVAILED FOR REPLACEMENT OF INSULATOR
CKT	132kV SILCHAR-MELRIAT-2	LCSD	03-02-2024	07:21:00	03-02-2024	16:05:00	0.36	0.00	0.00	0.00	8.73		* 01.02.2024 12:00:52 INDIA (60041674)* H/T S/D AVAILED FOR REPLACEMENT OF INSULATOR
CKT	132kV SILCHAR-MELRIAT-2	LCSD	04-02-2024	06:49:00	04-02-2024	15:50:00	0.38	0.00	0.00	0.00	9.02		** H/T S/D AVAILED FOR REPLACEMENT OF INSULATOR
CKT	400kV SILCHAR-P K BARI(STERLITE)-1	OSFT	28-02-2024	11:50:00	28-02-2024	16:02:00	0.18	4.20	0.00	0.00	0.00	100.00	* EMERGENCY SHUTDOWN AVAILED FOR REPLACEMENT OF DAMAGE INSULATOR IN TOWER NO 137
CKT	400kV SILCHAR-P K BARI(STERLITE)-1	LCSD	01-02-2024	00:00:01	20-02-2024	19:40:00	19.82	0.00	0.00	0.00	475.67	99.40	* SHIFTING OF CKT-1 FROM EXISTING TOWER NO. 353 TO ERS TOWER FOR FACILITATIMNG THE ERECTION OF PILE FOUNDATION TOWER LOC. NO. 353P.
CKT	400kV SILCHAR-P K BARI(STERLITE)-2	LCSD	21-02-2024	09:46:00	29-02-2024	23:59:59	20.00	4.20	0.00	0.00	475.67	99.40	** C/S/D TAKEN FOR ERECTION OF NEW PILE FOUNDATION TOWER LOC. NO. 353P
CKT	400kV SM.NAGAR(TSECL)-COMILLA(BANGLAD)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SM.NAGAR(TSECL)-COMILLA(BANGLAD)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-LOWER_SUBANSIRI-B'CHARIALI-C1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-LOWER_SUBANSIRI-B'CHARIALI-C2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-LOWER_SUBANSIRI-B'CHARIALI-C3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-LOWER_SUBANSIRI-B'CHARIALI-C4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63 MVAR SWLR OF B'CHARIALI-2 AT BALIPARA	SCSD	01-02-2024	00:00:01	07-02-2024	18:02:00	6.75	0.00	0.00	0.00	162.03	100.00	* "C/S/D FOR DISMANTLING OF EXISTING CHARGED 63 MVAR SPARE REACTOR AND INSTALLATION AND COMMISSIONING OF RECTIFIED/REPAIRED 63 MVAR LINE REACTOR"
LNR	50MVAR,SWLR OF B'CHARIALI-1 AT BALIPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,LR OF BONGAIGAON-3 AT BALIPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,LR OF BONGAIGAON-4 AT BALIPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,LR OF SUBANSIRI-1 AT B CHARIALI	SVRD	09-02-2024	08:21:00	11-02-2024	21:59:00	2.57	0.00	0.00	0.00	61.63	100.00	* H/T FOR VOLTAGE REGLATION AS PER INSTRUCTION OF NELDC
LNR	63MVAR,SWLR OF SUBANSIRI-2 AT B'CHARIALI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SUBANSIRI-3 AT B'CHARIALI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR_SILCHAR-2_LINE_REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR_SILCHAR_1_LINE_REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF HAZRA AT SILCHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF BYRNHAT AT SILCHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PALLATANA-2 AT SILCHAR	OSPT	03-02-2024	10:10:00	03-02-2024	14:51:00	0.20	4.68	0.00	0.00	0.00	99.33	* SHUTDOWN TAKEN FOR AMP OF BAY EQUIPMENTS
LNR	50MVAR,SWLR OF PALLATANA-1 AT SILCHAR	OSPT	02-02-2024	10:40:00	02-02-2024	14:22:00	0.15	3.70	0.00	0.00	0.00	99.47	* SHUTDOWN TAKEN FOR AMP OF BAY EQUIPMENTS
XMER	160MVA,220/132kV ICT-1 AT BALIPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BALIPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BALIPARA	SCSD	21-02-2024	13:09:00	21-02-2024	15:34:00	0.10	0.00	0.00	0.00	2.42		* SHUTDOWN TAKEN FOR ALIGNMENT OF ISOLATORS AFTER INSTALING OF ISOLATOR MOM BOXES

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN EASTERN REGION

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.10	0.00	0.00	0.00	2.42	100.00	
XMER	160MVA,220/132kV ICT-2 AT BALIPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	200MVA,400/132kV ICT-1 AT B'CHARIALI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	200MVA,400/132kV ICT-2 AT B'CHARIALI	OSPT	13-02-2024	07:57:00	13-02-2024	15:09:00	0.30	7.20	0.00	0.00	0.00		* SHUTDOWN TAKEN FOR AMP OF BAY EQUIPMENTS
							0.30	7.20	0.00	0.00	0.00	98.97	
XMER	315MVA,400/220kV ICT-1 AT BONGAIGAON	SCSD	27-02-2024	10:29:00	29-02-2024	23:59:59	2.56	0.00	0.00	0.00	61.52		* FOR UP-GRADATION OF BAY EQUIPMENT'S TO ENHANCE CURRENT CARRYING CAPACITY UNDER NERSS-XII. (PROJECT RELATED SHUTDOWN)
							2.56	0.00	0.00	0.00	61.52	100.00	
XMER	315MVA,400/220kV ICT-2 AT BONGAIGAON	SCSD	20-02-2024	07:28:00	20-02-2024	15:56:00	0.35	0.00	0.00	0.00	8.47		* SHUTDOWN TAKEN FOR BUCHHOLZ TRIP LOGIC MODIFICATION WORK
							0.35	0.00	0.00	0.00	8.47	100.00	
XMER	220KV ICT 3 HV_XMER_BAY_203			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	220KV ICT 1 HV_XMER_201			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	220KV ICT 2 HV_XMER_202			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	220KV ICT 3 HV_XMER_203	SCSD	01-02-2024	09:08:00	01-02-2024	18:10:00	0.38	0.00	0.00	0.00	9.03		* H/T S/D TAKEN FOR BUCHHOLZ RELAY TRIP LOGIC MODIFICATION
							0.38	0.00	0.00	0.00	9.03	100.00	
XMER	50MVA,132/33kV ICT-1 AT IMPHAL	SCSD	25-02-2024	07:19:00	25-02-2024	12:20:00	0.21	0.00	0.00	0.00	5.02		*** SHUTDOWN TAKEN FOR ERECTION OF GIB DUCT FOR 132KV GIS CONSTRUCTION WORK
							0.61	0.00	0.00	0.00	14.65	100.00	
XMER	315MVA,400/132kV ICT-1 AT IMPHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,132/33kV ICT-2 AT IMPHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/132kV ICT-2 AT IMPHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/132kV ICT-1 AT KOPILI	OSFT	29-02-2024	10:47:00	29-02-2024	12:37:00	0.08	1.83	0.00	0.00	0.00		* EMERGENCY SHUTDOWN TAKEN FOR ATTENDING TC 1 FAULTY
							0.08	1.83	0.00	0.00	0.00	99.74	
XMER	500MVA ICT-3_429			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT MISA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MISA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	30MVA,220/132kV ICT-1 AT MOKOKCHUNG	OSPT	17-02-2024	13:18:00	17-02-2024	17:04:00	0.16	3.77	0.00	0.00	0.00		* "ANNUAL MAINTENANCE OF 132KV BUS BAR AND BAYS. (I.E. GREASING OF ISOLATOR CONTACTS AND RECTIFYING THE HOTSPOTS ISSUE)* "
							0.16	3.77	0.00	0.00	0.00	99.46	
XMER	30MVA,220/132kV ICT-2 AT MOKOKCHUNG	OSPT	17-02-2024	13:21:00	17-02-2024	17:07:00	0.16	3.77	0.00	0.00	0.00		* "ANNUAL MAINTENANCE OF 132KV BUS BAR AND BAYS. (I.E. GREASING OF ISOLATOR CONTACTS AND RECTIFYING THE HOTSPOTS ISSUE)* "
							0.16	3.77	0.00	0.00	0.00	99.46	
XMER	30MVA,220/132kV ICT-3 MOKOKCHUNG	OSPT	17-02-2024	13:13:00	17-02-2024	17:10:00	0.17	3.95	0.00	0.00	0.00		* "ANNUAL MAINTENANCE OF 132KV BUS BAR AND BAYS. (I.E. GREASING OF ISOLATOR CONTACTS AND RECTIFYING THE HOTSPOTS ISSUE)* "
							0.17	3.95	0.00	0.00	0.00	99.43	
XMER	50MVA,132/33kV ICT-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,132/33kV ICT-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	400/220KV ICT-1	SCSD	13-02-2024	08:36:00	13-02-2024	16:51:00	0.34	0.00	0.00	0.00	8.25		* SHUTDOWN TAKEN FOR BUCHHOLZ RELAY TRIP LOGIC MODIFICATION
							0.34	0.00	0.00	0.00	8.25	100.00	
XMER	400/220KV ICT2BAY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	15MVA,132/33kV ICT-1 AT NAMSAI	OSPT	06-02-2024	11:02:00	06-02-2024	11:45:00	0.03	0.72	0.00	0.00	0.00		** SHUTDOWN TAKEN FOR JUMPER CONNECTION OF 132KV MIAO BAY UNDER CTDS AT NAMSAI S/S
							0.03	0.72	0.00	0.00	0.00	99.90	
XMER	15MVA,132/33kV ICT-2 AT NAMSAI	OSPT	06-02-2024	11:02:00	06-02-2024	11:46:00	0.03	0.73	0.00	0.00	0.00		*** SHUTDOWN TAKEN FOR JUMPER CONNECTION OF 132KV MIAO BAY UNDER CTDS AT NAMSAI S/S
							0.03	0.73	0.00	0.00	0.00	99.89	
XMER	15MVA,132/33kV ICT-1 AT ROING	OSFT	14-02-2024	12:24:00	14-02-2024	13:22:00	0.04	0.97	0.00	0.00	0.00		* EMERGENCY SHUTDOWN TAKEN FOR ATTENDING AND REFILL SF6 GAS IN GD
							0.04	0.97	0.00	0.00	0.00	99.86	
XMER	15MVA,132/33kV ICT-2 AT ROING			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN EASTERN REGION

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifying	Detailed Reasons for Outage
XMER	50MVA,220/132kV ICT-1 AT SALAKATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,220/132kV ICT-2 AT SALAKATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	200MVA,400/132kV ICT-1 AT SILCHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	200MVA,400/132kV ICT-2 AT SILCHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/200kV ICT-3 AT SILCHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	15MVA,132/33kV ICT-1 AT TEZU	OMSU	22-02-2024	01:14:00	22-02-2024	01:14:00	0.00	0.00	0.00	0.00	0.00		* OVER CURRENT EARTH FAULT. TRIPPED DUE TO FAULT IN 33KV TEZU-TEZU STATE FEEDER. AFTER ISOLATION OF 33KV TEZU-TEZU STATE FEEDER ICTs CHARGED* 24.02.2024 16:12:14 INDIA (60051135)* Relay Setting Issue
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	15MVA,132/33kV ICT-2 AT TEZU	OMSU	22-02-2024	01:14:00	22-02-2024	01:14:00	0.00	0.00	0.00	0.00	0.00		* OVER CURRENT EARTH FAULT. TRIPPED DUE TO FAULT IN 33KV TEZU-TEZU STATE FEEDER. AFTER ISOLATION OF 33KV TEZU-TEZU STATE FEEDER ICTs CHARGED* 24.02.2024 16:15:32 INDIA (60051135)* Relay Setting Issue
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	15MVA,132/33kV ICT-1 AT ZIRO			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	