













Sr.No.	Unique ID of transmission Element	ELEMENT NAME	Description (Length/No. /MVA/MVA/ MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		DURATION OF OUTAGE ATTRIBUTABLE TO (in hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm +2	Classification / Category Code	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	Total Duration Available for Consideration	NSC	Ckt. Kms.	Weightage Factor	H=(G*(Z-@))/Z	% Availability as certified by certifying agency				
						DATE	TIME	DATE	TIME	No. of towers damaged	no. of insulator failed	Total outage in days (1)	ISTS Licensee	OTHERS	System constraint/ Natural calamity/ Militancy													Decreed Available	@ (T) Hrs:Min	# (U) Hrs:Min	* (D) Hrs:Min
						Z	Hrs	(E) E	(F) F	G=E x F	H																				
77	NR140064	400KV KOTESHR-KHEP-II	2.700	NRI		26/10/20 11:03	26/10/20 12:07					00:00	00:00	00:00	01:04				OSPD	Shutdown by KHEP(THDC) for shifting of line from BUS-I to BUS-II at KHEP end.											
						30/10/20 12:23	30/10/20 13:23					00:00	01:00	00:00	00:00				SBBU	Tripped on Bus Bar protection Operated at KHEP (THDC) end.											
						31/10/20 11:17	31/10/20 12:30					00:00	00:00	00:00	01:13				OSPD	Shutdown by KHEP(THDC) for charging of 400KV BUS-I at KHEP after completion of insulator replacement work.											
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>01:00</b>	<b>00:00</b>	<b>04:16</b>						744.00	2	2.700	5.40	5.40	100.00					
78	NR140065	400KV KOTESHR-TEHRI-I	14.463	NRI								00:00	00:00	00:00	00:00																
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						744.00	4	14.463	57.85	57.85	100.00					
79	NR140098	400KV KOTESHR-TEHRI-II	16.490	NRI								00:00	00:00	00:00	00:00																
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						744.00	4	16.490	65.96	65.96	100.00					
80	NR140165	400KV MEERUT-BAGPAT-I	70.976	NRI		23/10/20 22:22	24/10/20 05:32					00:00	00:00	00:00	07:10				LVRD	Hand tripped on Voltage Regulation. Bagpat-414KV.											
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>07:10</b>						744.00	4	70.976	283.90	283.90	100.00					
81	NR140166	400KV MEERUT-BAGPAT-II	70.976	NRI								00:00	00:00	00:00	00:00																
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						744.00	4	70.976	283.90	283.90	100.00					
82	NR140142	400KV MEERUT-BAREILLY-I	66.009	NRI		06/10/20 15:16	06/10/20 15:16					00:00	00:00	00:00	00:00				LART	Line successfully auto-reclose during R-N Fault. FLR: Meerut-37.8Km/8.5Ka. Bareilly-211.6Km/1.8Ka.											
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						744.00	2	66.009	132.02	132.02	100.00					
83	NR140130	400KV MEERUT-BAREILLY-II	66.009	NRI								00:00	00:00	00:00	00:00																
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						744.00	2	66.009	132.02	132.02	100.00					
84	NR140077	400KV MEERUT-KOTESHR-I	178.690	NRI								00:00	00:00	00:00	00:00																
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>			744.00	4	178.690	714.76	714.76	100.00					
85	NR140099	400KV MEERUT-KOTESHR-II	175.630	NRI								00:00	00:00	00:00	00:00																
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						744.00	4	175.630	702.52	702.52	100.00					
86	NR140078	400KV MEERUT-MND-I	59.868	NRI								00:00	00:00	00:00	00:00																
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						744.00	2	59.868	119.74	119.74	100.00					
87	NR140079	400KV MEERUT-MND-II	59.868	NRI								00:00	00:00	00:00	00:00																
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						744.00	2	59.868	119.74	119.74	100.00					
88	NR140143	400KV MEERUT-MND-III	54.298	NRI		01/10/20 00:00	03/10/20 19:56					00:00	00:00	00:00	67:56				OSPD	S/D by Powerlink for NHAI Delhi-Meerut Expressway related line diversion work between their T/Loc no-548-550. Out since 25/09/2020 10:33:00											
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>67:56</b>						744.00	2	54.298	108.60	108.60	100.00					
89	NR140131	400KV MEERUT-MND-IV	54.298	NRI		01/10/20 00:00	03/10/20 19:47					00:00	00:00	00:00	67:47				OSPD	S/D by Powerlink for NHAI Delhi-Meerut Expressway related line diversion work between their T/Loc no-548-550. Out since 25/09/2020 10:33:00											
		<b>SUB TOTAL</b>				21/10/20 21:14	01/11/20 00:00					00:00	00:00	00:00	242:46				LVRD	Hand tripped on Voltage Regulation. Meerut-423 KV.											
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>310:33</b>						744.00	2	54.298	108.60	108.60	100.00					
90	NR140080	400KV MEERUT-MUZFRNGR	37.380	NRI		01/10/20 11:22	01/10/20 18:50					07:28	00:00	00:00	00:00				OSPT	S/D for jumper tightening and replacement of insulator at loc 698.70.											
		<b>SUB TOTAL</b>				26/10/20 14:05	26/10/20 16:40					00:00	02:35	00:00	00:00				SBBU	BUS Bar-B protection trip at Muzaffnrg-UP SS on LBB operation of another UPPCL line. DT received at Meerut end.											
		<b>SUB TOTAL</b>										<b>07:28</b>	<b>02:35</b>	<b>00:00</b>	<b>00:00</b>						744.00	2	37.380	74.76	74.01	99.00					
91	NR140103	400KV MERTA-BEAWAR	76.018	NRI								00:00	00:00	00:00	00:00																
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						744.00	2	76.018	152.04	152.04	100.00					
92	NR140176	400KV MORADABD-HAPUR(UP)	106.850	NRI								00:00	00:00	00:00	00:00																
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						744.00	2	106.850	213.70	213.70	100.00					
93	NR140177	400KV MURADNGR-HAPUR(UP)	26.650	NRI								00:00	00:00	00:00	00:00																
		<b>SUB TOTAL</b>										<b>00:00</b>	<b>00:00</b>	<b>00:00</b>	<b>00:00</b>						744.00	2	26.650	53.30	53.30	100.00					

Sr.No.	Unique ID of transmission Element	ELEMENT NAME	Description (Length/No. MW/VA/MVA/ MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		DURATION OF OUTAGE ATTRIBUTABLE TO (in hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (7/8)	Difference between Actual and Norm 1-2	Classification/ Category Code	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	Total Duration Available for Consideration	NSC	Ckt. Kms.	Weightage Factor	H=(G*(Z-@))/Z	% Availability as certified by certifying agency											
						DATE TIME	DATE TIME	No. of towers damaged	no. of insulator failed	Total outage in days (1)	STS Licensee	OTHERS	System constraint/ Natural calamity/ Militancy & (C)	Decreed Available	@ (T) Hrs:Min													# (U) Hrs:Min	* (D) Hrs:Min	Z	E	F	G=E x F	H				
																																			G		I	
																																			J		K	
94	NR140139	400KV NAVADA-GR,NOIDA	30.150	NR1	--	--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	4	30.150	120.60	120.60	100.00														
SUB TOTAL						--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	4	30.150	120.60	120.60	100.00														
95	NR140118	400KV NIMRANA-MANESAR-I	67.041	NR1	--	--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	2	67.041	134.08	134.08	100.00														
SUB TOTAL						--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	2	67.041	134.08	134.08	100.00														
96	NR140119	400KV NIMRANA-MANESAR-II	67.041	NR1	--	--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	2	67.041	134.08	134.08	100.00														
SUB TOTAL						--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	2	67.041	134.08	134.08	100.00														
97	NR140183	400KV NIMRANA-BABAI(RRVPNL)	81.000	NR1	--	--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	2	81.000	162.00	162.00	100.00														
SUB TOTAL						--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	2	81.000	162.00	162.00	100.00														
98	NR140109	400KV NIMRANA-SIKAR-II	175.859	NR1	--	09/10/20 21:40	12/10/20 09:41				00:00	00:00	00:00	60:01				LVRD	Hand tripped on Voltage Regulation. Sikar-424KV.																			
					--	14/10/20 21:20	16/10/20 09:30				00:00	00:00	00:00	36:10				LVRD	Hand tripped on Voltage Regulation. Ntm-422KV.																			
					--	17/10/20 02:43	18/10/20 07:23				00:00	00:00	00:00	28:40				LVRD	Hand tripped on Voltage Regulation. Ntm-422KV.																			
					--	19/10/20 21:01	20/10/20 07:51				00:00	00:00	00:00	10:50				LVRD	Hand tripped on Voltage Regulation.Sikar-421 KV.																			
					--	20/10/20 20:10	21/10/20 08:54				00:00	00:00	00:00	12:44				LVRD	Hand tripped on Voltage Regulation.Sikar-424 KV.																			
					--	21/10/20 20:54	22/10/20 06:37				00:00	00:00	00:00	09:43				LVRD	Hand tripped on Voltage Regulation. Sikar-428 KV.																			
					--	22/10/20 21:17	23/10/20 07:53				00:00	00:00	00:00	10:36				LVRD	Hand tripped on Voltage Regulation. Ntm-425 KV.																			
					--	24/10/20 20:59	25/10/20 06:17				00:00	00:00	00:00	09:18				LVRD	Hand tripped on Voltage Regulation. Sikar-425 KV.																			
					--	27/10/20 20:20	28/10/20 09:11				00:00	00:00	00:00	12:51				LVRD	Hand tripped on Voltage Regulation. Agra-428KV.																			
					--	28/10/20 20:20	29/10/20 07:49				00:00	00:00	00:00	11:29				LVRD	Hand tripped on Voltage Regulation. Agra-428 KV.																			
					--	29/10/20 20:59	30/10/20 06:42				00:00	00:00	00:00	09:43				LVRD	Hand tripped on Voltage Regulation. Sikar-424 KV.																			
					--	30/10/20 08:21	30/10/20 19:42				00:00	00:00	00:00	11:21				OSPD	S/D for Stringing work of new 400V DC Khetri-Sikar Line under Rajasthan SEZ PART-C TBCB project.																			
					--	31/10/20 07:40	31/10/20 19:50				00:00	00:00	00:00	12:10				OSPD	S/D for Stringing work of new 400V DC Khetri-Sikar Line under Rajasthan SEZ PART-C TBCB project.																			
--	31/10/20 21:40	01/11/20 06:00				00:00	00:00	00:00	02:20				LVRD	Hand tripped on Voltage Regulation. Sikar-424 KV.																								
SUB TOTAL						--	--	--	--	00:00	00:00	00:00	237:56	--	--	--	--	--	744.00	2	175.859	351.72	351.72	100.00														
99	NR140170	400KV RAPP-CHITTOR(RJ)-I	155.150	NR1	--	--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	2	155.150	310.30	310.30	100.00														
SUB TOTAL						--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	2	155.150	310.30	310.30	100.00														
100	NR140175	400KV ROORKEE-DEHRADUN	79.700	NR1	--	--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	4	79.700	318.80	318.80	100.00														
SUB TOTAL						--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	4	79.700	318.80	318.80	100.00														
101	NR140161	400KV ROORKEE-KASHIPUR-I	150.832	NR1	--	17/10/20 22:59	17/10/20 23:47				00:48	00:00	00:00	00:00				LEFT	Tripped on R-N fault,FLR,Roorkee-31.3km/9.28kA.																			
					--	27/10/20 11:22	27/10/20 12:37				00:00	01:15	00:00	00:00				OMSU	CB Tripped only from Kashipur. Line remain charged from Roorkee end.																			
SUB TOTAL						--	--	--	--	00:48	01:15	00:00	00:00	--	--	--	--	--	744.00	4	150.832	603.33	602.68	99.89														
102	NR140162	400KV ROORKEE-KASHIPUR-II	150.832	NR1	--	--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	4	150.832	603.33	603.33	100.00														
SUB TOTAL						--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	4	150.832	603.33	603.33	100.00														
103	NR140086	400KV ROORKEE-MUZFRNGR	2.100	NR1	--	03/10/20 09:33	03/10/20 15:16				05:43	00:00	00:00	00:00				OSFT	Forced S/D for attending hot spot on 40189B isolator at Roorkee end.																			
					--	22/10/20 12:36	22/10/20 13:34				00:00	00:58	00:00	00:00				OMSU	CB Arrip at Muzaffarnagar(UPPCL) end during R-N fault in their portion. FLR,Roorkee-51.90km/5.6kA. Muzaffgr-13.34km/11.14kA. Line remain charged from Roorkee end.																			
					--	24/10/20 08:48	24/10/20 08:48				00:00	00:00	00:00	00:00				LART	A/R Successful,FLR-Roorkee- R-N fault,45.7km/5.6kA. Fault in PTCUL portion.																			
SUB TOTAL						--	--	--	--	05:43	00:58	00:00	00:00	--	--	--	--	--	744.00	2	2.100	4.20	4.17	99.23														
104	NR140087	400KV ROORKEE-RUSHIKESH	2.100	NR1	--	28/10/20 10:41	28/10/20 18:19				00:00	00:00	00:00	07:38				OSPD	Shutdown by PTCUL for maintenance work at their end.																			
SUB TOTAL						--	--	--	--	00:00	00:00	00:00	07:38	--	--	--	--	--	744.00	2	2.100	4.20	4.20	100.00														
105	NR140167	400KV ROORKEE-SAHARANPUR-I	36.535	NR1	--	--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	4	36.535	146.14	146.14	100.00														
SUB TOTAL						--	--	--	--	00:00	00:00	00:00	00:00	--	--	--	--	--	744.00	4	36.535	146.14	146.14	100.00														
106	NR140184	400KV SIKAR-BABAI(RRVPNL)	94.430	NR1	--	30/10/20 08:30	30/10/20 20:21				00:00	00:00	00:00	11:51				OSPD	S/D for Stringing work of new 400V DC Khetri-Sikar Line under Rajasthan SEZ PART-C TBCB project.																			







Sr.No.	Unique ID of transmission Element	ELEMENT NAME	Description (Length/No. /MW/MVA/ MW/etc.)	Region	Type of failure	OUTAGE	RESTORATION	Details of Outage		DURATION OF OUTAGE ATTRIBUTABLE TO (in hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Classification/ Category Code	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	Total Duration Available for Consideration	NSC	Ckt. Kms.	Weightage Factor	H=(G*(Z-@))/Z	% Availability as certified by certifying agency	
						DATE TIME	DATE TIME	No. of towers damaged	no. of insulator failed	Total outage in days (1)	ISTS Licensee	OTHERS	System constraint/ Natural calamity/ Mishancy													Deemed Available
						@ (T)	# (U)	& (C)	* (D)																	
						Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min																	
Z	Hrs	(E)	(F)	G	G=E x F	H																				
		SUB TOTAL			--			--	--	--	00:00	00:00	00:00	00:00	--	--	--	OSFD	S/D by UPPCL to attend hotspot in their Y-pb CT at Modipuram end.		744.00	1	2.316	2.32	2.32	100.00
20	BILUP2205	220KV MEERUT-MPURAM-II	9.254	NR1	--	29/10/20 18:46	29/10/20 20:34				00:00	00:00	00:00	01:48												
		SUB TOTAL			--			--	--	--	00:00	00:00	00:00	01:48	--	--	--				744.00	1	9.254	9.25	9.25	100.00
21	BILUP2206	220KV MEERUT-NARA	2.316	NR1	--	09/10/20 11:57	09/10/20 11:57				00:00	00:00	00:00	00:00				LART	Successfully A/R during Y-N fault in UPPCL portion. FLR-Mer4.7km-9.58KA.							
		SUB TOTAL			--			--	--	--	00:00	00:00	00:00	00:00	--	--	--				744.00	1	2.316	2.32	2.32	100.00
22	BILUP2207	220KV MEERUT-SHTBDNGR	8.234	NR1							00:00	00:00	00:00	00:00												
		SUB TOTAL			--			--	--	--	00:00	00:00	00:00	00:00							744.00	1	8.234	8.23	8.23	100.00
23	BILUP2208	220KV MEERUT-SIMBHOLI	9.254	NR1							00:00	00:00	00:00	00:00												
		SUB TOTAL			--			--	--	--	00:00	00:00	00:00	00:00							744.00	1	9.254	9.25	9.25	100.00
24	NR122027	220KV RAPPB-CHITT-I	128.833	NR1							00:00	00:00	00:00	00:00												
		SUB TOTAL			--			--	--	--	00:00	00:00	00:00	00:00							744.00	1	128.833	128.83	128.83	100.00
25	NR122028	220KV RAPPB-CHITT-II	128.833	NR1							00:00	00:00	00:00	00:00												
		SUB TOTAL			--			--	--	--	00:00	00:00	00:00	00:00							744.00	1	128.833	128.83	128.83	100.00
26	NR122029	220KV RAPPB-RAPP	0.175	NR1							00:00	00:00	00:00	00:00												
		SUB TOTAL			--			--	--	--	00:00	00:00	00:00	00:00							744.00	1	0.175	0.18	0.18	100.00
27	NR122030	220KV RAPPB-UDAIPUR	230.297	NR1		09/10/20 13:34	09/10/20 20:45				07:11	00:00	00:00	00:00				OSPT	S/D for tightening of Jumper bolts and fixing of quarter pin at loc. No. 79,142							
						10/10/20 09:44	10/10/20 19:30				09:46	00:00	00:00	00:00				OSPT	S/D for tightening of jumpers,bolts and fixing of quarter pin at loc no-79 &142.							
		SUB TOTAL			--			--	--	--	16:57	00:00	00:00	00:00							744.00	1	230.297	230.30	225.05	97.72
28	NR122031	220KV S.MDHPR-DAUSA-I	106.243	NR1							00:00	00:00	00:00	00:00												
		SUB TOTAL			--			--	--	--	00:00	00:00	00:00	00:00							744.00	1	106.243	106.24	106.24	100.00
29	NR122042	220KV SIKAR-RATANGARH-I	2.830	NR1		13/10/20 09:37	13/10/20 19:57				10:20	00:00	00:00	00:00				OSPT	S/D for AMP of line bay equipments at Sikar end.							
		SUB TOTAL			--			--	--	--	10:20	00:00	00:00	00:00							744.00	1	2.830	2.83	2.79	98.61
30	NR122044	220KV SIKAR-RATANGARH-II	2.830	NR1		14/10/20 09:18	14/10/20 18:21				09:03	00:00	00:00	00:00				OSPT	S/D for Annual maintenance work at Sikar(PG) end.							
		SUB TOTAL			--			--	--	--	09:03	00:00	00:00	00:00							744.00	1	2.830	2.83	2.80	98.78
31	NR122043	220KV SIKAR-SIKAR(RJ)-I	3.000	NR1		12/10/20 10:25	12/10/20 18:14				07:49	00:00	00:00	00:00				OSPT	Shutdown for annual maintenance planned work.							
						25/10/20 07:50	25/10/20 13:16				00:00	00:00	00:00	05:26				OSPD	S/D by RRVPNL to attend their damaged Bus isolator clamp at Sikar RRVPNL end.							
		SUB TOTAL			--			--	--	--	07:49	00:00	00:00	05:26							744.00	1	3.000	3.00	2.97	98.95
32	NR122045	220KV SIKAR-SIKAR(RJ)-II	3.000	NR1		15/10/20 10:21	15/10/20 20:44				10:23	00:00	00:00	00:00				OSPT	S/D for Annual maintenance planned work at Sikar(PG) end.							
						25/10/20 07:50	25/10/20 13:16				00:00	00:00	00:00	05:26				OSPD	S/D by RRVPNL to attend their damaged Bus isolator clamp at Sikar RRVPNL end.							
		SUB TOTAL			--			--	--	--	10:23	00:00	00:00	05:26							744.00	1	3.000	3.00	2.96	98.60
					--			--	--	--																
	Lines	TOTAL FOR T/L'S			--			--	--	--	323:55	13:40	00:00	4540:45												
E		765/400 KV ICT'S																		MVA		15413.4	48672.2	48569.8	99.79	
1	NR1ICT86	765/400KV ICT-I AJMER	1500	NR1							00:00	00:00	00:00	00:00												
		SUB TOTAL		NR1	--			--	--	--	00:00	00:00	00:00	00:00							744.00	1500		1500.00	1500.00	100.00
2	NR1ICT87	765/400KV ICT-II AJMER	1500	NR1							00:00	00:00	00:00	00:00												
		SUB TOTAL			--			--	--	--	00:00	00:00	00:00	00:00							744.00	1500		1500.00	1500.00	100.00
3	NR1ICT88	765/400KV ICT-I CHITTORGHR	1500	NR1		16/10/20 09:08	16/10/20 17:50				08:42	00:00	00:00	00:00				OSPT	Shutdown for annual maintenance work.							

Sr.No.	Unique ID of Transmission Element	ELEMENT NAME	Description (Length/Nos./MVA/MVA/ MW/WTG.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		DURATION OF OUTAGE ATTRIBUTABLE TO (in hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Classification/ Category Code	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	Total Duration Available for Consideration	NSC	Ckt. Kms.	Weightage Factor	H=(G²(Z-@))/Z	% Availability as certified by certifying agency		
						DATE	TIME	DATE	TIME	No. of towers damaged	no. of insulator failed	Total outage in days (1)	ISTS Licensee	OTHERS														System constraint/ Natural calamity/ Millibancy & (C)	Deemed Available
														@ (T)	# (U)														
						Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Z	H	E	F	G=E x F															
							17/10/20	09:19	17/10/20	18:35								OSPT	Shutdown for annual maintenance work.										
		SUB TOTAL											17:58	00:00	00:00	00:00					744.00	1500		1500.00	1463.78	97.59			
4	NR1CT89	765400KV ICT-II CHITTORGRH	1500	NR1									00:00	00:00	00:00	00:00													
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1500.00	100.00			
5	NR1CT709	765400kv ICT-I JHATIKALA	1500	NR1			02/10/20	05:51	02/10/20	12:36			06:45	00:00	00:00	00:00			OSPT	S/D for attending Hot Spot observed in 400KV Y-phase busding and Isolator 407:89T at Jhatikara.									
		SUB TOTAL					27/10/20	09:15	27/10/20	15:39			06:24	00:00	00:00	00:00			OSPT	S/D for CSD commissioning work.									
		SUB TOTAL											13:09	00:00	00:00	00:00					744.00	1500		1500.00	1473.49	98.23			
6	NR1CT710	765400kv ICT-II JHATIKALA	1500	NR1									00:00	00:00	00:00	00:00													
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1500.00	100.00			
7	NR1CT711	765400kv ICT-III JHATIKALA	1500	NR1									00:00	00:00	00:00	00:00													
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1500.00	100.00			
8	NR1CT712	765400kv ICT-IV JHATIKALA	1500	NR1									00:00	00:00	00:00	00:00													
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1500.00	100.00			
9	NR1CT713	765400kv ICT-I MEERUT	1500	NR1									00:00	00:00	00:00	00:00													
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1500.00	100.00			
10	NR1CT714	765400kv ICT-II MEERUT	1500	NR1			23/10/20	09:53	23/10/20	19:53			10:00	00:00	00:00	00:00			OSPT	S/D for Annual maintenance work.									
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1479.84	98.66			
11	NR2ICT46	765400KV ICT-I BHIWANI	1500	NR1			07/10/20	09:05	07/10/20	21:36			12:31	00:00	00:00	00:00			OSPT	Shutdown for annual maintenance work.									
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1474.76	98.32			
12	NR2ICT48	765400KV ICT-II BHIWANI	1500	NR1			01/10/20	09:16	01/10/20	19:15			09:59	00:00	00:00	00:00			OSPT	S/D for annual maintenance planned works.									
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1479.87	98.66			
13	NR1CT715	765400KV ICT-I BIKANER	1500	NR1									00:00	00:00	00:00	00:00													
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1500.00	100.00			
14	NR1CT716	765400KV ICT-II BIKANER	1500	NR1			11/10/20	01:29	11/10/20	04:38			03:09	00:00	00:00	00:00			OSFT	Forced hand tripped due to heavy sparking observed in 400KV side R-phase isolator of the ICT-II.									
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1493.65	99.58			
15	NR1CT721	765400KV ICT-I BHADLA	1500	NR1									00:00	00:00	00:00	00:00													
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1500.00	100.00			
16	NR1CT722	765400KV ICT-II BHADLA	1500	NR1									00:00	00:00	00:00	00:00													
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1500.00	100.00			
17	NR1CT723	765400KV ICT-III BHADLA	1500	NR1									00:00	00:00	00:00	00:00													
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	1500		1500.00	1500.00	100.00			
18	NR1CT724	765400KV ICT-II KOTESHWR	800	NR1			02/10/20	15:24	02/10/20	18:14			02:50	00:00	00:00	00:00			OSFT	Forced Shutdown to attend oil leakage in conservator tank.									
		SUB TOTAL											00:00	00:00	00:00	00:00					744.00	800		800.00	796.95	99.62			
19	NR1CT725	765400KV ICT-III KOTESHWR	800	NR1			05/10/20	12:08	05/10/20	17:27			05:19	00:00	00:00	00:00			OSFT	Forced Shutdown to attend Oil leakage from expansion bellow radiator and main transformer tank of B Phase.									
		SUB TOTAL					06/10/20	11:39	06/10/20	15:57			04:18	00:00	00:00	00:00			OSFT	Forced Shutdown to attend Oil leakage from expansion bellow of radiator and main transformer tank of Y Phase.									











Sr.No.	Unique ID of Transmission Element	ELEMENT NAME	Description (Length/No./MVA/MVA/MW/Etc..)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage			DURATION OF OUTAGE ATTRIBUTABLE TO (in hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (70%)	Difference between Actual and Norm 1-2	Classification/ Category Code	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	Total Duration Available for Consideration	NSC	Ckt. Kms.	Weightage Factor	$H = (G^2 / (Z \cdot @)) / Z$	% Availability as certified by agency
						DATE	TIME	DATE	TIME	No. of towers damaged	no. of insulator failed	Total outage in days (1)	ISTS Licensee	OTHERS	System constraint/Natural calamity/Militancy	Deemed Available												
						@ (T)	# (U)	# (C)	* (D)																			
						Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min																			
		SUB TOTAL				--	--	--				04:17	00:00	00:00	00:00						744.00	500		500.00	497.12	99.42		
#####		TOTAL FOR ICTs										485.35	01:46	00:00	247:29						53000.0			53000.00	52684.14	99.40		
L		SVC,																			MVAR			OHxMVARxMF	THMxMVARxMF			
1	NR1SVC-01	+400-300MVAR SVC KANKROLI	700	NR1		23/10/20	12:11	23/10/20	15:43			03:32	00:00	00:00	00:00				OSFT	Forced S/D to attend hot spot in Ypb TCR3 bay.								
		SUB TOTAL				--	--	--				03:32	00:00	00:00	00:00						744.00	700		700.00	696.68	99.53		
		TOTAL FOR SVC		NR1		--	--	--				03:32	00:00	00:00	00:00									700.00	696.68	99.53		
M		Bus & Switch Line Reactor		NR1		--	--	--													MVAR			OHxMVARxMF	THMxMVARxMF			
1	NR1BRT67	240MVAR B/Reactor AJMER-765	240	NR1		02/10/20	10:21	03/10/20	16:18			00:00	00:00	00:00	29:57				SVRD	Hand Tripped on Voltage Regulation,Vol-754 KV.								
		SUB TOTAL				--	--	--				00:00	00:00	00:00	69:05						744.00	240		240.00	240.00	100.00		
2	NR1BRT66	125MVAR B/Reactor AJMER	125	NR1		03/10/20	09:33	03/10/20	15:41			00:00	00:00	00:00	06:08				SVRD	Hand Tripped on Voltage Regulation,Vol-397 KV.								
		SUB TOTAL				--	--	--				00:00	00:00	00:00	59:57						744.00	125		125.00	125.00	100.00		
3	NR1BRT57	125MVAR B/Reactor-I BAGPAT	50	NR1		06/10/20	11:43	06/10/20	15:44			00:00	00:00	00:00	04:01				SVRD	Hand Tripped on Voltage Regulation,Vol-397 KV.								
		SUB TOTAL				--	--	--				00:00	00:00	00:00	00:00						744.00	50		50.00	50.00	100.00		
4	NR1BRT04	50MVAR B/Reactor-I BASSI	50	NR1		08/10/20	10:16	09/10/20	22:38			00:00	00:00	00:00	36:22				SVRD	Hand Tripped on Voltage Regulation,Vol-397 KV.								
		SUB TOTAL				--	--	--				00:00	00:00	00:00	13:24						744.00	50		50.00	50.00	100.00		
5	NR1BRT53	50MVAR B/Reactor-II BASSI	50	NR1		03/10/20	11:39	05/10/20	04:16			00:00	00:00	00:00	40:37				SVRD	Hand Tripped on Voltage Regulation,Vol-397KV.								
		SUB TOTAL				--	--	--				00:00	00:00	00:00	106:07						744.00	50		50.00	50.00	100.00		
6	NR1BRT54	50MVAR B/Reactor-III BASSI	50	NR1		08/10/20	10:53	08/10/20	21:49			00:00	00:00	00:00	10:56				SVRD	Hand Tripped on Voltage Regulation,Vol-397 KV.								
		SUB TOTAL				--	--	--				00:00	00:00	00:00	13:15						744.00	50		50.00	50.00	100.00		
7	NR1BRT60	125MVAR B/Reactor-IV BASSI	125	NR1		08/10/20	10:17	08/10/20	21:49			00:00	00:00	00:00	11:32				SVRD	Hand Tripped on Voltage Regulation,Vol-397 KV.								
		SUB TOTAL				--	--	--				00:00	00:00	00:00	13:37						744.00	50		50.00	50.00	100.00		













Sr.No.	Unique ID of transmission Element	ELEMENT NAME	Description (Length/No. (MW/MVA/ MW/etc..))	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		DURATION OF OUTAGE ATTRIBUTABLE TO (in hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Classification/ Category Code	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	Total Duration Available for Consideration	NSC	Ckt. Kms.	Weightage Factor	H=(G*(Z-@))/Z	% Availability as certified by certifying agency							
						DATE TIME	DATE TIME	No. of towers damaged	no. of insulator failed	Total outage in days (1)	ISTS Licensee	OTHERS	System constraint/ Natural calamity/ M/B/Hancy	Deemed Available	@ (T)													# (U)	& (C)	* (D)				
																															Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min
Z	Hrs	(E)	(F)	G=E x F	H																													