

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-1 AT AJMER	SVRD	28-02-2024	11:02:00	28-02-2024	13:41:00	0.11	0.00	0.00	0.00	2.65		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT AJMER	SVRD	29-02-2024	10:51:00	29-02-2024	13:18:00	0.10	0.00	0.00	0.00	2.45		* BR opened on voltage regulation.Voltage 395 kV
BSR	125MVAR,BUS REACTOR-1 AT AJMER	SVRD	24-02-2024	10:34:00	24-02-2024	16:10:00	0.23	0.00	0.00	0.00	5.60		* BR opened on voltage regulation. Voltage-394KV.
BSR	125MVAR,BUS REACTOR-1 AT AJMER	SVRD	25-02-2024	10:38:00	25-02-2024	16:21:00	0.24	0.00	0.00	0.00	5.72		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT AJMER	SVRD	19-02-2024	10:34:00	19-02-2024	15:08:00	0.19	0.00	0.00	0.00	4.57		* BR opened on voltage regulation. Voltage-396KV
BSR	125MVAR,BUS REACTOR-1 AT AJMER	SVRD	14-02-2024	11:20:00	14-02-2024	16:25:00	0.21	0.00	0.00	0.00	5.08		* BR opened on voltage regulation.Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT AJMER	SVRD	10-02-2024	11:04:00	10-02-2024	15:21:00	0.18	0.00	0.00	0.00	4.28		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR,BUS REACTOR-1 AT AJMER	SVRD	13-02-2024	09:39:00	13-02-2024	13:23:00	0.16	0.00	0.00	0.00	3.73		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT AJMER	SVRD	15-02-2024	10:10:00	15-02-2024	17:01:00	0.29	0.00	0.00	0.00	6.85		* BR opened on voltage regulation. Voltage-395 KV.
							1.71	0.00	0.00	0.00	40.93	100.00	
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	27-02-2024	10:41:00	27-02-2024	15:54:00	0.22	0.00	0.00	0.00	5.22		* BR opened on voltage regulation.Voltage 795 kV
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	23-02-2024	10:28:00	23-02-2024	16:55:00	0.27	0.00	0.00	0.00	6.45		* BR opened on voltage regulation. Voltage-394KV.
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	28-02-2024	10:57:00	28-02-2024	15:40:00	0.20	0.00	0.00	0.00	4.72		* BR opened on voltage regulation. Voltage-756KV.
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	16-02-2024	10:26:00	16-02-2024	16:21:00	0.25	0.00	0.00	0.00	5.92		* BR opened on voltage regulation.Voltage-755 kV
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	11-02-2024	10:46:00	11-02-2024	15:30:00	0.20	0.00	0.00	0.00	4.73		* BR opened on voltage regulation.Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	15-02-2024	11:45:00	15-02-2024	16:22:00	0.19	0.00	0.00	0.00	4.62		* BR opened on voltage regulation. Voltage-756KV
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	19-02-2024	10:33:00	19-02-2024	13:07:00	0.11	0.00	0.00	0.00	2.57		* BR opened on voltage regulation. Voltage=760kV
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	22-02-2024	12:12:00	22-02-2024	16:57:00	0.20	0.00	0.00	0.00	4.75		* BR opened on voltage regulation.Voltage-755kV
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	13-02-2024	10:43:00	13-02-2024	12:51:00	0.09	0.00	0.00	0.00	2.13		* BR opened on voltage regulation.Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	25-02-2024	10:38:00	25-02-2024	14:51:00	0.18	0.00	0.00	0.00	4.22		* BR opened on voltage regulation. Voltage-756KV.
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	29-02-2024	10:37:00	29-02-2024	14:34:00	0.17	0.00	0.00	0.00	3.95		
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	18-02-2024	10:34:00	18-02-2024	15:45:00	0.22	0.00	0.00	0.00	5.18		* BR opened on voltage regulation. Voltage-756KV.
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	17-02-2024	10:10:00	17-02-2024	15:35:00	0.23	0.00	0.00	0.00	5.42		* BR opened on voltage regulation. Voltage-756KV.
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	10-02-2024	11:23:00	10-02-2024	17:17:00	0.25	0.00	0.00	0.00	5.90		* BR opened on voltage regulation.Voltage 755 KV NR2402-9343 /3538
BSR	240MVAR,BUS REACTOR-1 AT AJMER	SVRD	21-02-2024	10:58:00	21-02-2024	14:31:00	0.15	0.00	0.00	0.00	3.55		* BR opened on voltage regulation. Voltage-760KV.
							2.93	0.00	0.00	0.00	69.33	100.00	
BSR	125MVAR,BUS REACTOR-1 AT BAGPAT	SVRD	13-02-2024	11:02:00	13-02-2024	13:17:00	0.09	0.00	0.00	0.00	2.25		* BR opened on voltage regulation.Voltage-395 kV
BSR	125MVAR,BUS REACTOR-1 AT BAGPAT	SVRD	11-02-2024	09:52:00	11-02-2024	15:37:00	0.24	0.00	0.00	0.00	5.75		* BR opened on voltage regulation. Voltage-410KV.
BSR	125MVAR,BUS REACTOR-1 AT BAGPAT	SVRD	12-02-2024	11:21:00	12-02-2024	16:45:00	0.23	0.00	0.00	0.00	5.40		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT BAGPAT	SVRD	10-02-2024	11:27:00	10-02-2024	15:04:00	0.15	0.00	0.00	0.00	3.62		* BR opened on voltage regulation. Voltage 395 KV
							0.71	0.00	0.00	0.00	17.02	100.00	
BSR	80MVAR,BUS REACTOR-1 AT BALLABGARH	SCSD	19-02-2024	10:02:00	29-02-2024	23:59:59	10.58	0.00	0.00	0.00	253.97		* S/D for replacement of old 80MVAR Bus Reactor with 125 mvar in* Under O(-&(-)M ADD CAP.S/D till 20.03.2024
BSR	80MVAR,BUS REACTOR-1 AT BALLABGARH	SVRD	15-02-2024	10:46:00	15-02-2024	17:03:00	0.26	0.00	0.00	0.00	6.28		* BR opened on voltage regulation.Voltage-396kV
BSR	80MVAR,BUS REACTOR-1 AT BALLABGARH	SVRD	14-02-2024	08:33:00	14-02-2024	13:20:00	0.20	0.00	0.00	0.00	4.78		* BR opened on voltage regulation. Voltage-395 KV.
BSR	80MVAR,BUS REACTOR-1 AT BALLABGARH	SVRD	03-02-2024	09:46:00	03-02-2024	15:06:00	0.22	0.00	0.00	0.00	5.33		* BR opened on voltage regulation. V-401kV
							11.26	0.00	0.00	0.00	270.36	100.00	
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	14-02-2024	07:33:00	14-02-2024	16:13:00	0.36	0.00	0.00	0.00	8.67		* BR opened on voltage regulation.Voltage 395 KV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	17-02-2024	09:46:00	17-02-2024	16:29:00	0.28	0.00	0.00	0.00	6.72		* BR opened on voltage regulation. V-390kV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	19-02-2024	09:57:00	19-02-2024	13:02:00	0.13	0.00	0.00	0.00	3.08		* BR opened on voltage regulation. Voltage 395 KV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	27-02-2024	10:00:00	27-02-2024	15:38:00	0.24	0.00	0.00	0.00	5.63		* BR opened on voltage regulation. Voltage-397KV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	07-02-2024	07:43:00	07-02-2024	17:57:00	0.43	0.00	0.00	0.00	10.23		* BR opened on voltage regulation. Voltage-402KV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	26-02-2024	09:48:00	26-02-2024	15:48:00	0.25	0.00	0.00	0.00	6.00		* BR opened on voltage regulation.Voltage-396kV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	06-02-2024	09:52:00	06-02-2024	20:50:00	0.46	0.00	0.00	0.00	10.97		* BR opened on voltage regulation. V-382kV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	18-02-2024	09:41:00	18-02-2024	15:33:00	0.24	0.00	0.00	0.00	5.87		* Bus Reactor opened on voltage regulation. Voltage 395 KV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	21-02-2024	09:39:00	21-02-2024	16:28:00	0.28	0.00	0.00	0.00	6.82		* BR opened on voltage regulation. Voltage-399KV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	05-02-2024	10:47:00	05-02-2024	13:19:00	0.11	0.00	0.00	0.00	2.53		* BR opened on voltage regulation. Voltage-395kV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	03-02-2024	09:20:00	03-02-2024	15:04:00	0.24	0.00	0.00	0.00	5.73		* BR opened on voltage regulation. V-399kV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	01-02-2024	11:48:00	01-02-2024	15:42:00	0.16	0.00	0.00	0.00	3.90		* BR opened on voltage regulation. Voltage-394KV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	02-02-2024	09:00:00	02-02-2024	15:21:00	0.27	0.00	0.00	0.00	6.35		* BR opened on voltage regulation.Voltage 395 kV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	08-02-2024	07:49:00	09-02-2024	21:41:00	1.58	0.00	0.00	0.00	37.87		* BR opened on voltage regulation. Voltage-395 KV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	29-02-2024	09:13:00	29-02-2024	16:26:00	0.30	0.00	0.00	0.00	7.22		* BR opened on voltage regulation. Voltage-395KV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	28-02-2024	09:46:00	28-02-2024	13:26:00	0.15	0.00	0.00	0.00	3.67		* BR opened on voltage regulation.Voltage-396kV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	16-02-2024	08:07:00	16-02-2024	17:22:00	0.39	0.00	0.00	0.00	9.25		* BR Opened on Voltage Regulation.Voltage 395 KV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	25-02-2024	09:38:00	25-02-2024	15:34:00	0.25	0.00	0.00	0.00	5.93		* BR opened on voltage regulation. Voltage-395KV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	24-02-2024	09:32:00	24-02-2024	18:02:00	0.35	0.00	0.00	0.00	8.50		* BR opened on voltage regulation. Voltage-395KV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	22-02-2024	09:26:00	22-02-2024	17:55:00	0.35	0.00	0.00	0.00	8.48		* BR opened on voltage regulation. Voltage-395 KV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	12-02-2024	09:35:00	12-02-2024	18:10:00	0.36	0.00	0.00	0.00	8.58		* BR opened on voltage regulation. Voltage=390kV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	15-02-2024	07:54:00	15-02-2024	21:15:00	0.56	0.00	0.00	0.00	13.35		* BR opened on voltage regulation.Voltage 395 KV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	23-02-2024	07:59:00	23-02-2024	17:50:00	0.41	0.00	0.00	0.00	9.85		* BR opened on voltage regulation. Voltage-392KV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	11-02-2024	08:32:00	11-02-2024	16:24:00	0.33	0.00	0.00	0.00	7.87		* BR opened on voltage regulation.Voltage 395 KV NR2402-9316
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	04-02-2024	09:58:00	04-02-2024	14:16:00	0.18	0.00	0.00	0.00	4.30		* BR opened on voltage regulation. V-396kV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	13-02-2024	08:48:00	13-02-2024	16:26:00	0.32	0.00	0.00	0.00	7.63		* BR opened on voltage regulation. Voltage-400KV.
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	10-02-2024	10:48:00	10-02-2024	15:32:00	0.20	0.00	0.00	0.00	4.73		* BR opened on voltage regulation. Voltage=395 KV
BSR	50MVAR,BUS REACTOR-1 AT BASSI	SVRD	20-02-2024	08:50:00	20-02-2024	17:06:00	0.34	0.00	0.00	0.00	8.27		* Reactor opened on voltage regulation.Voltage 395 KV

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	17-02-2024	09:46:00	17-02-2024	16:29:00	0.28	0.00	0.00	0.00	6.72		* BR Opened on Voltage Regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	19-02-2024	09:57:00	19-02-2024	13:02:00	0.13	0.00	0.00	0.00	3.08		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	27-02-2024	10:00:00	27-02-2024	16:04:00	0.25	0.00	0.00	0.00	6.07		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	18-02-2024	09:41:00	18-02-2024	14:46:00	0.21	0.00	0.00	0.00	5.08		* BR opened on voltage regulation. V-390KV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	12-02-2024	10:02:00	12-02-2024	17:55:00	0.33	0.00	0.00	0.00	7.88		* BR opened on voltage regulation. Voltage=395 KV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	03-02-2024	09:20:00	03-02-2024	15:04:00	0.24	0.00	0.00	0.00	5.73		* BR opened on voltage regulation. Voltage-397KV.
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	29-02-2024	09:13:00	29-02-2024	16:30:00	0.30	0.00	0.00	0.00	7.28		* BR opened on voltage regulation. Voltage-402KV.
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	07-02-2024	07:43:00	07-02-2024	17:57:00	0.43	0.00	0.00	0.00	10.23		* BR opened on voltage regulation. Voltage=390KV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	20-02-2024	08:50:00	20-02-2024	16:00:00	0.30	0.00	0.00	0.00	7.17		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	25-02-2024	09:38:00	25-02-2024	15:34:00	0.25	0.00	0.00	0.00	5.93		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	14-02-2024	07:34:00	14-02-2024	20:38:00	0.54	0.00	0.00	0.00	13.07		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	21-02-2024	09:39:00	21-02-2024	16:28:00	0.28	0.00	0.00	0.00	6.82		* BR opened on voltage regulation. V-396KV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	26-02-2024	09:48:00	26-02-2024	15:48:00	0.25	0.00	0.00	0.00	6.00		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	13-02-2024	08:48:00	13-02-2024	16:26:00	0.32	0.00	0.00	0.00	7.63		* BR opened on voltage regulation Voltage 395 KV NR 2402-9315
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	08-02-2024	07:49:00	08-02-2024	22:00:00	0.59	0.00	0.00	0.00	14.18		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	09-02-2024	10:41:00	09-02-2024	21:41:00	0.46	0.00	0.00	0.00	11.00		* BR opened on voltage regulation. Voltage-392KV.
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	22-02-2024	09:26:00	22-02-2024	17:54:00	0.35	0.00	0.00	0.00	8.47		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	16-02-2024	08:07:00	16-02-2024	17:22:00	0.39	0.00	0.00	0.00	9.25		* BR opened on voltage regulation. Voltage 395 KV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	24-02-2024	09:32:00	24-02-2024	16:38:00	0.30	0.00	0.00	0.00	7.10		* Reactor opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	06-02-2024	09:52:00	06-02-2024	20:50:00	0.46	0.00	0.00	0.00	10.97		* BR opened on voltage regulation.Voltage-396KV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	11-02-2024	08:32:00	11-02-2024	15:15:00	0.28	0.00	0.00	0.00	6.72		* BR opened on voltage regulation. Voltage-399KV.
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	01-02-2024	11:48:00	01-02-2024	15:42:00	0.16	0.00	0.00	0.00	3.90		* Bus Reactor opened on voltage regulation. Voltage 395 KV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	04-02-2024	09:58:00	04-02-2024	14:16:00	0.18	0.00	0.00	0.00	4.30		* BR opened on voltage regulation. Voltage=395kV
BSR	125MVAR,BUS REACTOR-4 AT BASSI	SVRD	02-02-2024	09:00:00	02-02-2024	15:25:00	0.27	0.00	0.00	0.00	6.42		* BR opened on voltage regulation. V-397kV
							8.97	0.00	0.00	0.00	214.73	100.00	
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	29-02-2024	10:35:00	29-02-2024	17:42:00	0.30	0.00	0.00	0.00	7.12		* BR opened on voltage regulation. Voltage = 395 KV
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	28-02-2024	09:48:00	28-02-2024	17:37:00	0.33	0.00	0.00	0.00	7.82		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	23-02-2024	11:43:00	23-02-2024	17:44:00	0.25	0.00	0.00	0.00	6.02		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	13-02-2024	10:22:00	13-02-2024	13:09:00	0.12	0.00	0.00	0.00	2.78		* BR opened on voltage regulation. Voltage-397KV.
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	09-02-2024	12:02:00	09-02-2024	16:33:00	0.19	0.00	0.00	0.00	4.52		* BR opened on voltage regulation.Voltage -395 KV
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	11-02-2024	09:45:00	11-02-2024	16:34:00	0.28	0.00	0.00	0.00	6.82		* BR opened on voltage regulation. V-382KV
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	24-02-2024	10:34:00	24-02-2024	16:26:00	0.24	0.00	0.00	0.00	5.87		* BR opened on voltage regulation.Voltage-396KV
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	27-02-2024	10:20:00	27-02-2024	16:20:00	0.25	0.00	0.00	0.00	6.00		* BR opened on voltage regulation Voltage 395 KV NR 2402-9311
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	15-02-2024	11:05:00	15-02-2024	16:49:00	0.24	0.00	0.00	0.00	5.73		* BR opened on voltage regulation.Voltage-396KV
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	05-02-2024	10:42:00	05-02-2024	16:43:00	0.25	0.00	0.00	0.00	6.02		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	18-02-2024	09:25:00	18-02-2024	16:07:00	0.28	0.00	0.00	0.00	6.70		* BR opened on voltage regulation.Voltage-395 kV
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	16-02-2024	10:07:00	16-02-2024	16:25:00	0.26	0.00	0.00	0.00	6.30		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	10-02-2024	09:32:00	10-02-2024	17:44:00	0.34	0.00	0.00	0.00	8.20		* BR opened on voltage regulation. Voltage-399KV.
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	26-02-2024	12:45:00	26-02-2024	16:07:00	0.14	0.00	0.00	0.00	3.37		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	25-02-2024	11:08:00	25-02-2024	16:36:00	0.23	0.00	0.00	0.00	5.47		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	07-02-2024	10:54:00	07-02-2024	18:04:00	0.30	0.00	0.00	0.00	7.17		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	19-02-2024	10:04:00	19-02-2024	15:37:00	0.23	0.00	0.00	0.00	5.55		* BR opened on voltage regulation. Voltage-394KV.
							4.23	0.00	0.00	0.00	101.46	100.00	
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	12-02-2024	09:39:00	12-02-2024	18:06:00	0.35	0.00	0.00	0.00	8.45		* BR opened on voltage regulation. Voltage-760KV.
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	20-02-2024	10:17:00	20-02-2024	16:38:00	0.27	0.00	0.00	0.00	6.35		* BR opened on voltage regulation. Voltage-754KV.
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	23-02-2024	10:01:00	23-02-2024	16:05:00	0.25	0.00	0.00	0.00	6.07		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	27-02-2024	09:38:00	27-02-2024	15:46:00	0.26	0.00	0.00	0.00	6.13		* BR opened on voltage regulation. Voltage-755KV.
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	06-02-2024	10:58:00	06-02-2024	17:00:00	0.25	0.00	0.00	0.00	6.03		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	05-02-2024	10:15:00	05-02-2024	16:43:00	0.27	0.00	0.00	0.00	6.47		* BR opened on voltage regulation. Voltage-760KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	09-02-2024	10:38:00	09-02-2024	21:46:00	0.46	0.00	0.00	0.00	11.13		* BR opened on voltage regulation. Voltage-762KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	28-02-2024	09:44:00	28-02-2024	15:37:00	0.25	0.00	0.00	0.00	5.88		* BR opened on voltage regulation. Voltage=765KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	29-02-2024	09:31:00	29-02-2024	17:39:00	0.34	0.00	0.00	0.00	8.13		* BR opened on voltage regulation. V-760kV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	13-02-2024	10:22:00	13-02-2024	17:30:00	0.30	0.00	0.00	0.00	7.13		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	16-02-2024	09:26:00	16-02-2024	15:25:00	0.25	0.00	0.00	0.00	5.98		* Reactor opened on voltage regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	07-02-2024	10:46:00	07-02-2024	15:53:00	0.21	0.00	0.00	0.00	5.12		* BR opened on voltage regulation Voltage 755 KV NR2402-9267 / 3509
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	25-02-2024	09:28:00	25-02-2024	14:55:00	0.23	0.00	0.00	0.00	5.45		* BR opened on voltage regulation. Voltage-755KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	15-02-2024	09:38:00	15-02-2024	17:26:00	0.33	0.00	0.00	0.00	7.80		* BR opened on voltage regulation. Voltage = 760kV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	17-02-2024	09:41:00	17-02-2024	16:17:00	0.28	0.00	0.00	0.00	6.60		* BR Opened on Voltage Regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	11-02-2024	09:25:00	11-02-2024	16:32:00	0.30	0.00	0.00	0.00	7.12		* BR opened on voltage regulation. Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	22-02-2024	11:19:00	22-02-2024	16:13:00	0.20	0.00	0.00	0.00	4.90		* BR opened on voltage regulation.Voltage-762kV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	24-02-2024	09:30:00	24-02-2024	16:18:00	0.28	0.00	0.00	0.00	6.80		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	21-02-2024	10:28:00	21-02-2024	16:51:00	0.27	0.00	0.00	0.00	6.38		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	08-02-2024	09:45:00	08-02-2024	16:02:00	0.26	0.00	0.00	0.00	6.28		* BR opened on voltage regulation. Voltage-760KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	14-02-2024	09:44:00	14-02-2024	16:08:00	0.27	0.00	0.00	0.00	6.40		* BR opened on voltage regulation. Voltage-755KV.
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	19-02-2024	09:52:00	19-02-2024	20:30:00	0.44	0.00	0.00	0.00	10.63		* BR opened on voltage regulation. Voltage-756KV.

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	10-02-2024	09:35:00	10-02-2024	17:36:00	0.33	0.00	0.00	0.00	8.02		* BR opened on voltage regulation. Voltage-760KV.
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	26-02-2024	10:40:00	26-02-2024	15:31:00	0.20	0.00	0.00	0.00	4.85		* V
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	18-02-2024	09:47:00	18-02-2024	15:56:00	0.26	0.00	0.00	0.00	6.15		* BR opened on voltage regulation.Voltage-755 kV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	02-02-2024	10:24:00	02-02-2024	16:02:00	0.24	0.00	0.00	0.00	5.63		* BR opened on voltage regulation. Voltage=750KV
BSR	240MVAR,BUS REACTOR-1 AT BHADLA-2	SVRD	01-02-2024	10:35:00	01-02-2024	15:56:00	0.22	0.00	0.00	0.00	5.35		* BR opened on voltage regulation.Voltage-395 kV
							7.57	0.00	0.00	0.00	181.23	100.00	
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	07-02-2024	10:50:00	07-02-2024	17:53:00	0.29	0.00	0.00	0.00	7.05		* BR opened on voltage regulation. Voltage-754KV.
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	01-02-2024	11:27:00	01-02-2024	16:31:00	0.21	0.00	0.00	0.00	5.07		* BR opened on voltage regulation Voltage 795 kV
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	28-02-2024	09:46:00	28-02-2024	17:03:00	0.30	0.00	0.00	0.00	7.28		* BR opened on voltage regulation. Voltage-760KV.
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	23-02-2024	10:02:00	23-02-2024	17:35:00	0.32	0.00	0.00	0.00	7.55		* BR opened on voltage regulation.Voltage-755 KV.
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	08-02-2024	10:18:00	10-02-2024	17:37:00	2.31	0.00	0.00	0.00	55.32		* BR opened on voltage regulation. Voltage-754KV.
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	14-02-2024	10:18:00	14-02-2024	16:16:00	0.25	0.00	0.00	0.00	5.97		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	18-02-2024	09:52:00	18-02-2024	16:19:00	0.27	0.00	0.00	0.00	6.45		* BR opened on voltage regulation. Voltage 755 KV
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	24-02-2024	09:47:00	24-02-2024	16:29:00	0.28	0.00	0.00	0.00	6.70		* BR opened on voltage regulation.Voltage-755 kV
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	17-02-2024	10:17:00	17-02-2024	16:18:00	0.25	0.00	0.00	0.00	6.02		* BR opened on voltage regulation.Voltage-754KV.
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	27-02-2024	09:38:00	27-02-2024	16:22:00	0.28	0.00	0.00	0.00	6.73		* Reactor opened on voltage regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	15-02-2024	09:40:00	15-02-2024	16:10:00	0.27	0.00	0.00	0.00	6.50		* BR opened on voltage regulation. Voltage-763KV.
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	05-02-2024	10:36:00	05-02-2024	16:18:00	0.24	0.00	0.00	0.00	5.70		* BR opened on voltage regulation. Voltage-760KV.
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	25-02-2024	10:11:00	25-02-2024	16:15:00	0.25	0.00	0.00	0.00	6.07		* BR opened on voltage regulation. V-765kV
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	06-02-2024	10:55:00	06-02-2024	18:01:00	0.30	0.00	0.00	0.00	7.10		* BR opened on voltage regulation.Voltage-755 kV
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	21-02-2024	11:24:00	21-02-2024	17:27:00	0.25	0.00	0.00	0.00	6.05		* BR opened on voltage regulation Voltage 755 KV NR2402-9282 /3513
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	11-02-2024	09:34:00	11-02-2024	16:37:00	0.29	0.00	0.00	0.00	7.05		* BR opened on voltage regulation. Voltage=750KV
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	12-02-2024	09:37:00	12-02-2024	17:41:00	0.34	0.00	0.00	0.00	8.07		* BR opened on voltage regulation. Voltage-756KV.
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	19-02-2024	09:52:00	19-02-2024	15:39:00	0.24	0.00	0.00	0.00	5.78		* BR opened on voltage regulation.Voltage 755 KV
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	16-02-2024	10:10:00	16-02-2024	16:35:00	0.27	0.00	0.00	0.00	6.42		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	13-02-2024	10:22:00	13-02-2024	18:39:00	0.35	0.00	0.00	0.00	8.28		* BR opened on voltage regulation. Voltage-760KV.
BSR	240MVAR,BUS REACTOR-2 AT BHADLA-2	SVRD	29-02-2024	10:13:00	29-02-2024	18:12:00	0.33	0.00	0.00	0.00	7.98		* BR opened on voltage regulation. Voltage-757KV.
							7.89	0.00	0.00	0.00	189.14	100.00	
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	28-02-2024	10:06:00	28-02-2024	17:50:00	0.32	0.00	0.00	0.00	7.73		* BR Opened on Voltage Regulation Voltage 395 Kv
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	26-02-2024	11:46:00	26-02-2024	15:53:00	0.17	0.00	0.00	0.00	4.12		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	07-02-2024	11:01:00	07-02-2024	17:53:00	0.29	0.00	0.00	0.00	6.87		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	14-02-2024	10:44:00	14-02-2024	16:48:00	0.25	0.00	0.00	0.00	6.07		* Reactor opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	06-02-2024	09:44:00	06-02-2024	16:39:00	0.29	0.00	0.00	0.00	6.92		* BR opened on voltage regulation.Voltage-395 kV
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	11-02-2024	09:42:00	11-02-2024	16:14:00	0.27	0.00	0.00	0.00	6.53		* BR opened on voltage regulation. Voltage-394KV.
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	23-02-2024	09:26:00	23-02-2024	17:55:00	0.35	0.00	0.00	0.00	8.48		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	21-02-2024	10:50:00	21-02-2024	17:22:00	0.27	0.00	0.00	0.00	6.53		* BR opened on voltage regulation. Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	12-02-2024	11:14:00	12-02-2024	12:45:00	0.06	0.00	0.00	0.00	1.52		* BR opened on voltage regulation. Voltage-397KV.
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	24-02-2024	10:32:00	24-02-2024	17:59:00	0.31	0.00	0.00	0.00	7.45		* BR opened on voltage regulation. Voltage-394KV.
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	09-02-2024	11:44:00	10-02-2024	21:26:00	1.40	0.00	0.00	0.00	33.70		* BR opened on voltage regulation Voltage 395 kv
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	27-02-2024	10:16:00	27-02-2024	15:51:00	0.23	0.00	0.00	0.00	5.58		* BR opened on voltage regulation. Voltage=390KV
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	19-02-2024	10:04:00	19-02-2024	15:20:00	0.22	0.00	0.00	0.00	5.27		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	20-02-2024	10:44:00	20-02-2024	16:01:00	0.22	0.00	0.00	0.00	5.28		* BR opened on voltage regulation Voltage 395 KV NR 2402- 9310
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	17-02-2024	11:05:00	17-02-2024	16:46:00	0.24	0.00	0.00	0.00	5.68		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	13-02-2024	09:50:00	13-02-2024	13:26:00	0.15	0.00	0.00	0.00	3.60		* BR opened on voltage regulation.Voltage-395 kV
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	15-02-2024	09:34:00	15-02-2024	17:05:00	0.31	0.00	0.00	0.00	7.52		* BR opened on voltage regulation. V-396kV
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	22-02-2024	11:24:00	22-02-2024	17:55:00	0.27	0.00	0.00	0.00	6.52		* BR opened on voltage regulation. Voltage-397KV.
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	16-02-2024	09:40:00	16-02-2024	17:42:00	0.34	0.00	0.00	0.00	8.03		* BR opened on voltage regulation.Voltage -395 KV
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	18-02-2024	09:17:00	18-02-2024	16:09:00	0.29	0.00	0.00	0.00	6.87		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	25-02-2024	10:21:00	25-02-2024	16:27:00	0.25	0.00	0.00	0.00	6.10		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT BADHLA	SVRD	29-02-2024	10:11:00	29-02-2024	17:30:00	0.31	0.00	0.00	0.00	7.32		* BR opened on voltage regulation. Voltage = 395 KV
							6.81	0.00	0.00	0.00	163.69	100.00	
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	02-02-2024	10:17:00	02-02-2024	16:12:00	0.25	0.00	0.00	0.00	5.92		* BR opened on voltage regulation. Voltage-756KV.
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	26-02-2024	09:36:00	26-02-2024	16:16:00	0.28	0.00	0.00	0.00	6.67		* BR Opened on Voltage Regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	05-02-2024	10:15:00	05-02-2024	16:26:00	0.26	0.00	0.00	0.00	6.18		* BR opened on voltage regulation. Voltage-760KV
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	07-02-2024	11:27:00	07-02-2024	17:11:00	0.24	0.00	0.00	0.00	5.73		* Reactor opened on voltage regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	16-02-2024	09:32:00	16-02-2024	16:25:00	0.29	0.00	0.00	0.00	6.88		* BR opened on voltage regulation Voltage 755 KV NR2402-9268 /3510
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	22-02-2024	09:58:00	22-02-2024	17:07:00	0.30	0.00	0.00	0.00	7.15		* BR opened on voltage regulation. Voltage-760KV.
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	29-02-2024	09:22:00	29-02-2024	17:29:00	0.34	0.00	0.00	0.00	8.12		* BR opened on voltage regulation. Voltage-756KV.
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	28-02-2024	09:36:00	28-02-2024	16:45:00	0.30	0.00	0.00	0.00	7.15		* BR opened on voltage regulation. Voltage-756KV.
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	23-02-2024	09:30:00	23-02-2024	16:53:00	0.31	0.00	0.00	0.00	7.38		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	13-02-2024	10:05:00	13-02-2024	17:27:00	0.31	0.00	0.00	0.00	7.37		* BR opened on voltage regulation. Voltage-754KV.
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	21-02-2024	11:01:00	21-02-2024	16:52:00	0.24	0.00	0.00	0.00	5.85		* BR opened on voltage regulation Voltage 755 kV
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	25-02-2024	09:36:00	25-02-2024	16:08:00	0.27	0.00	0.00	0.00	6.53		* BR opened on voltage regulation. Voltage-755KV.
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	09-02-2024	09:53:00	09-02-2024	18:08:00	0.34	0.00	0.00	0.00	8.25		* BR opened on voltage regulation. V-750kV
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	27-02-2024	09:41:00	27-02-2024	16:17:00	0.28	0.00	0.00	0.00	6.60		* BR opened on voltage regulation. Voltage-754KV.

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	06-02-2024	09:41:00	06-02-2024	16:37:00	0.29	0.00	0.00	0.00	6.93		* BR opened on voltage regulation. Voltage=760KV.
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	08-02-2024	09:39:00	08-02-2024	17:05:00	0.31	0.00	0.00	0.00	7.43		* BR opened on voltage regulation. Voltage=765kV
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	20-02-2024	10:05:00	20-02-2024	17:22:00	0.30	0.00	0.00	0.00	7.28		* BR opened on voltage regulation. Voltage=760KV.
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	24-02-2024	09:44:00	24-02-2024	16:23:00	0.28	0.00	0.00	0.00	6.65		* BR opened on voltage regulation. Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	12-02-2024	09:31:00	12-02-2024	17:27:00	0.33	0.00	0.00	0.00	7.93		* BR opened on voltage regulation. Voltage=760 KV
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	18-02-2024	09:14:00	18-02-2024	16:13:00	0.29	0.00	0.00	0.00	6.98		* BR opened on voltage regulation. V-765kV
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	15-02-2024	09:22:00	15-02-2024	17:24:00	0.34	0.00	0.00	0.00	8.03		* BR opened on voltage regulation.Voltage=755 kv
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	19-02-2024	09:34:00	19-02-2024	15:19:00	0.24	0.00	0.00	0.00	5.75		* BR opened on voltage regulation. Voltage=750kV
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	14-02-2024	09:22:00	14-02-2024	17:48:00	0.35	0.00	0.00	0.00	8.43		* BR opened on voltage regulation. Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	17-02-2024	09:34:00	17-02-2024	16:46:00	0.30	0.00	0.00	0.00	7.20		* BR opened on voltage regulation. Voltage=754KV.
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	11-02-2024	09:28:00	11-02-2024	16:11:00	0.28	0.00	0.00	0.00	6.72		* BR opened on voltage regulation Voltage 755kv
BSR	240MVAR,BUS REACTOR-1 AT BADHLA	SVRD	01-02-2024	10:33:00	01-02-2024	16:02:00	0.23	0.00	0.00	0.00	5.48		* BR opened on voltage regulation. Voltage=755 KV.
							7.55	0.00	0.00	0.00	180.59	100.00	
BSR	80MVAR,BUS REACTOR-1 AT BHIWADI	SVRD	23-02-2024	11:20:00	23-02-2024	18:17:00	0.29	0.00	0.00	0.00	6.95		* BR opened on voltage regulation Voltage 395 KV NR 2402-9298
BSR	80MVAR,BUS REACTOR-1 AT BHIWADI	SVRD	12-02-2024	11:17:00	12-02-2024	13:49:00	0.11	0.00	0.00	0.00	2.53		* BR opened on voltage regulation. Voltage=395 KV.
BSR	80MVAR,BUS REACTOR-1 AT BHIWADI	SVRD	15-02-2024	10:53:00	15-02-2024	17:43:00	0.29	0.00	0.00	0.00	6.83		* BR opened on voltage regulation.Voltage=396kV
BSR	80MVAR,BUS REACTOR-1 AT BHIWADI	SVRD	16-02-2024	11:01:00	16-02-2024	14:49:00	0.16	0.00	0.00	0.00	3.80		* BR opened on voltage regulation. Voltage=395KV.
BSR	80MVAR,BUS REACTOR-1 AT BHIWADI	SVRD	27-02-2024	10:59:00	27-02-2024	14:52:00	0.16	0.00	0.00	0.00	3.88		* BR opened on voltage regulation. Voltage=394KV.
BSR	80MVAR,BUS REACTOR-1 AT BHIWADI	SVRD	14-02-2024	10:32:00	14-02-2024	20:00:00	0.39	0.00	0.00	0.00	9.47		* BR opened on voltage regulation. Voltage 395 KV
BSR	80MVAR,BUS REACTOR-1 AT BHIWADI	SVRD	13-02-2024	11:03:00	13-02-2024	16:31:00	0.23	0.00	0.00	0.00	5.47		* BR opened on voltage regulation.Voltage=396kV
							1.63	0.00	0.00	0.00	38.93	100.00	
BSR	240MVAR,BUS REACTOR-1 AT BHIWANI	SVRD	23-02-2024	11:18:00	23-02-2024	16:00:00	0.20	0.00	0.00	0.00	4.70		* BR opened on voltage regulation. Voltage=755KV.
BSR	240MVAR,BUS REACTOR-1 AT BHIWANI	SVRD	08-02-2024	10:40:00	08-02-2024	15:48:00	0.21	0.00	0.00	0.00	5.13		* BR opened on voltage regulation. Voltage=760KV.
BSR	240MVAR,BUS REACTOR-1 AT BHIWANI	SVRD	14-02-2024	10:36:00	14-02-2024	16:10:00	0.23	0.00	0.00	0.00	5.57		* BR opened on voltage regulation. Voltage=755 KV.
BSR	240MVAR,BUS REACTOR-1 AT BHIWANI	SVRD	24-02-2024	11:17:00	24-02-2024	16:22:00	0.21	0.00	0.00	0.00	5.08		* BR opened on voltage regulation. Voltage=757KV.
BSR	240MVAR,BUS REACTOR-1 AT BHIWANI	SVRD	13-02-2024	10:39:00	13-02-2024	13:20:00	0.11	0.00	0.00	0.00	2.68		* BR opened on voltage regulation. Voltage=755 KV.
							0.96	0.00	0.00	0.00	23.16	100.00	
BSR	240MVAR,BUS REACTOR-2 AT BHIWANI	SVRD	10-02-2024	11:36:00	10-02-2024	15:19:00	0.16	0.00	0.00	0.00	3.72		* BR opened on voltage regulation.Voltage=756kV
							0.16	0.00	0.00	0.00	3.72	100.00	
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	08-02-2024	07:52:00	08-02-2024	21:29:00	0.57	0.00	0.00	0.00	13.62		* BR opened on voltage regulation. Voltage=395KV.
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	18-02-2024	09:18:00	18-02-2024	17:19:00	0.33	0.00	0.00	0.00	8.02		* BR opened on voltage regulation.Voltage=395 KV
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	14-02-2024	07:47:00	14-02-2024	18:27:00	0.44	0.00	0.00	0.00	10.67		* Reactor opened on voltage regulation Voltage 395kV
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	15-02-2024	10:01:00	15-02-2024	20:28:00	0.44	0.00	0.00	0.00	10.45		* BR opened on voltage regulation. Voltage=395 KV.
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	01-02-2024	08:08:00	01-02-2024	18:12:00	0.42	0.00	0.00	0.00	10.07		* BR opened on voltage regulation.Voltage=395 kv
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	03-02-2024	09:18:00	03-02-2024	17:11:00	0.33	0.00	0.00	0.00	7.88		* BR opened on voltage regulation. Voltage=402KV.
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	04-02-2024	09:32:00	04-02-2024	14:42:00	0.22	0.00	0.00	0.00	5.17		* BR opened on voltage regulation. V=397kV
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	23-02-2024	08:04:00	23-02-2024	20:50:00	0.53	0.00	0.00	0.00	12.77		* Bus Reactor opened on voltage regulation. Voltage 395 KV
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	19-02-2024	06:21:00	19-02-2024	18:39:00	0.51	0.00	0.00	0.00	12.30		* BR opened on voltage regulation. Voltage=395kV
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	29-02-2024	09:33:00	29-02-2024	17:47:00	0.34	0.00	0.00	0.00	8.23		* BR opened on voltage regulation Voltage 395 kv
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	13-02-2024	08:43:00	13-02-2024	18:35:00	0.41	0.00	0.00	0.00	9.87		
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	16-02-2024	08:06:00	17-02-2024	22:10:00	1.59	0.00	0.00	0.00	38.07		* BR opened on voltage regulation. Voltage=395 KV.
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	07-02-2024	07:08:00	07-02-2024	17:48:00	0.44	0.00	0.00	0.00	10.67		* BR opened on voltage regulation. Voltage=395KV.
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	11-02-2024	08:28:00	11-02-2024	17:26:00	0.37	0.00	0.00	0.00	8.97		* BR opened on voltage regulation. Voltage=398KV.
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	24-02-2024	08:30:00	24-02-2024	22:16:00	0.57	0.00	0.00	0.00	13.77		* BR opened on voltage regulation.Voltage=396kV
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	12-02-2024	09:54:00	12-02-2024	17:53:00	0.33	0.00	0.00	0.00	7.98		* BR opened on voltage regulation. Voltage=400KV.
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	09-02-2024	09:16:00	09-02-2024	20:35:00	0.47	0.00	0.00	0.00	11.32		* BR opened on voltage regulation. Voltage=400KV.
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	10-02-2024	07:18:00	10-02-2024	17:51:00	0.44	0.00	0.00	0.00	10.55		* BR opened on voltage regulation. Voltage 395 KV
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	20-02-2024	08:53:00	20-02-2024	20:53:00	0.50	0.00	0.00	0.00	12.00		* BR opened on voltage regulation. Voltage=395KV.
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	22-02-2024	09:31:00	22-02-2024	18:42:00	0.38	0.00	0.00	0.00	9.18		* BR opened on voltage regulation Voltage 395 KV NR2402-9271
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	02-02-2024	09:01:00	02-02-2024	17:41:00	0.36	0.00	0.00	0.00	8.67		* BR opened on voltage regulation. Voltage=395KV.
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	06-02-2024	08:44:00	06-02-2024	21:00:00	0.51	0.00	0.00	0.00	12.27		* BR opened on voltage regulation. V=382kV
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	25-02-2024	09:42:00	25-02-2024	17:52:00	0.34	0.00	0.00	0.00	8.17		* BR opened on voltage regulation. Voltage = 395 KV
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	26-02-2024	12:34:00	26-02-2024	17:07:00	0.19	0.00	0.00	0.00	4.55		* BR Opened on Voltage Regulation Voltage 395 K
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	05-02-2024	10:09:00	05-02-2024	17:32:00	0.31	0.00	0.00	0.00	7.38		* BR opened on voltage regulation. V=386kV
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	27-02-2024	09:42:00	27-02-2024	17:12:00	0.31	0.00	0.00	0.00	7.50		* BR opened on voltage regulation Voltage 395 KV
BSR	80MVAR,BUS REACTOR-1 AT BHNIMMAL	SVRD	28-02-2024	08:07:00	28-02-2024	18:41:00	0.44	0.00	0.00	0.00	10.57		* BR opened on voltage regulation. Voltage=396KV.
							12.09	0.00	0.00	0.00	290.67	100.00	
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	26-02-2024	12:35:00	26-02-2024	15:54:00	0.14	0.00	0.00	0.00	3.32		* BR opened on voltage regulation Voltage 395 KV NR2402-9292
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	20-02-2024	10:41:00	20-02-2024	16:56:00	0.26	0.00	0.00	0.00	6.25		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	22-02-2024	10:22:00	22-02-2024	17:42:00	0.31	0.00	0.00	0.00	7.33		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	17-02-2024	10:34:00	17-02-2024	18:33:00	0.33	0.00	0.00	0.00	7.98		* BR Opened on Voltage Regulation Voltage 395 Kv
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	23-02-2024	09:48:00	23-02-2024	17:25:00	0.32	0.00	0.00	0.00	7.62		* BR opened on voltage regulation. Voltage = 395 KV
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	05-02-2024	11:18:00	05-02-2024	16:19:00	0.21	0.00	0.00	0.00	5.02		* Reactor opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	07-02-2024	10:58:00	07-02-2024	17:56:00	0.29	0.00	0.00	0.00	6.97		* BR opened on voltage regulation. Voltage=395KV.
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	16-02-2024	11:14:00	16-02-2024	16:28:00	0.22	0.00	0.00	0.00	5.23		* BR opened on voltage regulation. V=392kV

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	24-02-2024	10:19:00	24-02-2024	16:17:00	0.25	0.00	0.00	0.00	5.97		* BR opened on voltage regulation. Voltage-394KV.
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	13-02-2024	09:54:00	13-02-2024	13:40:00	0.16	0.00	0.00	0.00	3.77		* BR opened on voltage regulation Voltage 395 kV
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	09-02-2024	10:54:00	09-02-2024	17:29:00	0.27	0.00	0.00	0.00	6.58		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	10-02-2024	09:58:00	10-02-2024	17:31:00	0.32	0.00	0.00	0.00	7.55		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	25-02-2024	10:20:00	25-02-2024	16:28:00	0.26	0.00	0.00	0.00	6.13		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	06-02-2024	09:39:00	06-02-2024	21:03:00	0.48	0.00	0.00	0.00	11.40		* BR opened on voltage regulation. Voltage-390kV
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	27-02-2024	09:49:00	27-02-2024	16:16:00	0.27	0.00	0.00	0.00	6.45		* BR opened on voltage regulation. Voltage-392KV.
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	18-02-2024	09:55:00	18-02-2024	15:47:00	0.24	0.00	0.00	0.00	5.87		* BR opened on voltage regulation. V-382kV
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	19-02-2024	09:51:00	19-02-2024	15:17:00	0.23	0.00	0.00	0.00	5.43		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	21-02-2024	10:12:00	21-02-2024	17:22:00	0.30	0.00	0.00	0.00	7.17		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	29-02-2024	10:28:00	29-02-2024	13:44:00	0.14	0.00	0.00	0.00	3.27		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT BIKANER	SVRD	28-02-2024	10:09:00	28-02-2024	17:52:00	0.32	0.00	0.00	0.00	7.72		* BR opened on voltage regulation. Voltage-395 KV.
							5.32	0.00	0.00	0.00	127.03	100.00	
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	27-02-2024	09:45:00	27-02-2024	16:15:00	0.27	0.00	0.00	0.00	6.50		* BR opened on voltage regulation. Voltage-760KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	24-02-2024	09:49:00	24-02-2024	16:24:00	0.27	0.00	0.00	0.00	6.58		* BR opened on voltage regulation. Voltage-762KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	11-02-2024	09:37:00	11-02-2024	16:26:00	0.28	0.00	0.00	0.00	6.82		* BR opened on voltage regulation. Voltage-760KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	20-02-2024	10:34:00	20-02-2024	16:20:00	0.24	0.00	0.00	0.00	5.77		* BR opened on voltage regulation. Voltage-754KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	22-02-2024	10:19:00	22-02-2024	16:37:00	0.26	0.00	0.00	0.00	6.30		* BR opened on voltage regulation. Voltage-755 KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	28-02-2024	10:22:00	28-02-2024	15:19:00	0.21	0.00	0.00	0.00	4.95		* BR opened on voltage regulation. Voltage-760KV
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	29-02-2024	09:25:00	29-02-2024	16:24:00	0.29	0.00	0.00	0.00	6.98		* BR opened on voltage regulation Voltage 755kv
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	08-02-2024	10:39:00	08-02-2024	16:05:00	0.23	0.00	0.00	0.00	5.43		* BR opened on voltage regulation. Voltage 755 KV
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	01-02-2024	10:32:00	01-02-2024	15:41:00	0.22	0.00	0.00	0.00	5.15		* BR opened on voltage regulation. Voltage-756KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	09-02-2024	10:46:00	09-02-2024	21:51:00	0.46	0.00	0.00	0.00	11.08		* BR opened on voltage regulation Voltage-755 KV
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	14-02-2024	09:55:00	14-02-2024	16:32:00	0.28	0.00	0.00	0.00	6.62		* BR opened on voltage regulation. Voltage-760KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	19-02-2024	09:47:00	19-02-2024	15:15:00	0.23	0.00	0.00	0.00	5.47		* BR opened on voltage regulation. Voltage-754KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	13-02-2024	10:24:00	13-02-2024	16:18:00	0.25	0.00	0.00	0.00	5.90		* BR opened on voltage regulation. Voltage-756KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	06-02-2024	09:38:00	06-02-2024	16:41:00	0.29	0.00	0.00	0.00	7.05		* BR opened on voltage regulation. Voltage=750KV
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	25-02-2024	09:58:00	25-02-2024	16:11:00	0.26	0.00	0.00	0.00	6.22		* BR opened on voltage regulation. Voltage-755 KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	23-02-2024	09:45:00	23-02-2024	16:48:00	0.29	0.00	0.00	0.00	7.05		* BR opened on voltage regulation. V-765kV
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	10-02-2024	10:24:00	10-02-2024	17:21:00	0.29	0.00	0.00	0.00	6.95		* Reactor opened on voltage regulation Voltage 755 KV
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	12-02-2024	09:49:00	12-02-2024	17:16:00	0.31	0.00	0.00	0.00	7.45		* BR opened on voltage regulation. Voltage-760KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	21-02-2024	09:53:00	21-02-2024	16:18:00	0.27	0.00	0.00	0.00	6.42		* BR opened on voltage regulation Voltage 755 KV NR 2402-9285 /3514
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	18-02-2024	09:39:00	18-02-2024	15:53:00	0.26	0.00	0.00	0.00	6.23		* BR opened on voltage regulation. Voltage-756KV.
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	07-02-2024	09:54:00	07-02-2024	17:05:00	0.30	0.00	0.00	0.00	7.18		* BR opened on voltage regulation.Voltage-755 kV
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	16-02-2024	09:19:00	16-02-2024	16:24:00	0.30	0.00	0.00	0.00	7.08		* BR Opened on Voltage Regulation Voltage 755 KV
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	15-02-2024	10:24:00	15-02-2024	16:27:00	0.25	0.00	0.00	0.00	6.05		* BR opened on voltage regulation. V-753kV
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	17-02-2024	09:38:00	17-02-2024	16:20:00	0.28	0.00	0.00	0.00	6.70		* BR opened on voltage regulation Voltage 795 kV
BSR	330MVAR,BUS REACTOR-1 AT BIKANER	SVRD	05-02-2024	10:40:00	05-02-2024	15:35:00	0.21	0.00	0.00	0.00	4.92		* BR opened on voltage regulation. Voltage-755KV.
							6.80	0.00	0.00	0.00	162.85	100.00	
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	28-02-2024	11:19:00	28-02-2024	13:40:00	0.10	0.00	0.00	0.00	2.35		* BR opened on voltage regulation Voltage 395 kV
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	13-02-2024	10:45:00	13-02-2024	13:14:00	0.10	0.00	0.00	0.00	2.48		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	05-02-2024	10:46:00	05-02-2024	13:19:00	0.11	0.00	0.00	0.00	2.55		* BR opened on voltage regulation. V-382kV
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	18-02-2024	09:48:00	18-02-2024	15:42:00	0.25	0.00	0.00	0.00	5.90		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	09-02-2024	10:59:00	09-02-2024	18:01:00	0.29	0.00	0.00	0.00	7.03		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	20-02-2024	10:51:00	20-02-2024	16:43:00	0.24	0.00	0.00	0.00	5.87		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	15-02-2024	11:48:00	15-02-2024	16:48:00	0.21	0.00	0.00	0.00	5.00		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	23-02-2024	11:25:00	23-02-2024	14:09:00	0.11	0.00	0.00	0.00	2.73		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	14-02-2024	11:24:00	14-02-2024	16:18:00	0.20	0.00	0.00	0.00	4.90		* BR Opened on Voltage Regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	07-02-2024	11:01:00	07-02-2024	17:58:00	0.29	0.00	0.00	0.00	6.95		* BR opened on voltage regulation. Voltage-394KV.
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	10-02-2024	10:33:00	10-02-2024	15:24:00	0.20	0.00	0.00	0.00	4.85		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	19-02-2024	10:26:00	19-02-2024	15:23:00	0.21	0.00	0.00	0.00	4.95		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	01-02-2024	11:06:00	01-02-2024	15:45:00	0.19	0.00	0.00	0.00	4.65		* BR opened on voltage regulation. Voltage-402KV.
							2.50	0.00	0.00	0.00	60.21	100.00	
BSR	240MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	18-02-2024	10:51:00	18-02-2024	13:43:00	0.12	0.00	0.00	0.00	2.87		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT CHITTORGARH	SVRD	23-02-2024	11:39:00	23-02-2024	14:30:00	0.12	0.00	0.00	0.00	2.85		* BR opened on voltage regulation. Voltage-755KV.
							0.24	0.00	0.00	0.00	5.72	100.00	
BSR	80MVAR,BUS REACTOR-1 AT DEHRADUN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT DWARKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT FATEHGARH-2	SVRD	19-02-2024	07:15:00	29-02-2024	23:59:59	10.70	0.00	0.00	0.00	256.75		* BR opened on voltage regulation Voltage 395 KV
							10.70	0.00	0.00	0.00	256.75	100.00	
BSR	240MVAR,BUS REACTOR-1 AT FATEHGARH-2	SVRD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00		* BR opened on voltage regulation. Voltage-760KV.
							29.00	0.00	0.00	0.00	696.00	100.00	

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR,BUS REACTOR-1 AT JHATIKARA	SVRD	27-02-2024	10:43:00	27-02-2024	15:04:00	0.18	0.00	0.00	0.00	4.35		* BR Opened on Voltage Regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT JHATIKARA	SVRD	26-02-2024	10:17:00	26-02-2024	15:23:00	0.21	0.00	0.00	0.00	5.10		* BR opened on voltage regulation. Voltage-754KV.
BSR	240MVAR,BUS REACTOR-1 AT JHATIKARA	SVRD	25-02-2024	10:16:00	25-02-2024	16:42:00	0.27	0.00	0.00	0.00	6.43		* BR opened on voltage regulation. Voltage-760KV
BSR	240MVAR,BUS REACTOR-1 AT JHATIKARA	SVRD	20-02-2024	09:47:00	20-02-2024	13:28:00	0.15	0.00	0.00	0.00	3.68		* BR opened on voltage regulation. Voltage-756KV.
BSR	240MVAR,BUS REACTOR-1 AT JHATIKARA	SVRD	23-02-2024	10:06:00	23-02-2024	15:51:00	0.24	0.00	0.00	0.00	5.75		* BR opened on voltage regulation Voltage 755 KV
							1.78	0.00	0.00	0.00	42.96	100.00	
BSR	240MVAR,BUS REACTOR-2 AT JHATIKARA	SVRD	29-02-2024	09:38:00	29-02-2024	13:12:00	0.15	0.00	0.00	0.00	3.57		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR,BUS REACTOR-2 AT JHATIKARA	SVRD	28-02-2024	10:33:00	28-02-2024	13:18:00	0.12	0.00	0.00	0.00	2.75		* BR opened on voltage regulation. Voltage=760KV
BSR	240MVAR,BUS REACTOR-2 AT JHATIKARA	SVRD	12-02-2024	09:27:00	12-02-2024	22:24:00	0.54	0.00	0.00	0.00	12.95		* BR opened on voltage regulation. Voltage 755 KV
BSR	240MVAR,BUS REACTOR-2 AT JHATIKARA	SVRD	17-02-2024	09:47:00	17-02-2024	15:24:00	0.23	0.00	0.00	0.00	5.62		* BR opened on voltage regulation Voltage 795 kV
BSR	240MVAR,BUS REACTOR-2 AT JHATIKARA	SVRD	21-02-2024	09:58:00	21-02-2024	13:00:00	0.13	0.00	0.00	0.00	3.03		* BR opened on voltage regulation. Voltage-755KV.
BSR	240MVAR,BUS REACTOR-2 AT JHATIKARA	SVRD	14-02-2024	10:36:00	14-02-2024	15:18:00	0.20	0.00	0.00	0.00	4.70		* BR opened on voltage regulation. Voltage-755KV.
							1.37	0.00	0.00	0.00	32.62	100.00	
BSR	125MVAR,BUS REACTOR-1 AT JIND			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	25MVAR,BUS REACTOR-2 AT JIND			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT KANKROLI	SCSD	22-02-2024	09:40:00	23-02-2024	07:02:00	0.89	0.00	0.00	0.00	21.37		* For Stability testing of existing bay No. 401 and 402 after replacement of Bay equipment (CT).
BSR	125MVAR,BUS REACTOR-1 AT KANKROLI	SVRD	27-02-2024	18:49:00	29-02-2024	20:13:00	2.06	0.00	0.00	0.00	49.40		* BR opened on voltage regulation.Voltage-400KV. NR2402-9511
BSR	125MVAR,BUS REACTOR-1 AT KANKROLI	SVRD	23-02-2024	07:02:00	23-02-2024	18:06:00	0.46	0.00	0.00	0.00	11.07		* BR opened on voltage regulation. Voltage-402KV.
BSR	125MVAR,BUS REACTOR-1 AT KANKROLI	SVRD	15-02-2024	10:47:00	15-02-2024	17:05:00	0.26	0.00	0.00	0.00	6.30		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT KANKROLI	SVRD	16-02-2024	08:23:00	16-02-2024	17:32:00	0.38	0.00	0.00	0.00	9.15		* BR opened on voltage regulation. Voltage-395KV.
							4.05	0.00	0.00	0.00	97.29	100.00	
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	02-02-2024	09:05:00	02-02-2024	16:45:00	0.32	0.00	0.00	0.00	7.67		* BR opened on voltage regulation. Voltage-390KV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	06-02-2024	11:05:00	06-02-2024	21:18:00	0.43	0.00	0.00	0.00	10.22		* BR opened on voltage regulation. Voltage 395 KV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	05-02-2024	10:15:00	05-02-2024	16:32:00	0.26	0.00	0.00	0.00	6.28		* BR opened on voltage regulation Voltage 395 kV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	22-02-2024	09:26:00	22-02-2024	17:06:00	0.32	0.00	0.00	0.00	7.67		
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	24-02-2024	08:39:00	24-02-2024	18:04:00	0.39	0.00	0.00	0.00	9.42		* BR opened on voltage regulation.Voltage-396kV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	27-02-2024	10:34:00	27-02-2024	17:10:00	0.28	0.00	0.00	0.00	6.60		* BR opened on voltage regulation. V-397kV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	09-02-2024	10:42:00	15-02-2024	21:16:00	6.44	0.00	0.00	0.00	154.57		* BR opened on voltage regulation. Voltage=395kV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	25-02-2024	10:34:00	25-02-2024	16:38:00	0.25	0.00	0.00	0.00	6.07		* Bus Reactor opened on voltage regulation. Voltage 395 KV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	07-02-2024	09:26:00	07-02-2024	18:07:00	0.36	0.00	0.00	0.00	8.68		* Reactor opened on voltage regulation Voltage 395 KV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	03-02-2024	09:28:00	03-02-2024	16:44:00	0.30	0.00	0.00	0.00	7.27		* BR opened on voltage regulation. V-382kV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	04-02-2024	09:49:00	04-02-2024	15:10:00	0.22	0.00	0.00	0.00	5.35		* BR opened on voltage regulation.Voltage-396kV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	08-02-2024	09:32:00	08-02-2024	21:58:00	0.52	0.00	0.00	0.00	12.43		* BR opened on voltage regulation. V-390kV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	20-02-2024	09:31:00	20-02-2024	17:15:00	0.32	0.00	0.00	0.00	7.73		* BR Opened on Voltage Regulation Voltage 395 KV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	19-02-2024	10:15:00	19-02-2024	15:26:00	0.22	0.00	0.00	0.00	5.18		* BR opened on voltage regulation Voltage 395 KV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	21-02-2024	09:41:00	21-02-2024	19:05:00	0.39	0.00	0.00	0.00	9.40		* BR opened on voltage regulation. V-394kV
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	23-02-2024	08:06:00	23-02-2024	18:13:00	0.42	0.00	0.00	0.00	10.12		* BR opened on voltage regulation. Voltage-400KV.
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	28-02-2024	09:37:00	29-02-2024	20:12:00	1.44	0.00	0.00	0.00	34.58		* BR opened on voltage regulation. Voltage-400KV.
BSR	50MVAR,BUS REACTOR-2 AT KANKROLI	SVRD	29-02-2024	09:37:00	29-02-2024	20:12:00	0.44	0.00	0.00	0.00	10.58		* BR opened on voltage regulation Voltage 395 KV NR2402-9289
							13.32	0.00	0.00	0.00	319.82	100.00	
BSR	125MVAR,BUS REACTOR-1 AT KOTESHWAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT KOTESHWAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	28-02-2024	11:03:00	28-02-2024	16:38:00	0.23	0.00	0.00	0.00	5.58		* BR opened on voltage regulation Voltage 395 kV
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	29-02-2024	09:30:00	29-02-2024	16:08:00	0.28	0.00	0.00	0.00	6.63		* BR opened on voltage regulation. Voltage-394KV.
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	14-02-2024	09:30:00	14-02-2024	18:41:00	0.38	0.00	0.00	0.00	9.18		* BR opened on voltage regulation. V-392kV
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	21-02-2024	11:20:00	21-02-2024	16:39:00	0.22	0.00	0.00	0.00	5.32		* Reactor opened on voltage regulation Voltage 395 KV.
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	20-02-2024	10:54:00	20-02-2024	16:54:00	0.25	0.00	0.00	0.00	6.00		* BR opened on voltage regulation. Voltage-395 KV.
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	16-02-2024	10:33:00	16-02-2024	16:53:00	0.26	0.00	0.00	0.00	6.33		* BR opened on voltage regulation. Voltage-395 KV.
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	11-02-2024	10:21:00	11-02-2024	15:27:00	0.21	0.00	0.00	0.00	5.10		* BR opened on voltage regulation. Voltage-391KV.
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	06-02-2024	11:14:00	06-02-2024	17:02:00	0.24	0.00	0.00	0.00	5.80		* BR opened on voltage regulation. Voltage-394KV.
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	13-02-2024	09:33:00	13-02-2024	16:45:00	0.30	0.00	0.00	0.00	7.20		* BR opened on voltage regulation. Voltage-394KV.
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	23-02-2024	09:21:00	23-02-2024	18:12:00	0.37	0.00	0.00	0.00	8.85		* BR Opened on Voltage Regulation Voltage 395 KV
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	15-02-2024	10:06:00	15-02-2024	17:35:00	0.31	0.00	0.00	0.00	7.48		* BR opened on voltage regulation. Voltage 395 KV
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	12-02-2024	10:52:00	12-02-2024	17:07:00	0.26	0.00	0.00	0.00	6.25		* BR opened on voltage regulation.Voltage-396kV
BSR	80MVAR,BUS REACTOR-1 AT KOTA	SVRD	22-02-2024	10:19:00	22-02-2024	21:42:00	0.47	0.00	0.00	0.00	11.38		* BR opened on voltage regulation.Voltage-395 kV
							3.78	0.00	0.00	0.00	91.10	100.00	
BSR	50MVAR,BUS REACTOR-2 AT KOTA	SVRD	23-02-2024	09:20:00	23-02-2024	18:14:00	0.37	0.00	0.00	0.00	8.90		
BSR	50MVAR,BUS REACTOR-2 AT KOTA	SVRD	21-02-2024	11:26:00	21-02-2024	16:39:00	0.22	0.00	0.00	0.00	5.22		* BR opened on voltage regulation Voltage 395 kV
BSR	50MVAR,BUS REACTOR-2 AT KOTA	SVRD	22-02-2024	10:19:00	22-02-2024	21:43:00	0.48	0.00	0.00	0.00	11.40		* BR opened on voltage regulation. V-390kV
BSR	50MVAR,BUS REACTOR-2 AT KOTA	SVRD	11-02-2024	10:22:00	11-02-2024	15:27:00	0.21	0.00	0.00	0.00	5.08		* BR opened on voltage regulation. Voltage-394KV.

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	14-02-2024	09:30:00	14-02-2024	18:42:00	0.38	0.00	0.00	0.00	9.20		* BR opened on voltage regulation. Voltage-391KV.
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	16-02-2024	10:34:00	16-02-2024	16:52:00	0.26	0.00	0.00	0.00	6.30		* Reactor opened on voltage regulation Voltage 395 KV
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	20-02-2024	10:53:00	20-02-2024	16:54:00	0.25	0.00	0.00	0.00	6.02		* BR opened on voltage regulation.Voltage-395 KV
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	15-02-2024	10:05:00	15-02-2024	17:36:00	0.31	0.00	0.00	0.00	7.52		* BR opened on voltage regulation. Voltage-395 KV.
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	13-02-2024	09:33:00	13-02-2024	16:45:00	0.30	0.00	0.00	0.00	7.20		* BR opened on voltage regulation.Voltage-396KV
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	04-02-2024	09:48:00	04-02-2024	14:26:00	0.19	0.00	0.00	0.00	4.63		* BR Opened on Voltage Regulation Voltage 395 KV
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	04-02-2024	09:48:00	04-02-2024	14:26:00	0.19	0.00	0.00	0.00	4.63		* BR opened on voltage regulation. Voltage-394KV.
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	29-02-2024	09:30:00	29-02-2024	16:11:00	0.28	0.00	0.00	0.00	6.68		* BR opened on voltage regulation. Voltage 395 KV
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	28-02-2024	11:01:00	28-02-2024	16:38:00	0.23	0.00	0.00	0.00	5.62		* BR opened on voltage regulation. Voltage-395 KV.
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	06-02-2024	11:16:00	06-02-2024	17:14:00	0.25	0.00	0.00	0.00	5.97		* Bus Reactor opened on voltage regulation. Voltage 395 KV
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	12-02-2024	11:13:00	12-02-2024	17:07:00	0.25	0.00	0.00	0.00	5.90		* Bus Reactor opened on voltage regulation. Voltage 395 KV
							4.17	0.00	0.00	0.00	100.27	100.00	
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	07-02-2024	07:45:00	07-02-2024	17:49:00	0.42	0.00	0.00	0.00	10.07		* BR opened on voltage regulation. Voltage-395KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	26-02-2024	09:54:00	26-02-2024	15:41:00	0.24	0.00	0.00	0.00	5.78		* BR opened on voltage regulation Voltage 395 Kv
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	06-02-2024	09:51:00	06-02-2024	20:46:00	0.46	0.00	0.00	0.00	10.92		* BR opened on voltage regulation. V-398kV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	17-02-2024	10:07:00	17-02-2024	18:29:00	0.35	0.00	0.00	0.00	8.37		* BR opened on voltage regulation Voltage 395 KV NR2402-9297
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	11-02-2024	08:26:00	11-02-2024	15:26:00	0.29	0.00	0.00	0.00	7.00		* BR opened on voltage regulation. Voltage-395KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	22-02-2024	12:02:00	22-02-2024	17:37:00	0.23	0.00	0.00	0.00	5.58		* BR opened on voltage regulation. Voltage-395 KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	19-02-2024	09:56:00	19-02-2024	13:15:00	0.14	0.00	0.00	0.00	3.32		* BR opened on voltage regulation Voltage 395 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	13-02-2024	08:45:00	13-02-2024	16:23:00	0.32	0.00	0.00	0.00	7.63		* BR opened on voltage regulation. V-392kV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	27-02-2024	09:59:00	27-02-2024	15:42:00	0.24	0.00	0.00	0.00	5.72		* BR opened on voltage regulation. Voltage-420KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	18-02-2024	09:44:00	18-02-2024	15:36:00	0.24	0.00	0.00	0.00	5.87		* BR opened on voltage regulation.Voltage-396KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	03-02-2024	09:11:00	03-02-2024	15:00:00	0.24	0.00	0.00	0.00	5.82		* BR opened on voltage regulation. Voltage-395KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	02-02-2024	09:03:00	02-02-2024	15:21:00	0.26	0.00	0.00	0.00	6.30		* BR opened on voltage regulation. Voltage=390KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	20-02-2024	08:51:00	20-02-2024	16:38:00	0.32	0.00	0.00	0.00	7.78		* Reactor opened on voltage regulation Voltage 395 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	05-02-2024	10:07:00	05-02-2024	13:18:00	0.13	0.00	0.00	0.00	3.18		* BR opened on voltage regulation. Voltage = 395 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	16-02-2024	08:07:00	16-02-2024	17:24:00	0.39	0.00	0.00	0.00	9.28		* BR opened on voltage regulation. Voltage-402KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	12-02-2024	09:21:00	12-02-2024	17:14:00	0.33	0.00	0.00	0.00	7.88		* BR opened on voltage regulation. V-382kV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	25-02-2024	09:40:00	25-02-2024	16:03:00	0.27	0.00	0.00	0.00	6.38		* BR opened on voltage regulation. Voltage-400KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	21-02-2024	09:21:00	21-02-2024	16:26:00	0.30	0.00	0.00	0.00	7.08		* BR opened on voltage regulation. V-395kV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	10-02-2024	07:15:00	10-02-2024	17:09:00	0.41	0.00	0.00	0.00	9.90		* BR opened on voltage regulation. Voltage=395kV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	LVRD	04-02-2024	09:34:00	04-02-2024	14:42:00	0.21	0.00	0.00	0.00	5.13		* Bus Reactor opened on voltage regulation. Voltage 395 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	24-02-2024	08:35:00	24-02-2024	16:33:00	0.33	0.00	0.00	0.00	7.97		* BR opened on voltage regulation Voltage 395 kv
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	28-02-2024	09:32:00	28-02-2024	17:01:00	0.31	0.00	0.00	0.00	7.48		* BR opened on voltage regulation. Voltage-400KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	29-02-2024	09:28:00	29-02-2024	17:54:00	0.35	0.00	0.00	0.00	8.43		* BR opened on voltage regulation.Voltage-396KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	15-02-2024	07:50:00	15-02-2024	21:16:00	0.56	0.00	0.00	0.00	13.43		* BR opened on voltage regulation. Voltage-395 KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	08-02-2024	07:53:00	08-02-2024	21:35:00	0.57	0.00	0.00	0.00	13.70		* BR opened on voltage regulation. Voltage-395KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	14-02-2024	07:28:00	14-02-2024	18:58:00	0.48	0.00	0.00	0.00	11.50		* BR Opened on Voltage Regulation Voltage 395 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	09-02-2024	10:42:00	09-02-2024	20:58:00	0.43	0.00	0.00	0.00	10.27		* BR opened on voltage regulation. Voltage-402KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	23-02-2024	08:02:00	23-02-2024	17:10:00	0.38	0.00	0.00	0.00	9.13		
							9.20	0.00	0.00	0.00	220.90	100.00	
BSR	125MVAR.BUS REACTOR-1 AT KURUKSHETRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR.BUS REACTOR-1 AT MANDOLA	SVRD	23-02-2024	11:53:00	23-02-2024	17:39:00	0.24	0.00	0.00	0.00	5.77		* BR opened on voltage regulation. Voltage-395KV.
							0.24	0.00	0.00	0.00	5.77	100.00	
BSR	125MVAR.BUS REACTOR-2 AT MANDOLA	OSFT	17-02-2024	12:54:00	17-02-2024	18:41:00	0.24	5.78	0.00	0.00	0.00		* Forced S/D to attend/ check isolator alignment issue in 42689A
BSR	125MVAR.BUS REACTOR-2 AT MANDOLA	SVRD	23-02-2024	11:33:00	23-02-2024	18:00:00	0.27	0.00	0.00	0.00	6.45		* BR opened on voltage regulation. V-392kV
							0.51	5.78	0.00	0.00	6.45	99.17	
BSR	25MVAR.BUS REACTOR-3 AT MANDOLA	OSPT	24-02-2024	10:10:00	24-02-2024	18:41:00	0.36	8.52	0.00	0.00	0.00		* BR opened on voltage regulation. Voltage-395KV.
BSR	25MVAR.BUS REACTOR-3 AT MANDOLA	SVRD	23-02-2024	11:53:00	23-02-2024	17:39:00	0.24	0.00	0.00	0.00	5.77		* Shutdown for Annual Maintenance Planned works.
							0.60	8.52	0.00	0.00	5.77	98.78	
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	24-02-2024	09:34:00	24-02-2024	16:23:00	0.28	0.00	0.00	0.00	6.82		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	26-02-2024	09:34:00	26-02-2024	15:28:00	0.25	0.00	0.00	0.00	5.90		* BR opened on voltage regulation.Voltage-396KV
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	13-02-2024	10:32:00	13-02-2024	16:25:00	0.25	0.00	0.00	0.00	5.88		* BR opened on voltage regulation. Voltage=395KV
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	21-02-2024	11:13:00	21-02-2024	13:04:00	0.08	0.00	0.00	0.00	1.85		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	23-02-2024	11:14:00	23-02-2024	17:13:00	0.25	0.00	0.00	0.00	5.98		* BR opened on voltage regulation. Voltage-393KV.
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	18-02-2024	10:45:00	18-02-2024	14:44:00	0.17	0.00	0.00	0.00	3.98		* BR opened on voltage regulation.Voltage-396KV
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	19-02-2024	10:02:00	19-02-2024	13:12:00	0.13	0.00	0.00	0.00	3.17		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	29-02-2024	10:12:00	29-02-2024	13:15:00	0.13	0.00	0.00	0.00	3.05		* BR opened on voltage regulation. Voltage-393KV.
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	03-02-2024	09:34:00	03-02-2024	13:21:00	0.16	0.00	0.00	0.00	3.78		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	02-02-2024	09:59:00	02-02-2024	15:32:00	0.23	0.00	0.00	0.00	5.55		* BR opened on voltage regulation.Voltage-395 kv
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	01-02-2024	11:43:00	01-02-2024	15:40:00	0.17	0.00	0.00	0.00	3.95		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	06-02-2024	09:47:00	06-02-2024	16:45:00	0.29	0.00	0.00	0.00	6.97		* BR opened on voltage regulation. Voltage-394KV.
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	22-02-2024	10:13:00	22-02-2024	17:27:00	0.30	0.00	0.00	0.00	7.23		* BR opened on voltage regulation. V-394kV
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	14-02-2024	07:57:00	14-02-2024	13:29:00	0.23	0.00	0.00	0.00	5.53		* BR opened on voltage regulation. Voltage-392KV.

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-1 AT MANESAR	SVRD	08-02-2024	10:52:00	10-02-2024	21:24:00	2.44	0.00	0.00	0.00	58.53		* Reactor opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-1 AT MANESAR	SVRD	15-02-2024	09:29:00	15-02-2024	16:55:00	0.31	0.00	0.00	0.00	7.43		* BR opened on voltage regulation. Voltage-395KV
BSR	125MVAR,BUS REACTOR-1 AT MANESAR	SVRD	16-02-2024	10:26:00	16-02-2024	17:05:00	0.28	0.00	0.00	0.00	6.65		* BR opened on voltage regulation. Voltage=395KV
BSR	125MVAR,BUS REACTOR-1 AT MANESAR	SVRD	11-02-2024	09:53:00	11-02-2024	15:37:00	0.24	0.00	0.00	0.00	5.73		* BR opened on voltage regulation. V-398kV
							6.19	0.00	0.00	0.00	147.98	100.00	
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	13-02-2024	10:34:00	13-02-2024	16:07:00	0.23	0.00	0.00	0.00	5.55		* BR opened on voltage regulation. Voltage-394KV.
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	26-02-2024	09:58:00	26-02-2024	15:38:00	0.24	0.00	0.00	0.00	5.67		* BR opened on voltage regulation. Voltage-392KV.
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	06-02-2024	09:47:00	06-02-2024	16:50:00	0.29	0.00	0.00	0.00	7.05		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	29-02-2024	10:23:00	29-02-2024	13:20:00	0.12	0.00	0.00	0.00	2.95		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	14-02-2024	08:06:00	14-02-2024	16:02:00	0.33	0.00	0.00	0.00	7.93		* BR opened on voltage regulation. V-395kV
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	15-02-2024	10:04:00	15-02-2024	21:23:00	0.47	0.00	0.00	0.00	11.32		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	24-02-2024	09:40:00	24-02-2024	16:36:00	0.29	0.00	0.00	0.00	6.93		* BR opened on voltage regulation. Voltage-394KV.
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	09-02-2024	12:23:00	09-02-2024	21:50:00	0.39	0.00	0.00	0.00	9.45		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	22-02-2024	09:33:00	22-02-2024	17:57:00	0.35	0.00	0.00	0.00	8.40		* BR opened on voltage regulation.Voltage-395 kV
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	16-02-2024	10:36:00	16-02-2024	17:18:00	0.28	0.00	0.00	0.00	6.70		* BR opened on voltage regulation. Voltage = 395 KV
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	21-02-2024	11:25:00	21-02-2024	13:28:00	0.09	0.00	0.00	0.00	2.05		* Reactor opened on voltage regulation Voltage 395 KV
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	08-02-2024	10:57:00	08-02-2024	21:38:00	0.45	0.00	0.00	0.00	10.68		* BR opened on voltage regulation. Voltage-401KV.
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	11-02-2024	10:03:00	11-02-2024	15:17:00	0.22	0.00	0.00	0.00	5.23		* BR opened on voltage regulation. Voltage=395KV
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	01-02-2024	11:52:00	01-02-2024	15:42:00	0.16	0.00	0.00	0.00	3.83		* BR opened on voltage regulation. V-401kV
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	02-02-2024	10:09:00	02-02-2024	15:44:00	0.23	0.00	0.00	0.00	5.58		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR,BUS REACTOR-2 AT MANESAR	SVRD	03-02-2024	09:42:00	03-02-2024	15:13:00	0.23	0.00	0.00	0.00	5.52		* BR opened on voltage regulation. Voltage-394KV.
							4.37	0.00	0.00	0.00	104.84	100.00	
BSR	125MVAR,400kV BUS Reactor at MAHARANIBAG	OSFT	17-02-2024	15:55:00	17-02-2024	17:02:00	0.05	1.12	0.00	0.00	0.00		* Forced S/D to attend SF6 low alarm in Bushing compartment
							0.05	1.12	0.00	0.00	0.00	99.84	
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	28-02-2024	09:53:00	28-02-2024	13:33:00	0.15	0.00	0.00	0.00	3.67		* BR opened on voltage regulation. Voltage-756KV.
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	14-02-2024	09:24:00	14-02-2024	13:37:00	0.18	0.00	0.00	0.00	4.22		* BR opened on voltage regulation. Voltage-760KV.
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	13-02-2024	09:44:00	13-02-2024	16:34:00	0.29	0.00	0.00	0.00	6.83		* BR opened on voltage regulation. Voltage=760kV
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	25-02-2024	10:24:00	25-02-2024	15:26:00	0.21	0.00	0.00	0.00	5.03		* BR opened on voltage regulation. Voltage=765kV
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	16-02-2024	09:55:00	16-02-2024	15:15:00	0.22	0.00	0.00	0.00	5.33		* BR opened on voltage regulation.Voltage-755 kV
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	20-02-2024	09:31:00	20-02-2024	13:40:00	0.17	0.00	0.00	0.00	4.15		* BR opened on voltage regulation Voltage 795 kV
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	10-02-2024	10:31:00	10-02-2024	15:24:00	0.20	0.00	0.00	0.00	4.88		* BR opened on voltage regulation. Voltage-754KV.
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	18-02-2024	09:30:00	18-02-2024	14:38:00	0.21	0.00	0.00	0.00	5.13		* BR Opened on Voltage Regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	02-02-2024	10:33:00	02-02-2024	14:37:00	0.17	0.00	0.00	0.00	4.07		* BR opened on voltage regulation. Voltage-755 KV
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	17-02-2024	10:12:00	17-02-2024	15:24:00	0.22	0.00	0.00	0.00	5.20		* BR opened on voltage regulation. V-762kV
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	15-02-2024	10:09:00	15-02-2024	13:54:00	0.16	0.00	0.00	0.00	3.75		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	11-02-2024	09:37:00	11-02-2024	15:12:00	0.23	0.00	0.00	0.00	5.58		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	09-02-2024	10:35:00	09-02-2024	16:19:00	0.24	0.00	0.00	0.00	5.73		* BR opened on voltage regulation Voltage 755 KV NR 2402-9306 /3524
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	21-02-2024	09:46:00	21-02-2024	13:10:00	0.14	0.00	0.00	0.00	3.40		* BR opened on voltage regulation. Voltage=760kV
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	27-02-2024	10:13:00	27-02-2024	13:59:00	0.16	0.00	0.00	0.00	3.77		* BR opened on voltage regulation. Voltage-760KV.
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	08-02-2024	10:03:00	08-02-2024	13:58:00	0.16	0.00	0.00	0.00	3.92		* BR opened on voltage regulation. Voltage-760KV
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	26-02-2024	09:29:00	26-02-2024	15:14:00	0.24	0.00	0.00	0.00	5.75		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR,BUS REACTOR-1 AT MEERUT	SVRD	12-02-2024	09:26:00	12-02-2024	13:41:00	0.18	0.00	0.00	0.00	4.25		* BR opened on voltage regulation. Voltage-760KV.
							3.53	0.00	0.00	0.00	84.66	100.00	
BSR	50MVAR,BUS REACTOR-2 AT MEERUT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT MEERUT	SVRD	23-02-2024	11:56:00	23-02-2024	13:37:00	0.07	0.00	0.00	0.00	1.68		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-1 AT MEERUT	SVRD	25-02-2024	23:44:58	26-02-2024	16:26:00	0.70	0.00	0.00	0.00	16.68		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT MEERUT	SVRD	24-02-2024	09:37:00	24-02-2024	16:41:00	0.29	0.00	0.00	0.00	7.07		* BR opened on voltage regulation. Voltage-397KV.
BSR	125MVAR,BUS REACTOR-1 AT MEERUT	SVRD	27-02-2024	10:15:00	27-02-2024	13:54:00	0.15	0.00	0.00	0.00	3.65		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR,BUS REACTOR-1 AT MEERUT	SVRD	15-02-2024	10:12:00	15-02-2024	17:10:00	0.29	0.00	0.00	0.00	6.97		* BR opened on voltage regulation. Voltage-397KV.
BSR	125MVAR,BUS REACTOR-1 AT MEERUT	SVRD	14-02-2024	11:07:00	14-02-2024	14:00:00	0.12	0.00	0.00	0.00	2.88		* BR opened on voltage regulation. Voltage-392KV.
BSR	125MVAR,BUS REACTOR-1 AT MEERUT	SVRD	16-02-2024	09:57:00	16-02-2024	13:45:00	0.16	0.00	0.00	0.00	3.80		* BR opened on voltage regulation Voltage 390 KV NR2402-9303
BSR	125MVAR,BUS REACTOR-1 AT MEERUT	SVRD	10-02-2024	11:15:00	10-02-2024	15:37:00	0.18	0.00	0.00	0.00	4.37		* BR opened on voltage regulation.Voltage-396kV
							1.96	0.00	0.00	0.00	47.10	100.00	
BSR	50MVAR,BUS REACTOR-1 AT MURADNAGAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT NEEMRANA	SVRD	03-02-2024	09:53:00	03-02-2024	13:32:00	0.15	0.00	0.00	0.00	3.65		* BR opened on voltage regulation.Voltage-396kV
BSR	80MVAR,BUS REACTOR-1 AT NEEMRANA	SVRD	15-02-2024	11:30:00	15-02-2024	17:36:00	0.25	0.00	0.00	0.00	6.10		* BR opened on voltage regulation. Voltage=395KV
BSR	80MVAR,BUS REACTOR-1 AT NEEMRANA	SVRD	13-02-2024	10:28:00	13-02-2024	16:23:00	0.25	0.00	0.00	0.00	5.92		* BR opened on voltage regulation. V-403kV
BSR	80MVAR,BUS REACTOR-1 AT NEEMRANA	SVRD	11-02-2024	10:13:00	11-02-2024	15:36:00	0.22	0.00	0.00	0.00	5.38		* BR opened on voltage regulation. Voltage-395 KV.
BSR	80MVAR,BUS REACTOR-1 AT NEEMRANA	SVRD	09-02-2024	10:56:00	09-02-2024	21:53:00	0.46	0.00	0.00	0.00	10.95		* BR opened on voltage regulation.Voltage-396kV.
BSR	80MVAR,BUS REACTOR-1 AT NEEMRANA	SVRD	08-02-2024	10:55:00	08-02-2024	15:52:00	0.21	0.00	0.00	0.00	4.95		* BR opened on voltage regulation. Voltage-395 KV.
BSR	80MVAR,BUS REACTOR-1 AT NEEMRANA	SVRD	19-02-2024	10:04:00	19-02-2024	13:08:00	0.13	0.00	0.00	0.00	3.07		* BR opened on voltage regulation Voltage 395 KV
BSR	80MVAR,BUS REACTOR-1 AT NEEMRANA	SVRD	14-02-2024	08:39:00	14-02-2024	16:14:00	0.32	0.00	0.00	0.00	7.58		* BR opened on voltage regulation.Voltage-396kV
BSR	80MVAR,BUS REACTOR-1 AT NEEMRANA	SVRD	02-02-2024	10:07:00	02-02-2024	15:33:00	0.23	0.00	0.00	0.00	5.43		* BR opened on voltage regulation. Voltage-395KV.

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR,BUS REACTOR-1 AT NEEMRANA	SVRD	10-02-2024	09:16:00	10-02-2024	15:32:00	0.26	0.00	0.00	0.00	6.27		* BR opened on voltage regulation.Voltage-396kV
BSR	80MVAR,BUS REACTOR-1 AT NEEMRANA	SVRD	16-02-2024	11:26:00	16-02-2024	17:21:00	0.25	0.00	0.00	0.00	5.92		* BR opened on voltage regulation.Voltage-395 kV
							2.73	0.00	0.00	0.00	65.22	100.00	
BSR	125MVAR,BUS REACTOR-1 AT RATANGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT ROORKEE	SVRD	18-02-2024	10:36:00	18-02-2024	15:58:00	0.22	0.00	0.00	0.00	5.37		* BR opened on voltage regulation.Voltage-395 kV
BSR	125MVAR,BUS REACTOR-1 AT ROORKEE	SVRD	08-02-2024	11:01:00	08-02-2024	21:51:00	0.45	0.00	0.00	0.00	10.83		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT ROORKEE	SVRD	12-02-2024	10:54:00	12-02-2024	13:26:00	0.11	0.00	0.00	0.00	2.53		* BR opened on voltage regulation.Voltage 395 KV NR2402-9307
BSR	125MVAR,BUS REACTOR-1 AT ROORKEE	SVRD	27-02-2024	10:24:00	27-02-2024	14:49:00	0.18	0.00	0.00	0.00	4.42		* BR opened on voltage regulation. Voltage-394KV.
BSR	125MVAR,BUS REACTOR-1 AT ROORKEE	SVRD	24-02-2024	09:52:00	24-02-2024	18:01:00	0.34	0.00	0.00	0.00	8.15		* BR opened on voltage regulation. Voltage 395 KV.
BSR	125MVAR,BUS REACTOR-1 AT ROORKEE	SVRD	09-02-2024	10:09:00	09-02-2024	21:07:00	0.46	0.00	0.00	0.00	10.97		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-1 AT ROORKEE	SVRD	11-02-2024	10:16:00	11-02-2024	15:45:00	0.23	0.00	0.00	0.00	5.48		* BR opened on voltage regulation.Voltage 395 KV
							1.99	0.00	0.00	0.00	47.75	100.00	
BSR	50MVAR,BUS REACTOR-1 AT SAHARANPUR	SVRD	21-02-2024	10:44:00	21-02-2024	13:08:00	0.10	0.00	0.00	0.00	2.40		* BR opened on voltage regulation.Voltage-396kV
BSR	50MVAR,BUS REACTOR-1 AT SAHARANPUR	SVRD	16-02-2024	10:45:00	16-02-2024	17:09:00	0.27	0.00	0.00	0.00	6.40		* BR opened on voltage regulation.Voltage-396kV
BSR	50MVAR,BUS REACTOR-1 AT SAHARANPUR	SVRD	15-02-2024	10:11:00	15-02-2024	21:21:00	0.47	0.00	0.00	0.00	11.17		* BR opened on voltage regulation. Voltage-390KV
BSR	50MVAR,BUS REACTOR-1 AT SAHARANPUR	SVRD	17-02-2024	10:08:00	17-02-2024	15:26:00	0.22	0.00	0.00	0.00	5.30		* BR opened on voltage regulation. Voltage-395KV.
BSR	50MVAR,BUS REACTOR-1 AT SAHARANPUR	SVRD	22-02-2024	10:16:00	22-02-2024	17:28:00	0.30	0.00	0.00	0.00	7.20		* BR opened on voltage regulation.Voltage-395 kV
BSR	50MVAR,BUS REACTOR-1 AT SAHARANPUR	SVRD	14-02-2024	10:25:00	14-02-2024	18:23:00	0.33	0.00	0.00	0.00	7.97		* BR opened on voltage regulation. Voltage-394KV.
BSR	50MVAR,BUS REACTOR-1 AT SAHARANPUR	SVRD	12-02-2024	11:31:00	12-02-2024	16:54:00	0.22	0.00	0.00	0.00	5.38		* BR opened on voltage regulation. Voltage-395KV
BSR	50MVAR,BUS REACTOR-1 AT SAHARANPUR	SVRD	23-02-2024	09:22:00	23-02-2024	18:06:00	0.36	0.00	0.00	0.00	8.73		* BR opened on voltage regulation. Voltage-395 KV.
BSR	50MVAR,BUS REACTOR-1 AT SAHARANPUR	SVRD	11-02-2024	09:49:00	11-02-2024	15:19:00	0.23	0.00	0.00	0.00	5.50		* BR opened on voltage regulation. V-392kV
BSR	50MVAR,BUS REACTOR-1 AT SAHARANPUR	SVRD	25-02-2024	10:17:00	25-02-2024	16:33:00	0.26	0.00	0.00	0.00	6.27		* BR opened on voltage regulation. Voltage-395 KV.
BSR	50MVAR,BUS REACTOR-1 AT SAHARANPUR	SVRD	13-02-2024	10:14:00	13-02-2024	13:13:00	0.12	0.00	0.00	0.00	2.98		* BR opened on voltage regulation. Voltage=390kV
							2.88	0.00	0.00	0.00	69.30	100.00	
BSR	50MVAR,BUS REACTOR-2 AT SAHARANPUR	SVRD	15-02-2024	10:11:00	15-02-2024	21:21:00	0.47	0.00	0.00	0.00	11.17		* BR opened on voltage regulation. V-392kV
BSR	50MVAR,BUS REACTOR-2 AT SAHARANPUR	SVRD	16-02-2024	10:45:00	16-02-2024	17:09:00	0.27	0.00	0.00	0.00	6.40		* BR opened on voltage regulation. Voltage-395 KV.
BSR	50MVAR,BUS REACTOR-2 AT SAHARANPUR	SVRD	14-02-2024	10:25:00	14-02-2024	18:23:00	0.33	0.00	0.00	0.00	7.97		* BR opened on voltage regulation.Voltage-395 kV
BSR	50MVAR,BUS REACTOR-2 AT SAHARANPUR	SVRD	12-02-2024	11:31:00	12-02-2024	16:54:00	0.22	0.00	0.00	0.00	5.38		* BR opened on voltage regulation. Voltage-392KV.
BSR	50MVAR,BUS REACTOR-2 AT SAHARANPUR	SVRD	21-02-2024	10:44:00	21-02-2024	13:08:00	0.10	0.00	0.00	0.00	2.40		* BR opened on voltage regulation. Voltage-395KV.
BSR	50MVAR,BUS REACTOR-2 AT SAHARANPUR	SVRD	17-02-2024	10:08:00	17-02-2024	15:26:00	0.22	0.00	0.00	0.00	5.30		* BR opened on voltage regulation.Voltage-396kV
BSR	50MVAR,BUS REACTOR-2 AT SAHARANPUR	SVRD	25-02-2024	10:17:00	25-02-2024	16:33:00	0.26	0.00	0.00	0.00	6.27		* BR opened on voltage regulation. Voltage 395 KV
BSR	50MVAR,BUS REACTOR-2 AT SAHARANPUR	SVRD	23-02-2024	09:22:00	23-02-2024	18:06:00	0.36	0.00	0.00	0.00	8.73		* BR opened on voltage regulation. Voltage-395 KV.
BSR	50MVAR,BUS REACTOR-2 AT SAHARANPUR	SVRD	11-02-2024	09:49:00	11-02-2024	15:19:00	0.23	0.00	0.00	0.00	5.50		* BR opened on voltage regulation.Voltage-396kV
BSR	50MVAR,BUS REACTOR-2 AT SAHARANPUR	SVRD	13-02-2024	10:14:00	13-02-2024	13:13:00	0.12	0.00	0.00	0.00	2.98		* BR opened on voltage regulation. Voltage-390KV
BSR	50MVAR,BUS REACTOR-2 AT SAHARANPUR	SVRD	22-02-2024	10:16:00	22-02-2024	17:28:00	0.30	0.00	0.00	0.00	7.20		* BR opened on voltage regulation. Voltage=390kV
							2.88	0.00	0.00	0.00	69.30	100.00	
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	13-02-2024	09:36:00	13-02-2024	16:19:00	0.28	0.00	0.00	0.00	6.72		* BR opened on voltage regulation.Voltage-395 kV
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	15-02-2024	10:01:00	15-02-2024	21:22:00	0.47	0.00	0.00	0.00	11.35		* BR opened on voltage regulation. V-391kV
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	20-02-2024	09:57:00	20-02-2024	17:04:00	0.30	0.00	0.00	0.00	7.12		* BR opened on voltage regulation. Voltage-395 KV.
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	10-02-2024	10:41:00	10-02-2024	15:16:00	0.19	0.00	0.00	0.00	4.58		* BR opened on voltage regulation. Voltage-397KV.
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	16-02-2024	10:05:00	16-02-2024	17:26:00	0.31	0.00	0.00	0.00	7.35		* BR opened on voltage regulation. Voltage-394KV.
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	21-02-2024	11:22:00	21-02-2024	13:32:00	0.09	0.00	0.00	0.00	2.17		* BR opened on voltage regulation.Voltage 395 KV
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	19-02-2024	10:35:00	19-02-2024	15:22:00	0.20	0.00	0.00	0.00	4.78		* BR opened on voltage regulation.Voltage 395 KV
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	27-02-2024	10:05:00	27-02-2024	16:13:00	0.26	0.00	0.00	0.00	6.13		* BR opened on voltage regulation.Voltage 395 KV NR2402-9296
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	24-02-2024	09:50:00	24-02-2024	17:24:00	0.32	0.00	0.00	0.00	7.57		* BR opened on voltage regulation. Voltage-394KV.
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	25-02-2024	09:56:00	25-02-2024	15:51:00	0.25	0.00	0.00	0.00	5.92		* BR opened on voltage regulation. Voltage-396KV.
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	17-02-2024	09:54:00	17-02-2024	16:37:00	0.28	0.00	0.00	0.00	6.72		* BR opened on voltage regulation. Voltage-394KV.
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	12-02-2024	10:33:00	12-02-2024	13:51:00	0.14	0.00	0.00	0.00	3.30		* BR opened on voltage regulation. Voltage=390kV
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	28-02-2024	09:41:00	28-02-2024	16:40:00	0.29	0.00	0.00	0.00	6.98		* BR opened on voltage regulation. Voltage-395 KV.
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	29-02-2024	09:51:00	29-02-2024	16:21:00	0.27	0.00	0.00	0.00	6.50		* BR opened on voltage regulation.Voltage-395 kV
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	11-02-2024	11:29:00	11-02-2024	15:37:00	0.17	0.00	0.00	0.00	4.13		* BR opened on voltage regulation. Voltage 395 KV
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	22-02-2024	09:36:00	22-02-2024	18:01:00	0.35	0.00	0.00	0.00	8.42		* BR Opened on Voltage Regulation.Voltage 395 KV
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	14-02-2024	07:41:00	14-02-2024	19:14:00	0.48	0.00	0.00	0.00	11.55		* BR opened on voltage regulation.Voltage-396kV
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	18-02-2024	09:41:00	18-02-2024	16:18:00	0.28	0.00	0.00	0.00	6.62		* BR opened on voltage regulation.Voltage 395 kV
BSR	80MVAR,BUS REACTOR-1 AT SIKAR	SVRD	23-02-2024	09:27:00	23-02-2024	17:57:00	0.35	0.00	0.00	0.00	8.50		* BR opened on voltage regulation. Voltage-394KV.
							5.28	0.00	0.00	0.00	126.41	100.00	
BSR	125MVAR,BUS REACTOR-2 AT SIKAR	SVRD	29-02-2024	09:52:00	29-02-2024	16:37:00	0.28	0.00	0.00	0.00	6.75		* BR opened on voltage regulation.Voltage 395 KV
BSR	125MVAR,BUS REACTOR-2 AT SIKAR	SVRD	28-02-2024	09:39:00	28-02-2024	16:40:00	0.29	0.00	0.00	0.00	7.02		* BR opened on voltage regulation. Voltage=390kV
BSR	125MVAR,BUS REACTOR-2 AT SIKAR	SVRD	10-02-2024	10:41:00	10-02-2024	15:15:00	0.19	0.00	0.00	0.00	4.57		* BR opened on voltage regulation.Voltage-396kV
BSR	125MVAR,BUS REACTOR-2 AT SIKAR	SVRD	16-02-2024	10:07:00	16-02-2024	17:26:00	0.31	0.00	0.00	0.00	7.32		* BR opened on voltage regulation. V-391kV
BSR	125MVAR,BUS REACTOR-2 AT SIKAR	SVRD	11-02-2024	09:52:00	11-02-2024	15:37:00	0.24	0.00	0.00	0.00	5.75		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR,BUS REACTOR-2 AT SIKAR	SVRD	18-02-2024	09:42:00	18-02-2024	16:18:00	0.28	0.00	0.00	0.00	6.50		
BSR	125MVAR,BUS REACTOR-2 AT SIKAR	SVRD	23-02-2024	09:25:00	23-02-2024	17:37:00	0.34	0.00	0.00	0.00	8.20		* BR opened on voltage regulation. Voltage-395 KV.
BSR	125MVAR,BUS REACTOR-2 AT SIKAR	SVRD	27-02-2024	10:05:00	27-02-2024	15:55:00	0.24	0.00	0.00	0.00	5.83		* BR opened on voltage regulation. Voltage-396KV.

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	220kV IG NAGAR(RRVPNL)-HIRAPURA(RRVPNL)	OMSU	14-02-2024	14:02:00	14-02-2024	22:12:00	0.34	0.00	8.17	0.00	0.00		* Line tripped on Phase to Phase Fault (Y-B). Heerapura-Zone-1/13.4km IG Nagra- Zone-1, Dist. 26.46km. Fault under Bassi TL jurisdiction. During emergency patrolling of line, foreign material found between location no. 801-802.
							0.34	0.00	8.17	0.00	0.00	100.00	
CKT	220kV LALSOT(RRVPNL)-DAUSA(RRVPNL)	OSPD	15-02-2024	11:10:00	15-02-2024	15:01:00	0.16	0.00	0.00	0.00	3.85		* Shutdown by RVPN for Quarterly maintenance works at RVPN end.
							0.16	0.00	0.00	0.00	3.85	100.00	
CKT	220kV MANSROVAR(RRVPNL)-HIRAPURA(RRVPNL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV MEERUT-MODIPURAM(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV MEERUT-MODIPURAM(UPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV MEERUT-NARA(UPPTCL)	OSFD	05-02-2024	15:15:00	05-02-2024	22:47:00	0.31	0.00	0.00	0.00	7.53		* Forced S/D by UPPCL to check CT connection and cable tracing as BRC flag is shown on the relay panel at Nara end.
							0.31	0.00	0.00	0.00	7.53	100.00	
CKT	220kV MEERUT-SHATABDINAGAR(UPPTCL)	OSFD	17-02-2024	08:00:00	17-02-2024	09:33:00	0.07	0.00	0.00	0.00	1.55		* Forced S/D by UPPCL along with 220 KV Main Bus at 220 KV Shatabdi Nagar to attend Hotspot.
							0.07	0.00	0.00	0.00	1.55	100.00	
CKT	220kV MEERUT-SIMBHOLI(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RAPPB(NPCIL)-CHITTORGARH(RRVPNL)-1	LCSD	13-02-2024	10:11:00	13-02-2024	20:12:00	0.42	0.00	0.00	0.00	10.02		* overhead powerline crossing work of under construction 400kV D/C Neemuch-Chittorgarh TL between loc AP 0 4/0 -AP 05/0,overhead powerline crossing work of under construction 400kV D/C Neemuch-Chittorgarh TL between loc AP 0 4/0 -AP 05/0.
							0.42	0.00	0.00	0.00	10.02	100.00	
CKT	220kV RAPPB(NPCIL)-CHITTORGARH(RRVPNL)-2	LCSD	13-02-2024	10:12:00	13-02-2024	20:12:00	0.42	0.00	0.00	0.00	10.00		* overhead powerline crossing work of under construction 400kV D/C Neemuch-Chittorgarh TL between loc AP 0 4/0 -AP 05/0.
							0.42	0.00	0.00	0.00	10.00	100.00	
CKT	220kV RAPPB(NPCIL)-RAPP(NPCIL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RAPPB(NPCIL)-UDAIPUR(RRVPNL)	LCSD	04-02-2024	10:05:00	04-02-2024	22:15:00	0.51	0.00	0.00	0.00	12.17		* S/D required for overhead powerline crossing work of 400 kV D/C* NEEMUCH CHITTORGARH TBCB Line work between LOC no. AP* 4/0 TO AP 5/0.
							0.51	0.00	0.00	0.00	12.17	100.00	
CKT	220kV RATANGARH(RRVPNL)-SIKAR-1	OMSU	03-02-2024	22:57:00	03-02-2024	23:43:00	0.03	0.00	0.77	0.00	0.00		* Tripped only from Ratangarh(Raj)end on R-N fault .Line successfully* Auto-reclosed from Sikar end.AFAS Sikar: R_N, 3.113kA,54.60KM* ,RATNGARH END-8.3 KM,Z1,B-PH,10.94 KA/SIKAR END- CB NOT TRIP* .Fault under RVPNL jurisdiction.
							0.86	0.00	20.74	0.00	0.00	100.00	
CKT	220kV RATANGARH(RRVPNL)-SIKAR-1	OMSU	02-02-2024	02:21:00	02-02-2024	22:19:00	0.83	0.00	19.97	0.00	0.00		* Tripped on R-N Fault.Sikar-53.671 km /3.6 kA.Ratangarh-M1:22.2 kms,M2: 21.58 Kms/ 6.235 KA.Fault under RRVPNL Jurisdiction.Emergency shutdown taken by RRVPNL for replacement work of damaged disc insulator (I-string) at loc.10
							0.84	0.00	20.15	0.00	0.00	100.00	
CKT	220kV RATANGARH(RRVPNL)-SIKAR-2	OMSU	02-02-2024	02:10:00	02-02-2024	22:19:00	0.84	0.00	20.15	0.00	0.00		* Tripped on R-N Fault.Sikar-58.73km /3.6 kA.Ratangarh-M1:4.1 kms,M2: 1.9 Kms/ 18.88 KA.Fault under RRVPNL Jurisdiction.Emergency shutdown taken by RRVPNL for replacement work of damaged disc insulator (I-string) at loc.70
							0.84	0.00	20.15	0.00	0.00	100.00	
CKT	220kV-SAMAYPUR(HVPNL)-SEC58-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV-SAMAYPUR(HVPNL)-SEC58-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SANGANER(RRVPNL)-MANSROVAR(RRVPNL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV S.MADHOPUR(RRVPNL)-DAUSA(RRVPNL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SIKAR(RRVPNL)-SIKAR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SIKAR(RRVPNL)-SIKAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	04-02-2024	16:22:00	05-02-2024	07:06:00	0.61	0.00	0.00	0.00	14.73		* Line opened on voltage regulation. Agra-422 KV.
							0.43	0.00	0.00	0.00	10.40		* Line opened on voltage regulation. Agra-422KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	11-02-2024	20:26:00	12-02-2024	07:30:00	0.46	0.00	0.00	0.00	11.07		* Line opened on voltage regulation. Agra-423KV.
							0.39	0.00	0.00	0.00	9.45		* Line opened on voltage regulation. Jaipur South-419KV.

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV BABAI(RRVPNL)-SIKAR	OSPD	02-02-2024	17:44:00	02-02-2024	20:55:00	0.13	0.00	0.00	0.00	3.18		* Shutdown by RRVPNL for their quarterly maintenance works at their Babai end.
							0.13	0.00	0.00	0.00	3.18	100.00	
CKT	400kV BAGPAT-DEHRADUN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAGPAT-MEERUT-1	LVRD	05-02-2024	03:12:00	05-02-2024	07:22:00	0.17	0.00	0.00	0.00	4.17		* Line opened on voltage regulation. Meerut-424 KV.
							0.17	0.00	0.00	0.00	4.17	100.00	
CKT	400kV BAGPAT-MEERUT-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAGPAT-SAHARANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BALLABHGARH-NAVADA(HVPNL)	OSFT	24-02-2024	09:13:00	24-02-2024	16:18:00	0.30	7.08	0.00	0.00	0.00		* Forced shutdown to attend B Phase Jumper Broken <-&<-> replace old existing Cotter Bolt with new one in QT fitting at either end of the Railway Crossing Span 125-126.
CKT	400kV BALLABHGARH-NAVADA(HVPNL)	OSFT	23-02-2024	09:29:00	23-02-2024	20:30:00	0.46	11.02	0.00	0.00	0.00		* Forced shutdown to replace old existing cotter bolt with new one in QT fitting at either end of the Railway Crossing Span 125-126, to avoid unwanted trippings in Railway Crossing Span.
							0.76	18.10	0.00	0.00	0.00	97.40	
CKT	400kV BASSI-HIRAPURA(RRVPNL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BASSI-HIRAPURA(RRVPNL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BASSI-JAIPUR SOUTH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BASSI-JAIPUR SOUTH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BASSI-PHAGI(RRVPNL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BASSI-PHAGI(RRVPNL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BEAWAR(SREE CEMENT)-MERTA(RRVPNL)	LCSD	08-02-2024	16:57:00	09-02-2024	00:35:00	0.32	0.00	0.00	0.00	7.63		* Shutdown for Commissioning of AR Relay at RVPN Merta SS.
CKT	400kV BEAWAR(SREE CEMENT)-MERTA(RRVPNL)	LCSD	09-02-2024	16:38:00	10-02-2024	05:08:00	0.52	0.00	0.00	0.00	12.50		* Shutdown for Commissioning of AR Relay at RVPN Merta SS.
							0.84	0.00	0.00	0.00	20.13	100.00	
CKT	400kV BAHADURGARH-BAWANA(DTL)	OMSU	06-02-2024	10:10:00	06-02-2024	20:39:00	0.44	0.00	10.48	0.00	0.00		* Line tripped on DT receive at PGCIL end. R-Ph Jumper Broken <-&<-> BPI Damage in 400kV Bus-1 and snapping of conductor Y-Phase of bay 413 for 400kV Bus-2 reported at Bawana end.
							0.44	0.00	10.48	0.00	0.00	100.00	
CKT	400kV BAHADURGARH-KABULPUR(HVPNL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAHADURGARH-SONIPAT-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAHADURGARH-SONIPAT-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADLA-BHADLA(RRVPNL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADLA-BHADLA(RRVPNL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BHADLA(PG) R-BHADLA2-1	LCSD	25-02-2024	22:11:00	26-02-2024	00:50:00	0.11	0.00	0.00	0.00	2.65		* S/D for Installation of Bid Diverter in the line .
							0.11	0.00	0.00	0.00	2.65	100.00	
CKT	400KV-BHADLA(PG) R-BHADLA2-2	LCSD	26-02-2024	00:52:00	26-02-2024	05:33:00	0.20	0.00	0.00	0.00	4.68		* S/D for Installation of Bid Diverter in the line .
							0.20	0.00	0.00	0.00	4.68	100.00	
CKT	400kV BASSI-BHIWADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHIWADI-KOTPUTLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHIWADI-NEEMRANA-1	LVRD	05-02-2024	00:59:00	05-02-2024	08:00:00	0.29	0.00	0.00	0.00	7.02		* Line opened on voltage regulation. Bhiwadi-424 KV.
							0.29	0.00	0.00	0.00	7.02	100.00	
CKT	400kV BHIWADI-NEEMRANA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHIWANI(BBMB)-BHIWANI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHIWANI-JIND-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHIWANI-JIND-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV BHIWANI-KABULPUR(HVPNL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BHIWN-MHNDGRH-CKT-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BHIWN-MHNDGRH-CKT-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHINMAL-KANKROLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BIKANER-BIKANR2-CKT-I			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BIKANER-BIKANR2-CKT-II			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAMNOLI(DTL)-TUGHLAKABD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAMNOLI(DTL)-TUGHLAKABD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BAREILY-MEERUT-3(LILO PART MEERUT)	LVRD	11-02-2024	02:08:00	11-02-2024	07:03:00	0.21	0.00	0.00	0.00	4.92		* Line auto-reclosed on B-N fault. BareilyAFAS: B-N, 1.873 kA, 223.148km(Double End).* Meerut AFAS: B-N, 12.70kA, 26.351Km (Double end). Fault under Meerut TL jurisdiction.*
CKT	400KV-BAREILY-MEERUT-3(LILO PART MEERUT)	LART	23-02-2024	14:40:00	23-02-2024	14:40:00	0.00	0.00	0.00	0.00	0.00		* Line opened on voltage regulation.Meerut-422 KV.
CKT	400KV-BAREILY-MEERUT-4(LILO PART MEERUT)	LVRD	04-02-2024	23:16:00	05-02-2024	08:32:00	0.39	0.00	0.00	0.00	9.27		* Line opened on voltage regulation. Meerut-422KV
CKT	400KV-BAREILY-MEERUT-4(LILO PART MEERUT)	LVRD	01-02-2024	23:23:00	02-02-2024	07:24:00	0.33	0.00	0.00	0.00	8.02		* Line Tripped distance protection, Fault Type :- B Ph to R Ph. Fault* Fault Current Meerut :- 2.463 kA* Location :- 243.825 KM from Meerut
CKT	400KV-BAREILY-MEERUT-4(LILO PART MEERUT)	LVRD	01-02-2024	01:11:00	01-02-2024	10:05:00	0.37	0.00	0.00	0.00	8.90		* Line opened on voltage regulation. Meerut=419kV
CKT	400KV-BAREILY-MEERUT-4(LILO PART MEERUT)	LVRD	19-02-2024	01:43:00	19-02-2024	06:15:00	0.19	0.00	0.00	0.00	4.53		* Line opened on voltage regulation. Meerut-422KV.
CKT	400KV-BAREILY-MEERUT-4(LILO PART MEERUT)	OMSU	28-02-2024	10:48:00	28-02-2024	11:23:00	0.02	0.00	0.58	0.00	0.00		* Line opened on voltage regulation. Meerut-424 KV
CKT	400KV-BAREILY-MEERUT-4(LILO PART MEERUT)	LVRD	29-02-2024	02:02:00	29-02-2024	07:53:00	0.24	0.00	0.00	0.00	5.85		* Line opened on voltage regulation. Meerut-422KV.
							1.54	0.00	0.58	0.00	36.57	100.00	
CKT	400kV BAWANA(DTL)-BHIWANI	OMSU	06-02-2024	10:10:00	06-02-2024	20:39:00	0.44	0.00	10.48	0.00	0.00		* Forced shutdown by DTL to attend Hot spot on 400KV bay 414 B phase isolators 89B and Misaligned M/F contact of 400KV Bay 415 at Bawana end.
CKT	400kV BAWANA(DTL)-BHIWANI	OSFD	14-02-2024	15:47:00	14-02-2024	19:57:00	0.17	0.00	0.00	0.00	4.17		* Forced SD to attend current zero issue in Y phase at Bhiwani end.
CKT	400kV BAWANA(DTL)-BHIWANI	OSFT	26-02-2024	19:12:00	26-02-2024	22:00:00	0.12	2.80	0.00	0.00	0.00		* Line tripped on DT receive at PGCIL end. R-Ph Jumper Broken <-&<-> BPI Damage in 400kV Bus-1 and snapping of conductor Y-Phase of bay 413 for 400kV Bus-2 reported at Bawana end.
CKT	400kV BAWANA(DTL)-BHIWANI	OMSU	01-02-2024	00:00:01	01-02-2024	10:48:00	0.45	0.00	10.80	0.00	0.00		* Tripped on DT received from Bawana. BPI failure of B-ph reported at Bawana CCGTB S/Y.
							1.18	2.80	21.28	0.00	4.17	99.59	
CKT	400kV CHITTORGARH-CHITTORGARH(RRVPNL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHITTORGARH-CHITTORGARH(RRVPNL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DADRI(NTPC)-GREATER NOIDA(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DADRI(NTPC)-MANDOLA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DADRI(NTPC)-MANDOLA-2	OSFT	07-02-2024	15:24:00	07-02-2024	16:47:00	0.06	1.38	0.00	0.00	0.00		* Forced shutdown to attend SF6 Gas pressure alarm in LSR (GIS) B phase G-65 41689A compartment at Mandola end.
							0.06	1.38	0.00	0.00	0.00	99.80	
CKT	400kV DADRI(NTPC)-MAHRANIBAGH	OSFT	25-02-2024	09:27:00	25-02-2024	17:52:00	0.35	8.42	0.00	0.00	0.00		* Emergency Shutdown taken to replace old existing Cotter Bolt with new one in QT fitting at either end of the Railway Crossing Span 125-126 to avoid unwanted trippings and any untoward incident and safety hazards in railway Crossing Span.
CKT	400kV DADRI(NTPC)-MAHRANIBAGH	OSFT	22-02-2024	10:11:00	22-02-2024	23:00:00	0.53	12.82	0.00	0.00	0.00		* Forced Shutdown to replace old existing Cotter Bolt with new* one in QT fitting at either end of the Railway Crossing Span 125-* 126 to avoid unwanted trippings and any untoward incident and* safety hazards in railway Crossing Span
CKT	400kV DADRI(NTPC)-MAHRANIBAGH	LHWT	20-02-2024	20:38:00	22-02-2024	00:02:00	1.14	27.40	0.00	0.00	0.00		* Tripped on R-Y-N fault. FLR- BLB- 28.709 kA/4.74km. Tripped due to* failure of d- shackle cotter bolt in top phase QT fitting and top* conductor with all hardware fitting fallen on middle phase at tower no* 125 (railway crossing). FLR- Dadri end -Earth
							2.02	48.64	0.00	0.00	0.00	93.01	
CKT	400kV DADRI(NTPC)-MURADNAGAR(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV GURGAON-SOHNNA(STERLITE)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GURGAON-SOHNNA(STERLITE)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HAPUR(UPPTCL)-MURADNAGAR(UPPTCL)	OSPT	29-02-2024	09:35:00	29-02-2024	20:03:00	0.44	10.47	0.00	0.00	0.00	98.50	* Shutdown for shut down nature defect rectification and installation of Pilot insulator at tower no. 300A.
CKT	400kV HISAR-BHIWADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HISAR-BHIWADI-2	LVRD	05-02-2024	02:19:00	05-02-2024	08:08:00	0.24	0.00	0.00	0.00	5.82	100.00	* Line opened on voltage regulation. Bhiwadi-422KV
CKT	400kV HISAR-BHIWADI-2	LVRD	19-02-2024	21:35:00	20-02-2024	07:44:00	0.42	0.00	0.00	0.00	10.15	100.00	* Line opened on voltage regulation. Bhiwadi-422 KV.
CKT	400kV HISAR-BHIWADI-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HISAR-BHIWANI(BBMB)	LCSD	05-02-2024	12:47:00	05-02-2024	20:37:00	0.33	0.00	0.00	0.00	7.83	100.00	* Shutdown for CVT Replacement in Add Cap R-><->Y Ph At BBMB Bhiwani end
CKT	400KV-HISAR-BHIWANI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-HISAR-BHIWANI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-HISAR-BHIWANI-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JAIPUR SOUTH-KOTA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JAIPUR SOUTH-RAPPD(NPCIL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHATIKARA-BAMNOLI(DTL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-JHATIKARA-DWARKA-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHATIKARA-MUNDKA(DTL)-1	OSFD	09-02-2024	07:31:00	09-02-2024	11:14:00	0.16	0.00	0.00	0.00	3.72	100.00	* Forced SD by DTL attend hot spot on Y-phase Line Isolator 401-89B at Mundka.
CKT	400kV JHATIKARA-MUNDKA(DTL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-HISAR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-HISAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KANKROLI-CHITTORGARH(RRVPNL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KANKROLI-JODHPUR(RRVPNL)	LCSD	01-02-2024	00:00:01	29-02-2024	21:23:00	28.89	0.00	0.00	0.00	693.38	100.00	* Shutdown for reconductoring work of all 188km of complete line.
CKT	400kV KOTA-BEAWAR(SREE CEMENT)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOTA-MERTA(RRVPNL)	LCSD	07-02-2024	16:12:00	08-02-2024	06:43:00	0.61	0.00	0.00	0.00	14.52	97.75	* Shutdown for Commissioning of AR Relay at RVPN Merta SS.
CKT	400kV KOTA-MERTA(RRVPNL)	OSPT	05-02-2024	16:54:00	06-02-2024	00:14:00	0.31	7.33	0.00	0.00	0.00	100.00	* Shutdown for AR Relay Commissioning at RVPN Merta SS.
CKT	400kV KOTA-MERTA(RRVPNL)	OSPT	06-02-2024	16:44:00	07-02-2024	01:04:00	0.35	8.33	0.00	0.00	0.00	100.00	* Shutdown for AR Relay Commissioning at RVPN Merta SS.
CKT	400kV KOTPUTLI-BASSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHIWADI-KOTPUTLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-KOTESHWAR(UK)-KOTESHWAR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-KOTESHWAR(UK)-KOTESHWAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOTESHWAR-TEHRI(THDC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOTESHWAR-TEHRI(THDC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOTESHWAR-TEHRI(THDC)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MANESAR-SOHNNA(STERLITE)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MANESAR-SOHNNA(STERLITE)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MAHARANIBAGH-BALLABHGARH	OSFT	22-02-2024	10:11:00	22-02-2024	23:00:00	0.53	12.82	0.00	0.00	0.00		* Emergency Shutdown taken to replace old existing Cotter Bolt with new one in QT fitting at either end of the Railway Crossing Span 125-126 to avoid unwanted trippings and any untoward incident and safety hazards in railway Crossing Span.
CKT	400kV MAHARANIBAGH-BALLABHGARH	LHWT	20-02-2024	20:38:00	22-02-2024	00:02:00	1.14	27.40	0.00	0.00	0.00		* Tripped on R-Y-N fault. FLR- BLB- 28.709 kA/4.74km. Tripped due to* failure of d- shackle cotter bolt in top phase QT fitting and top* conductor with all hardware fitting fallen on middle phase at tower no* 125 (railway crossing). FLR- Dadri end -Earth
CKT	400kV MAHARANIBAGH-BALLABHGARH	OSFT	25-02-2024	09:27:00	25-02-2024	17:52:00	0.35	8.42	0.00	0.00	0.00		* Forced Shutdown to replace old existing Cotter Bolt with new* one in QT fitting at either end of the Railway Crossing Span 125-* 126 to avoid unwanted trippings and any untoward incident and* safety hazards in railway Crossing Span
							2.02	48.64	0.00	0.00	0.00	93.01	
CKT	400KV-MBAGH-BAWANA-AC-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-MBAGH-BAWANA-AC-CKT2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-MBAGH-MANDOLA-AC-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-MBAGH-MANDOLA-AC-CKT2	SVRD	24-02-2024	14:55:00	24-02-2024	19:24:00	0.19	0.00	0.00	0.00	4.48		* Forced shutdown to attend high THRC value of R phase LA at Mandola.
CKT	400KV-MBAGH-MANDOLA-AC-CKT2	OSFT	24-02-2024	14:55:00	24-02-2024	19:24:00	0.19	4.48	0.00	0.00	0.00		* Forced shutdown to attend high THRC value of R phase LA at Mandola.
							0.38	4.48	0.00	0.00	4.48	99.36	
CKT	400kV HAPUR(UPPTCL)-MORADABAD(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MEERUT-MANDOLA-1	LVRD	13-02-2024	21:54:00	14-02-2024	06:30:00	0.36	0.00	0.00	0.00	8.60		* Line opened on voltage regulation. Meerut-790KV.
CKT	400kV MEERUT-MANDOLA-1	LVRD	23-02-2024	23:24:00	24-02-2024	06:58:00	0.32	0.00	0.00	0.00	7.57		* Line opened on voltage regulation. Meerut-422 KV.
CKT	400kV MEERUT-MANDOLA-1	LVRD	15-02-2024	23:33:00	16-02-2024	05:55:00	0.27	0.00	0.00	0.00	6.37		* Line opened on voltage regulation. Meerut-424KV.
CKT	400kV MEERUT-MANDOLA-1	LVRD	15-02-2024	00:49:00	15-02-2024	06:21:00	0.23	0.00	0.00	0.00	5.53		* Line opened on voltage regulation. Meerut-422 KV.
CKT	400kV MEERUT-MANDOLA-1	LVRD	12-02-2024	02:37:00	12-02-2024	06:57:00	0.18	0.00	0.00	0.00	4.33		* Line opened on voltage regulation. Voltage-422 KV.
CKT	400kV MEERUT-MANDOLA-1	LVRD	21-02-2024	22:22:00	22-02-2024	07:09:00	0.37	0.00	0.00	0.00	8.78		* Line opened on voltage regulation. Meerut-422KV.
CKT	400kV MEERUT-MANDOLA-1	LVRD	11-02-2024	02:03:00	11-02-2024	06:07:00	0.17	0.00	0.00	0.00	4.07		* Line opened on voltage regulation. Meerut-420KV.
CKT	400kV MEERUT-MANDOLA-1	LVRD	29-02-2024	22:57:00	29-02-2024	23:59:59	0.04	0.00	0.00	0.00	1.05		* Line opened on voltage regulation. Voltage-790 KV.
CKT	400kV MEERUT-MANDOLA-1	LVRD	01-02-2024	23:11:00	02-02-2024	07:10:00	0.33	0.00	0.00	0.00	7.98		* Line opened on voltage regulation. 420kV
CKT	400kV MEERUT-MANDOLA-1	LVRD	04-02-2024	23:18:00	05-02-2024	07:31:00	0.34	0.00	0.00	0.00	8.22		* Line opened on voltage regulation. Meerut-420KV.
CKT	400kV MEERUT-MANDOLA-1	SVRD	23-02-2024	01:30:00	23-02-2024	06:11:00	0.20	0.00	0.00	0.00	4.68		* Line opened on voltage regulation. Meerut-422KV.
CKT	400kV MEERUT-MANDOLA-1	LVRD	06-02-2024	00:43:00	06-02-2024	07:30:00	0.28	0.00	0.00	0.00	6.78		* Line opened on voltage regulation. Meerut-422KV.
CKT	400kV MEERUT-MANDOLA-1	LVRD	01-02-2024	00:10:00	01-02-2024	07:16:00	0.30	0.00	0.00	0.00	7.10		* Line opened on voltage regulation. Meerut-424 KV
							3.39	0.00	0.00	0.00	81.06	100.00	
CKT	400kV MEERUT-MANDOLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MEERUT-MANDOLA-3	LVRD	23-02-2024	01:30:00	23-02-2024	06:12:00	0.20	0.00	0.00	0.00	4.70		* Line opened on voltage regulation. Meerut-422KV.
CKT	400kV MEERUT-MANDOLA-3	LVRD	15-02-2024	23:33:00	16-02-2024	05:55:00	0.27	0.00	0.00	0.00	6.37		* Line opened on voltage regulation. Meerut-424 KV
CKT	400kV MEERUT-MANDOLA-3	LVRD	13-02-2024	21:54:00	14-02-2024	06:28:00	0.36	0.00	0.00	0.00	8.57		* Line opened on voltage regulation. Meerut-490KV.
CKT	400kV MEERUT-MANDOLA-3	LVRD	01-02-2024	23:11:00	02-02-2024	07:11:00	0.33	0.00	0.00	0.00	8.00		* Line opened on voltage regulation. Meerut-424KV.
CKT	400kV MEERUT-MANDOLA-3	LVRD	04-02-2024	23:18:00	05-02-2024	07:31:00	0.34	0.00	0.00	0.00	8.22		* Line opened on voltage regulation. Meerut-422 KV.
CKT	400kV MEERUT-MANDOLA-3	LVRD	29-02-2024	22:58:00	29-02-2024	23:59:59	0.04	0.00	0.00	0.00	1.03		* Line opened on voltage regulation. Voltage-422 KV.
CKT	400kV MEERUT-MANDOLA-3	LVRD	23-02-2024	23:25:00	24-02-2024	06:58:00	0.32	0.00	0.00	0.00	7.55		* Line opened on voltage regulation. 420kV
CKT	400kV MEERUT-MANDOLA-3	LVRD	01-02-2024	00:12:00	01-02-2024	07:16:00	0.29	0.00	0.00	0.00	7.07		* Line opened on voltage regulation. Meerut-420KV.
CKT	400kV MEERUT-MANDOLA-3	LVRD	21-02-2024	22:24:00	22-02-2024	07:22:00	0.37	0.00	0.00	0.00	8.97		* Line opened on voltage regulation. Meerut-422KV.
CKT	400kV MEERUT-MANDOLA-3	LVRD	12-02-2024	02:37:00	12-02-2024	06:54:00	0.18	0.00	0.00	0.00	4.28		* Line opened on voltage regulation. Voltage-790 KV.
CKT	400kV MEERUT-MANDOLA-3	LVRD	15-02-2024	00:49:00	15-02-2024	06:19:00	0.23	0.00	0.00	0.00	5.50		* Line opened on voltage regulation. Meerut-420KV.
CKT	400kV MEERUT-MANDOLA-3	LVRD	06-02-2024	00:43:00	06-02-2024	07:31:00	0.28	0.00	0.00	0.00	6.80		* Line opened on voltage regulation. Meerut-422KV.
							3.21	0.00	0.00	0.00	77.06	100.00	
CKT	400kV MEERUT-MANDOLA-4	LART	23-02-2024	14:39:00	23-02-2024	14:39:00	0.00	0.00	0.00	0.00	0.00		* *Line auto-reclosed on R-N fault. Mandola AFAS: R-N, 4.168 kA, 77.343km(Double End).* Meerut AFAS: R-N, 12.48kA, 24.476Km (Double end), Fault under Meerut TL ."
CKT	400kV MEERUT-MANDOLA-4	OSFT	14-02-2024	13:00:00	14-02-2024	19:54:00	0.29	6.90	0.00	0.00	0.00		* Forced shutdown for replacement of faulty M1 relay at Mandola SS.
							0.29	6.90	0.00	0.00	0.00	99.01	
CKT	400kV MEERUT-MUZAFFARNAGAR(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEEMRANA-BABA(RRVPNL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ROORKEE-RISHIKESH(PTCUL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ROORKEE-SAHARANPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIKAR-BASSI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIKAR-BASSI-2	LART	01-02-2024	03:29:00	01-02-2024	03:29:00	0.00	0.00	0.00	0.00	0.00		* Tripped on R-N fault. Bassi: 112.674Km. Sikar 56.82 KM , 5.685 KA. Fault under Sikar Jurisdiction.
CKT	400kV SIKAR-BASSI-2	LART	01-02-2024	00:54:00	01-02-2024	00:54:00	0.00	0.00	0.00	0.00	0.00		* Autoreclosed on R-N fault. Bassi: 112.4km. Sikar 57.052 KM , 5.627 KA. Fault under Sikar TL jurisdiction.
CKT	400kV SIKAR-BASSI-2	LEFT	01-02-2024	03:51:00	01-02-2024	18:55:00	0.63	15.07	0.00	0.00	0.00		* Autoreclosed on R-N fault. Bassi: 110.187km, 3.94kA. Sikar: 56.612km, 6.09kA. Fault under Sikar TL jurisdiction
							0.63	15.07	0.00	0.00	0.00	97.84	
CKT	400kV TUGHLAKABAD-BALLABHGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUGHLAKABAD-BALLABHGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV AGRA-JHATIKARA	OSFT	06-02-2024	17:45:00	06-02-2024	21:09:00	0.14	3.40	0.00	0.00	0.00		* Forced shutdown by NR-3 to attend hotspot observed at Y-ph CVT terminal connector at Agra End.
							0.14	3.40	0.00	0.00	0.00	99.51	
CKT	765kV AJMER-BHADLA2-1	LVRD	01-02-2024	00:00:01	01-02-2024	07:33:00	0.32	0.00	0.00	0.00	7.55		* Line opened on voltage regulation. Ajmer-790KV.
CKT	765kV AJMER-BHADLA2-1	LVRD	04-02-2024	18:05:00	05-02-2024	09:09:00	0.63	0.00	0.00	0.00	15.07		* Line opened on voltage regulation. Ajmer- 785 KV
CKT	765kV AJMER-BHADLA2-1	LVRD	26-02-2024	17:10:00	27-02-2024	09:04:00	0.66	0.00	0.00	0.00	15.90		* Line opened on voltage regulation. Ajmer-792KV.
CKT	765kV AJMER-BHADLA2-1	LVRD	07-02-2024	22:11:00	08-02-2024	06:57:00	0.37	0.00	0.00	0.00	8.77		* Line opened on voltage regulation. Voltage-790 KV.
CKT	765kV AJMER-BHADLA2-1	LVRD	15-02-2024	20:28:00	16-02-2024	08:26:00	0.50	0.00	0.00	0.00	11.97		* Line opened on voltage regulation. Ajmer-795KV
CKT	765kV AJMER-BHADLA2-1	SVRD	24-02-2024	17:28:00	25-02-2024	08:52:00	0.64	0.00	0.00	0.00	15.40		* Line opened on voltage regulation. Ajmer-795kv
CKT	765kV AJMER-BHADLA2-1	LVRD	02-02-2024	17:55:00	03-02-2024	08:00:00	0.59	0.00	0.00	0.00	14.08		* Line opened on voltage regulation. Ajmer-792KV.
CKT	765kV AJMER-BHADLA2-1	LVRD	13-02-2024	21:28:00	14-02-2024	07:22:00	0.41	0.00	0.00	0.00	9.90		* Line opened on voltage regulation. Ajmer-792KV.
CKT	765kV AJMER-BHADLA2-1	LVRD	11-02-2024	17:29:00	12-02-2024	07:05:00	0.57	0.00	0.00	0.00	13.60		* Line opened on voltage regulation. Ajmer-790 KV.
CKT	765kV AJMER-BHADLA2-1	LVRD	18-02-2024	21:25:00	19-02-2024	08:20:00	0.46	0.00	0.00	0.00	10.92		* Line opened on voltage regulation. Ajmer-790KV
CKT	765kV AJMER-BHADLA2-1	LVRD	05-02-2024	18:08:00	06-02-2024	09:33:00	0.64	0.00	0.00	0.00	15.42		* Line opened on voltage regulation. Ajmer-790KV
CKT	765kV AJMER-BHADLA2-1	LVRD	22-02-2024	20:19:00	23-02-2024	09:06:00	0.53	0.00	0.00	0.00	12.78		* Line opened on voltage regulation. Ajmer-790KV.
CKT	765kV AJMER-BHADLA2-1	LVRD	09-02-2024	17:14:00	10-02-2024	09:07:00	0.66	0.00	0.00	0.00	15.88		* Line opened on voltage regulation. Ajmer-795KV.
CKT	765kV AJMER-BHADLA2-1	LVRD	20-02-2024	18:08:00	21-02-2024	09:10:00	0.63	0.00	0.00	0.00	15.03		* Line opened on voltage regulation. Bhadla 2-421KV.
CKT	765kV AJMER-BHADLA2-1	LVRD	28-02-2024	17:46:00	29-02-2024	08:50:00	0.63	0.00	0.00	0.00	15.07		* Line opened on voltage regulation. Ajmer-787KV
							8.24	0.00	0.00	0.00	197.34	100.00	
CKT	765kV AJMER-BHADLA2-2	LVRD	29-02-2024	18:16:00	29-02-2024	23:59:59	0.24	0.00	0.00	0.00	5.73		
CKT	765kV AJMER-BHADLA2-2	LVRD	03-02-2024	21:42:00	04-02-2024	09:37:00	0.50	0.00	0.00	0.00	11.92		* Line opened on voltage regulation. Ajmer-790KV
CKT	765kV AJMER-BHADLA2-2	LVRD	01-02-2024	17:59:00	02-02-2024	07:18:00	0.56	0.00	0.00	0.00	13.32		* Line opened on voltage regulation. Ajmer - 785 KV
CKT	765kV AJMER-BHADLA2-2	LVRD	27-02-2024	22:19:00	28-02-2024	09:04:00	0.45	0.00	0.00	0.00	10.75		* Line opened on voltage regulation. Ajmer=799kv
CKT	765kV AJMER-BHADLA2-2	LVRD	10-02-2024	17:42:00	11-02-2024	07:25:00	0.57	0.00	0.00	0.00	13.72		* Line opened on voltage regulation. Ajmer- 785 KV
CKT	765kV AJMER-BHADLA2-2	LVRD	14-02-2024	20:34:00	15-02-2024	09:03:00	0.52	0.00	0.00	0.00	12.48		* Line opened on voltage regulation. Ajmer-790KV.
CKT	765kV AJMER-BHADLA2-2	LVRD	21-02-2024	18:13:00	22-02-2024	08:38:00	0.60	0.00	0.00	0.00	14.42		* Line opened on voltage regulation. Ajmer-792KV.
CKT	765kV AJMER-BHADLA2-2	LVRD	19-02-2024	19:47:00	20-02-2024	08:16:00	0.52	0.00	0.00	0.00	12.48		* Line opened on voltage regulation. Ajmer-790KV.
CKT	765kV AJMER-BHADLA2-2	LVRD	25-02-2024	17:38:00	26-02-2024	09:03:00	0.64	0.00	0.00	0.00	15.42		* Line opened on voltage regulation. Ajmer-790KV.
CKT	765kV AJMER-BHADLA2-2	LVRD	08-02-2024	17:43:00	09-02-2024	09:03:00	0.64	0.00	0.00	0.00	15.33		* Line opened on voltage regulation. Bhadla(2)-795KV.
CKT	765kV AJMER-BHADLA2-2	LVRD	16-02-2024	18:05:00	17-02-2024	09:30:00	0.64	0.00	0.00	0.00	15.42		* Line opened on voltage regulation Voltage 780 kV
CKT	765kV AJMER-BHADLA2-2	SVRD	23-02-2024	21:24:00	24-02-2024	08:58:00	0.48	0.00	0.00	0.00	11.57		* Line opened on voltage regulation. Ajmer-790kV
CKT	765kV AJMER-BHADLA2-2	LVRD	06-02-2024	19:14:00	07-02-2024	08:41:00	0.56	0.00	0.00	0.00	13.45		* Line opened on voltage regulation. Ajmer-792KV.
CKT	765kV AJMER-BHADLA2-2	LVRD	12-02-2024	21:22:00	13-02-2024	06:57:00	0.40	0.00	0.00	0.00	9.58		* Line opened on voltage regulation. Ajmer-792KV.
							7.32	0.00	0.00	0.00	175.59	100.00	
CKT	765kV BHADLA-BIKANER-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BHADLA-BIKANER-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BHIWANI-PHAGI(RRVPNL)-1	LVRD	03-02-2024	16:44:00	04-02-2024	09:36:00	0.70	0.00	0.00	0.00	16.87		* Line opened on voltage regulation. Bhiwani-790KV
CKT	765kV BHIWANI-PHAGI(RRVPNL)-1	LVRD	02-02-2024	16:42:00	02-02-2024	20:42:00	0.17	0.00	0.00	0.00	4.00		* Line opened on voltage regulation. Bhiwani-790KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-1	LVRD	18-02-2024	17:41:00	19-02-2024	06:57:00	0.55	0.00	0.00	0.00	13.27		* Line opened on voltage regulation. Bhiwani-789KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-1	LVRD	16-02-2024	21:49:00	17-02-2024	07:06:00	0.39	0.00	0.00	0.00	9.28		* Line opened on voltage regulation Voltage.Bhiwani- 780 kV
CKT	765kV BHIWANI-PHAGI(RRVPNL)-1	LVRD	09-02-2024	17:27:00	10-02-2024	07:20:00	0.58	0.00	0.00	0.00	13.88		* Line opened on voltage regulation. Bhiwani-790KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-1	LVRD	14-02-2024	18:11:00	15-02-2024	06:44:00	0.52	0.00	0.00	0.00	12.55		* Line opened on voltage regulation. Bhiwani-795KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-1	LVRD	06-02-2024	21:50:00	07-02-2024	06:29:00	0.36	0.00	0.00	0.00	8.65		* Line opened on voltage regulation. Bhiwani=800kV
CKT	765kV BHIWANI-PHAGI(RRVPNL)-1	LVRD	11-02-2024	21:25:00	12-02-2024	06:33:00	0.38	0.00	0.00	0.00	9.13		* Line opened on voltage regulation. Bhiwani-786KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-1	LVRD	25-02-2024	18:43:00	26-02-2024	07:49:00	0.55	0.00	0.00	0.00	13.10		* Line opened on voltage regulation Voltage 780 K

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	765kV BHIWANI-PHAGI(RRVPNL)-1	LVRD	22-02-2024	20:19:00	23-02-2024	06:54:00	0.44	0.00	0.00	0.00	10.58		* Line opened on voltage regulation. Bhiwani-792KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-1	LVRD	28-02-2024	17:52:00	29-02-2024	06:42:00	0.54	0.00	0.00	0.00	12.83		* Line opened on voltage regulation. Bhiwani-779kV
							5.18	0.00	0.00	0.00	124.14	100.00	
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	08-02-2024	17:45:00	09-02-2024	06:06:00	0.52	0.00	0.00	0.00	12.35		* Line opened on voltage regulation. Bhiwani-790 KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	24-02-2024	21:36:00	25-02-2024	06:39:00	0.38	0.00	0.00	0.00	9.05		* Line opened on voltage regulation. Bhiwani-790 KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	04-02-2024	14:54:00	05-02-2024	10:04:00	0.80	0.00	0.00	0.00	19.17		* Line opened on voltage regulation. Bhiwani--788KV
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	OSFT	03-02-2024	07:10:00	03-02-2024	12:00:00	0.20	4.83	0.00	0.00	0.00		* Line opened on voltage regulation. Bhiwani-790KV
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	01-02-2024	21:36:00	02-02-2024	06:37:00	0.38	0.00	0.00	0.00	9.02		* Line opened on voltage regulation. Bhiwani-793KV. NR2402-9495/3582
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	20-02-2024	18:41:00	21-02-2024	07:10:00	0.52	0.00	0.00	0.00	12.48		* Line opened on voltage regulation. Bhiwani-790KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	SVRD	23-02-2024	17:21:00	24-02-2024	06:49:00	0.56	0.00	0.00	0.00	13.47		* Line opened on voltage regulation Voltage 780 kV
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	27-02-2024	17:43:00	28-02-2024	06:59:00	0.55	0.00	0.00	0.00	13.27		* Line opened on voltage regulation. Bhiwani-790KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	26-02-2024	18:02:00	27-02-2024	07:46:00	0.57	0.00	0.00	0.00	13.73		* Line opened on voltage regulation. Bhiwani- 790 KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	21-02-2024	18:13:00	22-02-2024	06:47:00	0.52	0.00	0.00	0.00	12.57		* Line opened on voltage regulation. Bhiwani-790KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	13-02-2024	21:31:00	14-02-2024	06:21:00	0.37	0.00	0.00	0.00	8.83		* Line opened on voltage regulation. Bhiwani-790KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	15-02-2024	17:49:00	16-02-2024	06:27:00	0.53	0.00	0.00	0.00	12.63		* Line opened on voltage regulation. Voltage 780 kV
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	29-02-2024	18:28:00	29-02-2024	23:59:59	0.23	0.00	0.00	0.00	5.53		* Line opened on voltage regulation. Bhiwani-790KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	07-02-2024	21:29:00	08-02-2024	06:45:00	0.39	0.00	0.00	0.00	9.27		* Line opened on voltage regulation. Bhiwani-790KV
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	19-02-2024	17:09:00	20-02-2024	08:17:00	0.63	0.00	0.00	0.00	15.13		* Line opened on voltage regulation. Bhiwani-793KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	17-02-2024	23:02:00	18-02-2024	08:16:00	0.39	0.00	0.00	0.00	9.23		* Line opened on voltage regulation. Bhiwani- 790 KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	10-02-2024	21:33:00	11-02-2024	06:56:00	0.39	0.00	0.00	0.00	9.38		* Line opened on voltage regulation. BHIWANI 790KV
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	12-02-2024	21:11:00	13-02-2024	06:48:00	0.40	0.00	0.00	0.00	9.62		* Line opened on voltage regulation. Bhiwani-789KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	05-02-2024	18:37:00	06-02-2024	06:28:00	0.49	0.00	0.00	0.00	11.85		* Line opened on voltage regulation. Bhiwani-790 KV.
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	01-02-2024	00:00:01	01-02-2024	09:16:00	0.39	0.00	0.00	0.00	9.27		* Line opened on voltage regulation. Bhiwani-790kV
CKT	765kV BHIWANI-PHAGI(RRVPNL)-2	LVRD	02-02-2024	23:20:00	03-02-2024	07:09:00	0.33	0.00	0.00	0.00	7.82		* Forced shutdown to attend the B phase insulator snapping issue* in Main Bay Gantry tower (Bus side) at Bhiwani.
							9.54	4.83	0.00	0.00	223.67	99.31	
CKT	765kV BHIWANI-MEERUT	LVRD	24-02-2024	01:36:00	24-02-2024	07:48:00	0.26	0.00	0.00	0.00	6.20		* Line opened on voltage regulation. Bhiwani=798kV
CKT	765kV BHIWANI-MEERUT	OSFT	22-02-2024	13:34:00	22-02-2024	20:20:00	0.28	6.77	0.00	0.00	0.00		* Line opened on voltage regulation. Bhiwani-793KV
CKT	765kV BHIWANI-MEERUT	LVRD	27-02-2024	22:51:00	28-02-2024	09:20:00	0.44	0.00	0.00	0.00	10.48		* Line opened on voltage regulation. Meerut-789KV.
CKT	765kV BHIWANI-MEERUT	LVRD	26-02-2024	23:20:00	27-02-2024	07:30:00	0.34	0.00	0.00	0.00	8.17		* Line opened on voltage regulation. Meerut-795KV.
CKT	765kV BHIWANI-MEERUT	LVRD	01-02-2024	00:00:01	01-02-2024	07:14:00	0.30	0.00	0.00	0.00	7.23		* Line opened on voltage regulation. Bhiwani-790KV.
CKT	765kV BHIWANI-MEERUT	LVRD	26-02-2024	00:13:00	26-02-2024	08:29:00	0.34	0.00	0.00	0.00	8.27		* Emergency Shutdown to attend broken tension type Insulators (R-Ph) at location 450.
CKT	765kV BHIWANI-MEERUT	LVRD	24-02-2024	23:07:00	25-02-2024	09:13:00	0.42	0.00	0.00	0.00	10.10		* Line opened on voltage regulation. Meerut-790kV
CKT	765kV BHIWANI-MEERUT	LVRD	09-02-2024	01:35:00	09-02-2024	05:55:00	0.18	0.00	0.00	0.00	4.33		* Line opened on voltage regulation Voltage.Bhiwani- 780 kV
							2.56	6.77	0.00	0.00	54.78	99.03	
CKT	765kV BHIWANI-MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV-BIKANER-BHADLA2-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV-BIKANER-BHADLA2-ACL-CKT2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BIKANER-MOGA-1	LVRD	28-02-2024	17:42:00	29-02-2024	06:37:00	0.54	0.00	0.00	0.00	12.92		* Line opened on voltage regulation. Bikaner-792KV.
CKT	765kV BIKANER-MOGA-1	LVRD	03-02-2024	16:31:00	04-02-2024	08:12:00	0.65	0.00	0.00	0.00	15.68		* Line opened on voltage regulation. Bikaner-790KV
CKT	765kV BIKANER-MOGA-1	LVRD	01-02-2024	17:43:00	02-02-2024	06:05:00	0.52	0.00	0.00	0.00	12.37		* S/D for diversion work due to infringement of Ganga Expressway* of M/s UPEIDA,S/D till 14.02.2024* 21.02.2024 21:47:49 INDIA (60003382)* Line opened on voltage regulation. Bikaner-790KV.
CKT	765kV BIKANER-MOGA-1	LVRD	21-02-2024	18:09:00	22-02-2024	06:33:00	0.52	0.00	0.00	0.00	12.40		* Line opened on voltage regulation. Bikaner-790KV.
CKT	765kV BIKANER-MOGA-1	SVRD	23-02-2024	18:18:00	24-02-2024	06:09:00	0.49	0.00	0.00	0.00	11.85		* Line opened on voltage regulation. Voltage-790 KV.
CKT	765kV BIKANER-MOGA-1	LVRD	13-02-2024	21:32:00	14-02-2024	06:00:00	0.35	0.00	0.00	0.00	8.47		* Line opened on voltage regulation. Bikaner-782kV
CKT	765kV BIKANER-MOGA-1	LVRD	11-02-2024	17:00:00	12-02-2024	06:35:00	0.57	0.00	0.00	0.00	13.58		* Line opened on voltage regulation. Bikaner-790KV.
CKT	765kV BIKANER-MOGA-1	LVRD	25-02-2024	17:36:00	26-02-2024	08:44:00	0.63	0.00	0.00	0.00	15.13		* Line opened on voltage regulation. Moga=793kv
CKT	765kV BIKANER-MOGA-1	LVRD	09-02-2024	17:11:00	10-02-2024	06:45:00	0.57	0.00	0.00	0.00	13.57		* Line opened on voltage regulation . Bikaner-780kV
CKT	765kV BIKANER-MOGA-1	LVRD	18-02-2024	17:17:00	19-02-2024	08:54:00	0.65	0.00	0.00	0.00	15.62		* Line opened on voltage regulation Voltage 780 K
CKT	765kV BIKANER-MOGA-1	LVRD	05-02-2024	22:05:00	06-02-2024	06:38:00	0.36	0.00	0.00	0.00	8.55		* Line opened on voltage regulation Voltage 780
CKT	765kV BIKANER-MOGA-1	LVRD	20-02-2024	18:15:00	21-02-2024	06:27:00	0.51	0.00	0.00	0.00	12.20		* Line opened on voltage regulation. Bikaner--790KV.
CKT	765kV BIKANER-MOGA-1	LVRD	15-02-2024	17:45:00	16-02-2024	05:21:00	0.48	0.00	0.00	0.00	11.60		* Line opened on voltage regulation . Bikaner-780kV
CKT	765kV BIKANER-MOGA-1	LVRD	07-02-2024	18:54:00	08-02-2024	06:10:00	0.47	0.00	0.00	0.00	11.27		* Line opened on voltage regulation. Bikaner-790 KV
							7.31	0.00	0.00	0.00	175.21	100.00	
CKT	765kV BIKANER-MOGA-2	LVRD	04-02-2024	14:50:00	05-02-2024	07:13:00	0.68	0.00	0.00	0.00	16.38		* Line opened on voltage regulation. Bikaner-790KV.
CKT	765kV BIKANER-MOGA-2	LVRD	01-02-2024	00:00:01	01-02-2024	09:55:00	0.41	0.00	0.00	0.00	9.92		* Line opened on voltage regulation. Bikaner-790KV.
CKT	765kV BIKANER-MOGA-2	LVRD	02-02-2024	16:36:00	03-02-2024	07:46:00	0.63	0.00	0.00	0.00	15.17		* Line opened on voltage regulation. Bikaner-790kV
CKT	765kV BIKANER-MOGA-2	LVRD	19-02-2024	16:54:00	20-02-2024	07:04:00	0.59	0.00	0.00	0.00	14.17		* Line opened on voltage regulation. Bikaner-792KV.
CKT	765kV BIKANER-MOGA-2	LVRD	12-02-2024	21:11:00	13-02-2024	06:43:00	0.40	0.00	0.00	0.00	9.53		* Line opened on voltage regulation. Bikaner-790KV.
CKT	765kV BIKANER-MOGA-2	LVRD	14-02-2024	18:21:00	15-02-2024	05:23:00	0.46	0.00	0.00	0.00	11.03		* Line opened on voltage regulation Voltage 780 kV

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BIKANER-2 AT AJMER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF CHITTORGARH-1 AT AJMER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF CHITTORGARH-2 AT AJMER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF AJMER-2 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BIKANER-2 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF AJMER-1 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BIKANER-1 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BIKANER-1 AT BHADLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BIKANER-2 AT BHADLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF MEERUT AT BHIWANI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KANKAROLI AT BHINMAL	SVRD	01-02-2024	00:00:01	07-02-2024	18:07:00	6.76	0.00	0.00	0.00	162.12	100.00	* BR opened on voltage regulation.Voltage-396kV
							6.76	0.00	0.00	0.00	162.12	100.00	
LNR	330MVAR,SWLR OF BHADLA2-1 AT BIKANER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BHADLA2-2 AT BIKANER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF MOGA-1 AT BIKANER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF MOGA-2 AT BIKANER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHADLA-2 AT BIKANER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHADLA-1 AT BIKANER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BANSKANTA-2 AT CHITORGRH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BANSKANTA-1 AT CHITORGRH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF AJMER-2 AT CHITTORGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF AJMER-1 AT CHITTORGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHADLA1-2 AT FATEHGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHADLA1-1 AT FATEHGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHIWANI-2 AT PHAGI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHIWANI-1 AT PHAGI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF AGRA AT JHATIKARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF ALIGARH AT JHATIKARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF ZERDA AT KANKROLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF GR.NOIDA AT MEERUT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF AGRA-2 AT SIKAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF AGRA-1 AT SIKAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	Coupling Xmer 550MVA 400/34.5kV	OSPT	25-02-2024	21:20:00	26-02-2024	05:28:00	0.34	8.13	0.00	0.00	0.00		* S/D for RTV coating and AMP of STATCOM-1

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.34	8.13	0.00	0.00	0.00	98.83	
STATCOM	Coupling Xmer 550MVA 400/34.5kV	OSFT	12-02-2024	18:20:00	12-02-2024	23:09:00	0.20	4.82	0.00	0.00	0.00		* Forced shutdown for checking the supply of IR sensor.
							0.20	4.82	0.00	0.00	0.00	99.31	
STATCOM	Coupling Xmer ST-1 550MVA 400/34.5kV			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	Coupling Xmer ST-2 550MVA 400/34.5kV	OMST	04-02-2024	12:27:00	04-02-2024	15:14:00	0.12	2.78	0.00	0.00	0.00		* Tripped due to operation of Earth fault relay of Main Sw. Board of STATCOM-2 causing tripping of cooling system of VSC
							0.12	2.78	0.00	0.00	0.00	99.60	
SVC	- 300/+ 400MVAR SVC AT KANKROLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC CHAMPA-KURUKSHETRA POLE-1	OSFT	04-02-2024	11:31:00	04-02-2024	13:35:00	0.09	2.07	0.00	0.00	0.00		* DC Line transient fault on HVDC Champa-Kurukshetra positive poles i.e.* Pole-1 Kurukshetra End -66.642km, Tower No. 3290;* Champa End - 1221.3km, Tower No. 3292.Fault under Meerut TL* jurisdiction.
							0.09	2.07	0.00	0.00	0.00	99.70	
VALVE_HALL	800kV HVDC CHAMPA-KURUKSHETRA POLE-1	LART	26-02-2024	17:26:00	26-02-2024	17:26:00	0.00	0.00	0.00	0.00	0.00		* Forced Shutdown for replacing 5008 card in Pole 1 Measurement Panel.
							0.09	2.07	0.00	0.00	0.00	99.70	
VALVE_HALL	800kV HVDC CHAMPA-KURUKSHETRA POLE-2	OSFT	04-02-2024	11:32:00	04-02-2024	13:36:00	0.09	2.07	0.00	0.00	0.00		* Forced Shutdown for replacing 5008 card in Pole 1 Measurement Panel.
							0.09	2.07	0.00	0.00	0.00	99.70	
VALVE_HALL	800kV HVDC CHAMPA-KURUKSHETRA POLE-3	LART	26-02-2024	17:26:00	26-02-2024	17:26:00	0.00	0.00	0.00	0.00	0.00		* Forced shutdown to attend VBE fail alarm <(>&< replacement of faulty COSI CT in lane-1<(>&<2 of Bipole-2 at Kurukshetra end.
VALVE_HALL	800kV HVDC CHAMPA-KURUKSHETRA POLE-3	OSFT	14-02-2024	12:38:00	14-02-2024	16:56:00	0.18	4.30	0.00	0.00	0.00		* DC Line transient fault on HVDC Champa-Kurukshetra positive poles i.e.* Pole-3 Kurukshetra End -66.642km, Tower No. 3290;* Champa End - 1221.3km, Tower No. 3292.Fault under Meerut TL* jurisdiction.
							0.18	4.30	0.00	0.00	0.00	99.38	
VALVE_HALL	800kV HVDC CHAMPA-KURUKSHETRA POLE-4	OSFT	14-02-2024	12:38:00	14-02-2024	16:58:00	0.18	4.33	0.00	0.00	0.00		* Forced shutdown to attend VBE fail alarm <(>&< replacement of faulty COSI CT in lane-1<(>&<2 of Bipole-2 at Kurukshetra end.
							0.18	4.33	0.00	0.00	0.00	99.38	
XMER	1500MVA,765/400kV ICT-1 AT AJMER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT AJMER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BAGPAT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BAGPAT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BALLABGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BALLABGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT BALLABGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT BALLABGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BASSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BASSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT BASSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT BHADLA-2	SCSD	28-02-2024	20:02:00	29-02-2024	07:03:00	0.46	0.00	0.00	0.00	11.02		* Shutdown for commissioning of 720 Bay
							0.46	0.00	0.00	0.00	11.02	100.00	
XMER	500MVA,400/220kV ICT-4 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-6 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-7 AT BHADLA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BAHADURGARH	OSPT	20-02-2024	11:31:00	20-02-2024	18:23:00	0.29	6.87	0.00	0.00	0.00	99.01	* SD for AMP work.
							0.29	6.87	0.00	0.00	0.00	99.01	
XMER	500MVA,400/220kV ICT-2 AT BAHADURGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BADHLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BADHLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BADHLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BADHLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT BADHLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT BADHLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT BHADLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT BADHLA	OSFT	05-02-2024	21:42:00	06-02-2024	00:31:00	0.12	2.82	0.00	0.00	0.00	99.60	* Hotspot to attend Hot spot in 40689C (R Phase) isolator (Temp 171 degree Celsius)
							0.12	2.82	0.00	0.00	0.00	99.60	
XMER	500MVA,400/220kV ICT-6 AT BHADLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-7 AT BADHLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA ICT-8	OSPT	27-02-2024	17:20:00	28-02-2024	03:19:00	0.42	9.98	0.00	0.00	0.00	98.57	* Shutdown for AMP works NR 2402-9465
							0.42	9.98	0.00	0.00	0.00	98.57	
XMER	315MVA,400/220kV ICT-1 AT BHIWADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHIWADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT BHIWADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BHIWANI	OSFT	10-02-2024	20:16:00	10-02-2024	22:27:00	0.09	2.18	0.00	0.00	0.00	99.69	* Forced Shutdown to replace the faulty cable.
							0.09	2.18	0.00	0.00	0.00	99.69	
XMER	1000MVA,765/400kV ICT-1 AT BHIWANI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHIWANI	OSFT	17-02-2024	13:52:00	17-02-2024	18:02:00	0.17	4.17	0.00	0.00	0.00	98.24	* Forced S/D to attend the LA THRC value discrepancy.
							0.17	4.17	0.00	0.00	0.00	98.24	
XMER	315MVA,400/220kV ICT-2 AT BHIWANI	OSPT	15-02-2024	11:21:00	15-02-2024	19:25:00	0.34	8.07	0.00	0.00	0.00	98.24	* Shutdwn for Annual Maintenance Planned works.
							0.51	12.24	0.00	0.00	0.00	98.24	
XMER	1000MVA,765/400kV ICT-2 AT BHIWANI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1000MVA,765/400kV ICT-3 AT BHIWANI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BHINMAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHINMAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BIKANER	OSPT	20-02-2024	18:45:00	21-02-2024	04:16:00	0.40	9.52	0.00	0.00	0.00	98.63	* Shutdown for AMP works
							0.40	9.52	0.00	0.00	0.00	98.63	
XMER	1500MVA,765/400kV ICT-1 AT BIKANER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BIKANER	OSPT	19-02-2024	18:12:00	20-02-2024	06:25:00	0.51	12.22	0.00	0.00	0.00	98.24	* Shutdown for AMP works.
							0.51	12.22	0.00	0.00	0.00	98.24	
XMER	1500MVA,765/400kV ICT-2 AT BIKANER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT BIKANER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT MEERUT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MEERUT	OSPT	27-02-2024	11:38:00	27-02-2024	18:24:00	0.28	6.77	0.00	0.00	0.00	99.03	* SD for AMP work NR 2402- 9340
							0.28	6.77	0.00	0.00	0.00	99.03	
XMER	1500MVA,765/400kV ICT-2 AT MEERUT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT MEERUT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT MEERUT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT MUZAFFARNAGAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT NEEMRANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT NEEMRANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT ROORKEE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT ROORKEE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT ROORKEE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SAHARANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SAHARANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SAHARANPUR	OSPT	23-02-2024	10:15:00	23-02-2024	19:06:00	0.37	8.85	0.00	0.00	0.00	98.73	* Shutdown for Annual Maintenance Planned works.
							0.37	8.85	0.00	0.00	0.00	98.73	
XMER	315MVA,400/220kV ICT-1 AT SIKAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SIKAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SIKAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SONIPAT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SONIPAT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SONIPAT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUGHLAKABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUGHLAKABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT TUGHLAKABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT TUGHLAKABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	