

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/23/2025	10:08:00 AM	2/23/2025	3:54:00 PM	0.24	0.00	0.00	0.00	5.77		* BR opened on voltage regulation. Voltage=392 KV.
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/28/2025	10:03:00 AM	2/28/2025	4:16:00 PM	0.26	0.00	0.00	0.00	6.22		* BR opened on voltage regulation. Voltage=405KV.
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/7/2025	11:28:00 AM	2/7/2025	4:19:00 PM	0.20	0.00	0.00	0.00	4.85		* BR opened on voltage regulation. Voltage=395 KV
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/9/2025	10:18:00 AM	2/9/2025	5:08:00 PM	0.29	0.00	0.00	0.00	6.83		* BR opened on voltage regulation. Voltage=394 KV
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/12/2025	9:48:00 AM	2/12/2025	4:03:00 PM	0.26	0.00	0.00	0.00	6.25		* BR opened on voltage regulation. Voltage=395KV.
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/8/2025	9:47:00 AM	2/8/2025	6:43:00 PM	0.37	0.00	0.00	0.00	8.93		* BR opened on voltage regulation. Voltage=
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/1/2025	10:36:00 AM	2/1/2025	3:54:00 PM	0.22	0.00	0.00	0.00	5.30		* BR opened on voltage regulation. Voltage=396kV
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/2/2025	9:46:00 AM	2/2/2025	3:57:00 PM	0.26	0.00	0.00	0.00	6.18		* BR opened on voltage regulation. Voltage=393 kV
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/18/2025	11:05:00 AM	2/18/2025	3:50:00 PM	0.20	0.00	0.00	0.00	4.75		* BR opened on voltage regulation. Voltage=393 KV
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/17/2025	10:00:00 AM	2/17/2025	4:53:00 PM	0.29	0.00	0.00	0.00	6.88		* BR opened on voltage regulation. Voltage=393 KV
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/27/2025	9:39:00 AM	2/27/2025	4:59:00 PM	0.31	0.00	0.00	0.00	7.33		* BR opened on voltage regulation. Voltage=397 KV
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/24/2025	9:44:00 AM	2/24/2025	4:15:00 PM	0.27	0.00	0.00	0.00	6.52		* BR opened on voltage regulation. Voltage=392 KV.
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/25/2025	9:26:00 AM	2/25/2025	1:25:00 PM	0.17	0.00	0.00	0.00	3.98		* BR opened on voltage regulation. Voltage=392 KV
BSR	125MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/26/2025	10:17:00 AM	2/26/2025	2:55:00 PM	0.19	0.00	0.00	0.00	4.63		* BR opened on voltage regulation. Voltage=392 KV
							3.53	0.00	0.00	0.00	84.42	100.00	
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/17/2025	9:06:00 AM	2/17/2025	3:40:00 PM	0.27	0.00	0.00	0.00	6.57		* BR opened on voltage regulation. Voltage=755 KV.
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/5/2025	9:21:00 AM	2/5/2025	3:52:00 PM	0.27	0.00	0.00	0.00	6.52		* BR opened on voltage regulation. Voltage=754 KV
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/18/2025	9:13:00 AM	2/18/2025	3:51:00 PM	0.28	0.00	0.00	0.00	6.63		* BR opened on voltage regulation. Voltage=755 KV.
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/24/2025	9:26:00 AM	2/24/2025	5:05:00 PM	0.32	0.00	0.00	0.00	7.65		* BR opened on voltage regulation. Voltage=754 KV.
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/25/2025	9:33:00 AM	2/25/2025	1:19:00 PM	0.16	0.00	0.00	0.00	3.77		* BR opened on voltage regulation. Voltage=754 KV
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/26/2025	10:16:00 AM	2/26/2025	2:51:00 PM	0.19	0.00	0.00	0.00	4.58		* BR opened on voltage regulation. Voltage=754 KV
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/23/2025	10:21:00 AM	2/23/2025	3:19:00 PM	0.21	0.00	0.00	0.00	4.97		* BR opened on voltage regulation. Voltage=755 KV.
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/28/2025	10:24:00 AM	2/28/2025	4:35:00 PM	0.26	0.00	0.00	0.00	6.18		* BR opened on voltage regulation. Voltage=762KV.
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/16/2025	9:18:00 AM	2/16/2025	3:33:00 PM	0.26	0.00	0.00	0.00	6.25		* BR opened on voltage regulation. Voltage=754 KV.
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/10/2025	9:48:00 AM	2/10/2025	4:25:00 PM	0.28	0.00	0.00	0.00	6.62		* BR opened on voltage regulation. Voltage=755 KV.
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/15/2025	9:32:00 AM	2/15/2025	4:18:00 PM	0.28	0.00	0.00	0.00	6.77		* BR opened on voltage regulation. Voltage=754 KV.
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/7/2025	9:14:00 AM	2/7/2025	4:16:00 PM	0.29	0.00	0.00	0.00	7.03		* BR opened on voltage regulation. Voltage=756 KV
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/2/2025	9:42:00 AM	2/2/2025	3:55:00 PM	0.26	0.00	0.00	0.00	6.22		* BR opened on voltage regulation. Voltage=759 KV
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/8/2025	9:07:00 AM	2/8/2025	4:33:00 PM	0.31	0.00	0.00	0.00	7.43		* BR opened on voltage regulation. Voltage=755 KV
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/9/2025	9:32:00 AM	2/9/2025	4:02:00 PM	0.27	0.00	0.00	0.00	6.50		* BR opened on voltage regulation. Voltage=755 KV
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/12/2025	9:48:00 AM	2/12/2025	4:57:00 PM	0.30	0.00	0.00	0.00	7.15		* BR opened on voltage regulation. Voltage=758KV
BSR	240MVAR.BUS REACTOR-1 AT AJMER	SVRD	2/1/2025	9:35:00 AM	2/1/2025	3:31:00 PM	0.25	0.00	0.00	0.00	5.93		* BR opened on voltage regulation. Voltage=760kV
							4.46	0.00	0.00	0.00	106.77	100.00	
BSR	125MVAR.BUS REACTOR-1 AT BAGPAT			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR.BUS REACTOR-1 AT BALLABGARH	SVRD	2/15/2025	11:09:00 AM	2/15/2025	3:23:00 PM	0.18	0.00	0.00	0.00	4.23		* BR opened on voltage regulation. Voltage=394 KV.
							0.18	0.00	0.00	0.00	4.62	100.00	
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/17/2025	11:48:00 AM	2/17/2025	4:25:00 PM	0.19	0.00	0.00	0.00	4.62		* BR opened on voltage regulation. Voltage=393 KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/18/2025	11:00:00 AM	2/18/2025	3:49:00 PM	0.20	0.00	0.00	0.00	4.82		* BR opened on voltage regulation. Voltage=393 KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/25/2025	9:17:00 AM	2/25/2025	4:59:00 PM	0.32	0.00	0.00	0.00	7.70		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/23/2025	9:11:00 AM	2/23/2025	3:15:00 PM	0.25	0.00	0.00	0.00	6.07		* BR opened on voltage regulation. Voltage=393 KV.
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/24/2025	10:03:00 AM	2/24/2025	3:54:00 PM	0.24	0.00	0.00	0.00	5.85		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/26/2025	10:06:00 AM	2/26/2025	4:25:00 PM	0.26	0.00	0.00	0.00	6.32		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/28/2025	10:04:00 AM	2/28/2025	4:03:00 PM	0.25	0.00	0.00	0.00	5.98		* BR opened on voltage regulation. Voltage=397KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/27/2025	9:30:00 AM	2/27/2025	4:44:00 PM	0.30	0.00	0.00	0.00	7.23		* BR opened on voltage regulation. Voltage=394 KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/16/2025	9:05:00 AM	2/16/2025	4:26:00 PM	0.31	0.00	0.00	0.00	7.35		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/15/2025	10:21:00 AM	2/15/2025	6:09:00 PM	0.33	0.00	0.00	0.00	8.00		* BR opened on voltage regulation. Voltage=392 KV.
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/1/2025	9:51:00 AM	2/1/2025	5:35:00 PM	0.32	0.00	0.00	0.00	7.73		* BR opened on voltage regulation. Voltage=396kV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/2/2025	9:26:00 AM	2/2/2025	3:51:00 PM	0.27	0.00	0.00	0.00	6.42		* BR opened on voltage regulation. Voltage=395 KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/10/2025	9:49:00 AM	2/10/2025	6:27:00 PM	0.36	0.00	0.00	0.00	8.63		* BR opened on voltage regulation. Voltage=394 KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/12/2025	9:27:00 AM	2/12/2025	3:44:00 PM	0.26	0.00	0.00	0.00	6.28		* BR opened on voltage regulation. Voltage=393KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/7/2025	6:51:00 AM	2/7/2025	7:20:00 PM	0.52	0.00	0.00	0.00	12.48		* BR opened on voltage regulation. Voltage=395 KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/8/2025	7:35:00 AM	2/8/2025	6:34:00 PM	0.46	0.00	0.00	0.00	10.98		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-1 AT BASSI	SVRD	2/9/2025	9:28:00 AM	2/9/2025	5:04:00 PM	0.32	0.00	0.00	0.00	7.60		* BR opened on voltage regulation. Voltage=394 KV
							5.16	0.00	0.00	0.00	123.86	100.00	
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/27/2025	9:32:00 AM	2/27/2025	4:46:00 PM	0.30	0.00	0.00	0.00	7.23		* BR opened on voltage regulation. Voltage=394 KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/17/2025	11:46:00 AM	2/17/2025	4:21:00 PM	0.19	0.00	0.00	0.00	4.58		* BR opened on voltage regulation. Voltage=393 KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/18/2025	10:59:00 AM	2/18/2025	3:48:00 PM	0.20	0.00	0.00	0.00	4.82		* BR opened on voltage regulation. Voltage=393 KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/23/2025	9:14:00 AM	2/23/2025	3:32:00 PM	0.26	0.00	0.00	0.00	6.30		* BR opened on voltage regulation. Voltage=392 KV.
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/26/2025	10:04:00 AM	2/26/2025	5:09:00 PM	0.30	0.00	0.00	0.00	7.08		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/24/2025	10:05:00 AM	2/24/2025	3:52:00 PM	0.24	0.00	0.00	0.00	5.78		* BR opened on voltage regulation. Voltage=392 KV.
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/25/2025	9:17:00 AM	2/25/2025	4:57:00 PM	0.32	0.00	0.00	0.00	7.67		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/28/2025	10:05:00 AM	2/28/2025	4:04:00 PM	0.25	0.00	0.00	0.00	5.98		* BR opened on voltage regulation. Voltage=397KV.
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/16/2025	9:33:00 AM	2/16/2025	4:25:00 PM	0.29	0.00	0.00	0.00	6.87		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/15/2025	10:22:00 AM	2/15/2025	6:08:00 PM	0.32	0.00	0.00	0.00	7.77		* BR opened on voltage regulation. Voltage=392 KV.
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/8/2025	7:37:00 AM	2/8/2025	6:25:00 PM	0.45	0.00	0.00	0.00	10.80		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/10/2025	9:42:00 AM	2/10/2025	6:28:00 PM	0.37	0.00	0.00	0.00	8.77		* BR opened on voltage regulation. Voltage=394 KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/9/2025	9:27:00 AM	2/9/2025	5:09:00 PM	0.32	0.00	0.00	0.00	7.20		* BR opened on voltage regulation. Voltage=394 KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/2/2025	9:25:00 AM	2/2/2025	4:38:00 PM	0.30	0.00	0.00	0.00	7.22		* BR opened on voltage regulation. Voltage=395 KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/7/2025	6:50:00 AM	2/7/2025	6:05:00 PM	0.47	0.00	0.00	0.00	11.25		* BR opened on voltage regulation. Voltage=395 KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/12/2025	9:28:00 AM	2/12/2025	4:03:00 PM	0.27	0.00	0.00	0.00	6.58		* BR opened on voltage regulation. Voltage=393KV
BSR	50MVAR.BUS REACTOR-2 AT BASSI	SVRD	2/1/2025	9:53:00 AM	2/1/2025	5:39:00 PM	0.32	0.00	0.00	0.00	7.77		* BR opened on voltage regulation. Voltage=395kV
							5.17	0.00	0.00	0.00	124.17	100.00	
BSR	50MVAR.BUS REACTOR-3 AT BASSI	SVRD	2/17/2025	11:46:00 AM	2/17/2025	4:21:00 PM	0.19	0.00	0.00	0.00	4.58		* BR opened on voltage regulation. Voltage=393 KV
BSR	50MVAR.BUS REACTOR-3 AT BASSI	SVRD	2/25/2025	9:17:00 AM	2/26/2025	1:04:00 AM	0.66	0.00	0.00	0.00	15.78		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-3 AT BASSI	SVRD	2/27/2025	9:32:00 AM	2/27/2025	4:46:00 PM	0.30	0.00	0.00	0.00	7.23		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-3 AT BASSI	SVRD	2/23/2025	9:13:00 AM	2/23/2025	3:20:00 PM	0.26	0.00	0.00	0.00	6.12		* BR opened on voltage regulation. Voltage=392 KV.
BSR	50MVAR.BUS REACTOR-3 AT BASSI	SVRD	2/26/2025	10:04:00 AM	2/26/2025	8:57:00 PM	0.45	0.00	0.00	0.00	10.88		* BR opened on voltage regulation. Voltage=392 KV
BSR	50MVAR.BUS REACTOR-3 AT BASSI	SVRD	2/24/2025	10:05:00 AM									

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE To ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR.BUS REACTOR-3 AT BASSI	SVRD	2/18/2025	10:59:00 AM	2/18/2025	8:55:00 PM	0.41	0.00	0.00	0.00	9.93	100.00	* BR opened on voltage regulation. Voltage-393 KV
							7.09	0.00	0.00	0.00	170.14		
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/23/2025	9:32:00 AM	2/23/2025	3:15:00 PM	0.24	0.00	0.00	0.00	5.72		* BR opened on voltage regulation. Voltage-391 KV.
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/25/2025	9:18:00 AM	2/26/2025	1:05:00 AM	0.66	0.00	0.00	0.00	15.78		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/26/2025	10:06:00 AM	2/26/2025	8:58:00 PM	0.45	0.00	0.00	0.00	10.87		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/28/2025	10:04:00 AM	2/28/2025	9:28:00 PM	0.48	0.00	0.00	0.00	11.40		* BR opened on voltage regulation. Voltage-397KV.
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/24/2025	10:03:00 AM	2/24/2025	3:54:00 PM	0.24	0.00	0.00	0.00	5.87		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/16/2025	9:05:00 AM	2/16/2025	4:26:00 PM	0.31	0.00	0.00	0.00	7.35		* BR opened on voltage regulation. Voltage-390KV.
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/15/2025	10:20:00 AM	2/15/2025	6:09:00 PM	0.33	0.00	0.00	0.00	7.82		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/8/2025	7:35:00 AM	2/8/2025	6:34:00 PM	0.46	0.00	0.00	0.00	10.98		* BR opened on voltage regulation Voltage 392 KV
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/10/2025	9:48:00 AM	2/10/2025	9:52:00 PM	0.50	0.00	0.00	0.00	12.07		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/9/2025	9:29:00 AM	2/9/2025	5:05:00 PM	0.32	0.00	0.00	0.00	7.60		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/7/2025	6:50:00 AM	2/7/2025	6:04:00 PM	0.47	0.00	0.00	0.00	11.23		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/12/2025	9:27:00 AM	2/12/2025	3:45:00 PM	0.26	0.00	0.00	0.00	6.30		* BR opened on voltage regulation. Voltage-393KV.
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/1/2025	9:51:00 AM	2/2/2025	4:38:00 PM	1.28	0.00	0.00	0.00	30.78		* BR opened on voltage regulation. Voltage-395kv.
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/7/2025	6:50:00 AM	2/7/2025	6:04:00 PM	0.47	0.00	0.00	0.00	11.23		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/27/2025	9:31:00 AM	2/27/2025	4:45:00 PM	0.30	0.00	0.00	0.00	7.23		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/22/2025	8:54:00 AM	2/22/2025	4:31:00 PM	0.32	0.00	0.00	0.00	7.62		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/18/2025	10:42:00 AM	2/18/2025	8:56:00 PM	0.43	0.00	0.00	0.00	10.23		* BR opened on voltage regulation. Voltage-393 KV
BSR	125MVAR.BUS REACTOR-4 AT BASSI	SVRD	2/17/2025	11:48:00 AM	2/17/2025	4:25:00 PM	0.19	0.00	0.00	0.00	4.62		* BR opened on voltage regulation. Voltage-393 KV
							7.71	0.00	0.00	0.00	184.70	100.00	
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/27/2025	9:35:00 AM	2/27/2025	5:30:00 PM	0.33	0.00	0.00	0.00	7.92		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/26/2025	10:08:00 AM	2/26/2025	4:31:00 PM	0.27	0.00	0.00	0.00	6.38		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/25/2025	9:36:00 AM	2/25/2025	4:51:00 PM	0.30	0.00	0.00	0.00	7.25		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/24/2025	7:15:00 AM	2/24/2025	6:50:00 PM	0.48	0.00	0.00	0.00	11.58		* BR opened on voltage regulation. Voltage-400KV.
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/16/2025	9:08:00 AM	2/16/2025	4:37:00 PM	0.31	0.00	0.00	0.00	7.48		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/1/2025	12:00:01 AM	2/1/2025	4:07:00 PM	0.67	0.00	0.00	0.00	16.12		* BR opened on voltage regulation. Voltage-396KV.
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/15/2025	9:52:00 AM	2/15/2025	6:26:00 PM	0.36	0.00	0.00	0.00	8.57		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/10/2025	9:36:00 AM	2/10/2025	6:06:00 PM	0.35	0.00	0.00	0.00	8.50		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/9/2025	9:15:00 AM	2/9/2025	5:42:00 PM	0.35	0.00	0.00	0.00	8.45		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/12/2025	9:36:00 AM	2/14/2025	6:21:00 PM	2.37	0.00	0.00	0.00	56.75		* BR opened on voltage regulation. Voltage-392KV.
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/2/2025	9:27:00 AM	2/2/2025	4:03:00 PM	0.28	0.00	0.00	0.00	6.60		* BR opened on voltage regulation. Voltage-395 KV
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/7/2025	10:55:00 AM	2/7/2025	5:31:00 PM	0.28	0.00	0.00	0.00	6.60		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/8/2025	9:14:00 AM	2/8/2025	6:32:00 PM	0.39	0.00	0.00	0.00	9.30		* BR opened on voltage regulation Voltage 392 KV
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/17/2025	9:37:00 AM	2/17/2025	4:43:00 PM	0.30	0.00	0.00	0.00	7.10		* BR opened on voltage regulation. Voltage-393 KV
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/18/2025	10:07:00 AM	2/18/2025	4:16:00 PM	0.26	0.00	0.00	0.00	6.15		* BR opened on voltage regulation. Voltage-393 KV
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/23/2025	9:40:00 AM	2/23/2025	4:33:00 PM	0.29	0.00	0.00	0.00	6.88		* BR opened on voltage regulation. Voltage-393 KV.
BSR	125MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/28/2025	10:52:00 AM	2/28/2025	4:21:00 PM	0.23	0.00	0.00	0.00	5.48		* BR opened on voltage regulation. Voltage-397KV.
							7.82	0.00	0.00	0.00	187.11	100.00	
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/17/2025	9:10:00 AM	2/17/2025	4:09:00 PM	0.29	0.00	0.00	0.00	6.98		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/24/2025	9:23:00 AM	2/24/2025	5:17:00 PM	0.33	0.00	0.00	0.00	7.90		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/26/2025	9:23:00 AM	2/26/2025	4:31:00 PM	0.30	0.00	0.00	0.00	7.13		* BR opened on voltage regulation. Voltage-754 KV
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/23/2025	9:17:00 AM	2/23/2025	4:29:00 PM	0.30	0.00	0.00	0.00	7.20		* BR opened on voltage regulation. Voltage-754 KV
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/28/2025	10:26:00 AM	2/28/2025	5:22:00 PM	0.29	0.00	0.00	0.00	6.93		* BR opened on voltage regulation. Voltage-757KV.
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/27/2025	11:30:00 AM	2/27/2025	4:23:00 PM	0.20	0.00	0.00	0.00	4.88		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/25/2025	9:33:00 AM	2/25/2025	4:28:00 PM	0.29	0.00	0.00	0.00	6.92		* BR opened on voltage regulation. Voltage-754 KV
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/22/2025	9:20:00 AM	2/22/2025	6:00:00 PM	0.36	0.00	0.00	0.00	7.57		* BR opened on voltage regulation. Voltage-752 KV
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/18/2025	9:17:00 AM	2/18/2025	3:42:00 PM	0.27	0.00	0.00	0.00	6.42		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/15/2025	9:29:00 AM	2/15/2025	5:31:00 PM	0.34	0.00	0.00	0.00	8.03		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/5/2025	9:15:00 AM	2/5/2025	5:24:00 PM	0.34	0.00	0.00	0.00	8.15		* BR opened on voltage regulation Voltage 758 KV
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/8/2025	9:12:00 AM	2/8/2025	4:48:00 PM	0.32	0.00	0.00	0.00	7.60		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/12/2025	9:36:00 AM	2/12/2025	5:06:00 PM	0.31	0.00	0.00	0.00	7.50		* BR opened on voltage regulation. Voltage-750KV.
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/9/2025	9:30:00 AM	2/9/2025	3:24:00 PM	0.25	0.00	0.00	0.00	5.90		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/10/2025	9:19:00 AM	2/10/2025	4:00:00 PM	0.28	0.00	0.00	0.00	6.68		* BR opened on voltage regulation Voltage 755 KV.
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/13/2025	9:18:00 AM	2/13/2025	5:04:00 PM	0.32	0.00	0.00	0.00	7.77		* BR opened on voltage regulation. V-760kv
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/7/2025	8:26:00 AM	2/7/2025	5:15:00 PM	0.37	0.00	0.00	0.00	8.82		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/2/2025	9:14:00 AM	2/2/2025	4:09:00 PM	0.28	0.00	0.00	0.00	6.77		* BR opened on voltage regulation. Voltage-755 KV
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/1/2025	9:37:00 AM	2/1/2025	4:29:00 PM	0.28	0.00	0.00	0.00	6.87		* BR opened on voltage regulation. Voltage-760KV
BSR	240MVAR.BUS REACTOR-1 AT BHADLA-2	SVRD	2/18/2025	10:06:00 AM	2/18/2025	4:02:00 PM	0.25	0.00	0.00	0.00	5.93		* BR opened on voltage regulation. Voltage-755 KV.
							5.98	0.00	0.00	0.00	143.05	100.00	
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/13/2025	9:18:00 AM	2/13/2025	5:42:00 PM	0.35	0.00	0.00	0.00	8.40		* BR opened on voltage regulation. V-760KV
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/2/2025	9:14:00 AM	2/2/2025	4:00:00 PM	0.28	0.00	0.00	0.00	6.77		* BR opened on voltage regulation. Voltage-755 KV
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/5/2025	9:15:00 AM	2/5/2025	5:20:00 PM	0.34	0.00	0.00	0.00	8.08		* BR opened on voltage regulation Voltage 758 KV
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/8/2025	9:26:00 AM	2/8/2025	6:31:00 PM	0.38	0.00	0.00	0.00	9.08		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/17/2025	9:11:00 AM	2/17/2025	4:09:00 PM	0.29	0.00	0.00	0.00	6.97		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/18/2025	10:06:00 AM	2/18/2025	4:03:00 PM	0.25	0.00	0.00	0.00	5.95		* BR opened on voltage regulation. Voltage-755 KV
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/23/2025	9:18:00 AM	2/23/2025	4:30:00 PM	0.30	0.00	0.00	0.00	7.20		* BR opened on voltage regulation. Voltage-753 KV.
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/28/2025	10:17:00 AM	2/28/2025	4:01:00 PM	0.24	0.00	0.00	0.00	5.73		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/24/2025	9:23:00 AM	2/24/2025	5:17:00 PM	0.33	0.00	0.00	0.00	7.90		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/22/2025	9:21:00 AM	2/22/2025	5:05:00 PM	0.32	0.00	0.00	0.00	7.73		* BR opened on voltage regulation Voltage 752 KV
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/28/2025	11:38:00 AM	2/28/2025	5:23:00 PM	0.24	0.00	0.00	0.00	5.75		* BR opened on voltage regulation. Voltage-397KV.
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/16/2025	9:33:00 AM	2/16/2025	3:43:00 PM	0.26	0.00	0.00	0.00	6.17		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/15/2025	9:48:00 AM	2/15/2025	6:41:00 PM	0.37	0.00	0.00	0.00	8.88		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/7/2025	8:26:00 AM	2/7/2025	5:28:00 PM	0.38	0.00	0.00	0.00	9.03		* BR opened on voltage regulation Voltage 395 KV
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/9/2025	9:49:00 AM	2/9/2025	3:57:00 PM	0.26	0.00	0.00	0.00	6.13		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/12/2025	9:36:00 AM	2/12/2025	5:07:00 PM	0.31	0.00	0.00	0.00	7.52		* BR opened on voltage regulation. Voltage-750KV.
BSR	240MVAR.BUS REACTOR-2 AT BHADLA-2	SVRD	2/1/2025	10:28:00 AM	2/								

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/14/2025	9:02:00 AM	2/14/2025	5:13:00 PM	0.34	0.00	0.00	0.00	8.18		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/15/2025	9:06:00 AM	2/15/2025	6:51:00 PM	0.41	0.00	0.00	0.00	9.75		* BR opened on voltage regulation. Voltage-390 KV.
BSR	125MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/12/2025	9:53:00 AM	2/12/2025	4:18:00 PM	0.27	0.00	0.00	0.00	6.42		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/10/2025	9:30:00 AM	2/10/2025	6:45:00 PM	0.39	0.00	0.00	0.00	9.25		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/9/2025	9:14:00 AM	2/9/2025	5:17:00 PM	0.34	0.00	0.00	0.00	8.05		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/2/2025	9:19:00 AM	2/2/2025	4:00:00 PM	0.28	0.00	0.00	0.00	6.68		* BR opened on voltage regulation. Voltage-394 kV
BSR	125MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/13/2025	9:24:00 AM	2/13/2025	5:10:00 PM	0.32	0.00	0.00	0.00	7.77		* BR opened on voltage regulation. Voltage-393 KV.
BSR	125MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/1/2025	10:02:00 AM	2/1/2025	4:12:00 PM	0.26	0.00	0.00	0.00	6.17		* BR opened on voltage regulation. Voltage-395kV
BSR	125MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/8/2025	9:09:00 AM	2/8/2025	6:26:00 PM	0.39	0.00	0.00	0.00	9.28		* BR opened on voltage regulation Voltage 392 KV
BSR	125MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/7/2025	9:43:00 AM	2/7/2025	5:45:00 PM	0.34	0.00	0.00	0.00	8.03		* BR opened on voltage regulation Voltage 395 KV
							6.41	0.00	0.00	0.00	153.37	100.00	
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/1/2025	9:42:00 AM	2/1/2025	4:31:00 PM	0.28	0.00	0.00	0.00	6.82		* BR opened on voltage regulation. Voltage=760kV
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/2/2025	9:16:00 AM	2/2/2025	4:03:00 PM	0.28	0.00	0.00	0.00	6.78		* BR opened on voltage regulation. Voltage-755 kV
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/13/2025	9:24:00 AM	2/14/2025	9:38:00 PM	1.51	0.00	0.00	0.00	36.23		* BR opened on voltage regulation. V-761kV
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/5/2025	9:23:00 AM	2/5/2025	5:35:00 PM	0.34	0.00	0.00	0.00	8.20		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/9/2025	9:13:00 AM	2/9/2025	3:27:00 PM	0.26	0.00	0.00	0.00	6.23		* BR opened on voltage regulation Voltage 755 KV.
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/7/2025	9:40:00 AM	2/7/2025	5:32:00 PM	0.33	0.00	0.00	0.00	7.67		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/8/2025	9:07:00 AM	2/8/2025	5:06:00 PM	0.33	0.00	0.00	0.00	7.98		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/18/2025	10:09:00 AM	2/18/2025	5:39:00 PM	0.31	0.00	0.00	0.00	7.50		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/17/2025	9:12:00 AM	2/17/2025	4:04:00 PM	0.29	0.00	0.00	0.00	6.87		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/24/2025	9:18:00 AM	2/24/2025	5:16:00 PM	0.33	0.00	0.00	0.00	7.97		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/28/2025	10:25:00 AM	2/28/2025	5:29:00 PM	0.29	0.00	0.00	0.00	7.07		* BR opened on voltage regulation. Voltage-757KV.
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/26/2025	9:25:00 AM	2/26/2025	3:25:00 PM	0.25	0.00	0.00	0.00	6.00		* BR opened on voltage regulation. Voltage-754 KV
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/27/2025	11:34:00 AM	2/27/2025	4:27:00 PM	0.20	0.00	0.00	0.00	4.88		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/22/2025	9:11:00 AM	2/22/2025	4:51:00 PM	0.32	0.00	0.00	0.00	7.67		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/23/2025	9:34:00 AM	2/23/2025	5:30:00 PM	0.33	0.00	0.00	0.00	7.93		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/25/2025	9:31:00 AM	2/25/2025	4:54:00 PM	0.31	0.00	0.00	0.00	7.38		* BR opened on voltage regulation. Voltage-754 KV
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/15/2025	9:03:00 AM	2/15/2025	5:58:00 PM	0.37	0.00	0.00	0.00	8.92		* BR opened on voltage regulation. Voltage-753 KV
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/16/2025	9:16:00 AM	2/16/2025	4:01:00 PM	0.28	0.00	0.00	0.00	6.75		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/12/2025	9:38:00 AM	2/12/2025	4:50:00 PM	0.30	0.00	0.00	0.00	7.20		* BR opened on voltage regulation. Voltage-755KV.
BSR	240MVAR.BUS REACTOR-1 AT BADHLA	SVRD	2/10/2025	9:28:00 AM	2/10/2025	3:55:00 PM	0.27	0.00	0.00	0.00	6.45		* BR opened on voltage regulation Voltage 755 KV.
							7.18	0.00	0.00	0.00	172.70	100.00	
BSR	80MVAR.BUS REACTOR-1 AT BHIWADI	SVRD	2/9/2025	9:07:00 AM	2/9/2025	5:23:00 PM	0.34	0.00	0.00	0.00	8.27		* BR opened on voltage regulation Voltage 394 KV
BSR	80MVAR.BUS REACTOR-1 AT BHIWADI	SVRD	2/7/2025	9:30:00 AM	2/7/2025	3:54:00 PM	0.27	0.00	0.00	0.00	6.40		* BR opened on voltage regulation Voltage 395 KV
BSR	80MVAR.BUS REACTOR-1 AT BHIWADI	SVRD	2/12/2025	9:23:00 AM	2/12/2025	4:22:00 PM	0.29	0.00	0.00	0.00	6.98		* BR opened on voltage regulation. Voltage-396KV.
BSR	80MVAR.BUS REACTOR-1 AT BHIWADI	SVRD	2/8/2025	9:53:00 AM	2/8/2025	6:44:00 PM	0.37	0.00	0.00	0.00	8.85		* BR opened on voltage regulation Voltage
BSR	80MVAR.BUS REACTOR-1 AT BHIWADI	SVRD	2/15/2025	9:31:00 AM	2/15/2025	6:48:00 PM	0.36	0.00	0.00	0.00	8.52		* BR opened on voltage regulation. Voltage-392 KV.
BSR	80MVAR.BUS REACTOR-1 AT BHIWADI	SVRD	2/18/2025	9:37:00 AM	2/18/2025	4:35:00 PM	0.29	0.00	0.00	0.00	6.97		* BR opened on voltage regulation. Voltage-393 KV.
BSR	80MVAR.BUS REACTOR-1 AT BHIWADI	SVRD	2/24/2025	10:18:00 AM	2/24/2025	1:24:00 PM	0.13	0.00	0.00	0.00	3.10		* BR opened on voltage regulation. Voltage-392 KV.
BSR	80MVAR.BUS REACTOR-1 AT BHIWADI	SVRD	2/17/2025	9:50:00 AM	2/17/2025	4:28:00 PM	0.28	0.00	0.00	0.00	6.63		* BR opened on voltage regulation. Voltage-393 KV
							2.33	0.00	0.00	0.00	55.82	100.00	
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/17/2025	10:39:00 AM	2/17/2025	3:38:00 PM	0.21	0.00	0.00	0.00	4.98		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/18/2025	9:28:00 AM	2/18/2025	3:12:00 PM	0.24	0.00	0.00	0.00	5.73		* BR opened on voltage regulation. Voltage-755 KV
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/24/2025	9:45:00 AM	2/24/2025	1:07:00 PM	0.14	0.00	0.00	0.00	3.37		* BR opened on voltage regulation. Voltage-754 KV
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/16/2025	9:44:00 AM	2/16/2025	1:08:00 PM	0.14	0.00	0.00	0.00	3.40		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/12/2025	10:04:00 AM	2/12/2025	5:13:00 PM	0.30	0.00	0.00	0.00	7.15		* BR opened on voltage regulation. Voltage-757KV.
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/15/2025	9:44:00 AM	2/15/2025	3:06:00 PM	0.22	0.00	0.00	0.00	5.27		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/8/2025	9:43:00 AM	2/8/2025	1:33:00 PM	0.16	0.00	0.00	0.00	3.83		* BR opened on voltage regulation Voltage 757 KV
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/9/2025	9:38:00 AM	2/9/2025	1:49:00 PM	0.17	0.00	0.00	0.00	4.18		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/1/2025	10:09:00 AM	2/1/2025	3:26:00 PM	0.22	0.00	0.00	0.00	5.28		* BR opened on voltage regulation. Voltage=760kV
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/5/2025	12:04:00 PM	2/5/2025	3:49:00 PM	0.16	0.00	0.00	0.00	3.75		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/2/2025	11:21:00 AM	2/2/2025	2:15:00 PM	0.12	0.00	0.00	0.00	2.90		* BR opened on voltage regulation. Voltage-759 KV
BSR	240MVAR.BUS REACTOR-1 AT BHIWANI	SVRD	2/7/2025	9:59:00 AM	2/7/2025	3:24:00 PM	0.23	0.00	0.00	0.00	5.42		* BR opened on voltage regulation Voltage 754KV
							2.31	0.00	0.00	0.00	55.36	100.00	
BSR	240MVAR.BUS REACTOR-2 AT BHIWANI	SVRD	2/17/2025	10:54:00 AM	2/17/2025	1:29:00 PM	0.11	0.00	0.00	0.00	2.58		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-2 AT BHIWANI	SVRD	2/18/2025	9:31:00 AM	2/18/2025	3:12:00 PM	0.24	0.00	0.00	0.00	5.68		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-2 AT BHIWANI	SVRD	2/15/2025	10:01:00 AM	2/15/2025	4:13:00 PM	0.30	0.00	0.00	0.00	7.20		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-2 AT BHIWANI	SVRD	2/16/2025	9:34:00 AM	2/16/2025	3:05:00 PM	0.23	0.00	0.00	0.00	5.62		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-2 AT BHIWANI	SVRD	2/1/2025	11:30:00 AM	2/1/2025	3:05:00 PM	0.15	0.00	0.00	0.00	3.58		* BR opened on voltage regulation. Voltage=760kV
BSR	240MVAR.BUS REACTOR-2 AT BHIWANI	SVRD	2/7/2025	9:38:00 AM	2/7/2025	4:45:00 PM	0.30	0.00	0.00	0.00	7.12		* BR opened on voltage regulation Voltage 395 KV
BSR	240MVAR.BUS REACTOR-2 AT BHIWANI	SVRD	2/8/2025	10:33:00 AM	2/8/2025	1:22:00 PM	0.12	0.00	0.00	0.00	2.82		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-2 AT BHIWANI	SVRD	2/9/2025	10:26:00 AM	2/9/2025	3:50:00 PM	0.23	0.00	0.00	0.00	5.40		* BR opened on voltage regulation Voltage 755 KV.
							1.68	0.00	0.00	0.00	39.90	100.00	
BSR	80MVAR.BUS REACTOR-1 AT BHNIMAL	SVRD	2/19/2025	5:08:00 AM	2/19/2025	8:38:00 PM	0.65	0.00	0.00	0.00	15.50		* BR opened on voltage regulation. Voltage-392 KV
BSR	80MVAR.BUS REACTOR-1 AT BHNIMAL	SVRD	2/18/2025	5:23:00 AM	2/18/2025	8:58:00 PM	0.65	0.00	0.00	0.00	15.58		* BR opened on voltage regulation. Voltage-392 KV
BSR	80MVAR.BUS REACTOR-1 AT BHNIMAL	SVRD	2/28/2025	5:45:00 AM	2/28/2025	4:00:00 PM	0.43	0.00	0.00	0.00	10.25		* BR opened on voltage regulation Voltage 394 KV
BSR	80MVAR.BUS REACTOR-1 AT BHNIMAL	SVRD	2/27/2025	5:45:00 AM	2/27/2025	9:47:00 PM	0.63	0.00	0.00	0.00	15.03		* BR opened on voltage regulation. Voltage-392 KV.
BSR	80MVAR.BUS REACTOR-1 AT BHNIMAL	SVRD	2/20/2025	6:14:00 AM	2/20/2025	6:19:00 PM	6.59	0.00	0.00	0.00	156.08		* BR opened on voltage regulation. Voltage-392 KV.
BSR	80MVAR.BUS REACTOR-1 AT BHNIMAL	SVRD	2/12/2025	6:25:00 AM	2/17/2025	9:49:00 PM	5.64	0.00	0.00	0.00	135.40		* BR opened on voltage regulation. V-390KV.
BSR	80MVAR.BUS REACTOR-1 AT BHNIMAL	SVRD	2/1/2025	10:27:00 AM	2/11/2025	9:04:00 PM	10.44	0.00	0.00	0.00	250.62		* BR opened on voltage regulation. Voltage=395kV
							24.94	0.00	0.00	0.00	598.46	100.00	
BSR	125MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/24/2025	7:08:00 AM	2/24/2025	5:53:00 PM	0.45	0.00	0.00	0.00	10.75		* BR opened on voltage regulation. Voltage-400KV.
BSR	125MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/17/2025	9:52:00 AM	2/17/2025	5:24:00 PM	0.31	0.00	0.00	0.00	7.53		* BR opened on voltage regulation. Voltage-393 KV
BSR	125MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/18/2025	10:51:00 AM	2/18/2025	3:23:00 PM	0.19	0.00	0.00	0.00	4.53		* BR opened on voltage regulation. Voltage-393 KV
BSR	125MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/28/2025	10:49:00 AM	2/28/2025	4:35:00 PM	0.24	0.00	0.00	0.00	5.77		* BR opened on voltage regulation. Voltage-398KV.
BSR	125MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/25/2025	9:21:00 AM	2/25/2025	4:46:00 PM	0.31	0.00	0.00	0.00	7.42		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/22/2025	9:17:00 AM	2/22/2025	3:46:00 PM	0.27	0.00	0.00	0.00	6.48		* BR opened on voltage regulation. Voltage 393 KV
BSR	125MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/23/2025	9:28:00 AM	2/23/2025	5:15:00 PM	0.52	0.00	0.00	0.00	7.78</		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/7/2025	9:41:00 AM	2/7/2025	5:51:00 PM	0.34	0.00	0.00	0.00	8.17	100.00	* BR opened on voltage regulation Voltage 395 KV
							5.76	0.00	0.00	0.00	138.29		
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/16/2025	9:20:00 AM	2/16/2025	3:07:00 PM	0.24	0.00	0.00	0.00	5.78		* BR opened on voltage regulation. Voltage-753 KV.
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/22/2025	9:16:00 AM	2/22/2025	3:45:00 PM	0.27	0.00	0.00	0.00	6.48		* BR opened on voltage regulation Voltage 753 KV
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/17/2025	9:22:00 AM	2/17/2025	3:46:00 PM	0.27	0.00	0.00	0.00	6.40		* BR opened on voltage regulation. Voltage-755 KV.
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/27/2025	11:20:00 AM	2/27/2025	4:12:00 PM	0.20	0.00	0.00	0.00	4.87		* BR opened on voltage regulation Voltage 754 KV
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/23/2025	9:26:00 AM	2/23/2025	4:21:00 PM	0.25	0.00	0.00	0.00	5.92		* BR opened on voltage regulation. Voltage-755 KV.
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/25/2025	9:19:00 AM	2/25/2025	4:20:00 PM	0.18	0.00	0.00	0.00	4.35		* BR opened on voltage regulation. Voltage-754 KV
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/28/2025	9:15:00 AM	2/28/2025	3:14:00 PM	0.25	0.00	0.00	0.00	5.98		* BR opened on voltage regulation. Voltage-754 KV
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/24/2025	9:22:00 AM	2/24/2025	4:51:00 PM	0.31	0.00	0.00	0.00	7.48		* BR opened on voltage regulation. Voltage-754 KV.
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/28/2025	10:22:00 AM	2/28/2025	5:32:00 PM	0.30	0.00	0.00	0.00	7.17		* BR opened on voltage regulation. Voltage-397KV.
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/13/2025	9:13:00 AM	2/13/2025	5:44:00 PM	0.36	0.00	0.00	0.00	8.52		* BR opened on voltage regulation. V-753KV
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/2/2025	9:13:00 AM	2/2/2025	3:55:00 PM	0.28	0.00	0.00	0.00	6.70		* BR opened on voltage regulation. Voltage-755 KV
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/15/2025	9:16:00 AM	2/15/2025	5:13:00 PM	0.33	0.00	0.00	0.00	7.95		* BR opened on voltage regulation. Voltage-754 KV.
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/8/2025	9:41:00 AM	2/8/2025	6:02:00 PM	0.35	0.00	0.00	0.00	8.35		* BR opened on voltage regulation Voltage 755 KV
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/12/2025	9:07:00 AM	2/12/2025	4:51:00 PM	0.32	0.00	0.00	0.00	7.73		* BR opened on voltage regulation. Voltage-762KV.
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/6/2025	9:12:00 AM	2/5/2025	3:43:00 PM	0.27	0.00	0.00	0.00	6.52		* BR opened on voltage regulation Voltage 758 KV
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/9/2025	9:11:00 AM	2/9/2025	3:10:00 PM	0.25	0.00	0.00	0.00	5.98		* BR opened on voltage regulation Voltage 755 KV.
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/10/2025	9:15:00 AM	2/10/2025	3:33:00 PM	0.26	0.00	0.00	0.00	6.30		* BR opened on voltage regulation Voltage 755 KV.
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/6/2025	8:51:00 AM	2/6/2025	4:44:00 PM	0.33	0.00	0.00	0.00	7.88		* BR opened on voltage regulation Voltage 755 KV
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/1/2025	10:33:00 AM	2/1/2025	4:16:00 PM	0.24	0.00	0.00	0.00	5.72		* BR opened on voltage regulation. V-760KV
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/7/2025	8:24:00 AM	2/7/2025	4:12:00 PM	0.33	0.00	0.00	0.00	7.80		* BR opened on voltage regulation Voltage 755 KV
BSR	330MVAR.BUS REACTOR-1 AT BIKANER	SVRD	2/18/2025	9:30:00 AM	2/18/2025	3:42:00 PM	0.26	0.00	0.00	0.00	6.20		* BR opened on voltage regulation. Voltage-755 KV.
							5.85	0.00	0.00	0.00	140.08	100.00	
BSR	125MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/17/2025	10:44:00 AM	2/17/2025	5:08:00 PM	0.27	0.00	0.00	0.00	6.40		* BR opened on voltage regulation. Voltage-393 KV
BSR	125MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/23/2025	9:18:00 AM	2/23/2025	5:21:00 PM	0.34	0.00	0.00	0.00	8.05		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/24/2025	10:26:00 AM	2/24/2025	4:06:00 PM	0.24	0.00	0.00	0.00	5.68		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/16/2025	9:36:00 AM	2/16/2025	4:33:00 PM	0.29	0.00	0.00	0.00	6.95		* BR opened on voltage regulation. Voltage-393 KV.
BSR	125MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/15/2025	10:10:00 AM	2/15/2025	5:16:00 PM	0.30	0.00	0.00	0.00	7.10		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/12/2025	10:03:00 AM	2/12/2025	4:07:00 PM	0.25	0.00	0.00	0.00	6.07		* BR opened on voltage regulation. Voltage-393KV.
BSR	125MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/9/2025	10:31:00 AM	2/9/2025	4:09:00 PM	0.24	0.00	0.00	0.00	5.63		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/2/2025	10:41:00 AM	2/2/2025	3:54:00 PM	0.22	0.00	0.00	0.00	5.22		* BR opened on voltage regulation. Voltage-396 KV
BSR	125MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/18/2025	10:39:00 AM	2/18/2025	3:50:00 PM	0.22	0.00	0.00	0.00	5.18		* BR opened on voltage regulation. Voltage-393 KV
							2.37	0.00	0.00	0.00	56.28	100.00	
BSR	240MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/18/2025	10:38:00 AM	2/18/2025	3:45:00 PM	0.21	0.00	0.00	0.00	5.12		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/17/2025	10:44:00 AM	2/17/2025	4:42:00 PM	0.25	0.00	0.00	0.00	5.97		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/24/2025	9:36:00 AM	2/24/2025	1:06:00 PM	0.15	0.00	0.00	0.00	3.50		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/7/2025	9:44:00 AM	2/7/2025	3:32:00 PM	0.24	0.00	0.00	0.00	5.80		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/9/2025	9:42:00 AM	2/9/2025	4:05:00 PM	0.27	0.00	0.00	0.00	6.38		* BR opened on voltage regulation Voltage 755 KV.
BSR	240MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/5/2025	9:24:00 AM	2/5/2025	7:39:00 PM	0.43	0.00	0.00	0.00	10.25		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/2/2025	9:42:00 AM	2/2/2025	4:10:00 PM	0.27	0.00	0.00	0.00	6.47		* BR opened on voltage regulation. Voltage-752 KV
BSR	240MVAR.BUS REACTOR-1 AT CHITTORGARH	SVRD	2/8/2025	9:35:00 AM	2/8/2025	1:10:00 PM	0.15	0.00	0.00	0.00	3.58		* BR opened on voltage regulation Voltage 751 KV
							1.97	0.00	0.00	0.00	47.07	100.00	
BSR	80MVAR.BUS REACTOR-1 AT DEHRADUN	SVRD	2/12/2025	9:55:00 AM	2/12/2025	3:42:00 PM	0.24	0.00	0.00	0.00	5.78		* BR opened on voltage regulation. Voltage-396KV.
							0.24	0.00	0.00	0.00	5.78	100.00	
BSR	125MVAR.BUS REACTOR-1 AT DWARKA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	125MVAR.BUS REACTOR-1 AT FATEHGARH-2	SVRD	2/1/2025	12:00:01 AM	2/28/2025	11:59:59 PM	28.00	0.00	0.00	0.00	672.00		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-1 AT FATEHGARH-2	SVRD	2/25/2025	9:15:00 AM	2/28/2025	4:53:00 PM	3.32	0.00	0.00	0.00	79.63		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT FATEHGARH-2	SVRD	2/24/2025	9:31:00 AM	2/24/2025	6:31:00 PM	0.38	0.00	0.00	0.00	9.00		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT FATEHGARH-2	SVRD	2/1/2025	12:00:01 AM	2/23/2025	4:40:00 PM	22.69	0.00	0.00	0.00	544.67		* BR opened on voltage regulation. Voltage-395 KV.
							54.39	0.00	0.00	0.00	1,305.30	100.00	
BSR	240MVAR.BUS REACTOR-1 AT FATEHGARH-2	SVRD	2/24/2025	7:22:00 AM	2/28/2025	11:59:59 PM	4.69	0.00	0.00	0.00	112.63		* BR opened on voltage regulation. Voltage-760KV.
BSR	240MVAR.BUS REACTOR-1 AT FATEHGARH-2	SVRD	2/15/2025	7:55:00 AM	2/23/2025	4:38:00 PM	8.36	0.00	0.00	0.00	200.72		* BR opened on voltage regulation. Voltage-756 KV.
BSR	240MVAR.BUS REACTOR-1 AT FATEHGARH-2	SVRD	2/1/2025	12:00:01 AM	2/3/2025	10:28:00 PM	2.94	0.00	0.00	0.00	70.47		* BR opened on voltage regulation. Voltage=770kv
BSR	240MVAR.BUS REACTOR-1 AT FATEHGARH-2	SVRD	2/12/2025	6:48:00 AM	2/14/2025	9:35:00 PM	2.62	0.00	0.00	0.00	62.78		* BR opened on voltage regulation. Voltage-756 KV
BSR	240MVAR.BUS REACTOR-1 AT FATEHGARH-2	SVRD	2/4/2025	6:38:00 AM	2/10/2025	10:02:00 PM	6.04	0.00	0.00	0.00	159.40		* BR opened on voltage regulation. V-757KV
							25.25	0.00	0.00	0.00	806.00	100.00	
BSR	240MVAR.BUS REACTOR-2 AT FATEHGARH-2	SVRD	2/25/2025	8:56:00 AM	2/28/2025	11:59:59 PM	3.63	0.00	0.00	0.00	87.07		* BR opened on voltage regulation. Voltage-754 KV
BSR	240MVAR.BUS REACTOR-2 AT FATEHGARH-2	SVRD	2/20/2025	7:42:00 AM	2/23/2025	4:30:00 PM	3.37	0.00	0.00	0.00	80.80		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-2 AT FATEHGARH-2	SVRD	2/24/2025	7:23:00 AM	2/24/2025	5:50:00 PM	0.44	0.00	0.00	0.00	10.45		* BR opened on voltage regulation. Voltage-760KV.
BSR	240MVAR.BUS REACTOR-2 AT FATEHGARH-2	SVRD	2/15/2025	7:55:00 AM	2/18/2025	9:17:00 PM	3.56	0.00	0.00	0.00	85.37		* BR opened on voltage regulation. Voltage-756 KV.
BSR	240MVAR.BUS REACTOR-2 AT FATEHGARH-2	SVRD	2/12/2025	6:49:00 AM	2/14/2025	9:46:00 PM	2.62	0.00	0.00	0.00	62.95		* BR opened on voltage regulation. Voltage-756 KV.
BSR	240MVAR.BUS REACTOR-2 AT FATEHGARH-2	SVRD	2/4/2025	6:48:00 AM	2/10/2025	9:34:00 PM	6.62	0.00	0.00	0.00	158.77		* BR opened on voltage regulation. V-757KV
BSR	240MVAR.BUS REACTOR-2 AT FATEHGARH-2	SVRD	2/1/2025	12:00:01 AM	2/3/2025	10:22:00 PM	2.93	0.00	0.00	0.00	70.37		* BR opened on voltage regulation. Voltage=770KV
							23.17	0.00	0.00	0.00	565.78	100.00	
BSR	50MVAR.BUS REACTOR-1 AT HISAR	SVRD	2/16/2025	9:58:00 AM	2/16/2025	4:29:00 PM	0.27	0.00	0.00	0.00	6.52		* BR opened on voltage regulation. Voltage-394 KV.
BSR	50MVAR.BUS REACTOR-1 AT HISAR	SVRD	2/17/2025	11:56:00 AM	2/17/2025	4:54:00 PM	0.21	0.00	0.00	0.00	4.87		* BR opened on voltage regulation. Voltage-393 KV
BSR	50MVAR.BUS REACTOR-1 AT HISAR	SVRD	2/24/2025	10:22:00 AM	2/24/2025	1:10:00 PM	0.12	0.00	0.00	0.00	2.80		* BR opened on voltage regulation. Voltage-392 KV.
BSR	50MVAR.BUS REACTOR-1 AT HISAR	SVRD	2/15/2025	10:42:00 AM	2/15/2025	3:25:00 PM	0.20	0.00	0.00	0.00	4.72		* BR opened on voltage regulation. Voltage-392 KV.
BSR	50MVAR.BUS REACTOR-1 AT HISAR	SVRD	2/7/2025	10:19:00 AM	2/7/2025	3:46:00 PM	0.23	0.00	0.00	0.00	5.45		* BR opened on voltage regulation Voltage 395 KV
BSR	50MVAR.BUS REACTOR-1 AT HISAR	SVRD	2/12/2025	9:42:00 AM	2/12/2025	3:54:00 PM	0.26	0.00	0.00	0.00	6.20		* BR opened on voltage regulation. Voltage-395KV.
BSR	50MVAR.BUS REACTOR-1 AT HISAR	SVRD	2/8/2025	10:02:00 AM	2/8/2025	6:21:00 PM	0.35	0.00	0.00	0.00	8.32		* BR opened on voltage regulation Voltage 395 KV
BSR	50MVAR.BUS REACTOR-1 AT HISAR	SVRD	2/18/2025	9:55:00 AM	2/18/2025	4:09:00 PM	0.26	0.00	0.00	0.00	6.23		* BR opened on voltage regulation. Voltage-393 KV
							1.90	0.00	0.00	0.00	45.21	100.00	
BSR	125MVAR.BUS REACTOR-2 AT HISAR	SVRD	2/7/2025	10:21:00 AM	2/7/2025	4:36:00 PM	0.26	0.00	0.00	0.00	6.25		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-2 AT HISAR	SVRD	2/8/2025	10:03:00 AM	2/8/2025	6:25:00 PM	0.35	0.00	0.00	0.00	8.37		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-2 AT HISAR	SVRD	2/5/2025	11:35:00 AM	2/5/2025	3:59:00 PM	0.18	0.00	0.00	0.00	4.40		* BR opened on voltage regulation Voltage 395 KV
							0.79	0.00	0.00	0.00	19.02	100.00	
BSR	125MVAR. BUS RECTOR-3 AT HISAR	SVRD	2/16/2025	9:13:00 AM	2/16/2025	4:27:							

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/2/2025	9:29:00 AM	2/2/2025	4:03:00 PM	0.27	0.00	0.00	0.00	6.57		* BR opened on voltage regulation. Voltage-392 kV
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/1/2025	9:42:00 AM	2/1/2025	5:06:00 PM	0.31	0.00	0.00	0.00	7.40		* BR opened on voltage regulation. Voltage-395kV
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/12/2025	9:26:00 AM	2/12/2025	4:15:00 PM	0.28	0.00	0.00	0.00	6.82		* BR opened on voltage regulation. Voltage-394kV.
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/10/2025	9:58:00 AM	2/10/2025	6:24:00 PM	0.35	0.00	0.00	0.00	8.43		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/8/2025	9:56:00 AM	2/8/2025	6:28:00 PM	0.36	0.00	0.00	0.00	8.53		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/15/2025	10:26:00 AM	2/15/2025	5:24:00 PM	0.29	0.00	0.00	0.00	6.97		* BR opened on voltage regulation. Voltage-393 KV.
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/14/2025	9:06:00 AM	2/14/2025	5:15:00 PM	0.34	0.00	0.00	0.00	8.15		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/16/2025	9:12:00 AM	2/16/2025	4:45:00 PM	0.32	0.00	0.00	0.00	7.55		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/26/2025	10:01:00 AM	2/26/2025	3:41:00 PM	0.24	0.00	0.00	0.00	5.67		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/25/2025	9:38:00 AM	2/25/2025	1:44:00 PM	0.17	0.00	0.00	0.00	4.10		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/23/2025	9:14:00 AM	2/23/2025	3:33:00 PM	0.26	0.00	0.00	0.00	6.32		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/21/2025	9:02:00 AM	2/21/2025	3:54:00 PM	0.29	0.00	0.00	0.00	6.87		* BR opened on voltage regulation. Voltage-396KV.
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/27/2025	9:29:00 AM	2/27/2025	4:50:00 PM	0.31	0.00	0.00	0.00	7.35		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/28/2025	10:08:00 AM	2/28/2025	4:22:00 PM	0.26	0.00	0.00	0.00	6.23		* BR opened on voltage regulation. Voltage-397KV.
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/24/2025	10:34:00 AM	2/24/2025	4:10:00 PM	0.23	0.00	0.00	0.00	5.60		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-1 AT JAIPUR SOUTH	SVRD	2/17/2025	9:51:00 AM	2/17/2025	4:47:00 PM	0.29	0.00	0.00	0.00	6.93		* BR opened on voltage regulation. Voltage-393 KV
							5.55	0.00	0.00	0.00	133.09	100.00	
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/27/2025	9:30:00 AM	2/27/2025	4:51:00 PM	0.31	0.00	0.00	0.00	7.35		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/24/2025	10:35:00 AM	2/24/2025	1:34:00 PM	0.12	0.00	0.00	0.00	2.98		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/28/2025	10:08:00 AM	2/28/2025	4:23:00 PM	0.26	0.00	0.00	0.00	6.25		* BR opened on voltage regulation. Voltage-397KV.
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/2/2025	9:30:00 AM	2/2/2025	4:03:00 PM	0.27	0.00	0.00	0.00	6.55		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/10/2025	9:59:00 AM	2/10/2025	6:25:00 PM	0.35	0.00	0.00	0.00	8.43		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/12/2025	9:25:00 AM	2/12/2025	4:16:00 PM	0.29	0.00	0.00	0.00	6.85		* BR opened on voltage regulation. Voltage-394KV.
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/13/2025	9:10:00 AM	2/13/2025	4:41:00 PM	0.31	0.00	0.00	0.00	7.52		* BR opened on voltage regulation. V-389KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/9/2025	9:45:00 AM	2/9/2025	4:15:00 PM	0.27	0.00	0.00	0.00	6.50		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/8/2025	9:57:00 AM	2/8/2025	6:29:00 PM	0.36	0.00	0.00	0.00	8.53		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/7/2025	11:32:00 AM	2/7/2025	4:38:00 PM	0.21	0.00	0.00	0.00	5.10		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/1/2025	9:43:00 AM	2/1/2025	5:07:00 PM	0.31	0.00	0.00	0.00	7.40		* BR opened on voltage regulation. Voltage-395KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/14/2025	9:06:00 AM	2/14/2025	5:14:00 PM	0.34	0.00	0.00	0.00	8.13		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/15/2025	10:31:00 AM	2/15/2025	5:24:00 PM	0.29	0.00	0.00	0.00	6.88		* BR opened on voltage regulation. Voltage-393 KV.
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/16/2025	9:13:00 AM	2/16/2025	4:45:00 PM	0.31	0.00	0.00	0.00	7.53		* BR opened on voltage regulation. Voltage-393 KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/26/2025	10:01:00 AM	2/26/2025	3:41:00 PM	0.24	0.00	0.00	0.00	5.67		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/25/2025	9:38:00 AM	2/25/2025	1:44:00 PM	0.17	0.00	0.00	0.00	4.10		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/17/2025	9:52:00 AM	2/17/2025	4:47:00 PM	0.29	0.00	0.00	0.00	6.92		* BR opened on voltage regulation. Voltage-393 KV
BSR	125MVAR.BUS REACTOR-2 AT JAIPUR SOUTH	SVRD	2/18/2025	10:56:00 AM	2/18/2025	3:32:00 PM	0.19	0.00	0.00	0.00	4.60		* BR opened on voltage regulation. Voltage-393 KV
							4.89	0.00	0.00	0.00	117.29	100.00	
BSR	240MVAR.BUS REACTOR-1 AT PHAGI	SVRD	2/25/2025	9:52:00 AM	2/25/2025	4:56:00 PM	0.29	0.00	0.00	0.00	7.07		* Shutdown for Relay testing differential, REF, OC EF.
							0.29	0.00	0.00	0.00	7.07	100.00	
BSR	240MVAR.BUS REACTOR-1 AT JHATIKARA	SVRD	2/5/2025	11:46:00 AM	2/5/2025	1:52:00 PM	0.09	0.00	0.00	0.00	2.10		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR.BUS REACTOR-1 AT JHATIKARA	SVRD	2/8/2025	10:19:00 AM	2/8/2025	1:37:00 PM	0.14	0.00	0.00	0.00	3.30		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-1 AT JHATIKARA	SVRD	2/15/2025	10:05:00 AM	2/15/2025	4:32:00 PM	0.27	0.00	0.00	0.00	6.45		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT JHATIKARA	SVRD	2/17/2025	10:49:00 AM	2/17/2025	4:03:00 PM	0.22	0.00	0.00	0.00	5.23		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-1 AT JHATIKARA	SVRD	2/12/2025	9:45:00 AM	2/12/2025	3:35:00 PM	0.24	0.00	0.00	0.00	5.83		* BR opened on voltage regulation. Voltage-760KV.
BSR	240MVAR.BUS REACTOR-1 AT JHATIKARA	SVRD	2/7/2025	10:08:00 AM	2/7/2025	3:18:00 PM	0.22	0.00	0.00	0.00	5.17		* BR opened on voltage regulation Voltage 395 KV
BSR	240MVAR.BUS REACTOR-1 AT JHATIKARA	SVRD	2/9/2025	10:28:00 AM	2/9/2025	2:04:00 PM	0.15	0.00	0.00	0.00	3.60		* BR opened on voltage regulation Voltage 755 KV.
BSR	240MVAR.BUS REACTOR-1 AT JHATIKARA	SVRD	2/18/2025	9:38:00 AM	2/18/2025	3:28:00 PM	0.24	0.00	0.00	0.00	5.83		* BR opened on voltage regulation. Voltage-755 KV
							1.57	0.00	0.00	0.00	37.51	100.00	
BSR	240MVAR.BUS REACTOR-2 AT JHATIKARA	SVRD	2/17/2025	10:49:00 AM	2/17/2025	1:31:00 PM	0.11	0.00	0.00	0.00	2.70		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-2 AT JHATIKARA	SVRD	2/18/2025	9:37:00 AM	2/18/2025	3:28:00 PM	0.24	0.00	0.00	0.00	5.85		* BR opened on voltage regulation. Voltage-755 KV
BSR	240MVAR.BUS REACTOR-2 AT JHATIKARA	SVRD	2/24/2025	9:32:00 AM	2/24/2025	1:08:00 PM	0.15	0.00	0.00	0.00	3.60		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-2 AT JHATIKARA	SVRD	2/5/2025	9:15:00 AM	2/5/2025	5:25:00 PM	0.34	0.00	0.00	0.00	8.17		* BR opened on voltage regulation Voltage 758 KV
BSR	240MVAR.BUS REACTOR-2 AT JHATIKARA	SVRD	2/15/2025	9:11:00 AM	2/15/2025	3:31:00 PM	0.26	0.00	0.00	0.00	6.33		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-2 AT JHATIKARA	SVRD	2/7/2025	9:25:00 AM	2/7/2025	4:05:00 PM	0.28	0.00	0.00	0.00	6.67		* BR opened on voltage regulation Voltage 758 KV
BSR	240MVAR.BUS REACTOR-2 AT JHATIKARA	SVRD	2/9/2025	9:40:00 AM	2/9/2025	3:11:00 PM	0.23	0.00	0.00	0.00	5.52		* BR opened on voltage regulation Voltage 755 KV.
BSR	240MVAR.BUS REACTOR-2 AT JHATIKARA	SVRD	2/1/2025	10:08:00 AM	2/1/2025	1:29:00 PM	0.14	0.00	0.00	0.00	3.35		* BR opened on voltage regulation. Voltage=760kV
BSR	240MVAR.BUS REACTOR-2 AT JHATIKARA	SVRD	2/8/2025	9:31:00 AM	2/8/2025	12:47:00 PM	0.14	0.00	0.00	0.00	3.27		* BR opened on voltage regulation Voltage 756 KV
BSR	240MVAR.BUS REACTOR-2 AT JHATIKARA	SVRD	2/16/2025	9:57:00 AM	2/16/2025	1:14:00 PM	0.14	0.00	0.00	0.00	3.28		* BR opened on voltage regulation. Voltage-754 KV.
							2.03	0.00	0.00	0.00	48.74	100.00	
BSR	125MVAR.BUS REACTOR-1 AT JIND			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	25MVAR.BUS REACTOR-2 AT JIND	OSPT	2/1/2025	9:28:00 AM	2/1/2025	6:47:00 PM	0.39	9.32	0.00	0.00	0.00		* Shutdown for AMP work
							0.39	9.32	0.00	0.00	0.00	98.61	
BSR	125MVAR.BUS REACTOR-1 AT KANKROLI	SVRD	2/9/2025	9:11:00 AM	2/9/2025	9:10:00 PM	0.50	0.00	0.00	0.00	11.98		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-1 AT KANKROLI	SVRD	2/8/2025	9:03:00 AM	2/8/2025	9:36:00 PM	0.52	0.00	0.00	0.00	12.55		* BR opened on voltage regulation Voltage 392 KV
BSR	125MVAR.BUS REACTOR-1 AT KANKROLI	SVRD	2/10/2025	6:04:00 AM	2/10/2025	6:11:00 PM	0.51	0.00	0.00	0.00	12.12		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT KANKROLI	SVRD	2/1/2025	9:16:00 AM	2/2/2025	11:00:00 PM	1.57	0.00	0.00	0.00	37.73		* BR opened on voltage regulation. Voltage=395KV
BSR	125MVAR.BUS REACTOR-1 AT KANKROLI	SVRD	2/12/2025	9:25:00 AM	2/12/2025	4:35:00 PM	0.30	0.00	0.00	0.00	7.17		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR.BUS REACTOR-1 AT KANKROLI	SVRD	2/2/2025	7:14:00 AM	2/7/2025	9:45:00 PM	0.52	0.00	0.00	0.00	14.52		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-1 AT KANKROLI	SVRD	2/15/2025	9:57:00 AM	2/15/2025	5:24:00 PM	0.31	0.00	0.00	0.00	7.45		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT KANKROLI	SVRD	2/13/2025	10:34:00 AM	2/14/2025	8:43:00 PM	1.42	0.00	0.00	0.00	34.15		* BR opened on voltage regulation. V-389KV
							5.74	0.00	0.00	0.00	137.67	100.00	
BSR	50MVAR.BUS REACTOR-2 AT KANKROLI	SVRD	2/18/2025	11:19:00 AM	2/18/2025	6:00:00 PM	0.28	0.00	0.00	0.00	6.68		* BR opened on voltage regulation. Voltage-393 KV
BSR	50MVAR.BUS REACTOR-2 AT KANKROLI	SVRD	2/12/2025	9:25:00 AM	2/12/2025	4:36:00 PM	0.30	0.00	0.00	0.00	7.18		* BR opened on voltage regulation. Voltage-395KV.
BSR	50MVAR.BUS REACTOR-2 AT KANKROLI	SVRD	2/9/2025	9:09:00 AM	2/9/2025	9:11:00 PM	0.50	0.00	0.00	0.00	12.03		* BR opened on voltage regulation Voltage 394 KV
BSR	50MVAR.BUS REACTOR-2 AT KANKROLI	SVRD	2/8/2025	9:35:00 AM	2/8/2025	9:37:00 PM	0.50	0.00	0.00	0.00	12.03		* BR opened on voltage regulation Voltage 392 KV
BSR	50MVAR.BUS REACTOR-2 AT KANKROLI	SVRD	2/2/2025	10:33:00 AM	2/2/2025	8:39:00 PM	0.42	0.00	0.00	0.00	10.10		* BR opened on voltage regulation. Voltage-395 KV
BSR	50MVAR.BUS REACTOR-2 AT KANKROLI	SVRD	2/10/2025	10:03:00 AM	2/10/2025	9:10:00 PM	0.34	0.00	0.00	0.00	9.72		* BR opened on voltage regulation. Voltage-395KV.
BSR	50MVAR.BUS REACTOR-2 AT KANKROLI	SVRD	2/17/2025	9:44:00 AM	2/17/2025	4:56:00 PM	0.30	0.00	0.00	0.00	9.00		* BR opened on voltage regulation. Voltage-393 KV
BSR	50MVAR.BUS REACTOR-2 AT KANKROLI	OSPT	2/24/2025	9:49:00 AM	2/25/2025	10							

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR.BUS REACTOR-1 AT KOTESHWAR	SVRD	2/8/2025	11:11:00 AM	2/8/2025	1:05:00 PM	0.08	0.00	0.00	0.00	1.90		* BR opened on voltage regulation Voltage 756 KV.
BSR	240MVAR.BUS REACTOR-1 AT KOTESHWAR	SVRD	2/8/2025	11:11:00 AM	2/8/2025	1:05:00 PM	0.08	0.00	0.00	0.00	1.90		* BR opened on voltage regulation Voltage 752 KV
							0.16	0.00	0.00	0.00	3.80	100.00	
BSR	80MVAR.BUS REACTOR-1 AT KOTA	SVRD	2/2/2025	10:11:00 AM	2/2/2025	6:08:00 PM	0.33	0.00	0.00	0.00	7.95		* BR opened on voltage regulation. Voltage-395 kV
BSR	80MVAR.BUS REACTOR-1 AT KOTA	SVRD	2/23/2025	11:25:00 AM	2/24/2025	5:52:00 PM	1.27	0.00	0.00	0.00	30.45		* BR opened on voltage regulation. Voltage-393 KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTA	SVRD	2/1/2025	10:11:00 AM	2/1/2025	5:40:00 PM	0.31	0.00	0.00	0.00	7.48		* BR opened on voltage regulation. Voltage=395kV
							1.91	0.00	0.00	0.00	45.88	100.00	
BSR	50MVAR.BUS REACTOR-2 AT KOTA	SVRD	2/2/2025	10:53:00 AM	2/2/2025	6:08:00 PM	0.30	0.00	0.00	0.00	7.25		* BR opened on voltage regulation. Voltage-398 kV
							0.30	0.00	0.00	0.00	7.25	100.00	
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/28/2025	9:23:00 AM	2/28/2025	4:01:00 PM	0.28	0.00	0.00	0.00	6.63		* BR opened on voltage regulation. Voltage-400KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/26/2025	10:07:00 AM	2/26/2025	4:22:00 PM	0.26	0.00	0.00	0.00	6.25		* BR opened on voltage regulation. Voltage-392 KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/21/2025	9:00:00 AM	2/21/2025	4:12:00 PM	0.30	0.00	0.00	0.00	7.20		* BR opened on voltage regulation. Voltage-390KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/25/2025	9:27:00 AM	2/25/2025	4:47:00 PM	0.31	0.00	0.00	0.00	7.33		* BR opened on voltage regulation. Voltage-392 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/1/2025	9:09:00 AM	2/1/2025	5:33:00 PM	0.35	0.00	0.00	0.00	8.40		* BR opened on voltage regulation. Voltage-395 KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/16/2025	9:15:00 AM	2/16/2025	6:55:00 PM	0.40	0.00	0.00	0.00	9.67		* BR opened on voltage regulation. Voltage-393 KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/10/2025	9:37:00 AM	2/10/2025	6:02:00 PM	0.35	0.00	0.00	0.00	8.42		* BR opened on voltage regulation Voltage 394 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/14/2025	9:58:00 AM	2/14/2025	9:22:00 PM	0.52	0.00	0.00	0.00	12.40		* BR opened on voltage regulation. Voltage-395KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/15/2025	9:08:00 AM	2/15/2025	6:48:00 PM	0.40	0.00	0.00	0.00	9.65		* BR opened on voltage regulation. Voltage-392 KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/7/2025	6:40:00 AM	2/7/2025	5:59:00 PM	0.47	0.00	0.00	0.00	11.32		* BR opened on voltage regulation Voltage 395 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/12/2025	6:26:00 AM	2/12/2025	3:55:00 PM	0.40	0.00	0.00	0.00	9.48		* BR opened on voltage regulation. Voltage-392 KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/8/2025	7:31:00 AM	2/8/2025	6:21:00 PM	0.45	0.00	0.00	0.00	10.83		* BR opened on voltage regulation Voltage 392 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/2/2025	9:28:00 AM	2/2/2025	6:01:00 PM	0.36	0.00	0.00	0.00	8.55		* BR opened on voltage regulation. Voltage-392 kV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/5/2025	9:18:00 AM	2/5/2025	4:21:00 PM	0.29	0.00	0.00	0.00	7.05		* BR opened on voltage regulation Voltage 394 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/9/2025	9:13:00 AM	2/9/2025	5:21:00 PM	0.34	0.00	0.00	0.00	8.13		* BR opened on voltage regulation Voltage 394 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/23/2025	9:11:00 AM	2/23/2025	3:22:00 PM	0.26	0.00	0.00	0.00	6.18		* BR opened on voltage regulation. Voltage-393 KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/24/2025	9:28:00 AM	2/24/2025	6:18:00 PM	0.37	0.00	0.00	0.00	8.83		* BR opened on voltage regulation. Voltage-392 KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/27/2025	9:33:00 AM	2/27/2025	4:55:00 PM	0.31	0.00	0.00	0.00	7.37		* BR opened on voltage regulation Voltage 396 KV
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/18/2025	6:30:00 AM	2/18/2025	5:57:00 PM	0.48	0.00	0.00	0.00	11.45		* BR opened on voltage regulation. Voltage-392 KV.
BSR	80MVAR.BUS REACTOR-1 AT KOTPUTLI	SVRD	2/17/2025	9:16:00 AM	2/17/2025	4:48:00 PM	0.31	0.00	0.00	0.00	7.53		* BR opened on voltage regulation. Voltage-393 KV
							7.21	0.00	0.00	0.00	172.67	100.00	
BSR	125MVAR.BUS REACTOR-1 AT KURUKSHETRA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR.BUS REACTOR-1 AT MANDOLA	SCSD	2/15/2025	7:56:00 AM	2/15/2025	9:46:00 PM	0.58	0.00	0.00	0.00	13.83		* Shutdown for jack bus replacement at Mandola.
BSR	50MVAR.BUS REACTOR-1 AT MANDOLA	SCSD	2/21/2025	8:08:00 AM	2/22/2025	10:45:00 PM	1.61	0.00	0.00	0.00	38.62		* Shutdown for jack bus replacement at Mandola.
							2.19	0.00	0.00	0.00	52.45	100.00	
BSR	125MVAR.BUS REACTOR-2 AT MANDOLA	SVRD	2/23/2025	11:03:00 AM	2/23/2025	9:00:00 PM	0.42	0.00	0.00	0.00	9.95		* Shutdown for jack bus replacement at Mandola.
BSR	125MVAR.BUS REACTOR-2 AT MANDOLA	SCSD	2/25/2025	8:13:00 AM	2/26/2025	9:39:00 PM	1.56	0.00	0.00	0.00	37.43		* Shutdown for jack bus replacement at Mandola
							1.98	0.00	0.00	0.00	47.38	100.00	
BSR	25MVAR.BUS REACTOR-3 AT MANDOLA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	2/12/2025	9:40:00 AM	2/12/2025	3:55:00 PM	0.26	0.00	0.00	0.00	6.25		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	2/6/2025	9:50:00 AM	2/10/2025	9:54:00 PM	4.50	0.00	0.00	0.00	108.07		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	2/2/2025	10:44:00 AM	2/2/2025	3:45:00 PM	0.21	0.00	0.00	0.00	5.02		* BR opened on voltage regulation. Voltage-398 kV
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	2/1/2025	9:23:00 AM	2/1/2025	4:45:00 PM	0.31	0.00	0.00	0.00	7.37		* BR opened on voltage regulation. Voltage=395kV
BSR	125MVAR.BUS REACTOR-1 AT MANESAR	SVRD	2/22/2025	10:07:00 AM	2/26/2025	1:23:00 AM	3.64	0.00	0.00	0.00	87.27		* BR opened on voltage regulation Voltage 395 KV
							8.92	0.00	0.00	0.00	213.98	100.00	
BSR	125MVAR.BUS REACTOR-2 AT MANESAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR.400KV BUS Reactor at MAHARANIBAG			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/10/2025	9:26:00 AM	2/10/2025	8:58:00 PM	0.48	0.00	0.00	0.00	11.53		* BR opened on voltage regulation Voltage 755 KV.
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/12/2025	9:08:00 AM	2/12/2025	1:48:00 PM	0.19	0.00	0.00	0.00	4.67		* BR opened on voltage regulation. Voltage-758KV.
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/13/2025	9:11:00 AM	2/13/2025	1:02:00 PM	0.16	0.00	0.00	0.00	3.85		* BR opened on voltage regulation. V-755kV
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/5/2025	9:19:00 AM	2/5/2025	4:07:00 PM	0.28	0.00	0.00	0.00	6.80		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/8/2025	9:17:00 AM	2/8/2025	1:08:00 PM	0.16	0.00	0.00	0.00	3.85		* BR opened on voltage regulation Voltage 392 KV
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/9/2025	9:00:00 AM	2/9/2025	1:50:00 PM	0.20	0.00	0.00	0.00	4.83		* BR opened on voltage regulation Voltage 755 KV.
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/18/2025	9:24:00 AM	2/18/2025	3:15:00 PM	0.24	0.00	0.00	0.00	5.85		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/16/2025	9:18:00 AM	2/16/2025	1:12:00 PM	0.16	0.00	0.00	0.00	3.88		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/17/2025	9:16:00 AM	2/17/2025	1:28:00 PM	0.18	0.00	0.00	0.00	4.20		* BR opened on voltage regulation. Voltage-755 KV.
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/26/2025	9:17:00 AM	2/26/2025	3:37:00 PM	0.26	0.00	0.00	0.00	6.33		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/24/2025	9:48:00 AM	2/24/2025	1:05:00 PM	0.14	0.00	0.00	0.00	3.28		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/15/2025	9:25:00 AM	2/15/2025	3:07:00 PM	0.24	0.00	0.00	0.00	5.70		* BR opened on voltage regulation. Voltage-754 KV.
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/14/2025	9:00:00 AM	2/14/2025	12:33:00 PM	0.15	0.00	0.00	0.00	3.55		* BR opened on voltage regulation. Voltage-758KV.
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/1/2025	9:10:00 AM	2/1/2025	1:32:00 PM	0.18	0.00	0.00	0.00	4.37		* BR opened on voltage regulation. Voltage=770kV
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/6/2025	8:50:00 AM	2/6/2025	1:06:00 PM	0.18	0.00	0.00	0.00	4.27		* BR opened on voltage regulation Voltage 755 KV
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/7/2025	8:32:00 AM	2/7/2025	4:11:00 PM	0.32	0.00	0.00	0.00	7.65		* BR opened on voltage regulation Voltage 754 KV
BSR	240MVAR.BUS REACTOR-1 AT MEERUT	SVRD	2/2/2025	9:14:00 AM	2/2/2025	2:18:00 PM	0.21	0.00	0.00	0.00	5.07		* BR opened on voltage regulation. Voltage-755 KV
							3.73	0.00	0.00	0.00	89.68	100.00	
BSR	100MVAR. BUS REACTOR-2 AT MEERUT			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR.BUS REACTOR-1 AT MEERUT			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR.BUS REACTOR-1 AT MURADNAGAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR.BUS REACTOR-1 AT NEEMRANA	SVRD	2/10/2025	10:11:00 AM	2/10/2025	6:49:00 PM	0.36	0.00	0.00	0.00	8.63		* BR opened on voltage regulation Voltage 394 KV
BSR	80MVAR.BUS REACTOR-1 AT NEEMRANA	SVRD	2/1/2025	10:39:00 AM	2/1/2025	4:48:00 PM	0.26	0.00	0.00	0.00	6.15		* BR opened on voltage regulation. Voltage=395kV
BSR	80MVAR.BUS REACTOR-1 AT NEEMRANA	SVRD	2/17/2025	11:05:00 AM	2/17/2025	4:34:00 PM	0.23	0.00	0.00	0.00	5.48		* BR opened on voltage regulation. Voltage-393 KV
							0.85	0.00	0.00	0.00	20.26	100.00	
BSR	125MVAR.BUS REACTOR-1 AT RATANGARH			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR.BUS REACTOR-1 AT ROORKEE	SVRD	2/12/2025	9:49:00 AM	2/12/2025	3:48:00 PM	0.25	0.00	0.00	0.00	5.98		* BR opened on voltage regulation. Voltage-395KV.
BSR	125MVAR.BUS REACTOR-1 AT ROORKEE	SVRD	2/15/2025	10:54:00 AM	2/15/2025	3:35:00 PM	0.20	0.00	0.00	0.00	4.68		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-1 AT ROORKEE	SVRD	2/16/2025	10:03:00 AM	2/16/2025	1:19:00 PM	0.14	0.00	0.00	0.00	3.27		* BR opened on voltage regulation. Voltage-391 KV.
							0.59	0.00	0.00	0.00	13.93	100.00	
BSR	50MVAR.BUS REACTOR-1 AT SAHARANPUR	SVRD	2/23/2025	9:21:00 AM	2/24/2025	5:51:00 PM	1						

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR.BUS REACTOR-1 AT SAHARANPUR	SVRD	2/7/2025	9:18:00 AM	2/7/2025	4:16:00 PM	0.29	0.00	0.00	0.00	6.97		* BR opened on voltage regulation Voltage 395 KV
BSR	50MVAR.BUS REACTOR-1 AT SAHARANPUR	SVRD	2/2/2025	9:38:00 AM	2/2/2025	3:58:00 PM	0.26	0.00	0.00	0.00	6.33		* BR opened on voltage regulation. Voltage-393 KV
							4.26	0.00	0.00	0.00	102.39	100.00	
BSR	50MVAR.BUS REACTOR-2 AT SAHARANPUR	SVRD	2/23/2025	9:21:00 AM	2/24/2025	5:51:00 PM	1.35	0.00	0.00	0.00	32.50		* BR opened on voltage regulation. Voltage-392 KV.
BSR	50MVAR.BUS REACTOR-2 AT SAHARANPUR	SVRD	2/17/2025	9:18:00 AM	2/17/2025	4:36:00 PM	0.30	0.00	0.00	0.00	7.30		* BR opened on voltage regulation. Voltage-393 KV
BSR	50MVAR.BUS REACTOR-2 AT SAHARANPUR	SVRD	2/15/2025	10:03:00 AM	2/16/2025	8:50:00 PM	1.45	0.00	0.00	0.00	34.78		* BR opened on voltage regulation. Voltage-392 KV.
BSR	50MVAR.BUS REACTOR-2 AT SAHARANPUR	SVRD	2/2/2025	9:38:00 AM	2/2/2025	3:58:00 PM	0.26	0.00	0.00	0.00	6.33		* BR opened on voltage regulation. Voltage-393 KV
BSR	50MVAR.BUS REACTOR-2 AT SAHARANPUR	SVRD	2/12/2025	9:51:00 AM	2/12/2025	3:44:00 PM	0.25	0.00	0.00	0.00	5.88		* BR opened on voltage regulation. Voltage-393KV.
BSR	50MVAR.BUS REACTOR-2 AT SAHARANPUR	SVRD	2/7/2025	9:18:00 AM	2/7/2025	4:16:00 PM	0.29	0.00	0.00	0.00	6.97		* BR opened on voltage regulation Voltage 395 KV
BSR	50MVAR.BUS REACTOR-2 AT SAHARANPUR	SVRD	2/8/2025	9:38:00 AM	2/8/2025	6:16:00 PM	0.36	0.00	0.00	0.00	8.63		* BR opened on voltage regulation Voltage 392 KV
							4.26	0.00	0.00	0.00	102.39	100.00	
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/16/2025	9:05:00 AM	2/16/2025	4:27:00 PM	0.31	0.00	0.00	0.00	7.37		* BR opened on voltage regulation. Voltage-392 KV.
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/7/2025	9:27:00 AM	2/7/2025	5:05:00 PM	0.32	0.00	0.00	0.00	7.63		* BR opened on voltage regulation Voltage 395 KV
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/12/2025	10:09:00 AM	2/12/2025	3:59:00 PM	0.24	0.00	0.00	0.00	5.83		* BR opened on voltage regulation. Voltage-390KV.
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/26/2025	10:14:00 AM	2/26/2025	4:49:00 PM	0.27	0.00	0.00	0.00	6.58		* BR opened on voltage regulation. Voltage-392 KV
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/9/2025	9:03:00 AM	2/9/2025	5:13:00 PM	0.34	0.00	0.00	0.00	8.17		* BR opened on voltage regulation Voltage 394 KV
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/2/2025	9:52:00 AM	2/2/2025	3:46:00 PM	0.25	0.00	0.00	0.00	5.90		* BR opened on voltage regulation. Voltage-395 KV
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/10/2025	10:01:00 AM	2/10/2025	6:37:00 PM	0.36	0.00	0.00	0.00	8.60		* BR opened on voltage regulation Voltage 394 KV
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/8/2025	10:41:00 AM	2/8/2025	6:35:00 PM	0.33	0.00	0.00	0.00	7.90		* BR opened on voltage regulation Voltage 395 KV
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/15/2025	10:00:00 AM	2/15/2025	6:03:00 PM	0.34	0.00	0.00	0.00	8.05		* BR opened on voltage regulation. Voltage-392 KV.
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/1/2025	11:45:00 AM	2/1/2025	4:46:00 PM	0.21	0.00	0.00	0.00	5.02		* BR opened on voltage regulation. Voltage-395KV
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/27/2025	9:30:00 AM	2/27/2025	5:11:00 PM	0.32	0.00	0.00	0.00	7.68		* BR opened on voltage regulation Voltage 393 KV
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/25/2025	9:43:00 AM	2/25/2025	4:45:00 PM	0.29	0.00	0.00	0.00	7.03		* BR opened on voltage regulation. Voltage-392 KV
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/18/2025	10:26:00 AM	2/18/2025	3:44:00 PM	0.22	0.00	0.00	0.00	5.30		* BR opened on voltage regulation. Voltage-393 KV
BSR	80MVAR.BUS REACTOR-1 AT SIKAR	SVRD	2/17/2025	11:32:00 AM	2/17/2025	4:41:00 PM	0.22	0.00	0.00	0.00	5.15		* BR opened on voltage regulation. Voltage-393 KV
							4.02	0.00	0.00	0.00	96.21	100.00	
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/18/2025	9:44:00 AM	2/18/2025	4:24:00 PM	0.28	0.00	0.00	0.00	6.67		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/15/2025	10:00:00 AM	2/15/2025	4:29:00 PM	0.27	0.00	0.00	0.00	6.48		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/8/2025	9:02:00 AM	2/8/2025	6:38:00 PM	0.40	0.00	0.00	0.00	9.57		* BR opened on voltage regulation Voltage 392 KV
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/7/2025	9:25:00 AM	2/7/2025	6:13:00 PM	0.37	0.00	0.00	0.00	8.80		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/1/2025	9:28:00 AM	2/1/2025	4:45:00 PM	0.30	0.00	0.00	0.00	7.28		* BR opened on voltage regulation. Voltage-395KV
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/2/2025	9:32:00 AM	2/2/2025	3:47:00 PM	0.26	0.00	0.00	0.00	6.25		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/9/2025	9:02:00 AM	2/9/2025	5:11:00 PM	0.34	0.00	0.00	0.00	8.15		* BR opened on voltage regulation. SIKAR-395
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/3/2025	8:59:00 AM	2/3/2025	9:00:00 PM	0.50	0.00	0.00	0.00	12.02		* BR opened on voltage regulation. V-398KV
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/10/2025	10:00:00 AM	2/10/2025	6:38:00 PM	0.36	0.00	0.00	0.00	8.63		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/5/2025	12:24:00 PM	2/5/2025	4:23:00 PM	0.17	0.00	0.00	0.00	3.98		* BR opened on voltage regulation Voltage 755 KV
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/17/2025	10:18:00 AM	2/17/2025	4:42:00 PM	0.27	0.00	0.00	0.00	6.40		* BR opened on voltage regulation. Voltage-393 KV
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/18/2025	10:35:00 AM	2/18/2025	3:45:00 PM	0.22	0.00	0.00	0.00	5.17		* BR opened on voltage regulation. Voltage-393 KV
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/24/2025	10:01:00 AM	2/24/2025	3:52:00 PM	0.24	0.00	0.00	0.00	5.85		* BR opened on voltage regulation. Voltage-392 KV.
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/26/2025	10:14:00 AM	2/26/2025	4:31:00 PM	0.26	0.00	0.00	0.00	6.28		* BR opened on voltage regulation. Voltage-392 KV
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/23/2025	9:08:00 AM	2/23/2025	5:23:00 PM	0.34	0.00	0.00	0.00	8.25		* BR opened on voltage regulation. Voltage-393 KV.
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/27/2025	9:35:00 AM	2/27/2025	5:04:00 PM	0.31	0.00	0.00	0.00	7.48		* BR opened on voltage regulation Voltage 396 KV
BSR	125MVAR.BUS REACTOR-2 AT SIKAR	SVRD	2/25/2025	9:43:00 AM	2/25/2025	4:43:00 PM	0.29	0.00	0.00	0.00	7.00		* BR opened on voltage regulation. Voltage-392 KV
							5.18	0.00	0.00	0.00	124.26	100.00	
BSR	125MVAR.BUS REACTOR-1 AT SONIPAT	SVRD	2/1/2025	12:00:01 AM	2/28/2025	11:59:59 PM	28.00	0.00	0.00	0.00	672.00		* BR opened on voltage regulation. Voltage-390KV.
							28.00	0.00	0.00	0.00	672.00	100.00	
BSR	125MVAR.BUS REACTOR-2 AT SONIPAT	SVRD	2/15/2025	10:39:00 AM	2/15/2025	3:24:00 PM	0.20	0.00	0.00	0.00	4.75		* BR opened on voltage regulation. Voltage-393 KV.
BSR	125MVAR.BUS REACTOR-2 AT SONIPAT	SVRD	2/12/2025	9:55:00 AM	2/12/2025	4:01:00 PM	0.25	0.00	0.00	0.00	6.10		* BR opened on voltage regulation. Voltage-396KV.
BSR	125MVAR.BUS REACTOR-2 AT SONIPAT	SVRD	2/9/2025	9:06:00 AM	2/9/2025	6:08:00 PM	0.38	0.00	0.00	0.00	9.03		* BR opened on voltage regulation Voltage 394 KV
BSR	125MVAR.BUS REACTOR-2 AT SONIPAT	SVRD	2/8/2025	10:24:00 AM	2/8/2025	6:08:00 PM	0.32	0.00	0.00	0.00	7.73		* BR opened on voltage regulation Voltage 395 KV
BSR	125MVAR.BUS REACTOR-2 AT SONIPAT	SVRD	2/16/2025	9:57:00 AM	2/16/2025	4:21:00 PM	0.27	0.00	0.00	0.00	6.40		* BR opened on voltage regulation. Voltage-394 KV.
							1.42	0.00	0.00	0.00	34.01	100.00	
BSR	125MVAR.BUS REACTOR-1 AT TUGHLAKABAD			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV ANTA(NTPC)-BHILWARA(RRVPNL)-1	LPRD	2/1/2025	12:00:01 AM	2/28/2025	11:59:59 PM	28.00	0.00	0.00	0.00	672.00		* Line opened on power regulation to manage loading of 220kV Kota Sakatpura(RS)-Anta(ntpc) ckt
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	220kV ANTA(NTPC)-BHILWARA(RRVPNL)-2	LART	2/11/2025	7:08:00 PM	2/11/2025	7:08:00 AM	0.00	0.00	0.00	0.00	0.00		* Auto reclosed on R-N Fault.FLR: Anta - 8.207 KA/9.14 KM. Fault under Kota TLM Jurisdiction.
CKT	220kV ANTA(NTPC)-BHILWARA(RRVPNL)-2	LPRD	2/1/2025	12:00:01 AM	2/28/2025	11:59:59 PM	28.00	0.00	0.00	0.00	672.00		* Line opened on power regulation to manage loading of 220kV Kota Sakatpura(RS)-Anta(ntpc) ckt
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	220kV ANTA(NTPC)-LALSOT(RRVPNL)	OMSU	2/19/2025	6:00:00 PM	2/19/2025	9:33:00 PM	0.15	0.00	3.55	0.00	0.00		* Tripped on R-Y Fault due to kite thread infringement. FLR:Anta- 128.5 KM,Ir-1.884 KA Jy-1.634 KA Fault under Bassi TL.
							0.15	0.00	3.55	0.00	0.00	100.00	
CKT	220kV ANTA(NTPC)-RAPPC(NPCIL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV ANTA(NTPC)-SAWAI MADHOPUR(RRVPNL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV BASSI-IG NAGAR(RRVPNL)	OSPD	2/5/2025	11:14:00 AM	2/5/2025	9:56:00 PM	0.45	0.00	0.00	0.00	10.70		* Shutdown by RVPNL for Quatary maintenance of Bay Equipment
							0.45	0.00	0.00	0.00	10.70	100.00	
CKT	220kV BASSI-BAGRU(RRVPNL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV DAUSA(RRVPNL)-BASSI-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV DAUSA(RRVPNL)-BASSI-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV FGPP(NTPC)-PALLA(HVPNL)-1	OSPD	2/21/2025	12:25:00 PM	2/21/2025	4:03:00 PM	0.15	0.00	0.00	0.00	3.63		* Shutdown by HVPN for replacement of defective male female of" linebus isolator and overheated breaker calmp at Palla HVPN" end.
CKT	220kV FGPP(NTPC)-PALLA(HVPNL)-1	OSPD	2/3/2025	11:35:00 AM	2/3/2025	12:40:00 PM	0.05	0.00	0.00	0.00	1.08		* Shutdown by HVPN for installation and commissioning of IEMs under SAMAST project.
							0.20	0.00	0.00	0.00	4.71	100.00	
CKT	220kV-FGPP NTPC-SEC 58(HVPNL)-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV-FGPP NTPC-SEC 58(HVPNL)-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV-FGPP NTPC-SEC 78(HVPNL)-2	OSPD	2/3/2025	12:53:00 PM	2/3/2025	1:34:00 PM	0.03	0.00	0.00	0.00	0.68		* Shutdown by HVPNL for installation and commissioning of IEMs under SAMAST project.
							0.03	0.00	0.00	0.00	0.68	100.00	
CKT	220kV HISAR-HISAR(HVPNL)-1	LCSD	2/25/2025	10:00:00 AM	2/26/2025	2:15:00 AM	0.68	0.00	0.00	0.00	16.25		* Shutdown for 220 KV Busbar relay retro fitment work under Addcap at Hissar PG.
CKT	220kV HISAR-HISAR(HVPNL)-1	OMSU	2/11/2025	9:13:00 PM	2/11/2025	11:20:00 PM	0.09	0.00	2.12	0.00	0.00		* Tripped from Hissar IA(HVPNL) end onlydue to Bus Bar protection operated <(<8<-> 220KV Bus 2 tripped caused by failure of

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.77	0.00	2.12	0.00	16.25	100.00	
CKT	220kV IG NAGAR(RRVPNL)-HIRAPURA(RRVPNL)	OSPD	2/6/2025	10:46:00 AM	2/6/2025	5:20:00 PM	0.27	0.00	0.00	0.00	6.57		* Shutdown by RVPNL for Quarterly maintenance of Bay Equipment
							0.27	0.00	0.00	0.00	6.57	100.00	
CKT	220kV LALSOT(RRVPNL)-DAUSA(RRVPNL)	OSPD	2/27/2025	8:29:00 AM	2/28/2025	11:59:59 PM	1.65	0.00	0.00	0.00	39.52		* Shutdown by RVPNL for Overhauling of Pole of CB <-><-> Quarterly Maintenance.
CKT	220kV LALSOT(RRVPNL)-DAUSA(RRVPNL)	LPRD	2/21/2025	9:32:00 AM	2/27/2025	8:29:00 AM	5.96	0.00	0.00	0.00	142.95		* Line opened on Power regulation.
CKT	220kV LALSOT(RRVPNL)-DAUSA(RRVPNL)	LPRD	2/1/2025	12:00:01 AM	2/5/2025	10:14:00 PM	4.93	0.00	0.00	0.00	118.23		* Opened on power regulation to control overloading of 220 KV DAUSA BASSI CKT 1 and 2.
CKT	220kV LALSOT(RRVPNL)-DAUSA(RRVPNL)	LPRD	2/9/2025	1:16:00 PM	2/19/2025	7:23:00 PM	10.26	0.00	0.00	0.00	246.12		* Opened on power regulation to control loading in 220 kv Dausa-Bassi-ckt-I <-><-> ckt-II.
CKT	220kV LALSOT(RRVPNL)-DAUSA(RRVPNL)	LPRD	2/8/2025	10:39:00 AM	2/6/2025	4:50:00 PM	0.26	0.00	0.00	0.00	6.16		* Shutdown to control over loading of 220kV dausa-bassi D/C
CKT	220kV LALSOT(RRVPNL)-DAUSA(RRVPNL)	LPRD	2/4/2025	1:30:00 PM	2/5/2025	10:14:00 PM	1.36	0.00	0.00	0.00	32.73		* Opened to manage overloading of 220 KV DAUSA-BASSI-PGCIL CKT-I <-><-> CKT-I.
							24.42	0.00	0.00	0.00	585.73	100.00	
CKT	220kV MANSROVAR(RRVPNL)-HIRAPURA(RRVPNL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV MEERUT-MODIPURAM(UPPTCL)-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV MEERUT-MODIPURAM(UPPTCL)-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV MEERUT-NARA(UPPTCL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV MEERUT-SHATABDINAGAR(UPPTCL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV MEERUT-SIMBOLI(UPPTCL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RAPPB(NPCIL)-CHITTORGARH(RRVPNL)-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RAPPB(NPCIL)-CHITTORGARH(RRVPNL)-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RAPPB(NPCIL)-RAPPB(NPCIL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RAPPB(NPCIL)-UDAIPUR(RRVPNL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RATANGARH(RRVPNL)-SIKAR-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RATANGARH(RRVPNL)-SIKAR-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV-SAMAYPUR(HVPNL)-SEC58-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV-SAMAYPUR(HVPNL)-SEC58-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SANGANER(RRVPNL)-MANSROVAR(RRVPNL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV S.MADHOPUR(RRVPNL)-DAUSA(RRVPNL)-1	OSPD	2/28/2025	10:14:00 AM	2/28/2025	5:55:00 PM	0.32	0.00	0.00	0.00	7.68		* Shutdown by RRVPNL for Quarterly maintenance work.
CKT	220kV S.MADHOPUR(RRVPNL)-DAUSA(RRVPNL)-1	OMSU	2/13/2025	4:14:00 PM	2/13/2025	5:31:00 PM	0.05	0.00	1.28	0.00	0.00		* Tripped on B-N fault, Dausa END: M-I, C Phase, Dist-124.3 KM, Ic-1.637* Ka. Saimadhapur END:M-I, C Phase, Dist-1.638 KM, Ic-3.616 Ka. M-II,* Z1, C Phase, Dist-0.674 KM, Ic-3.636 Ka. Fault under RVPNL portion of the" line.
							0.37	0.00	1.28	0.00	7.68	100.00	
CKT	220kV-SEC 78(HVPNL)-PALLA-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SIKAR(RRVPNL)-SIKAR-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SIKAR(RRVPNL)-SIKAR-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/17/2025	9:45:00 PM	2/18/2025	6:00:00 AM	0.34	0.00	0.00	0.00	8.25		* Line opened on voltage regulation, Jaipur-423 KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/25/2025	9:47:00 PM	2/26/2025	7:29:00 AM	0.40	0.00	0.00	0.00	9.70		* Line opened on voltage regulation, Jaipur-423 KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/24/2025	10:19:00 PM	2/25/2025	6:15:00 AM	0.33	0.00	0.00	0.00	7.93		* Line opened on voltage regulation, Jaipur-423 KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/20/2025	9:24:00 PM	2/21/2025	6:43:00 AM	0.39	0.00	0.00	0.00	9.32		* Line opened on voltage regulation, Agra-425 KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/22/2025	9:37:00 PM	2/23/2025	7:16:00 AM	0.40	0.00	0.00	0.00	9.65		* Line opened on voltage regulation, Agra-423 KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/28/2025	10:11:00 PM	2/28/2025	11:59:59 PM	0.08	0.00	0.00	0.00	1.82		* Line opened on voltage regulation, Jaipur-423 KV
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/26/2025	6:34:00 PM	2/27/2025	6:07:00 AM	0.48	0.00	0.00	0.00	11.55		* Line opened on voltage regulation, Jaipur-423 KV
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/23/2025	9:56:00 PM	2/24/2025	6:12:00 AM	0.34	0.00	0.00	0.00	8.27		* Line opened on voltage regulation, Jaipur South-420KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/16/2025	8:39:00 PM	2/17/2025	5:41:00 AM	0.38	0.00	0.00	0.00	9.03		* Line opened on voltage regulation, Jaipur South-420KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/27/2025	9:05:00 PM	2/28/2025	8:07:00 AM	0.46	0.00	0.00	0.00	11.03		* Line opened on voltage regulation, Agra-424KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	OSFT	2/14/2025	5:26:00 PM	2/14/2025	9:14:00 PM	0.16	3.80	0.00	0.00	0.00		* Forced shutdown by NR-3 for insulation resistance test of LA at" Agra end
CKT	400kV AGRA-JAIPUR SOUTH-1	OSFT	2/15/2025	5:40:00 PM	2/15/2025	11:14:00 PM	0.23	5.57	0.00	0.00	0.00		* Manually hand tripped by NR-3 Agra end, Due to flashover in B-phase Line Isolator at Agra end.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/7/2025	9:05:00 PM	2/8/2025	5:53:00 AM	0.37	0.00	0.00	0.00	8.80		* Line opened on voltage regulation Jaipur S 421 KV
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/11/2025	8:56:00 PM	2/12/2025	6:28:00 AM	0.40	0.00	0.00	0.00	9.53		* Line opened on voltage regulation, Bhiwadi-423 KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/6/2025	9:41:00 PM	2/7/2025	7:05:00 AM	0.39	0.00	0.00	0.00	9.40		* Line opened on voltage regulation,Agra-425 KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/9/2025	9:26:00 PM	2/10/2025	5:56:00 AM	0.35	0.00	0.00	0.00	8.50		* Line opened on voltage regulation, Jaipur-423 KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/13/2025	9:14:00 PM	2/14/2025	6:52:00 AM	0.40	0.00	0.00	0.00	9.63		* Line opened on voltage regulation, Agra-423 KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/1/2025	12:00:01 AM	2/1/2025	7:20:00 AM	0.31	0.00	0.00	0.00	7.33		* Line opened on voltage regulation, Jaipur S 419 KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/2/2025	8:56:00 AM	2/3/2025	6:20:00 AM	0.39	0.00	0.00	0.00	9.40		* Line opened on voltage regulation, Jaipur-425 KV.
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/5/2025	9:13:00 PM	2/6/2025	7:23:00 AM	0.42	0.00	0.00	0.00	10.17		* Line opened on voltage regulation, Agra-425 KV
CKT	400kV AGRA-JAIPUR SOUTH-1	LVRD	2/19/2025	8:38:00 PM	2/20/2025	7:34:00 AM	0.46	0.00	0.00	0.00	10.93		* Line opened on voltage regulation, Agra-425 KV.
							7.48	9.37	0.00	0.00	170.24	98.61	
CKT	400kV AGRA-JAIPUR SOUTH-2	LVRD	2/18/2025	9:30:00 PM	2/19/2025	6:43:00 AM	0.38	0.00	0.00	0.00	9.22		* Line opened on voltage regulation, Jaipur -423 KV.
CKT	400kV AGRA-JAIPUR SOUTH-2	LVRD	2/16/2025	12:27:00 AM	2/16/2025	7:03:00 AM	0.28	0.00	0.00	0.00	6.60		* Line opened on voltage regulation, Jaipur South-420KV.
CKT	400kV AGRA-JAIPUR SOUTH-2	LVRD	2/4/2025	9:20:00 PM	2/5/2025	6:07:00 AM	0.37	0.00	0.00	0.00	8.78		* Line opened on voltage regulation,Agra-425 KV
CKT	400kV AGRA-JAIPUR SOUTH-2	LVRD	2/12/2025	10:08:00 PM	2/13/2025	7:18:00 AM	0.38	0.00	0.00	0.00	9.17		* Line opened on voltage regulation, Agra-423 KV.
CKT	400kV AGRA-JAIPUR SOUTH-2	LVRD	2/10/2025	6:44:00 PM	2/11/2025	6:44:00 AM	0.50	0.00	0.00	0.00	12.00		* Line opened on voltage regulation, Agra-423 KV.
CKT	400kV AGRA-JAIPUR SOUTH-2	LVRD	2/1/2025	8:48:00 PM	2/2/2025	7:11:00 AM	0.43	0.00	0.00	0.00	10.38		* Line opened on voltage regulation, Jaipur-425 KV.
CKT	400kV AGRA-JAIPUR SOUTH-2	LVRD	2/8/2025	9:38:00 PM	2/9/2025	6:04:00 AM	0.35	0.00	0.00	0.00	8.43		* Line opened on voltage regulation, Jaipur S 419 KV
CKT	400kV AGRA-JAIPUR SOUTH-2	LVRD	2/3/2025	9:06:00 PM	2/4/2025	8:35:00 AM	0.40	0.00	0.00	0.00	9.48		* Line opened on voltage regulation,Agra-425 KV.
							3.09	0.00	0.00	0.00	74.06	100.00	
CKT	400kV AGRA-SIKAR-1	LVRD	2/8/2025	9:36:00 PM	2/9/2025	5:49:00 AM	0.34	0.00	0.00	0.00	8.22		* Line opened on voltage regulation, Sikar 420 KV
CKT	400kV AGRA-SIKAR-1	LVRD	2/2/2025	8:55:00 PM	2/3/2025	6:08:00 AM	0.38	0.00	0.00	0.00	9.22		* Line opened on voltage regulation, Sikar-423 kv.
CKT	400kV AGRA-SIKAR-1	LVRD	2/1/2025	8:47:00 PM	2/2/2025	7:02:00 AM	0.43	0.00	0.00	0.00	10.25		* Line opened on voltage regulation, Sikar-425 KV.
CKT	400kV AGRA-SIKAR-1	LVRD	2/1/2025	12:00:01 AM	2/1/2025	6:52:00 AM	0.29	0.00	0.00	0.00	6.87		* Line opened on voltage regulation, Sikar 419 KV.
CKT	400kV AGRA-SIKAR-1	LVRD	2/6/2025	12:50:00 AM	2/6/2025	7:22:00 AM	0.27	0.00	0.00	0.00	6.53		* Line opened on voltage regulation,Sikar-425 KV
CKT	400kV AGRA-SIKAR-1	LVRD	2/12/2025	10:06:00 PM	2/13/2025	7:19:00 AM	0.38	0.00	0.00	0.00	9.22		* Line opened on voltage regulation, Agra-423 KV.

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
OKT	400kV AGRA-SIKAR-1	LVRD	2/10/2025	6:42:00 PM	2/11/2025	6:42:00 AM	0.50	0.00	0.00	0.00	12.00		* Line opened on voltage regulation. Sikar-423 KV.
OKT	400kV AGRA-SIKAR-1	LVRD	2/7/2025	9:04:00 PM	2/8/2025	6:02:00 AM	0.37	0.00	0.00	0.00	8.97		* Line opened on voltage regulation Sikar 420 KV
OKT	400kV AGRA-SIKAR-1	LVRD	2/4/2025	9:21:00 PM	2/5/2025	6:09:00 AM	0.37	0.00	0.00	0.00	8.80		* Line opened on voltage regulation.Agra-425 KV
OKT	400kV AGRA-SIKAR-1	LVRD	2/15/2025	10:16:00 PM	2/16/2025	5:59:00 AM	0.32	0.00	0.00	0.00	7.72		
OKT	400kV AGRA-SIKAR-1	LVRD	2/13/2025	9:13:00 PM	2/14/2025	6:43:00 AM	0.40	0.00	0.00	0.00	9.50		* Line opened on voltage regulation. Agra-423 KV.
OKT	400kV AGRA-SIKAR-1	LVRD	2/14/2025	9:25:00 PM	2/15/2025	6:29:00 AM	0.38	0.00	0.00	0.00	9.07		* Line opened on voltage regulation.Agra-424KV.
OKT	400kV AGRA-SIKAR-1	LVRD	2/28/2025	10:10:00 PM	2/28/2025	11:59:59 PM	0.08	0.00	0.00	0.00	1.83		* Line opened on voltage regulation. Sikar-423 KV
OKT	400kV AGRA-SIKAR-1	LVRD	2/23/2025	9:55:00 PM	2/24/2025	6:14:00 AM	0.35	0.00	0.00	0.00	8.32		* Line opened on voltage regulation. Sikar-420KV.
OKT	400kV AGRA-SIKAR-1	LVRD	2/27/2025	10:13:00 PM	2/28/2025	8:05:00 AM	0.41	0.00	0.00	0.00	9.87		* Line opened on voltage regulation. Aimer-792 KV
OKT	400kV AGRA-SIKAR-1	LVRD	2/26/2025	9:21:00 PM	2/27/2025	6:38:00 AM	0.39	0.00	0.00	0.00	9.28		* Line opened on voltage regulation. Sikar-423 KV
OKT	400kV AGRA-SIKAR-1	LVRD	2/25/2025	9:45:00 PM	2/26/2025	7:33:00 AM	0.41	0.00	0.00	0.00	9.80		* Line opened on voltage regulation. Sikar-423 KV.
OKT	400kV AGRA-SIKAR-1	LVRD	2/20/2025	9:26:00 PM	2/21/2025	6:42:00 AM	0.39	0.00	0.00	0.00	9.27		* Line opened on voltage regulation. Agra-425 KV.
OKT	400kV AGRA-SIKAR-1	LVRD	2/18/2025	9:29:00 PM	2/19/2025	6:35:00 AM	0.38	0.00	0.00	0.00	9.10		* Line opened on voltage regulation. Sikar -423 KV.
OKT	400kV AGRA-SIKAR-1	LVRD	2/17/2025	9:45:00 PM	2/18/2025	5:46:00 AM	0.33	0.00	0.00	0.00	8.02		* Line opened on voltage regulation. Sikar-423 KV.
OKT	400kV AGRA-SIKAR-1	LVRD	2/22/2025	9:35:00 PM	2/23/2025	7:15:00 AM	0.40	0.00	0.00	0.00	9.67		* Line opened on voltage regulation.Sikar-423 KV
OKT	400kV AGRA-SIKAR-1	LVRD	2/3/2025	9:05:00 PM	2/4/2025	6:32:00 AM	0.39	0.00	0.00	0.00	9.45		* Line opened on voltage regulation.Agra-425 KV
OKT	400kV AGRA-SIKAR-1	LVRD	2/11/2025	8:54:00 PM	2/12/2025	6:33:00 AM	0.40	0.00	0.00	0.00	9.65		* Line opened on voltage regulation. Sikar-423 KV.
OKT	400kV AGRA-SIKAR-1	LVRD	2/16/2025	8:37:00 PM	2/17/2025	5:39:00 AM	0.38	0.00	0.00	0.00	9.03		* Line opened on voltage regulation. Sikar-420KV.
OKT	400kV AGRA-SIKAR-1	LVRD	2/19/2025	8:38:00 PM	2/20/2025	7:32:00 AM	0.45	0.00	0.00	0.00	10.90		* Line opened on voltage regulation. Agra-425 KV.
OKT	400kV AGRA-SIKAR-1	LVRD	2/9/2025	9:23:00 PM	2/10/2025	5:55:00 AM	0.36	0.00	0.00	0.00	8.53		* Line opened on voltage regulation. Sikar-423 KV.
							9.55	0.00	0.00	0.00	229.09	100.00	
OKT	400kV AGRA-SIKAR-2	OMSU	2/20/2025	9:24:00 AM	2/20/2025	1:55:00 PM	0.19	0.00	4.52	0.00	0.00		* Forced shutdown for removing of polythene from conductor near tower location 998 .
OKT	400kV AGRA-SIKAR-2	LART	2/19/2025	6:15:00 PM	2/19/2025	6:15:00 PM	0.00	0.00	0.00	0.00	0.00		* Auto-reclosed on R-N fault.FLR. Sikar-13.732 KA/16.343 KM.Agra-M1.Z-2.386 KM/1.1 kA.M2-Z-2 .299 KM/1.12 kA Fault under Sikar TLM jurisdiction.
							0.19	0.00	4.52	0.00	0.00	100.00	
OKT	400kV AJMER-AJMER(RRVPNL)-1	OSFT	2/25/2025	3:43:00 PM	2/25/2025	8:31:00 PM	0.20	4.80	0.00	0.00	0.00		* Forced shutdown to attend damaged insulator at tower location no-4.
							0.20	4.80	0.00	0.00	0.00	99.29	
OKT	400kV AJMER-AJMER(RRVPNL)-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BABA(RRVPNL)-SIKAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BAGPAT-DEHRADUN			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BAGPAT-MEERUT-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BAGPAT-MEERUT-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BAGPAT-SAHARANPUR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BALLABHGARH-NAVADA(HVPNL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BASSI-HIRAPURA(RRVPNL)-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BASSI-HIRAPURA(RRVPNL)-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BASSI-JAIPUR SOUTH-1	LCSD	2/21/2025	5:29:00 PM	2/21/2025	11:48:00 PM	0.26	0.00	0.00	0.00	6.32		* Shutdown for 400kV Busbar Relay Retrofitment work and Tie Bay" LBB Back Trip testing under ADD CAP at Bassi.
							0.26	0.00	0.00	0.00	6.32	100.00	
OKT	400kV BASSI-JAIPUR SOUTH-2	LCSD	2/20/2025	3:21:00 PM	2/21/2025	1:04:00 AM	0.41	0.00	0.00	0.00	9.72		* S/D for 400kV Busbar Relay Retrofitment work and Tie Bay LBB Back Trip testing under ADD CAP at Bassi.
							0.41	0.00	0.00	0.00	9.72	100.00	
OKT	400kV BASSI-PHAGI(RRVPNL)-1	LCSD	2/21/2025	5:04:00 PM	2/21/2025	11:47:00 PM	0.28	0.00	0.00	0.00	6.72		* Shutdown for 400kV Busbar Relay Retrofitment work and Tie Bay" LBB Back Trip testing under ADD CAP at Bassi.
							0.28	0.00	0.00	0.00	6.72	100.00	
OKT	400kV BASSI-PHAGI(RRVPNL)-2	LCSD	2/28/2025	5:52:00 PM	2/28/2025	10:51:00 PM	0.21	0.00	0.00	0.00	4.98		* Shutdown for 400kV Busbar Relay Retrofitment work under ADD CAP at Bassi.
							0.21	0.00	0.00	0.00	4.98	100.00	
OKT	400kV BEAWAR(SREE CEMENT)-MERTA(RRVPNL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BAHADURGARH-BAWANA(DTL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BAHADURGARH-KABULPUR(HVPNL)	OSPT	2/28/2025	9:50:00 AM	2/28/2025	10:05:00 PM	0.51	12.25	0.00	0.00	0.00		* **Shutdown for AMP of line side equipment at Bahadurgarh. *
							0.51	12.25	0.00	0.00	0.00	98.18	
OKT	400kV BAHADURGARH-SONIPAT-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BAHADURGARH-SONIPAT-2	LART	2/16/2025	3:31:00 AM	2/16/2025	3:31:00 AM	0.00	0.00	0.00	0.00	0.00		* Line autoreclose on B-N fault. Sonipat-12.026KA/4.369KM. Bahadurgarh-5.034KA/41.014KM. Fault under Bahadurgarh TLM jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BHADLA-BHADLA(RRVPNL)-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BHADLA-BHADLA(RRVPNL)-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV-BHDLA(PG) R-BHADLA2-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV-BHDLA(PG) R-BHADLA2-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BASSI-BHIWADI-1	LART	2/9/2025	12:39:00 AM	2/9/2025	12:39:00 AM	0.00	0.00	0.00	0.00	0.00		* Autoreclosed : Bhiwadi-Y-N/8.285KA/34.836KM. Fault under Bhiwadi TLM jurisdiction.
OKT	400kV BASSI-BHIWADI-1	LART	2/9/2025	12:39:00 AM	2/9/2025	12:39:00 AM	0.00	0.00	0.00	0.00	0.00		* Autoreclosed : Bhiwadi-Y-N/8.285KA/34.836KM. Fault under Bhiwadi TLM jurisdiction.
OKT	400kV BASSI-BHIWADI-1	LVRD	2/9/2025	12:39:00 AM	2/9/2025	12:39:00 AM	0.00	0.00	0.00	0.00	0.00		* Autoreclosed : Bhiwadi-Y-N/8.285KA/34.836KM. Fault under Bhiwadi TLM jurisdiction.
OKT	400kV BASSI-BHIWADI-1	LART	2/16/2025	10:52:00 PM	2/16/2025	10:52:00 PM	0.00	0.00	0.00	0.00	0.00		* Line autoreclose on Y-N fault. Bassi-2.635KA/133.586km <(>-&<-> Bhiwadi: 7.588KA/39.685km. Fault under Bhiwadi TL jurisdiction.
OKT	400kV BASSI-BHIWADI-1	LART	2/16/2025	11:39:00 PM	2/16/2025	11:39:00 PM	0.00	0.00	0.00	0.00	0.00		* Line autoreclose on Y-N fault. Bassi: 2.185KA/135.208km <(>-&<-> Bhiwadi: 7.506KA/38.412km.Fault under Bhiwadi TL jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BHIWADI-KOTPUTLI	LCSD	2/10/2025	5:08:00 PM	2/25/2025	12:05:00 AM	14.29	0.00	0.00	0.00	342.95		* Shutdown for NCRTC Diversion work. Continous S/D till 28.02.2025
							14.29	0.00	0.00	0.00	342.95	100.00	
OKT	400kV BHIWADI-NEEMRANA-1	LVRD	2/20/2025	2:00:00 AM	2/20/2025	6:56:00 AM	0.21	0.00	0.00	0.00	4.93		* Line opened on voltage regulation.Bhiwadi -423 KV
OKT	400kV BHIWADI-NEEMRANA-1	LVRD	2/26/2025	9:33:00 PM	2/27/2025	5:55:00 AM	0.35	0.00	0.00	0.00	8.37		* Line opened on voltage regulation. Bwd-423 KV
OKT	400kV BHIWADI-NEEMRANA-1	LVRD	2/3/2025	10:53:00 PM	2/4/2025	5:46:00 AM	0.29	0.00	0.00	0.00	6.88		* Line opened on voltage regulation. Bhiwadi-423 KV.
OKT	400kV BHIWADI-NEEMRANA-1	LVRD	2/12/2025	12:46:00 AM	2/12/2025	6:45:00 AM	0.25	0.00	0.00	0.00	5.98		* Line opened on voltage regulation. Bhiwadi-423 KV.
OKT	400kV BHIWADI-NEEMRANA-1	LVRD	2/10/2025	9:46:00 PM	2/11/2025	6:01:00 AM	0.34	0.00	0.00	0.00	8.25		* Line opened on voltage regulation. BWD-423 KV.
OKT	400kV BHIWADI-NEEMRANA-1	LVRD	2/7/2025	9:39:00 PM	2/8/2025	5:12:00 AM	0.32	0.00	0.00	0.00	7.55		* Line opened on voltage regulation Bhiwadi 418 KV
							1.76	0.00	0.00	0.00	41.96	100.00	
OKT	400kV BHIWADI-NEEMRANA-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
OKT	400kV BHIWANI(BBMB)-BHIWANI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHIWANI-JIND-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHIWANI-JIND-2	OSPT	2/17/2025	10:05:00 AM	2/17/2025	8:28:00 PM	0.43	10.38	0.00	0.00	0.00		* Shutdown for rectification of shutdown nature defects in line.
							0.43	10.38	0.00	0.00	0.00	96.45	
CKT	400kV BHIWANI-KABULPUR(HVPNL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BHIWN-MHNDGRH-CKT-3			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BHIWN-MHNDGRH-CKT-4			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHINMAL-KANKROLI	OSPD	2/8/2025	3:43:00 PM	2/8/2025	11:34:00 PM	0.33	0.00	0.00	0.00	7.85		* Shut down taken by Zerda for attending shutdown defects in Line and Yearly AMP of LTE and main bay circuit breaker at Zerda.
CKT	400kV BHINMAL-KANKROLI	LART	2/11/2025	3:25:00 PM	2/11/2025	3:25:00 PM	0.00	0.00	0.00	0.00	0.00		* 400KV KANKROLI-ZERDA-II Auto-reclosed on R-N fault.FLR- KankrolI-7.924 KA/16.939km (8.390%). Zerda-290 km.Fault under KankrolI TL.Auto reclose was caused by Forest Fire at location 588.
							0.33	0.00	0.00	0.00	7.85	100.00	
CKT	400KV-BIKANER-BIKANR2-CKT-I			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BIKANER-BIKANR2-CKT-II			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAMNOLI(DTL)-TUGHLAKABD-1	OSPT	2/13/2025	8:56:00 AM	2/13/2025	7:31:00 PM	0.44	10.58	0.00	0.00	0.00		* SD for replacement of critically damaged insulators
CKT	400kV BAMNOLI(DTL)-TUGHLAKABD-1	OSPT	2/12/2025	9:17:00 AM	2/12/2025	9:22:00 PM	0.50	12.08	0.00	0.00	0.00		* Shutdown taken for for replacement of critically damaged insulators.
CKT	400kV BAMNOLI(DTL)-TUGHLAKABD-1	OSPD	2/1/2025	12:00:01 AM	2/28/2025	11:59:59 PM	28.00	0.00	0.00	0.00	672.00		* S/D by DTL for capacitance and other testing works of line CVT at their end.
							28.94	22.66	0.00	0.00	672.00	96.63	
CKT	400kV BAMNOLI(DTL)-TUGHLAKABD-2	OSPT	2/11/2025	9:20:00 AM	2/11/2025	7:30:00 PM	0.42	10.17	0.00	0.00	0.00		* Shutdown for replacement of critically damaged insulators on M/C towers.
CKT	400kV BAMNOLI(DTL)-TUGHLAKABD-2	OSPT	2/10/2025	8:26:00 AM	2/10/2025	8:08:00 PM	0.31	21.87	0.00	0.00	0.00		* Shutdown for replacement of critically damaged insulators on M/C towers.
							0.00	0.00	0.00	0.00	0.00	96.75	
CKT	400KV-BAREILY-MEERUT-3(ILLO PART MEERUT)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BAREILY-MEERUT-4(ILLO PART MEERUT)	LVRD	2/3/2025	10:45:00 PM	2/4/2025	6:30:00 AM	0.32	0.00	0.00	0.00	7.75		* Line opened on voltage regulation. Meerut-423 KV.
CKT	400KV-BAREILY-MEERUT-4(ILLO PART MEERUT)	OMSU	2/7/2025	5:27:00 PM	2/7/2025	6:37:00 PM	0.05	0.00	1.17	0.00	0.00		* Tripped on Y-B Phase Fault.MEERUT-M1:2.451 KA/239.316km (95.920%) <->&-> M2:2.447 KA/239.909km (96.160%).BAREILLEY-M2:23.734 KA /8.162km (3.270%). Fault at the border of POWERLINK and NR-3 jurisdiction. Fault under kite prone area.
CKT	400KV-BAREILY-MEERUT-4(ILLO PART MEERUT)	LVRD	2/21/2025	12:48:00 AM	2/21/2025	6:59:00 AM	0.26	0.00	0.00	0.00	6.18		* Line opened on voltage regulation. Meerut -425 KV.
							0.63	0.00	1.17	0.00	13.93	100.00	
CKT	400kV BAWANA(DTL)-BHIWANI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHITTORGARH-CHITTORGARH(RRVPNL)-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHITTORGARH-CHITTORGARH(RRVPNL)-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DADR(NTPC)-GREATER NOIDA(UPPTCL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DADR(NTPC)-MANDOLA-1	LCSD	2/19/2025	7:42:00 AM	2/19/2025	8:50:00 PM	0.55	0.00	0.00	0.00	13.13		* Shutdown for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-1	LCSD	2/18/2025	7:55:00 AM	2/18/2025	7:36:00 PM	0.49	0.00	0.00	0.00	11.68		* Shutdown for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-1	LCSD	2/17/2025	7:01:00 AM	2/17/2025	8:23:00 PM	0.56	0.00	0.00	0.00	13.37		* Shutdown for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-1	LCSD	2/22/2025	6:46:00 AM	2/22/2025	11:07:00 PM	0.68	0.00	0.00	0.00	16.35		* Shutdown for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-1	LVRD	2/21/2025	9:50:00 PM	2/22/2025	6:46:00 AM	0.37	0.00	0.00	0.00	8.93		* Line opened on voltage regulation.Mandola-430 KV.
CKT	400kV DADR(NTPC)-MANDOLA-1	LCSD	2/21/2025	8:06:00 AM	2/21/2025	9:50:00 PM	0.57	0.00	0.00	0.00	13.73		* Shutdown for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-1	LCSD	2/16/2025	6:51:00 AM	2/16/2025	9:15:00 PM	0.60	0.00	0.00	0.00	14.40		* Shutdown for for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-1	LVRD	2/16/2025	9:15:00 PM	2/17/2025	7:01:00 AM	0.41	0.00	0.00	0.00	9.77		* Line kept open on voltage regulation. Mandola- 424KV.
CKT	400kV DADR(NTPC)-MANDOLA-1	LCSD	2/15/2025	8:19:00 AM	2/15/2025	11:30:00 PM	0.63	0.00	0.00	0.00	15.18		* Shutdown for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-1	LVRD	2/15/2025	11:30:00 PM	2/16/2025	6:51:00 AM	0.31	0.00	0.00	0.00	7.35		* Line kept open on voltage regulation. Mandola-421 KV.
							5.17	0.00	0.00	0.00	123.89	100.00	
CKT	400kV DADR(NTPC)-MANDOLA-2	LCSD	2/15/2025	8:23:00 AM	2/15/2025	11:30:00 PM	0.63	0.00	0.00	0.00	15.12		* Shutdown for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-2	LVRD	2/15/2025	11:30:00 PM	2/16/2025	6:52:00 AM	0.31	0.00	0.00	0.00	7.37		* Line kept open on voltage regulation. Mandola-421 KV.
CKT	400kV DADR(NTPC)-MANDOLA-2	LVRD	2/16/2025	9:16:00 PM	2/17/2025	7:01:00 AM	0.41	0.00	0.00	0.00	9.75		* Line kept open on voltage regulation. Mandola- 424KV.
CKT	400kV DADR(NTPC)-MANDOLA-2	LCSD	2/16/2025	6:52:00 AM	2/16/2025	9:16:00 PM	0.60	0.00	0.00	0.00	14.40		* Shutdown for for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-2	LCSD	2/22/2025	6:47:00 AM	2/22/2025	11:09:00 PM	0.68	0.00	0.00	0.00	16.37		* Shutdown for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-2	LVRD	2/21/2025	9:50:00 PM	2/22/2025	6:47:00 AM	0.37	0.00	0.00	0.00	8.95		* Line opened on voltage regulation.Mandola-430 KV.
CKT	400kV DADR(NTPC)-MANDOLA-2	LCSD	2/21/2025	8:07:00 AM	2/21/2025	9:50:00 PM	0.57	0.00	0.00	0.00	13.72		* Shutdown for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-2	LCSD	2/18/2025	7:56:00 AM	2/18/2025	7:35:00 PM	0.49	0.00	0.00	0.00	11.65		* Shutdown for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-2	LCSD	2/17/2025	7:01:00 AM	2/17/2025	8:25:00 PM	0.56	0.00	0.00	0.00	13.40		* Shutdown for jack bus replacement at Mandola.
CKT	400kV DADR(NTPC)-MANDOLA-2	LCSD	2/19/2025	7:43:00 AM	2/19/2025	8:53:00 PM	0.55	0.00	0.00	0.00	13.17		* Shutdown for jack bus replacement at Mandola.
							5.17	0.00	0.00	0.00	123.90	100.00	
CKT	400kV DADR(NTPC)-MAHRANIBAGH	LCSD	2/24/2025	5:15:00 PM	2/24/2025	8:25:00 PM	0.13	0.00	0.00	0.00	3.17		* S/D for removal of by pass arrangement and connectivity of 400kV Dabri- Maharanibagh and 400KV Maharanibagh-Ballabgarh at Maharanibagh for facilitate SD at Mandola for jack bus replacement work under ADD CAP 400KV Ballabgarh-Mahamibagh line charged at 1
							0.13	0.00	0.00	0.00	3.17	100.00	
CKT	400kV DADR(NTPC)-MURADNAGAR(UPPTCL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DADR(NTPC)-PANIPAT(BBMB)-1	LVRD	2/11/2025	11:31:00 PM	2/12/2025	6:32:00 AM	0.29	0.00	0.00	0.00	7.02		* Line opened on voltage regulation. Dabri-423 KV.
CKT	400kV DADR(NTPC)-PANIPAT(BBMB)-1	LVRD	2/4/2025	9:24:00 PM	2/5/2025	5:41:00 AM	0.35	0.00	0.00	0.00	8.28		* Line opened on voltage regulation. Dabri-423 KV.
CKT	400kV DADR(NTPC)-PANIPAT(BBMB)-1	LVRD	2/3/2025	10:30:00 PM	2/4/2025	6:49:00 AM	0.35	0.00	0.00	0.00	8.32		* Line opened on voltage regulation. Dabri-423 KV.
CKT	400kV DADR(NTPC)-PANIPAT(BBMB)-1	LVRD	2/13/2025	12:11:00 AM	2/13/2025	6:43:00 AM	0.27	0.00	0.00	0.00	6.53		* Line opened on voltage regulation. Dabri-423 KV.
CKT	400kV DADR(NTPC)-PANIPAT(BBMB)-1	LVRD	2/27/2025	11:55:00 PM	2/28/2025	8:18:00 AM	0.35	0.00	0.00	0.00	8.38		* Line opened on voltage regulation. Dabri-423 KV
							1.61	0.00	0.00	0.00	38.53	100.00	
CKT	400kV DADR(NTPC)-PANIPAT(BBMB)-2	LVRD	2/2/2025	11:53:00 PM	2/3/2025	5:59:00 AM	0.25	0.00	0.00	0.00	6.10		* Line opened on voltage regulation. Dabri-422 Kv.
CKT	400kV DADR(NTPC)-PANIPAT(BBMB)-2	LVRD	2/1/2025	12:12:00 AM	2/1/2025	6:41:00 AM	0.27	0.00	0.00	0.00	6.48		* Line opened on voltage regulation. Dabri 418 KV.
CKT	400kV DADR(NTPC)-PANIPAT(BBMB)-2	LVRD	2/10/2025	11:58:00 PM	2/11/2025	7:16:00 AM	0.30	0.00	0.00	0.00	7.30		* Line opened on voltage regulation
CKT	400kV DADR(NTPC)-PANIPAT(BBMB)-2	LVRD	2/10/2025	1:16:00 AM	2/10/2025	5:36:00 AM	0.18	0.00	0.00	0.00	4.33		* Line opened on voltage regulation. Dabri-423 KV.
CKT	400kV DADR(NTPC)-PANIPAT(BBMB)-2	OSFD	2/1/2025	10:05:00 AM	2/11/2025	3:58:00 PM	0.25	0.00	0.00	0.00	5.88		* Forced shutdown by BBMB to attend hot point on line isolator clamp of R. Phase towards Bus-1 at Panipat end.
CKT	400kV DADR(NTPC)-PANIPAT(BBMB)-2	LVRD	2/7/2025	11:08:00 PM	2/8/2025	5:28:00 AM	0.26	0.00	0.00	0.00	6.33		* Line opened on voltage regulation Dabri 418 KV
							1.51	0.00	0.00	0.00	36.42	100.00	
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/1/2025	12:00:01 AM	2/1/2025	9:06:00 AM	0.38	0.00	0.00	0.00	9.10		* Line opened on voltage regulation. Dehradun 421 KV.
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/5/2025	9:38:00 PM	2/6/2025	7:20:00 AM	0.40	0.00	0.00	0.00	9.70		* Line opened on voltage regulation.Dehradun-425 KV
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/10/2025	9:39:00 PM	2/11/2025	6:33:00 AM	0.37	0.00	0.00	0.00	8.90		* Line opened on voltage regulation. DDN-423 KV.
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/6/2025	9:30:00 PM	2/7/2025	6:27:00 AM	0.37	0.00	0.00	0.00	8.95		* Line opened on voltage regulation.Dehradun-425 KV
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/2/2025	10:39:00 PM	2/3/2025	5:39:00 AM	0.29	0.00	0.00	0.00	7.00		* Line opened on voltage regulation
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/11/2025	11:34:00 PM	2/12/2025	6:36:00 AM	0.29	0.00	0.00	0.00	7.03		* Line opened on voltage regulation. Dehradun-425 KV
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/9/2025	10:36:00 PM	2/10/2025	5:22:00 AM	0.28	0.00	0.00	0.00	6.77		* Line opened on voltage regulation.

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE TO Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/16/2025	9:20:00 PM	2/17/2025	5:32:00 AM	0.34	0.00	0.00	0.00	8.20		* Line opened on voltage regulation. Dehradun-420KV.
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/28/2025	9:41:00 PM	2/28/2025	11:59:59 PM	0.10	0.00	0.00	0.00	2.32		* Line opened on voltage regulation. Dehradun-423 KV.
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/22/2025	9:28:00 PM	2/23/2025	5:18:00 AM	0.33	0.00	0.00	0.00	7.83		* Line opened on voltage regulation. Dehradun-425 KV
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/21/2025	12:29:00 AM	2/21/2025	5:37:00 AM	0.21	0.00	0.00	0.00	5.13		* Line opened on voltage regulation.Dehradun-425 KV
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/27/2025	11:36:00 PM	2/28/2025	7:43:00 AM	0.34	0.00	0.00	0.00	8.12		* Line opened on voltage regulation. Dehradun-790 KV.
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/26/2025	1:39:00 AM	2/26/2025	5:45:00 AM	0.17	0.00	0.00	0.00	4.10		* Line opened on voltage regulation. DDN-423 KV
CKT	400kV DEHRADUN-ABDULLAPUR-1	LVRD	2/17/2025	9:25:00 PM	2/18/2025	5:20:00 AM	0.33	0.00	0.00	0.00	7.92		* Line opened on voltage regulation. DDN-423 KV.
							4.20	0.00	0.00	0.00	101.07	100.00	
CKT	400kV DEHRADUN-ABDULLAPUR-2	LVRD	2/4/2025	9:42:00 PM	2/5/2025	5:36:00 AM	0.33	0.00	0.00	0.00	7.90		* Line opened on voltage regulation. Dehradun-423 KV.
CKT	400kV DEHRADUN-ABDULLAPUR-2	LVRD	2/1/2025	8:52:00 PM	2/2/2025	5:21:00 AM	0.35	0.00	0.00	0.00	8.48		* Line opened on voltage regulation. DDN-425 KV.
CKT	400kV DEHRADUN-ABDULLAPUR-2	LVRD	2/3/2025	9:12:00 PM	2/4/2025	5:39:00 AM	0.35	0.00	0.00	0.00	8.45		* Line opened on voltage regulation. Dehradun-425 KV
							1.03	0.00	0.00	0.00	24.83	100.00	
CKT	400KV-DWARKA-BAMNAULI-CKT1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV FATEHABAD-HISAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GR NOIDA(UPPTCL)-NAVADA(HVPNL)	OSFD	2/20/2025	11:50:00 AM	2/20/2025	1:52:00 PM	0.09	0.00	0.00	0.00	2.03		* Shutdown by HVPNL To attend hotspot on R phase line isolator at their end.
							0.09	0.00	0.00	0.00	2.03	100.00	
CKT	400kV GURGAON-BALLABHGARH			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GURGAON-BHIWADI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GURGAON-SOHNA(STERLITE)-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GURGAON-SOHNA(STERLITE)-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HAPUR(UPPTCL)-MURADNAGAR(UPPTCL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HISAR-BHIWADI-1	LVRD	2/1/2025	12:00:01 AM	2/1/2025	6:56:00 AM	0.29	0.00	0.00	0.00	6.93		* Line opened on voltage regulation. Bhiwadi 419 KV.
CKT	400kV HISAR-BHIWADI-1	LVRD	2/2/2025	12:06:00 AM	2/2/2025	7:13:00 AM	0.30	0.00	0.00	0.00	7.12		* Line opened on voltage regulation.
CKT	400kV HISAR-BHIWADI-1	LVRD	2/3/2025	10:41:00 PM	2/4/2025	5:50:00 AM	0.30	0.00	0.00	0.00	7.15		* Line opened on voltage regulation. Bhiwadi-423 KV.
CKT	400kV HISAR-BHIWADI-1	LCSD	2/10/2025	5:11:00 PM	2/25/2025	12:08:00 AM	14.29	0.00	0.00	0.00	342.95		* Shutdown for NCRTC Diversion work. Continuous S/D till 28.02.2025.
CKT	400kV HISAR-BHIWADI-1	LVRD	2/4/2025	9:32:00 PM	2/5/2025	5:50:00 AM	0.35	0.00	0.00	0.00	8.30		* Line opened on voltage regulation.Bhiwadi-425 KV
							15.53	0.00	0.00	0.00	372.45	100.00	
CKT	400kV HISAR-BHIWADI-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HISAR-BHIWADI-3			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HISAR-BHIWANI(BMB)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-HISAR-BHIWANI-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-HISAR-BHIWANI-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-HISAR-BHIWANI-3			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JAIPUR SOUTH-KOTA	LVRD	2/20/2025	2:06:00 AM	2/20/2025	6:44:00 AM	0.19	0.00	0.00	0.00	4.63		* Line opened on voltage regulation. Kota-425 KV.
							0.19	0.00	0.00	0.00	4.63	100.00	
CKT	400kV JAIPUR SOUTH-RAPPD(NPCL)	OSPT	2/6/2025	5:07:00 PM	2/6/2025	10:28:00 PM	0.22	5.35	0.00	0.00	0.00		* Shutdown for AMP work <*> to attend shutdown nature defects.
							0.22	5.35	0.00	0.00	0.00	99.20	
CKT	400kV JHATIKARA-BAMNOLI(DTL)-2	OSPT	2/3/2025	3:40:00 PM	2/3/2025	11:56:00 PM	0.34	8.27	0.00	0.00	0.00		* Shutdown for attending damagedisolator fingers (409-89A, R phase) of the Main Bay of Bamnoli-2 at Jhatikara end.
							0.34	8.27	0.00	0.00	0.00	98.77	
CKT	400KV-JHATIKARA-DWARKA-CKT1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHATIKARA-MUNDKA(DTL)-1	LCSD	2/11/2025	3:39:00 PM	2/12/2025	12:36:00 AM	0.37	0.00	0.00	0.00	8.95		* Shutdown for Retrofitment of Isolator (414- 89 B) of Tie bay of Mundka-1/ICT-3 at Jhatikara.
							0.37	0.00	0.00	0.00	8.95	100.00	
CKT	400kV JHATIKRA-MUNDKA(DTL)-2	OSFT	2/14/2025	4:35:00 PM	2/14/2025	8:08:00 PM	0.15	3.55	0.00	0.00	0.00		* Forced shutdown by DTL to attend hotspot of 218°C observed" on Jumper cone of the Y phase gantry line side at Mundka end.
CKT	400kV JHATIKRA-MUNDKA(DTL)-2	LCSD	2/10/2025	4:09:00 PM	2/10/2025	11:55:00 PM	0.32	0.00	0.00	0.00	7.77		* Shutdown for retrofitment of Isolator (417- 89 B) of Tie bay of Mundka-2 and ICT-4 at Jhatikara.
CKT	400kV JHATIKRA-MUNDKA(DTL)-2	OSFD	2/27/2025	5:15:00 PM	2/27/2025	10:04:00 PM	0.20	0.00	0.00	0.00	4.82		* S/D By DTL for attending hotspot inside male arm of Y phase line Isolator 403-89L of 400KV Jhatikara circuit 2 at Mundka end.
CKT	400kV JHATIKRA-MUNDKA(DTL)-2	OSFD	2/18/2025	4:44:00 PM	2/18/2025	8:38:00 PM	0.16	0.00	0.00	0.00	3.90		* Forced shutdown by DTL to attend broken conductor <*> shoe clamp of B phase conductor.
							0.83	3.55	0.00	0.00	16.48	99.47	
CKT	400kV KATHAL-HISAR-1	LCSD	2/4/2025	12:04:00 PM	2/8/2025	5:04:00 PM	4.21	0.00	0.00	0.00	101.00		* Shutdown for Retrofitment of isolators 404 89L, 404 89B <*> 405 89A ISOLATORS at Hisar Substation in ADD CAP 2019-24.
							4.21	0.00	0.00	0.00	101.00	100.00	
CKT	400kV KATHAL-HISAR-2	LCSD	2/25/2025	10:15:00 AM	2/28/2025	11:59:59 PM	3.57	0.00	0.00	0.00	85.75		* Shutdown for retrofitment of isolators 409 89L, 409 89B <*> 408 89B isolators at Hisar PG under ADD CAP 2019-24. Continued shutdown till 05.03.2025.
CKT	400kV KATHAL-HISAR-2	OSFT	2/6/2025	5:29:00 PM	2/7/2025	3:05:00 AM	0.40	9.60	0.00	0.00	0.00		* Forced shutdown NR-2 for attending hotspot observed in Y phase" Tower gantry dead end side Line dropper at kathal end.
							3.97	9.60	0.00	0.00	85.75	98.57	
CKT	400kV KANKROLI-JODHPUR(RRVPNL)	LART	2/1/2025	2:26:00 AM	2/1/2025	2:26:00 AM	0.00	0.00	0.00	0.00	0.00		* Autoreclosed Kankrol-Y-N/4.979KA/59.614KM. Fault under Kankrol TLM jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOTA-BEAWAR(SREE CEMENT)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOTA-MERTA(RRVPNL)	OMSU	2/23/2025	6:18:00 AM	2/23/2025	8:10:00 AM	0.08	0.00	1.87	0.00	0.00		**"Tripped on DT receive at Kota end * Kota FLRY Phase to Ground, 1.164 kA,257.890km (100.000%).Fault at Merta end." Tripping due to 400KV Merta-kankani RRVPNL line."
CKT	400kV KOTA-MERTA(RRVPNL)	OMSU	2/23/2025	6:18:00 AM	2/23/2025	8:10:00 AM	0.08	0.00	1.87	0.00	0.00		* Tripped onY Phase to Ground, Kota-Fault FAULT CURRENT: 1.164 kA* LOCATION: 257.890km (100.000%).Fault at Merta end,M/bay belong to" powergrid.Tripping during Kankani RRVPNL line.* 25.02.2025 00:03:18 INDIA (60011930)" Tripped on receipt of DT signal at Kota end.
				12:00:00 AM		12:00:00 AM	0.16	0.00	3.74	0.00	0.00	100.00	
CKT	400kV KOTPUTLI-BASSI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-KOTESHWAR(UK)-KOTESHWAR-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-KOTESHWAR(UK)-KOTESHWAR-2	OMSU	2/1/2025	12:00:01 AM	2/1/2025	12:32:00 AM	0.02	0.00	0.53	0.00	0.00		* Shutdown for retrofitting of Differential cum distance relays at Koteswar PG.
							0.02	0.00	0.53	0.00	0.00	100.00	
CKT	400kV KOTESHWAR-TEHRI(THDC)-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOTESHWAR-TEHRI(THDC)-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOTESHWAR-TEHRI(THDC)-3			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MANESAR-SOHNA(STERLITE)-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400KV MANESAR-SOHN(A/STERLITE)-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV MAHARANIBAGH-BALLABHGARH	LCSD	2/24/2025	5:15:00 PM	2/24/2025	8:25:00 PM	0.13	0.00	0.00	0.00	3.17		* S/D for removal of by pass arrangement and connectivity of 400KV Dadri- Maharanibagh and 400KV Maharanibagh-Ballabgarh at Maharanibagh for facilitate SD at Mandola for jack bus replacement work under ADD CAP 400kV Ballabgarh-Mahamibagh line charged at 1
CKT	400KV MAHARANIBAGH-BALLABHGARH	LART	2/15/2025	12:27:00 PM	2/15/2025	12:27:00 PM	0.00	0.00	0.00	0.00	0.00		* A/R on R-N fault. Ballabgarh: M1/5 981kA/56 182km <-> M2/5953kA/56 713km. Fault under Dadri TL jurisdiction.
CKT	400KV MAHARANIBAGH-BALLABHGARH	LART	2/15/2025	12:27:00 PM	2/15/2025	12:27:00 PM	0.00	0.00	0.00	0.00	0.00		* A/R on R-N fault. Ballabgarh: M1/5 981kA/56 182km <-> M2/5953kA/56 713km. Fault under Dadri TL jurisdiction.
CKT	400KV MAHARANIBAGH-BALLABHGARH	LCSD	2/24/2025	5:15:00 PM	2/24/2025	8:25:00 PM	0.13	0.00	0.00	0.00	3.17		* S/D for removal of by pass arrangement and connectivity of 400KV Dadri- Maharanibagh and 400KV Maharanibagh-Ballabgarh at Maharanibagh for facilitate SD at Mandola for jack bus replacement work under ADD CAP 400kV Ballabgarh-Mahamibagh line charged at 1
							0.26	0.00	0.00	0.00	6.34	100.00	
CKT	400KV-MBAGH-BAWANA-AC-CKT1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-MBAGH-BAWANA-AC-CKT2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-MBAGH-MANDOLA-AC-CKT1	LCSD	2/25/2025	8:08:00 AM	2/26/2025	9:36:00 PM	1.56	0.00	0.00	0.00	37.47		* Shutdown for jack bus replacement at Mandola
CKT	400KV-MBAGH-MANDOLA-AC-CKT1	LCSD	2/23/2025	10:48:00 AM	2/23/2025	8:54:00 PM	0.42	0.00	0.00	0.00	10.10		* Shutdown for jack bus replacement at Mandola
							0.98	0.00	0.00	0.00	47.57	100.00	
CKT	400KV-MBAGH-MANDOLA-AC-CKT2	LCSD	2/23/2025	11:00:00 AM	2/23/2025	9:00:00 PM	0.42	0.00	0.00	0.00	10.00		* Shutdown for jack bus replacement at Mandola
CKT	400KV-MBAGH-MANDOLA-AC-CKT2	LCSD	2/25/2025	8:10:00 AM	2/28/2025	12:00:00 PM	3.22	0.00	0.00	0.00	77.17		* Shutdown for jack bus replacement at Mandola
							3.64	0.00	0.00	0.00	87.17	100.00	
CKT	400KV HAPUR(UPPTCL)-MORADABAD(UPPTCL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV MEERUT-MANDOLA-1	LVRD	2/3/2025	10:39:00 PM	2/4/2025	6:23:00 AM	0.32	0.00	0.00	0.00	7.73		* Line opened on voltage regulation. Meerut-423 KV.
CKT	400KV MEERUT-MANDOLA-1	LCSD	2/15/2025	8:03:00 AM	2/22/2025	10:34:00 PM	7.61	0.00	0.00	0.00	182.52		* Shutdown for jack bus replacement at Mandola.
CKT	400KV MEERUT-MANDOLA-1	LVRD	2/28/2025	10:38:00 PM	2/28/2025	11:59:59 PM	0.06	0.00	0.00	0.00	1.37		* Line opened on voltage regulation. Meerut-423 KV
CKT	400KV MEERUT-MANDOLA-1	LVRD	2/28/2025	1:02:00 AM	2/28/2025	7:56:00 AM	0.29	0.00	0.00	0.00	6.90		* Line opened on voltage regulation. Meerut-423 KV
							8.28	0.00	0.00	0.00	196.82	100.00	
CKT	400KV MEERUT-MANDOLA-2	LCSD	2/15/2025	8:26:00 AM	2/22/2025	10:36:00 PM	7.59	0.00	0.00	0.00	182.17		* Shutdown for jack bus replacement at Mandola.
							7.59	0.00	0.00	0.00	182.17	100.00	
CKT	400KV MEERUT-MANDOLA-3	LVRD	2/3/2025	10:39:00 PM	2/4/2025	6:25:00 AM	0.32	0.00	0.00	0.00	7.77		* Line opened on voltage regulation. Meerut-423 KV.
CKT	400KV MEERUT-MANDOLA-3	LCSD	2/15/2025	8:26:00 AM	2/22/2025	10:44:00 PM	7.60	0.00	0.00	0.00	182.30		* Shutdown for jack bus replacement at Mandola.
							7.92	0.00	0.00	0.00	190.07	100.00	
CKT	400KV MEERUT-MANDOLA-4	LCSD	2/23/2025	11:07:00 AM	2/23/2025	8:22:00 PM	0.39	0.00	0.00	0.00	9.25		* Shutdown for jack bus replacement at Mandola.
CKT	400KV MEERUT-MANDOLA-4	LCSD	2/25/2025	8:15:00 AM	2/26/2025	9:48:00 PM	1.57	0.00	0.00	0.00	37.55		* Shutdown for jack bus replacement at Mandola
							1.96	0.00	0.00	0.00	46.80	100.00	
CKT	400KV MEERUT-MUZAFFARNAGAR(UPPTCL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NEEMRANA-BABAI(RRVPNL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NEEMRANA-MANESAR-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NEEMRANA-MANESAR-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NEEMRANA-SIKAR-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV RAPPC(NPCL)-CHITTORGARH(RRVPNL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV RAPPC(NPCL)-KANKROLI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV RAPPC(NPCL)-KOTA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV RAPPD(NPCL)-KOTA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV RATANGARH(RRVPNL)-SIKAR-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/19/2025	7:50:00 PM	2/20/2025	6:03:00 AM	0.43	0.00	0.00	0.00	10.22		* Line opened on voltage regulation. Sikar -423 KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/9/2025	9:54:00 PM	2/10/2025	6:00:00 AM	0.34	0.00	0.00	0.00	8.10		* Line opened on voltage regulation. Sikar-423 KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/1/2025	10:09:00 PM	2/2/2025	5:45:00 AM	0.32	0.00	0.00	0.00	7.80		* Line opened on voltage regulation. Sikar-424 KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/5/2025	9:42:00 PM	2/6/2025	5:46:00 AM	0.34	0.00	0.00	0.00	8.07		* Line opened on voltage regulation.Sikar-425 KV
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/1/2025	12:00:01 AM	2/1/2025	6:07:00 AM	0.26	0.00	0.00	0.00	6.12		* Line opened on voltage regulation. Sikar 418 KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/13/2025	10:02:00 PM	2/14/2025	6:09:00 AM	0.34	0.00	0.00	0.00	8.12		* Line opened on voltage regulation.Sikar- 422 KV
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/12/2025	10:07:00 PM	2/13/2025	5:29:00 AM	0.31	0.00	0.00	0.00	7.37		* Line opened on voltage regulation. Sikar-423 KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/2/2025	8:47:00 PM	2/3/2025	5:39:00 AM	0.37	0.00	0.00	0.00	8.87		* Line opened on voltage regulation. Sikar-423 kv.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/8/2025	11:02:00 PM	2/9/2025	5:41:00 AM	0.28	0.00	0.00	0.00	6.65		* Line opened on voltage regulation. Sikar 419 KV
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/1/2025	12:37:00 PM	2/1/2025	8:56:00 PM	0.35	0.00	0.00	0.00	8.32		* Line opened on Power regulation to manage loading of Sikar -Ratangarh' line (to be opened from sikar side only)
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/16/2025	8:18:00 PM	2/17/2025	5:43:00 AM	0.39	0.00	0.00	0.00	9.42		* Line opened on voltage regulation. Sikar-420KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/16/2025	12:18:00 AM	2/16/2025	5:52:00 AM	0.23	0.00	0.00	0.00	5.57		* Line opened on voltage regulation. Sikar-420KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/7/2025	9:35:00 PM	2/10/2025	6:00:00 AM	2.35	0.00	0.00	0.00	56.42		* Line opened on voltage regulation Sikar 420 KV
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/6/2025	9:16:00 PM	2/7/2025	5:35:00 AM	0.35	0.00	0.00	0.00	8.32		* Line opened on voltage regulation.Sikar-425 KV
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/24/2025	9:47:20 PM	2/25/2025	5:41:00 AM	0.33	0.00	0.00	0.00	7.89		* Line opened on voltage regulation. Sikar-423 KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/26/2025	6:21:00 PM	2/27/2025	5:25:00 AM	0.46	0.00	0.00	0.00	11.07		* Line opened on voltage regulation. Sikar-423 KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/28/2025	8:43:00 PM	2/28/2025	11:59:59 PM	0.14	0.00	0.00	0.00	3.28		* Line opened on voltage regulation. Sikar-423 KV
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/27/2025	8:33:00 PM	2/28/2025	5:50:00 AM	0.39	0.00	0.00	0.00	9.28		* Line opened on voltage regulation. Sikar-423 KV
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/21/2025	9:27:00 PM	2/22/2025	5:43:00 AM	0.34	0.00	0.00	0.00	8.27		* Line opened on voltage regulation. Sikar -423 KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/23/2025	9:03:00 PM	2/24/2025	5:41:00 AM	0.36	0.00	0.00	0.00	8.63		* Line opened on voltage regulation. Sikar-750KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/22/2025	9:19:00 PM	2/23/2025	5:41:00 AM	0.35	0.00	0.00	0.00	8.37		* Line opened on voltage regulation. Sikar -423 KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/25/2025	9:31:00 PM	2/26/2025	5:40:00 AM	0.34	0.00	0.00	0.00	8.15		* Line opened on voltage regulation. Sikar-423 KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/20/2025	9:17:00 PM	2/21/2025	6:12:00 AM	0.37	0.00	0.00	0.00	8.92		* Line opened on voltage regulation. Sikar -423 KV.
CKT	400KV RATANGARH(RRVPNL)-SIKAR-2	LVRD	2/18/2025	9:22:00 PM	2/19/2025	5:57:00 AM	0.36	0.00	0.00	0.00	8.58		* Line opened on voltage regulation. Sikar-423 KV.
							10.10	0.00	0.00	0.00	241.61	100.00	
CKT	400KV ROORKEE-DEHRADUN	OSFT	2/4/2025	9:48:00 AM	2/4/2025	12:56:00 PM	0.13	3.13	0.00	0.00	0.00		* Forced outage for replacement of Flashover Pilot insulator at TN-36.
							0.13	3.13	0.00	0.00	0.00	99.53	
CKT	400KV ROORKEE-KASHIPUR(PTCUL)-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV ROORKEE-KASHIPUR(PTCUL)-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV ROORKEE-MUZAFFARNAGAR(UPPTCL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV ROORKEE-RISHIKESH(PTCUL)			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE TO Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400KV ROORKEE-SAHARANPUR-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SIKAR-BASSI-1	QMSU	2/10/2025	3:24:00 PM	2/10/2025	11:15:00 PM	0.33	0.00	0.00	0.00	0.00		* Shutdown for 400KV Busbar Relay retrofitment work.
							0.33	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SIKAR-BASSI-2	QMSU	2/4/2025	2:41:00 PM	2/4/2025	5:29:00 PM	0.12	0.00	0.00	0.00	0.00		* Forced Shutdown to remove kites/kite threads to remove Kite thread (Chinese Manja) at location 51 on B-phase.
CKT	400KV SIKAR-BASSI-2	LART	2/4/2025	8:32:00 AM	2/4/2025	8:32:00 AM	0.00	0.00	0.00	0.00	0.00		* Auto reclosed on B-N Fault. FLR.SIKAR-16.926km (9.990%) /12.637 kA ,Fault under SIKAR TL jurisdiction.
CKT	400KV SIKAR-BASSI-2	LCSD	2/20/2025	3:19:00 PM	2/21/2025	1:05:00 AM	0.41	0.00	0.00	0.00	0.00		* S/D for 400KV Busbar Relay Retrofitment work and Tie Bay LBB Back Trip testing under ADD CAP at Bassi.
							0.53	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUGHLAKABAD-BALLABHGARH-1	OSPT	2/11/2025	9:16:00 AM	2/11/2025	7:38:00 PM	0.43	10.37	0.00	0.00	0.00		* Shutdown for replacement of critically damaged insulators on M/C towers.
CKT	400KV TUGHLAKABAD-BALLABHGARH-1	OSPT	2/10/2025	8:57:00 AM	2/10/2025	9:02:00 PM	0.50	12.08	0.00	0.00	0.00		* Shutdown for replacement of critically damaged insulators on M/C towers.
							0.93	22.45	0.00	0.00	0.00	96.66	
CKT	400KV TUGHLAKABAD-BALLABHGARH-2	OSPT	2/13/2025	9:16:00 AM	2/13/2025	7:37:00 PM	0.43	10.35	0.00	0.00	0.00		* SD for replacement of critically damaged insulators
CKT	400KV TUGHLAKABAD-BALLABHGARH-2	OSPT	2/12/2025	9:09:00 AM	2/12/2025	9:22:00 PM	0.51	12.22	0.00	0.00	0.00		* Shutdown taken for for replacement of critically damaged insulators.
							0.94	22.57	0.00	0.00	0.00	96.64	
CKT	765KV AGRA-JHATIKARA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV AJMER-BHADLA2-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV AJMER-BHADLA2-2	OSFT	2/22/2025	10:03:00 PM	2/23/2025	5:49:00 AM	0.32	7.77	0.00	0.00	0.00		* Forced S/D attend hotspot in R phase line isolator at Bhadla. 2" SS.
							0.32	7.77	0.00	0.00	0.00	98.84	
CKT	765KV BHADLA-BIKANER-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV BHADLA-BIKANER-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV BHIWANI-PHAGI(RRVPNL)-1	LVRD	2/23/2025	5:41:00 PM	2/24/2025	7:04:00 AM	0.56	0.00	0.00	0.00	0.00	13.38	* Line opened on voltage regulation. Bhiwani- 785KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-1	LVRD	2/22/2025	9:16:00 PM	2/23/2025	7:19:00 AM	0.42	0.00	0.00	0.00	0.00	10.05	* Line opened on voltage regulation. Bhiwani- 785KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-1	LVRD	2/27/2025	10:35:00 PM	2/28/2025	7:01:00 AM	0.35	0.00	0.00	0.00	0.00	8.43	* Line opened on voltage regulation. Bhiwani-790 KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-1	LVRD	2/25/2025	9:11:00 PM	2/26/2025	6:58:00 AM	0.41	0.00	0.00	0.00	0.00	9.78	* Line opened on voltage regulation. Bhiwani-790 KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-1	LVRD	2/16/2025	5:44:00 PM	2/17/2025	8:26:00 AM	0.61	0.00	0.00	0.00	0.00	14.70	* Line opened on voltage regulation. Bhiwani-790KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-1	LVRD	2/14/2025	9:35:00 PM	2/15/2025	7:58:00 AM	0.43	0.00	0.00	0.00	0.00	10.38	* Line opened on voltage regulation.Bhiwani-790KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-1	LVRD	2/4/2025	9:39:00 PM	2/5/2025	9:21:00 AM	0.49	0.00	0.00	0.00	0.00	11.70	* Line opened on voltage regulation. Bhiwani-790 kv
CKT	765KV BHIWANI-PHAGI(RRVPNL)-1	LVRD	2/1/2025	6:21:00 PM	2/2/2025	7:09:00 AM	0.53	0.00	0.00	0.00	0.00	12.80	* Line opened on voltage regulation. Bhiwani-790 kv
CKT	765KV BHIWANI-PHAGI(RRVPNL)-1	LVRD	2/7/2025	12:10:00 AM	2/7/2025	8:07:00 AM	0.33	0.00	0.00	0.00	0.00	7.95	* Line opened on voltage regulation. Bhiwani-790 kv
CKT	765KV BHIWANI-PHAGI(RRVPNL)-1	LVRD	2/8/2025	9:31:00 PM	2/9/2025	9:11:00 AM	0.49	0.00	0.00	0.00	0.00	11.67	* Line opened on voltage regulation. Bhiwani 797 KV
CKT	765KV BHIWANI-PHAGI(RRVPNL)-1	LVRD	2/18/2025	9:12:00 PM	2/19/2025	6:09:00 AM	0.37	0.00	0.00	0.00	0.00	8.95	* Line opened on voltage regulation. Bhiwani-790 KV.
							4.99	0.00	0.00	0.00	0.00	119.79	100.00
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/21/2025	9:29:00 PM	2/22/2025	8:03:00 AM	0.44	0.00	0.00	0.00	0.00	10.57	* Line opened on voltage regulation. Bhiwani- 785KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/17/2025	9:21:00 PM	2/18/2025	7:14:00 AM	0.41	0.00	0.00	0.00	0.00	9.88	* Line opened on voltage regulation. Bhiwani-790 KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/28/2025	6:07:00 PM	2/27/2025	8:47:00 AM	0.61	0.00	0.00	0.00	0.00	14.67	* Line opened on voltage regulation. Bhiwani-790 KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/16/2025	12:47:00 AM	2/16/2025	7:28:00 AM	0.28	0.00	0.00	0.00	0.00	6.68	* Line opened on voltage regulation. Bhiwani-790KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/25/2025	1:15:00 AM	2/25/2025	9:10:00 AM	0.33	0.00	0.00	0.00	0.00	7.92	* Line opened on voltage regulation. Bhiwani-790 KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/28/2025	9:00:00 PM	2/28/2025	11:59:59 PM	0.13	0.00	0.00	0.00	0.00	3.00	* Line opened on voltage regulation. Bhiwani-790 KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/19/2025	7:52:00 PM	2/20/2025	7:23:00 AM	0.48	0.00	0.00	0.00	0.00	11.52	* Line opened on voltage regulation. Bhiwani- 785KV.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/7/2025	9:31:00 PM	2/8/2025	7:59:00 AM	0.44	0.00	0.00	0.00	0.00	10.47	* Line opened on voltage regulation Bhiwani 796 KV
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/9/2025	5:17:00 PM	2/10/2025	7:35:00 AM	0.60	0.00	0.00	0.00	0.00	14.30	* Line opened on voltage regulation Bhiwani 796 KV
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/5/2025	9:58:00 PM	2/6/2025	7:01:00 AM	0.38	0.00	0.00	0.00	0.00	9.05	* Line opened on voltage regulation. Bhiwani-790 kv
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/10/2025	6:13:00 PM	2/11/2025	8:22:00 AM	0.59	0.00	0.00	0.00	0.00	14.15	* Line opened on voltage regulation Bhiwani 796 KV
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/13/2025	10:16:00 PM	2/14/2025	7:02:00 AM	0.32	0.00	0.00	0.00	0.00	8.77	* Line opened on voltage regulation. Bhiwani-796 KV
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/11/2025	8:47:00 PM	2/12/2025	6:20:00 AM	0.40	0.00	0.00	0.00	0.00	9.55	* Line opened on voltage regulation Bhiwani 796 KV
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/2/2025	5:30:00 PM	2/3/2025	7:01:00 AM	0.56	0.00	0.00	0.00	0.00	13.52	* Line opened on voltage regulation. Bhiwani-802 kv.
CKT	765KV BHIWANI-PHAGI(RRVPNL)-2	LVRD	2/1/2025	12:00:01 AM	2/1/2025	8:02:00 AM	0.34	0.00	0.00	0.00	0.00	8.03	* Line opened on voltage regulation. Bhiwani 796 KV.
							6.36	0.00	0.00	0.00	0.00	152.08	100.00
CKT	765KV BHIWANI-MEERUT	LVRD	2/22/2025	4:50:00 PM	2/23/2025	3:36:00 PM	0.95	0.00	0.00	0.00	0.00	22.77	* Line opened on voltage regulation.Meerut-792 KV
							0.95	0.00	0.00	0.00	0.00	22.77	100.00
CKT	765KV BHIWANI-MOGA	LVRD	2/28/2025	12:51:00 AM	2/28/2025	7:41:00 AM	0.29	0.00	0.00	0.00	0.00	6.83	* Line kept opened on voltage regulation. Bhiwani-790 KV.
CKT	765KV BHIWANI-MOGA	OSPT	2/27/2025	9:50:00 AM	2/28/2025	12:50:00 AM	0.63	15.00	0.00	0.00	0.00	6.83	* Shutdown by NR-2 for Replacement of Decan make single pilot Polymer Insulator (at 710 <-&->711 dropper) with double string insulator and Reactor <-&-> Reactor Bay AMP.
							0.92	15.00	0.00	0.00	0.00	6.83	97.77
CKT	765KV-BIKANER-BHADLA2-ACL-CKT1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV-BIKANER-BHADLA2-ACL-CKT2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV BIKANER-MOGA-1	LVRD	2/20/2025	2:11:00 AM	2/20/2025	7:24:00 AM	0.22	0.00	0.00	0.00	0.00	5.22	* Line opened on voltage regulation. Bikaner-795 KV.
CKT	765KV BIKANER-MOGA-1	LVRD	2/1/2025	10:51:00 PM	2/2/2025	6:57:00 AM	0.34	0.00	0.00	0.00	0.00	8.10	* Line opened on voltage regulation. Bikaner 795 KV.
CKT	765KV BIKANER-MOGA-1	LVRD	2/12/2025	8:18:00 PM	2/13/2025	8:34:00 AM	0.51	0.00	0.00	0.00	0.00	12.27	* Line opened on voltage regulation. Bikaner-790 KV.
CKT	765KV BIKANER-MOGA-1	LVRD	2/8/2025	9:32:00 PM	2/9/2025	7:19:00 AM	0.40	0.00	0.00	0.00	0.00	9.63	* Line opened on voltage regulation. Bikaner 797 KV
CKT	765KV BIKANER-MOGA-1	LVRD	2/16/2025	9:22:00 PM	2/17/2025	6:30:00 AM	0.38	0.00	0.00	0.00	0.00	9.13	* Line opened on voltage regulation. Bikaner-790KV.
CKT	765KV BIKANER-MOGA-1	LVRD	2/21/2025	9:32:00 PM	2/22/2025	7:46:00 AM	0.43	0.00	0.00	0.00	0.00	10.23	* Line opened on voltage regulation. Bikaner-795 KV.
							2.28	0.00	0.00	0.00	0.00	54.58	100.00
CKT	765KV BIKANER-MOGA-2	LVRD	2/17/2025	9:24:00 PM	2/18/2025	6:35:00 AM	0.38	0.00	0.00	0.00	0.00	9.18	* Line opened on voltage regulation. Bikaner-790 KV.
CKT	765KV BIKANER-MOGA-2	LVRD	2/9/2025	5:17:00 PM	2/10/2025	7:45:00 AM	0.60	0.00	0.00	0.00	0.00	14.47	* Line opened on voltage regulation Bikaner 795 KV
CKT	765KV BIKANER-MOGA-2	LVRD	2/2/2025	9:00:00 PM	2/3/2025	7:02:00 AM	0.42	0.00	0.00	0.00	0.00	10.03	* Line opened on voltage regulation. Bikaner-790 kv.
CKT	765KV BIKANER-MOGA-2	LVRD	2/7/2025	9:27:00 PM	2/8/2025	6:42:00 AM	0.39	0.00	0.00	0.00	0.00	9.25	* Line opened on voltage regulation Bikaner 795 KV
CKT	765KV BIKANER-MOGA-2	LVRD	2/4/2025	11:35:00 PM	2/5/2025	9:39:00 AM	0.42	0.00	0.00	0.00	0.00	10.07	* Line opened on voltage regulation. Bikaner-790 kv
CKT	765KV BIKANER-MOGA-2	LVRD	2/1/2025	12:00:01 AM	2/1/2025	9:18:00 AM	0.39	0.00	0.00	0.00	0.00	9.30	* Line opened on voltage regulation. Bikaner 795 KV.
CKT	765KV BIKANER-MOGA-2	LVRD	2/13/2025	10:19:00 PM	2/14/2025	6:07:00 AM	0.33	0.00	0.00	0.00	0.00	7.40	* Line opened on voltage regulation.Bikaner-796 KV
CKT	765KV BIKANER-MOGA-2	LVRD	2/20/2025	9:38:00 PM	2/21/2025	8:35:00 AM	0.46	0.00	0.00	0.00	0.00	10.95	* Line opened on voltage regulation. Bikaner-795 KV.
CKT	765KV BIKANER-MOGA-2	LVRD	2/22/2025	9:57:00 PM	2/23/2025	6:24:00 AM	0.35	0.00	0.00	0.00	0.00	8.45	* Line opened on voltage regulation. Bikaner-795 KV
CKT	765KV BIKANER-MOGA-2	LVRD	2/23/2025	5:44:00 PM	2/24/2025	8:54:00 AM	0.63	0.00	0.00	0.00	0.00	15.17	* Line opened on voltage regulation. Bikaner- 785KV.
							4.37	0.00	0.00	0.00	0.00	104.67	100.00
CKT	765KV CHITTORGARH-AJMER-1	LVRD	2/19/2025	7:41:00 PM	2/20/2025	7:54:00 AM	0.51	0.00	0.00	0.00	0.00	12.22	* Line opened on voltage regulation. Ajmer-790 KV.
CKT	765KV CHITTORGARH-AJMER-1	LVRD	2/22/2025	9:19:00 PM	2/23/2025	6:43:00 AM	0.39	0.00	0.00	0.00	0.00	9.40	* Line opened on voltage regulation. Ajmer-792 KV
CKT	765KV CHITTORGARH-AJMER-1	LVRD	2/28/2025	8:25:00 PM	2/28/2								

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE TO Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	765KV CHITTORGARH-AJMER-1	LVRD	2/3/2025	7:50:00 PM	2/4/2025	8:23:00 AM	0.52	0.00	0.00	0.00	12.55		* Line opened on voltage regulation. Ajmer-802 kV
CKT	765KV CHITTORGARH-AJMER-1	LVRD	2/11/2025	8:10:00 PM	2/12/2025	7:33:00 AM	0.47	0.00	0.00	0.00	11.38		* Line opened on voltage regulation. Ajmer-790 KV.
CKT	765KV CHITTORGARH-AJMER-1	LVRD	2/15/2025	5:41:00 PM	2/16/2025	7:07:00 AM	0.56	0.00	0.00	0.00	13.43		* Line opened on voltage regulation. Ajmer-790 KV.
CKT	765KV CHITTORGARH-AJMER-1	LVRD	2/25/2025	9:00:00 PM	2/26/2025	6:48:00 AM	0.41	0.00	0.00	0.00	9.80		* Line opened on voltage regulation. Ajmer-790 KV.
CKT	765KV CHITTORGARH-AJMER-1	LVRD	2/20/2025	8:15:00 PM	2/21/2025	8:14:00 AM	0.50	0.00	0.00	0.00	11.98		* Line opened on voltage regulation. Ajmer-792 KV.
CKT	765KV CHITTORGARH-AJMER-1	LVRD	2/23/2025	8:55:00 PM	2/24/2025	8:59:00 AM	0.50	0.00	0.00	0.00	12.07		* Line opened on voltage regulation. Ajmer-790KV.
							6.74	0.00	0.00	0.00	161.98	100.00	
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/6/2025	9:21:00 PM	2/7/2025	7:02:00 AM	0.40	0.00	0.00	0.00	9.68		* Line opened on voltage regulation Ajmer 799 KV
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/8/2025	8:09:00 PM	2/9/2025	7:34:00 AM	0.48	0.00	0.00	0.00	11.42		* Line opened on voltage regulation. Ajmer-800KV
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/18/2025	7:51:00 PM	2/19/2025	6:30:00 AM	0.44	0.00	0.00	0.00	10.65		* Line opened on voltage regulation. Ajmer-790 KV.
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/27/2025	8:17:00 PM	2/28/2025	7:51:00 AM	0.48	0.00	0.00	0.00	11.57		* Line opened on voltage regulation. Ajmer-792 KV
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/26/2025	6:05:00 PM	2/27/2025	7:40:00 AM	0.57	0.00	0.00	0.00	13.58		* Line opened on voltage regulation. Ajmer-792 KV
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/24/2025	6:55:00 PM	2/25/2025	7:57:00 AM	0.54	0.00	0.00	0.00	13.03		* Line opened on voltage regulation. Ajmer-792 KV
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/21/2025	9:17:00 PM	2/22/2025	7:11:00 AM	0.41	0.00	0.00	0.00	9.90		* Line opened on voltage regulation. Ajmer-790 KV.
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/14/2025	6:22:00 PM	2/15/2025	6:35:00 AM	0.51	0.00	0.00	0.00	12.22		* Line opened on voltage regulation. Ajmer-790 KV.
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/4/2025	8:15:00 PM	2/5/2025	9:10:00 AM	0.54	0.00	0.00	0.00	12.92		* Line opened on voltage regulation Ajmer 799 KV
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/12/2025	8:09:00 PM	2/13/2025	8:17:00 AM	0.51	0.00	0.00	0.00	12.13		* Line opened on voltage regulation. Ajmer-790 KV.
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/1/2025	12:00:01 AM	2/1/2025	9:20:00 AM	0.39	0.00	0.00	0.00	9.33		* Line opened on voltage regulation. Ajmer-790 KV.
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/4/2025	8:15:00 PM	2/5/2025	9:10:00 AM	0.54	0.00	0.00	0.00	12.92		* Line opened on voltage regulation Ajmer 799 KV
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/2/2025	5:28:00 PM	2/3/2025	7:15:00 AM	0.57	0.00	0.00	0.00	13.78		* Line opened on voltage regulation. Ajmer-802 kV
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/10/2025	6:04:00 PM	2/11/2025	8:23:00 AM	0.60	0.00	0.00	0.00	14.32		* Line opened on voltage regulation. Ajmer-790 KV.
CKT	765KV CHITTORGARH-AJMER-2	LVRD	2/16/2025	8:23:00 PM	2/17/2025	6:34:00 AM	0.42	0.00	0.00	0.00	10.18		* Line opened on voltage regulation. Ajmer-790 KV
							7.40	0.00	0.00	0.00	177.63	100.00	
CKT	765KV-FATEHGARH-II-BHADLA-I-CKT1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	765KV-FATEHGARH-II-BHADLA-I-CKT2	OSPT	2/24/2025	6:00:00 PM	2/25/2025	3:08:00 AM	0.38	0.00	0.00	0.00	0.00		* Shutdown for AMP works in line and bay equipments.
CKT	765KV-FATEHGARH-II-BHADLA-I-CKT2	OSPT	2/25/2025	6:06:00 PM									

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	240MVAR,SWLR OF BHADLA-1 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHIWANI-2 AT PHAGI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHIWANI-1 AT PHAGI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF AGRA AT JHATIKARA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF ALIGARH AT JHATIKARA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF ZERDA AT KANKROLI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF GR.NOIDA AT MEERUT			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF AGRA-2 AT SIKAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF AGRA-1 AT SIKAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	Coupling Xmer 550MVA 400/34.5kV			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	Coupling Xmer 550MVA 400/34.5kV			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	Coupling Xmer ST-1 550MVA 400/34.5kV			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	Coupling Xmer ST-2 550MVA 400/34.5kV			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
SVC	- 300/+ 400MVAR SVC AT KANKROLI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
SVC	400/33KV COUPLING XMER BAY TCR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC CHAMPA-KURUKSHETRA POLE-1			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC CHAMPA-KURUKSHETRA POLE-2	OSFT	2/13/2025	10:25:00 PM	2/14/2025	4:32:00 AM	0.26	6.12	0.00	0.00	0.00		* Forced S/D taken by WR-1 to attend Pump 2 of pole 2 due to* internal failure VFD-2 at Champa end.
							0.26	6.12	0.00	0.00	0.00	99.09	
VALVE_HALL	800kV HVDC CHAMPA-KURUKSHETRA POLE-3			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC CHAMPA-KURUKSHETRA POLE-4			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT AJMER			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT AJMER	OSPT	2/10/2025	3:41:00 PM	2/11/2025	5:10:00 AM	0.56	13.48	0.00	0.00	0.00		* Shutdown for CSD realy retrofitment and AMP work.
							0.56	13.48	0.00	0.00	0.00	97.99	
XMER	500MVA,400/220kV ICT-1 AT BAGPAT			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BAGPAT			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BALLABGARH			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BALLABGARH	OSFT	2/6/2025	10:24:00 AM	2/6/2025	8:55:00 PM	0.44	10.52	0.00	0.00	0.00		* Forced shutdown for attending hot point at 220 kV CT R Ph CB* side <*> 20989 Isolator Y ph CT side.
							0.44	10.52	0.00	0.00	0.00	98.44	
XMER	500MVA,400/220kV ICT-3 AT BALLABGARH			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT BALLABGARH			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BASSI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BASSI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT BASSI	SCSD	2/13/2025	4:18:00 PM	2/14/2025	12:14:00 AM	0.33	0.00	0.00	0.00	7.93		* Shutdown for 400kV Busbar Relay Retrofitment work.
							0.33	0.00	0.00	0.00	7.93	100.00	
XMER	500MVA,400/220kV ICT-1 AT BHADLA-2	OSPT	2/21/2025	7:27:00 PM	2/21/2025	11:12:00 PM	0.16	3.75	0.00	0.00	0.00		* Shutdown for AMP, CSD fine tuning works.
							0.16	3.75	0.00	0.00	0.00	99.44	
XMER	1500MVA,765/400kV ICT-1 AT BHADLA-2	OSPT	2/19/2025	8:14:00 PM	2/20/2025	1:13:00 AM	0.21	4.98	0.00	0.00	0.00		* Shutdown for CSD Fine Tuning work.
							0.21	4.98	0.00	0.00	0.00	99.26	
XMER	500MVA,400/220kV ICT-2 AT BHADLA-2	OSPT	2/25/2025	7:25:00 PM	2/26/2025	12:17:00 AM	0.20	4.87	0.00	0.00	0.00		* Shutdown for CSD fine Tuning in Bay 439 <*> 440.
							0.20	4.87	0.00	0.00	0.00	99.28	
XMER	1500MVA,765/400kV ICT-2 AT BHADLA-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT BHADLA-2	OSPT	2/26/2025	7:06:00 PM	2/26/2025	11:53:00 PM	0.20	4.78	0.00	0.00	0.00		* Shutdown for CSD fine tuning in 446 Bay.
							0.20	4.78	0.00	0.00	0.00	99.29	
XMER	1500MVA,765/400kV ICT-3 AT BHADLA-2	OSPT	2/24/2025	9:44:00 PM	2/25/2025	1:46:00 AM	0.17	4.03	0.00	0.00	0.00		* Shutdown for CSD fine Tuning in Bay 427 <*> 428.
XMER	1500MVA,765/400kV ICT-3 AT BHADLA-2	OSPT	2/23/2025	7:40:00 PM	2/23/2025	11:13:00 PM	0.15	3.55	0.00	0.00	0.00		* Shutdown for CSD Fine Tuning in Bay 720 <*> 721
							0.32	7.58	0.00	0.00	0.00	98.87	
XMER	500MVA,400/220kV ICT-4 AT BHADLA-2	OSPT	2/27/2025	8:26:00 PM	2/27/2025	11:48:00 PM	0.14	3.37	0.00	0.00	0.00		* S/D for CSD Fine Tuning in 447 Bays
							0.14	3.37	0.00	0.00	0.00	99.50	
XMER	765/400kV ICT-4	OSPT	2/20/2025	7:12:00 PM	2/20/2025	10:49:00 PM	0.15	3.62	0.00	0.00	0.00		* S/D for CSD Fine Tuning.
XMER	765/400kV ICT-4	OSPT	2/28/2025	7:51:00 PM	2/28/2025	11:59:59 PM	0.17	4.15	0.00	0.00	0.00		* Shutdown for CSD Fine Tuning work.
							0.32	7.77	0.00	0.00	0.00	98.64	
XMER	500MVA,400/220kV ICT-5 AT BHADLA-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-6 AT BHADLA-2	SCSD	2/6/2025	6:51:00 PM	2/7/2025	12:56:00 AM	0.25	0.00	0.00	0.00	6.08		* Shutdown for Bay extension work
							0.25	0.00	0.00	0.00	6.08	100.00	
XMER	500MVA,400/220kV ICT-7 AT BHADLA-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-8 AT BHADLA-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BAHADURGARH			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	500MVA,400/220kV ICT-2 AT BAHADURGARH			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT BAHADURGARH			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BADHLA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BADHLA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BADHLA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT BADHLA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT BHADLA	OSFT	2/14/2025	8:06:00 PM	2/15/2025	12:19:00 AM	0.18	4.22	0.00	0.00	0.00		* Forced shutdown to attend hot spot observed in ICT - 4 -Jack bus* Y pH.
							0.18	4.22	0.00	0.00	0.00	99.37	
XMER	500MVA,400/220kV ICT-5 AT BADHLA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-6 AT BHADLA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-7 AT BADHLA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA ICT-8			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BHIWADI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHIWADI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT BHIWADI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BHIWANI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1000MVA,765/400kV ICT-1 AT BHIWANI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHIWANI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1000MVA,765/400kV ICT-2 AT BHIWANI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1000MVA,765/400kV ICT-3 AT BHIWANI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BHINMAL	OSPT	2/10/2025	4:22:00 PM	2/11/2025	6:22:00 AM	0.58	14.00	0.00	0.00	0.00		* Shutdown for AMP work.
							0.58	14.00	0.00	0.00	0.00	97.92	
XMER	315MVA,400/220kV ICT-2 AT BHINMAL	OSPT	2/12/2025	4:29:00 PM	2/13/2025	5:43:00 AM	0.55	13.23	0.00	0.00	0.00		* S/D for AMP work
							0.55	13.23	0.00	0.00	0.00	98.03	
XMER	315MVA,400/220kV ICT-3 AT BHINMAL			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BIKANER			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BIKANER	OSPT	2/12/2025	5:23:00 PM	2/13/2025	4:59:00 AM	0.48	11.60	0.00	0.00	0.00		* S/D for AMP work.
							0.48	11.60	0.00	0.00	0.00	98.27	
XMER	500MVA,400/220kV ICT-2 AT BIKANER			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BIKANER	OSPT	2/7/2025	5:34:00 PM	2/8/2025	5:04:00 AM	0.48	11.50	0.00	0.00	0.00		* Shutdown for AMP work
							0.48	11.50	0.00	0.00	0.00	98.29	
XMER	1500MVA,765/400kV ICT-3 AT BIKANER			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	400/220KV ICT3			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT BAWANA DTL			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT CHITTORGARH	OSPT	2/3/2025	5:01:00 PM	2/4/2025	9:32:00 PM	1.19	28.52	0.00	0.00	0.00		* Shutdown for AMP work and insulation coating of 33KV tertiary S/D till 04.02.2025.
							1.19	28.52	0.00	0.00	0.00	95.76	
XMER	1500MVA,765/400kV ICT-2 AT CHITTORGARH	OSPT	2/7/2025	4:48:00 PM	2/8/2025	8:41:00 AM	0.66	15.88	0.00	0.00	0.00		* Shutdown for AMP work and insulation coating of 33KV tertiary
							0.66	15.88	0.00	0.00	0.00	97.64	
XMER	315MVA,400/220kV ICT-1 AT DEHRADUN			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT DEHRADUN			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT DWARKA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT DWARKA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT DWARKA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT DWARKA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA, 400/220kV ICT-10 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE To ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA, 765/400kV ICT-5 AT FATEHGARH-2	OSFT	2/6/2025	7:39:00 PM	2/6/2025	11:27:00 PM	0.16	3.80	0.00	0.00	0.00		* Forced shutdown to attend hotspot observed in 722-89T B-Ph of* 765/400 ICT-5
							0.16	3.80	0.00	0.00	0.00	99.43	
XMER	500MVA, 400/220kV ICT-6 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA, 765/400kV ICT-6 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA, 400/220kV ICT-7 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-8 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-9 AT FATEHGARH-2			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT GURGAON			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT GURGAON			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT GURGAON			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT GURGAON			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HISAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HISAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT HISAR	SCSD	2/27/2025	9:13:00 AM	2/27/2025	8:20:00 PM	0.46	0.00	0.00	0.00	11.12		* Shutdown 220 KV Busbar relay retrofit work under Addcap.
							0.46	0.00	0.00	0.00	11.12	100.00	
XMER	500MVA,400/220kV ICT-1 AT JAIPUR SOUTH			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT JAIPUR SOUTH			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT JHATIKARA	OSPT	2/3/2025	3:40:00 PM	2/3/2025	10:24:00 PM	0.28	6.73	0.00	0.00	0.00		* Shutdown for attending hotspot in isolator finger of 407-89B, Main Bay of ICT-1, when opening the 400kV Jhatikra-Barnnoul line at Jhatikara end.
							0.28	6.73	0.00	0.00	0.00	99.00	
XMER	1500MVA,765/400kV ICT-2 AT JHATIKARA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT JHATIKARA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT JHATIKARA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT JIND			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT JIND			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KANKROLI	OSPT	2/14/2025	2:37:00 PM	2/14/2025	7:21:00 PM	0.20	4.73	0.00	0.00	0.00		* Shutdown for Insulation coating on tertiary terminals.
							0.20	4.73	0.00	0.00	0.00	99.30	
XMER	315MVA,400/220kV ICT-2 AT KANKROLI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT KANKROLI	OSPT	2/15/2025	3:10:00 PM	2/15/2025	8:26:00 PM	0.22	5.27	0.00	0.00	0.00		* S/D for Insulation coating on tertiary terminals.
							0.22	5.27	0.00	0.00	0.00	99.22	
XMER	800MVA,765/400kV ICT-1 AT KOTESHWAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	800MVA,765/400kV ICT-2 AT KOTESHWAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	800MVA,765/400kV ICT-3 AT KOTESHWAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	800MVA,765/400kV ICT-4 AT KOTESHWAR			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KOTA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KOTA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KOTPUTLI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KOTPUTLI			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT KURUKSHETRA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT KURUKSHETRA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KURUKSHETRA			12:00:00 AM		12:00:00 AM	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT MANDOLA	SCSD	2/18/2025	7:57:00 AM	2/18/2025	7:31:00 PM	0.48	0.00	0.00	0.00	11.57		* Shutdown for jack bus replacement at Mandola.
XMER	500MVA,400/220kV ICT-1 AT MANDOLA	SCSD	2/15/2025	8:06:00 AM	2/15/2025	8:56:00 PM	0.54	0.00	0.00	0.00	12.83		* Shutdown for jack bus replacement at Mandola.
XMER	500MVA,400/220kV ICT-1 AT MANDOLA	SCSD	2/16/2025	8:07:00 AM	2/16/2025	7:23:00 PM	0.47	0.00	0.00	0.00	11.27		* Shutdown for for jack bus replacement at Mandola.
XMER	500MVA,400/220kV ICT-1 AT MANDOLA	SCSD	2/21/2025	8:07:00 AM	2/22/2025	10:48:00 PM	1.61	0.00	0.00	0.00	36.68		* Shutdown for jack bus replacement at Mandola.
XMER	500MVA,400/220kV ICT-1 AT MANDOLA	SCSD	2/19/2025	7:45:00 AM	2/19/2025	8:31:00 PM	0.53	0.00	0.00	0.00	12.77		* Shutdown for jack bus replacement at Mandola.
XMER	500MVA,400/220kV ICT-1 AT MANDOLA	SCSD	2/17/2025	8:11:00 AM	2/17/2025	8:14:00 PM	0.50	0.00	0.00	0.00	12.05		* Shutdown for jack bus replacement at Mandola.
							4.13	0.00	0.00	0.00	99.17	100.00	
XMER	500MVA,400/220kV ICT-2 AT MANDOLA	SCSD	2/15/2025	8:06:00 AM	2/15/2025	8:30:00 PM	0.52	0.00	0.00	0.00	12.40		* Shutdown for jack bus replacement at Mandola.

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-I

[illegible]