

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR,BUS REACTOR-1 AT ABDULLAPUR	SVRD	08-02-2025	10:20:00	08-02-2025	13:41:00	0.14	0.00	0.00	0.00	3.35		* 50MVAR,BUS REACTOR-1 AT ABDULLAPUR BR manually opened on Voltage Reg. (NR-3055)
BSR	50MVAR,BUS REACTOR-1 AT ABDULLAPUR	SVRD	13-02-2025	09:40:00	13-02-2025	16:26:00	0.28	0.00	0.00	0.00	6.77		* BR hand tripped for voltage regulation. NR2502-5077
BSR	50MVAR,BUS REACTOR-1 AT ABDULLAPUR	SVRD	12-02-2025	10:09:00	12-02-2025	16:27:00	0.26	0.00	0.00	0.00	6.30		* BR hand tripped for voltage regulation. NR2502-4680
							0.68	0.00	0.00	0.00	16.42	100.00	
BSR	125MVAR,BUS REACTOR-2 AT ABDULLAPUR	SVRD	14-02-2025	09:34:00	14-02-2025	16:30:00	0.29	0.00	0.00	0.00	6.93		* SVRD BR hand tripped for voltage regulation. NR2502-5521
BSR	125MVAR,BUS REACTOR-2 AT ABDULLAPUR	SVRD	15-02-2025	09:18:00	15-02-2025	15:14:00	0.25	0.00	0.00	0.00	5.93		* SVRD BR hand tripped for voltage regulation. NR2502-5948
BSR	125MVAR,BUS REACTOR-2 AT ABDULLAPUR	SVRD	08-02-2025	09:30:00	08-02-2025	18:19:00	0.37	0.00	0.00	0.00	8.82		* 125MVAR,BUS REACTOR-2 AT ABDULLAPUR BR manually opened on Voltage Reg. (NR-3001)
BSR	125MVAR,BUS REACTOR-2 AT ABDULLAPUR	SVRD	07-02-2025	09:08:00	07-02-2025	15:43:00	0.27	0.00	0.00	0.00	6.58		* BR hand tripped for voltage regulation. NR2502-2539
BSR	125MVAR,BUS REACTOR-2 AT ABDULLAPUR	SVRD	06-02-2025	09:51:00	06-02-2025	16:35:00	0.28	0.00	0.00	0.00	6.73		* BR hand tripped for voltage regulation. NR2502-2106
BSR	125MVAR,BUS REACTOR-2 AT ABDULLAPUR	SVRD	13-02-2025	09:41:00	13-02-2025	16:28:00	0.28	0.00	0.00	0.00	6.78		* BR hand tripped for voltage regulation. NR2502-5078
BSR	125MVAR,BUS REACTOR-2 AT ABDULLAPUR	SVRD	04-02-2025	11:30:00	04-02-2025	16:10:00	0.19	0.00	0.00	0.00	4.67		* BR hand tripped for voltage regulation. NR2502-1243
BSR	125MVAR,BUS REACTOR-2 AT ABDULLAPUR	SVRD	12-02-2025	10:08:00	12-02-2025	15:44:00	0.23	0.00	0.00	0.00	5.60		* BR hand tripped for voltage regulation. NR2502-4681
BSR	125MVAR,BUS REACTOR-2 AT ABDULLAPUR	SVRD	16-02-2025	10:12:00	16-02-2025	13:15:00	0.13	0.00	0.00	0.00	3.05		* SVRD BR hand tripped for voltage regulation. NR2502-6458
							2.29	0.00	0.00	0.00	55.09	100.00	
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	13-02-2025	09:28:00	13-02-2025	16:36:00	0.30	0.00	0.00	0.00	7.13		* BR hand tripped for voltage regulation. NR2502-5064
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	07-02-2025	08:40:00	07-02-2025	16:56:00	0.34	0.00	0.00	0.00	8.27		* BR hand tripped for voltage regulation. NR2502-2477
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	10-02-2025	09:13:00	10-02-2025	18:19:00	0.38	0.00	0.00	0.00	9.10		* BR hand tripped for voltage regulation. NR2502-3724
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	17-02-2025	09:59:00	17-02-2025	16:30:00	0.27	0.00	0.00	0.00	6.52		* SVRD BR hand tripped for voltage regulation. NR2502-6857
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	22-02-2025	08:47:00	22-02-2025	18:51:00	0.42	0.00	0.00	0.00	10.07		* BR hand tripped for voltage regulation. NR2502-9002
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	24-02-2025	09:23:00	24-02-2025	15:46:00	0.27	0.00	0.00	0.00	6.38		* 80MVAR,BUS REACTOR-1 AT AMRITSAR manually opened on Voltage Reg. (NR-9748)
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	26-02-2025	10:17:00	26-02-2025	15:29:00	0.22	0.00	0.00	0.00	5.20		* BR hand tripped for voltage regulation.NR2502-10511
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	25-02-2025	09:13:00	25-02-2025	17:35:00	0.35	0.00	0.00	0.00	8.37		* 80MVAR,BUS REACTOR-1 AT AMRITSAR manually opened on Voltage Reg. (NR-10152)
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	21-02-2025	09:10:00	21-02-2025	16:11:00	0.29	0.00	0.00	0.00	7.02		* BR hand tripped for voltage regulation. NR2502-8575
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	27-02-2025	09:27:00	27-02-2025	16:54:00	0.31	0.00	0.00	0.00	7.45		* BR hand tripped for voltage regulation. NR2502-10765
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	19-02-2025	09:39:00	19-02-2025	19:45:00	0.42	0.00	0.00	0.00	10.10		* Bus reactor hand tripped for voltage reg.NR2502-7683
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	14-02-2025	09:06:00	14-02-2025	18:55:00	0.41	0.00	0.00	0.00	9.82		* BR hand tripped for voltage regulation. NR2502-5470
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	03-02-2025	09:00:00	03-02-2025	15:45:00	0.28	0.00	0.00	0.00	6.75		* BR hand tripped for voltage regulation.NR2502-777
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	12-02-2025	10:06:00	12-02-2025	16:22:00	0.26	0.00	0.00	0.00	6.27		* BR hand tripped for voltage regulation. NR2502-4614
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	05-02-2025	09:37:00	05-02-2025	16:20:00	0.28	0.00	0.00	0.00	6.72		* BR hand tripped for voltage regulation. NR2502-1609
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	01-02-2025	10:14:00	01-02-2025	20:37:00	0.43	0.00	0.00	0.00	10.38		* 80MVAR,BUS REACTOR-1 AT AMRITSAR manually opened on Voltage Reg. (NR-147)
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	02-02-2025	09:31:00	02-02-2025	15:50:00	0.26	0.00	0.00	0.00	6.32		* BR hand tripped for voltage regulation.NR2502-496
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	06-02-2025	08:53:00	06-02-2025	17:30:00	0.36	0.00	0.00	0.00	8.62		* BR hand tripped for voltage regulation. NR2502-2004
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	09-02-2025	09:08:00	09-02-2025	17:25:00	0.35	0.00	0.00	0.00	8.28		* 80MVAR,BUS REACTOR-1 AT AMRITSAR BR manually opened on VR (NR-3399)
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	08-02-2025	08:27:00	08-02-2025	19:00:00	0.44	0.00	0.00	0.00	10.55		* 80MVAR,BUS REACTOR-1 AT AMRITSAR BR manually opened on Voltage Reg. (NR-2947)
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	04-02-2025	09:27:00	04-02-2025	16:11:00	0.28	0.00	0.00	0.00	6.73		* BR hand tripped for voltage regulation. NR2502-1186
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	18-02-2025	10:08:00	18-02-2025	19:27:00	0.39	0.00	0.00	0.00	9.32		* Bus reactor hand tripped for voltage reg.NR2502-7331
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	11-02-2025	09:25:00	11-02-2025	17:29:00	0.34	0.00	0.00	0.00	8.07		* BR hand tripped for voltage regulation. NR2502-4178
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	15-02-2025	08:58:00	15-02-2025	18:04:00	0.38	0.00	0.00	0.00	9.10		* SVRD BR hand tripped for voltage regulation. NR2502-5897 NL-2060* 15.02.2025 11:21:20 INDIA (60018024)* BR hand tripped for voltage regulation. NR2502-5923
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	16-02-2025	09:04:00	16-02-2025	16:41:00	0.32	0.00	0.00	0.00	7.62		* SVRD BR hand tripped for voltage regulation. NR2502-6385
							8.35	0.00	0.00	0.00	200.16	100.00	
BSR	25MVAR, BUS REACTOR-1 AT AMRITSAR	SVRD	08-02-2025	10:28:00	28-02-2025	23:59:59	20.56	0.00	0.00	0.00	493.53		* 25MVAR, BUS REACTOR-1 AT AMRITSAR BR manually opened on Voltage Reg. (NR-3059)
							20.56	0.00	0.00	0.00	493.53	100.00	
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	13-02-2025	09:53:00	13-02-2025	16:12:00	0.26	0.00	0.00	0.00	6.32		* BR hand tripped for voltage regulation. NR2502-5086
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	17-02-2025	09:49:00	17-02-2025	16:25:00	0.28	0.00	0.00	0.00	6.60		* SVRD BR hand tripped for voltage regulation. NR2502-6850
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	14-02-2025	09:05:00	14-02-2025	16:36:00	0.31	0.00	0.00	0.00	7.52		* BR hand tripped for voltage regulation. NR2502-5463
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	12-02-2025	09:54:00	12-02-2025	15:47:00	0.25	0.00	0.00	0.00	5.88		* BR hand tripped for voltage regulation. NR2502-4635
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	05-02-2025	09:40:00	05-02-2025	16:18:00	0.28	0.00	0.00	0.00	6.63		* BR hand tripped for voltage regulation. NR2502-1617
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	10-02-2025	09:20:00	10-02-2025	18:29:00	0.38	0.00	0.00	0.00	9.15		* BR hand tripped for voltage regulation. NR2502-3740
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	11-02-2025	09:26:00	11-02-2025	17:28:00	0.34	0.00	0.00	0.00	8.03		* BR hand tripped for voltage regulation. NR2502-4172
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	03-02-2025	09:31:00	03-02-2025	15:44:00	0.26	0.00	0.00	0.00	6.22		* BR hand tripped for voltage regulation.NR2502-810
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	08-02-2025	09:10:00	08-02-2025	21:24:00	0.51	0.00	0.00	0.00	12.23		* 80MVAR,BUS REACTOR-1 AT BANALA BR manually opened on Voltage Reg. (NR-2962)
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	01-02-2025	10:15:00	01-02-2025	16:37:00	0.27	0.00	0.00	0.00	6.37		* 80MVAR,BUS REACTOR-1 AT BANALA manually opened on Voltage Reg. (NR-148)
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	02-02-2025	09:29:00	02-02-2025	15:51:00	0.27	0.00	0.00	0.00	6.37		* BR hand tripped for voltage regulation.NR2502-500
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	04-02-2025	11:26:00	04-02-2025	20:26:00	0.38	0.00	0.00	0.00	9.00		* BR hand tripped for voltage regulation. NR2502-1251
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	06-02-2025	08:54:00	06-02-2025	16:55:00	0.33	0.00	0.00	0.00	8.02		* BR hand tripped for voltage regulation. NR2502-2005
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	15-02-2025	09:40:00	15-02-2025	15:07:00	0.23	0.00	0.00	0.00	5.45		* BR hand tripped for voltage regulation. NR2502-5968
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	07-02-2025	08:36:00	07-02-2025	17:29:00	0.37	0.00	0.00	0.00	8.88		* BR hand tripped for voltage regulation. NR2502-2481
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	18-02-2025	10:15:00	18-02-2025	15:19:00	0.21	0.00	0.00	0.00	5.07		* Bus reactor hand tripped for voltage reg.NR2502-7343
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	19-02-2025	09:42:00	19-02-2025	17:09:00	0.31	0.00	0.00	0.00	7.45		* Bus reactor hand tripped for voltage reg.NR2502-7748
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	16-02-2025	10:02:00	16-02-2025	13:20:00	0.14	0.00	0.00	0.00	3.30		* SVRD BR hand tripped for voltage regulation. NR2502-6452
							5.38	0.00	0.00	0.00	128.49	100.00	
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA	SVRD	08-02-2025	09:22:00	08-02-2025	21:20:00	0.50	0.00	0.00	0.00	11.97		* 80MVAR,BUS REACTOR-1 AT CHAMBA BR manually opened on Voltage Reg. (NR-2986)
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA	SVRD	04-02-2025	11:28:00	04-02-2025	15:59:00	0.19	0.00	0.00	0.00	4.52		* BR hand tripped for voltage regulation. NR2502-1247
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA	SVRD	07-02-2025	09:09:00	07-02-2025	17:28:00	0.35	0.00	0.00	0.00	8.32		* BR hand tripped for voltage regulation. NR2502-2532
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA	SVRD	05-02-2025	10:06:00	05-02-2025	15:59:00	0.25	0.00	0.00	0.00	5.88		* BR hand tripped for voltage regulation. NR2502-1247
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA	SVRD	01-02-2025	11:36:00	01-02-2025	17:35:00	0.25	0.00	0.00	0.00	5.98		* 80MVAR,BUS REACTOR-1 AT CHAMBA manually opened on Voltage Reg. (NR-184)
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA	SVRD	06-02-2025	09:24:00	06-02-2025	16:47:00	0.31	0.00	0.00	0.00	7.38		* BR hand tripped for voltage regulation. NR2502-2085
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA	SVRD	15-02-2025	09:45:00	15-02-2025	15:11:00	0.23	0.00	0.00	0.00	5.43		* BR hand tripped for voltage regulation. NR2502-5994
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA	SVRD	17-02-2025	10:00:00	17-02-2025	16:18:00	0.26	0.00	0.00	0.00	6.30		* SVRD BR hand tripped for voltage regulation. NR2502-6873
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA	SVRD	16-02-2025	09:59:00	16-02-2025	14:28:00	0.19	0.00	0.00	0.00	4.48		* SVRD BR hand tripped for voltage regulation. NR2502-6449
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA	SVRD	18-02-2025	10:04:00	18-02-2025	15:44:00	0.24	0.00	0.00	0.00	5.67		* Bus reactor hand tripped for voltage reg.NR2502-7328
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA	SVRD	19-02-2025	09:53:00	19-02-2025	17:15:00	0.31	0.00	0.00	0.00	7.37		* Bus reactor hand tripped for voltage reg.NR2502-7761
							3.08	0.00	0.00	0.00	73.30	100.00	
BSR	80MVAR,BUS REACTOR-2 AT CHAMBA												

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE To ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	16-02-2025	10:00:00	16-02-2025	14:29:00	0.19	0.00	0.00	0.00	4.48		* SVRD BR hand tripped for voltage regulation. NR2502-6448
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	18-02-2025	09:56:00	18-02-2025	15:44:00	0.24	0.00	0.00	0.00	5.80		* Bus reactor hand tripped for voltage reg.NR2502-7323
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	15-02-2025	09:47:00	15-02-2025	15:12:00	0.23	0.00	0.00	0.00	5.42		* BR hand tripped for voltage regulation. NR2502-5993
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	04-02-2025	11:29:00	04-02-2025	16:12:00	0.20	0.00	0.00	0.00	4.72		* BR hand tripped for voltage regulation. NR2502-1242
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	05-02-2025	10:58:00	05-02-2025	16:01:00	0.21	0.00	0.00	0.00	5.05		* BR hand tripped for voltage regulation. NR2502-1649
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	08-02-2025	09:23:00	08-02-2025	21:21:00	0.50	0.00	0.00	0.00	11.97		* 80MVAR.BUS REACTOR-2 AT CHAMBA BR manually opened on Voltage Reg. (NR-2985)
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	07-02-2025	09:07:00	07-02-2025	17:43:00	0.36	0.00	0.00	0.00	8.60		* BR hand tripped for voltage regulation. NR2502-2525
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	06-02-2025	09:25:00	06-02-2025	16:55:00	0.31	0.00	0.00	0.00	7.50		* BR hand tripped for voltage regulation. NR2502-2082
							3.05	0.00	0.00	0.00	72.83	100.00	
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	05-02-2025	10:21:00	05-02-2025	17:09:00	0.28	0.00	0.00	0.00	6.80		* BR hand tripped for voltage regulation. NR2502-1647
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	04-02-2025	10:16:00	04-02-2025	16:47:00	0.27	0.00	0.00	0.00	6.52		* BR hand tripped for voltage regulation. NR2502-1216
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	07-02-2025	09:13:00	07-02-2025	16:39:00	0.31	0.00	0.00	0.00	7.43		* BR hand tripped for voltage regulation. NR2502-2529
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	06-02-2025	09:36:00	06-02-2025	16:50:00	0.30	0.00	0.00	0.00	7.23		* BR hand tripped for voltage regulation. NR2502-2064
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	08-02-2025	09:37:00	08-02-2025	19:43:00	0.42	0.00	0.00	0.00	10.10		* 63MVAR.BUS REACTOR-1 AT DEHAR BR manually opened on Voltage Reg. (NR-2990)
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	17-02-2025	09:50:00	17-02-2025	16:27:00	0.28	0.00	0.00	0.00	6.62		* SVRD BR hand tripped for voltage regulation. NR2502-6876
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	16-02-2025	09:55:00	16-02-2025	13:21:00	0.14	0.00	0.00	0.00	3.43		* SVRD BR hand tripped for voltage regulation. NR2502-6455
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	19-02-2025	09:38:00	19-02-2025	16:55:00	0.30	0.00	0.00	0.00	7.28		* Bus reactor hand tripped for voltage reg.NR2502-7776
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	18-02-2025	10:02:00	18-02-2025	15:44:00	0.24	0.00	0.00	0.00	5.70		* Bus reactor hand tripped for voltage reg.NR2502-7341
							2.54	0.00	0.00	0.00	61.11	100.00	
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	16-02-2025	09:55:00	16-02-2025	13:21:00	0.14	0.00	0.00	0.00	3.43		* SVRD BR hand tripped for voltage regulation. NR2502-6456
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	19-02-2025	09:38:00	19-02-2025	16:55:00	0.30	0.00	0.00	0.00	7.28		* Bus reactor hand tripped for voltage reg.NR2502-7777
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	18-02-2025	10:02:00	18-02-2025	15:44:00	0.24	0.00	0.00	0.00	5.70		* Bus reactor hand tripped for voltage reg.NR2502-7355
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	05-02-2025	10:21:00	05-02-2025	17:09:00	0.28	0.00	0.00	0.00	6.80		* BR hand tripped for voltage regulation. NR2502-1669
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	06-02-2025	09:36:00	06-02-2025	16:50:00	0.30	0.00	0.00	0.00	7.23		* BR hand tripped for voltage regulation. NR2502-2065
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	04-02-2025	10:16:00	04-02-2025	16:47:00	0.27	0.00	0.00	0.00	6.52		* BR hand tripped for voltage regulation. NR2502-1217
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	08-02-2025	09:37:00	08-02-2025	19:43:00	0.42	0.00	0.00	0.00	10.10		* 63MVAR.BUS REACTOR-2 AT DEHAR BR manually opened on Voltage Reg. (NR-2991)
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	17-02-2025	09:50:00	17-02-2025	16:27:00	0.28	0.00	0.00	0.00	6.62		* SVRD BR hand tripped for voltage regulation. NR2502-6877
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	07-02-2025	09:13:00	07-02-2025	16:39:00	0.31	0.00	0.00	0.00	7.43		* BR hand tripped for voltage regulation. NR2502-2530
							2.54	0.00	0.00	0.00	61.11	100.00	
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	16-02-2025	09:52:00	16-02-2025	16:31:00	0.28	0.00	0.00	0.00	6.65		* SVRD BR hand tripped for voltage regulation. NR2502-6421
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	08-02-2025	09:15:00	08-02-2025	21:25:00	0.51	0.00	0.00	0.00	12.17		* 80MVAR.BUS REACTOR-1 AT FATEHABAD BR manually opened on Voltage Reg. (NR-2957)
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	19-02-2025	10:05:00	19-02-2025	16:57:00	0.29	0.00	0.00	0.00	6.87		* Bus reactor hand tripped for voltage reg.NR2502-7769
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	18-02-2025	09:55:00	18-02-2025	15:48:00	0.25	0.00	0.00	0.00	5.88		* Bus reactor hand tripped for voltage reg.NR2502-7322
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	07-02-2025	08:42:00	07-02-2025	17:45:00	0.38	0.00	0.00	0.00	9.05		* BR hand tripped for voltage regulation. NR2502-2489
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	15-02-2025	09:35:00	15-02-2025	17:14:00	0.32	0.00	0.00	0.00	7.65		* BR hand tripped for voltage regulation. NR2502-5974
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	17-02-2025	10:06:00	17-02-2025	16:25:00	0.26	0.00	0.00	0.00	6.32		* SVRD BR hand tripped for voltage regulation. NR2502-6861
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	24-02-2025	09:39:00	24-02-2025	13:18:00	0.15	0.00	0.00	0.00	3.65		* 80MVAR.BUS REACTOR-1 AT FATEHABAD manually opened on Voltage Reg. (NR-9761)
							2.44	0.00	0.00	0.00	58.24	100.00	
BSR	25MVAR. BUS REACTOR-1 AT FATEHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	26-02-2025	10:06:00	26-02-2025	16:15:00	0.26	0.00	0.00	0.00	6.15		* BR hand tripped for voltage regulation.NR2502-10512
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	18-02-2025	09:28:00	18-02-2025	18:00:00	0.36	0.00	0.00	0.00	8.53		* Bus reactor hand tripped for voltage reg.NR2502-7291
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	19-02-2025	08:55:00	19-02-2025	17:02:00	0.34	0.00	0.00	0.00	8.12		* Bus reactor hand tripped for voltage reg.NR2502-7684
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	22-02-2025	08:49:00	25-02-2025	01:24:00	2.69	0.00	0.00	0.00	64.58		* BR hand tripped for voltage regulation. NR2502-9001
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	14-02-2025	09:04:00	14-02-2025	16:33:00	0.31	0.00	0.00	0.00	7.48		* BR hand tripped for voltage regulation. NR2502-5462
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	10-02-2025	09:21:00	10-02-2025	18:28:00	0.38	0.00	0.00	0.00	9.12		* BR hand tripped for voltage regulation. NR2502-3742
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	15-02-2025	09:51:00	15-02-2025	15:08:00	0.22	0.00	0.00	0.00	5.28		* BR hand tripped for voltage regulation. NR2502-5969
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	07-02-2025	09:05:00	07-02-2025	21:25:00	0.51	0.00	0.00	0.00	12.33		* BR hand tripped for voltage regulation. NR2502-2528
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	02-02-2025	09:31:00	02-02-2025	15:47:00	0.26	0.00	0.00	0.00	6.27		* BR hand tripped for voltage regulation.NR2502-495
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	08-02-2025	09:05:00	08-02-2025	17:15:00	0.34	0.00	0.00	0.00	8.17		* 80MVAR.BUS REACTOR-1 AT HAMIRPUR BR manually opened on Voltage Reg. (NR-2950)
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	06-02-2025	08:57:00	06-02-2025	16:53:00	0.33	0.00	0.00	0.00	7.93		* BR hand tripped for voltage regulation. NR2502-2006
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	12-02-2025	09:51:00	12-02-2025	15:48:00	0.25	0.00	0.00	0.00	5.95		* BR hand tripped for voltage regulation. NR2502-4641
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	05-02-2025	09:41:00	05-02-2025	15:57:00	0.26	0.00	0.00	0.00	6.27		* BR hand tripped for voltage regulation. NR2502-1627
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	13-02-2025	09:47:00	13-02-2025	16:13:00	0.27	0.00	0.00	0.00	6.43		* BR hand tripped for voltage regulation. NR2502-5094
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	11-02-2025	09:23:00	11-02-2025	17:26:00	0.34	0.00	0.00	0.00	8.05		* BR hand tripped for voltage regulation. NR2502-4170
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	01-02-2025	11:35:00	01-02-2025	20:36:00	0.38	0.00	0.00	0.00	9.02		* 80MVAR.BUS REACTOR-1 AT HAMIRPUR manually opened on Voltage Reg. (NR-183)
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	04-02-2025	09:27:00	04-02-2025	16:17:00	0.29	0.00	0.00	0.00	6.83		* BR hand tripped for voltage regulation. NR2502-1192
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	17-02-2025	08:19:00	17-02-2025	21:17:00	0.54	0.00	0.00	0.00	12.97		* SVRD BR hand tripped for voltage regulation. NR2502-6770
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	16-02-2025	10:01:00	16-02-2025	13:19:00	0.14	0.00	0.00	0.00	3.30		* SVRD BR hand tripped for voltage regulation. NR2502-6451
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	25-02-2025	09:14:00	25-02-2025	13:16:00	0.17	0.00	0.00	0.00	4.03		* 80MVAR.BUS REACTOR-1 AT HAMIRPUR manually opened on Voltage Reg.(NR-10153)
							8.64	0.00	0.00	0.00	206.81	100.00	
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	17-02-2025	10:12:00	17-02-2025	16:22:00	0.26	0.00	0.00	0.00	6.17		* SVRD BR hand tripped for voltage regulation. NR2502-6865
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	15-02-2025	09:49:00	15-02-2025	16:54:00	0.30	0.00	0.00	0.00	7.08		* SVRD BR hand tripped for voltage regulation. NR2502-5991
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	01-02-2025	11:33:00	01-02-2025	17:58:00	0.27	0.00	0.00	0.00	6.42		* 25MVAR.BUS REACTOR-1 AT JALANDHAR manually opened on Voltage Reg. (NR-178)
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	08-02-2025	10:18:00	08-02-2025	21:30:00	0.47	0.00	0.00	0.00	11.20		* 25MVAR.BUS REACTOR-1 AT JALANDHAR BR manually opened on Voltage Reg. (NR-3051)
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	09-02-2025	09:14:00	09-02-2025	20:08:00	0.45	0.00	0.00	0.00	10.90		* 25MVAR.BUS REACTOR-1 AT JALANDHAR BR manually opened on VR (NR-3415)
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	16-02-2025	09:56:00	16-02-2025	16:24:00	0.27	0.00	0.00	0.00	6.47		* SVRD BR hand tripped for voltage regulation. NR2502-6437
							2.02	0.00	0.00	0.00	48.24	100.00	
BSR	125MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	11-02-2025	09:31:00	11-02-2025	17:45:00	0.34	0.00	0.00	0.00	8.23		* BR hand tripped for voltage regulation. NR2502-4191
BSR	125MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	07-02-2025	08:36:00	07-02-2025	17:23:00	0.37	0.00	0.00	0.00	8.78		* BR hand tripped for voltage regulation. NR2502-2474
BSR	125MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	03-02-2025	09:01:00	03-02-2025	15:49:00	0.28	0.00	0.00	0.00	6.80		* BR hand tripped for voltage regulation.NR2502-778
BSR	125MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	05-02-2025	09:33:00	05-02-2025	16:26:00	0.29	0.00	0.00	0.00	6.88		* BR hand tripped for voltage regulation. NR2502-1604
BSR	125MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	04-02-2025	09:34:00	04-02-2025	16:13:00	0.28	0.00	0.00	0.00	6.65		* BR hand tripped for voltage regulation. NR2502-1187
BSR	125MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	17-02-2025	09:36:00	17-02-2025	16:41:00	0.30	0.00	0.00	0.00	7.08		* SVRD BR hand tripped for voltage regulation. NR2502-6848
BSR	125MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	15-02-2025	09:31:00	15-02-2025	17:15:							

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE To ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	12-02-2025	09:43:00	12-02-2025	15:55:00	0.26	0.00	0.00	0.00	6.20		
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	26-02-2025	10:27:00	26-02-2025	15:25:00	0.21	0.00	0.00	0.00	4.97		* BR hand tripped for voltage regulation.NR2502-10522
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	24-02-2025	09:37:00	24-02-2025	14:18:00	0.20	0.00	0.00	0.00	4.68		* 125MVAR,BUS REACTOR-1 AT JALANDHAR manually opened on Voltage Reg. (NR-9756)
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	25-02-2025	09:26:00	25-02-2025	16:52:00	0.31	0.00	0.00	0.00	7.43		* 125MVAR,BUS REACTOR-1 AT JALANDHAR manually opened on Voltage Reg. (NR-10186)
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	21-02-2025	09:55:00	21-02-2025	16:03:00	0.26	0.00	0.00	0.00	6.13		* BR hand tripped for voltage regulation. NR2502-8569
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	19-02-2025	09:32:00	19-02-2025	17:07:00	0.32	0.00	0.00	0.00	7.58		* Bus reactor hand tripped for voltage reg.NR2502-7746
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	18-02-2025	10:18:00	18-02-2025	15:29:00	0.22	0.00	0.00	0.00	5.18		* Bus reactor hand tripped for voltage reg.NR2502-7349
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	01-02-2025	10:17:00	01-02-2025	17:56:00	0.32	0.00	0.00	0.00	7.65		* 125MVAR,BUS REACTOR-1 AT JALANDHAR manually opened on Voltage Reg. (NR-149)
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	10-02-2025	09:16:00	10-02-2025	18:20:00	0.38	0.00	0.00	0.00	9.07		* BR hand tripped for voltage regulation. NR2502-3732
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	02-02-2025	09:32:00	02-02-2025	15:59:00	0.27	0.00	0.00	0.00	6.45		* BR hand tripped for voltage regulation.NR2502-497
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	06-02-2025	08:51:00	06-02-2025	17:37:00	0.37	0.00	0.00	0.00	8.77		* BR hand tripped for voltage regulation. NR2502-2002
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	09-02-2025	09:17:00	09-02-2025	17:22:00	0.34	0.00	0.00	0.00	8.08		* 125MVAR,BUS REACTOR-1 AT JALANDHAR BR manually opened on VR (NR-3413)
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	08-02-2025	09:19:00	08-02-2025	18:23:00	0.38	0.00	0.00	0.00	9.07		* 125MVAR,BUS REACTOR-1 AT JALANDHAR BR manually opened on Voltage Reg. (NR-2964)
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	16-02-2025	09:48:00	16-02-2025	14:40:00	0.20	0.00	0.00	0.00	4.87		* SVRD BR hand tripped for voltage regulation. NR2502-6420
							6.80	0.00	0.00	0.00	162.24	100.00	
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	15-02-2025	09:50:00	15-02-2025	16:55:00	0.30	0.00	0.00	0.00	7.08		* SVRD BR hand tripped for voltage regulation. NR2502-5992
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	17-02-2025	10:10:00	17-02-2025	16:23:00	0.26	0.00	0.00	0.00	6.22		* SVRD BR hand tripped for voltage regulation. NR2502-6863
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	01-02-2025	11:34:00	01-02-2025	17:57:00	0.27	0.00	0.00	0.00	6.38		* 25MVAR,BUS REACTOR-2 AT JALANDHAR manually opened on Voltage Reg. (NR-177)
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	08-02-2025	10:19:00	08-02-2025	21:30:00	0.47	0.00	0.00	0.00	11.18		* 25MVAR,BUS REACTOR-2 AT JALANDHAR BR manually opened on Voltage Reg. (NR-3052)
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	09-02-2025	09:14:00	09-02-2025	20:09:00	0.46	0.00	0.00	0.00	10.92		* 25MVAR,BUS REACTOR-2 AT JALANDHAR BR manually opened on VR (NR-3416)
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	16-02-2025	09:56:00	16-02-2025	16:25:00	0.27	0.00	0.00	0.00	6.48		* SVRD BR hand tripped for voltage regulation. NR2502-6436
							2.03	0.00	0.00	0.00	48.26	100.00	
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	17-02-2025	09:33:00	17-02-2025	16:47:00	0.30	0.00	0.00	0.00	7.23		* SVRD BR hand tripped for voltage regulation. NR2502-6832
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	14-02-2025	09:21:00	14-02-2025	16:34:00	0.30	0.00	0.00	0.00	7.22		* BR hand tripped for voltage regulation. NR2502-5509
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	18-02-2025	09:35:00	18-02-2025	16:21:00	0.28	0.00	0.00	0.00	6.77		* Bus reactor hand tripped for voltage reg.NR2502-7298
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	19-02-2025	10:00:00	19-02-2025	17:04:00	0.29	0.00	0.00	0.00	7.07		* Bus reactor hand tripped for voltage reg.NR2502-7765
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	21-02-2025	09:55:00	21-02-2025	15:03:00	0.21	0.00	0.00	0.00	5.13		* BR hand tripped for voltage regulation. NR2502-8628
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	25-02-2025	09:25:00	25-02-2025	16:47:00	0.31	0.00	0.00	0.00	7.37		* 125MVAR,BUS REACTOR-2 AT JALANDHAR manually opened on Voltage Reg. (NR-10187)
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	24-02-2025	09:36:00	24-02-2025	13:19:00	0.16	0.00	0.00	0.00	3.72		* 125MVAR,BUS REACTOR-2 AT JALANDHAR manually opened on Voltage Reg. (NR-9758)
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	26-02-2025	10:10:00	26-02-2025	15:24:00	0.22	0.00	0.00	0.00	5.23		* BR hand tripped for voltage regulation.NR2502-105223
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	12-02-2025	09:44:00	12-02-2025	15:53:00	0.26	0.00	0.00	0.00	6.15		* BR hand tripped for voltage regulation. NR2502-4623
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	15-02-2025	09:30:00	15-02-2025	18:03:00	0.36	0.00	0.00	0.00	8.55		* SVRD BR hand tripped for voltage regulation. NR2502-5953
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	04-02-2025	09:32:00	04-02-2025	16:12:00	0.28	0.00	0.00	0.00	6.67		* BR hand tripped for voltage regulation. NR2502-1188
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	13-02-2025	09:49:00	13-02-2025	16:13:00	0.27	0.00	0.00	0.00	6.40		* BR hand tripped for voltage regulation. NR2502-5105
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	10-02-2025	09:17:00	10-02-2025	18:21:00	0.38	0.00	0.00	0.00	9.07		* BR hand tripped for voltage regulation. NR2502-3735
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	16-02-2025	09:05:00	16-02-2025	16:46:00	0.32	0.00	0.00	0.00	7.68		* SVRD BR hand tripped for voltage regulation. NR2502-6386
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	09-02-2025	09:16:00	09-02-2025	17:20:00	0.34	0.00	0.00	0.00	8.07		* 125MVAR,BUS REACTOR-2 AT JALANDHAR BR manually opened on VR (NR-3414)
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	08-02-2025	09:17:00	08-02-2025	18:25:00	0.38	0.00	0.00	0.00	9.13		* 125MVAR,BUS REACTOR-2 AT JALANDHAR BR manually opened on Voltage Reg. (NR-2965)
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	07-02-2025	08:39:00	07-02-2025	17:11:00	0.36	0.00	0.00	0.00	8.53		* BR hand tripped for voltage regulation. NR2502-2475
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	06-02-2025	08:52:00	06-02-2025	17:02:00	0.34	0.00	0.00	0.00	8.17		* BR hand tripped for voltage regulation. NR2502-2003
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	01-02-2025	10:16:00	01-02-2025	17:40:00	0.31	0.00	0.00	0.00	7.40		* 125MVAR,BUS REACTOR-2 AT JALANDHAR manually opened on Voltage Reg. (NR-150)
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	03-02-2025	09:02:00	03-02-2025	15:50:00	0.28	0.00	0.00	0.00	6.80		* BR hand tripped for voltage regulation.NR2502-779
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	11-02-2025	09:32:00	11-02-2025	17:39:00	0.34	0.00	0.00	0.00	8.12		* BR hand tripped for voltage regulation. NR2502-4175
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	05-02-2025	09:34:00	05-02-2025	16:22:00	0.28	0.00	0.00	0.00	6.80		* BR hand tripped for voltage regulation. NR2502-1606
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	02-02-2025	09:34:00	02-02-2025	15:52:00	0.26	0.00	0.00	0.00	6.30		* BR hand tripped for voltage regulation.
							6.83	0.00	0.00	0.00	163.58	100.00	
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	16-02-2025	09:55:00	16-02-2025	16:30:00	0.27	0.00	0.00	0.00	6.58		* SVRD BR hand tripped for voltage regulation. NR2502-6431
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	19-02-2025	09:55:00	19-02-2025	19:49:00	0.41	0.00	0.00	0.00	9.90		* Bus reactor hand tripped for voltage reg.NR2502-7762
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	01-02-2025	10:21:00	01-02-2025	16:44:00	0.27	0.00	0.00	0.00	6.38		* 80MVAR,BUS REACTOR-1 AT KAITHAL manually opened on Voltage Reg. (NR-153)
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	09-02-2025	09:07:00	09-02-2025	17:12:00	0.34	0.00	0.00	0.00	8.08		* 80MVAR,BUS REACTOR-1 AT KAITHAL BR manually opened on VR (NR-3403)
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	07-02-2025	09:19:00	07-02-2025	15:35:00	0.26	0.00	0.00	0.00	6.27		* BR hand tripped for voltage regulation. NR2502-2549
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	03-02-2025	09:32:00	03-02-2025	16:01:00	0.27	0.00	0.00	0.00	6.48		* BR hand tripped for voltage regulation.NR2502-817
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	06-02-2025	08:54:00	06-02-2025	15:55:00	0.29	0.00	0.00	0.00	7.02		* BR hand tripped for voltage regulation. NR2502-2013
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	02-02-2025	09:26:00	02-02-2025	15:50:00	0.27	0.00	0.00	0.00	6.40		* BR hand tripped for voltage regulation.
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	13-02-2025	09:45:00	13-02-2025	16:12:00	0.27	0.00	0.00	0.00	6.45		* BR hand tripped for voltage regulation. NR2502-5103
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	10-02-2025	09:08:00	10-02-2025	18:11:00	0.38	0.00	0.00	0.00	9.05		* BR hand tripped for voltage regulation. NR2502-3719
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	05-02-2025	09:47:00	05-02-2025	16:00:00	0.26	0.00	0.00	0.00	6.22		* BR hand tripped for voltage regulation. NR2502-1636
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	11-02-2025	09:29:00	11-02-2025	17:30:00	0.33	0.00	0.00	0.00	8.02		* BR hand tripped for voltage regulation. NR2502-4183
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	12-02-2025	09:46:00	12-02-2025	15:49:00	0.25	0.00	0.00	0.00	6.05		* BR hand tripped for voltage regulation. NR2502-4656
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	08-02-2025	09:31:00	08-02-2025	18:16:00	0.37	0.00	0.00	0.00	8.75		* 80MVAR,BUS REACTOR-1 AT KAITHAL BR manually opened on Voltage Reg. (NR-3003)
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	04-02-2025	09:20:00	04-02-2025	16:10:00	0.29	0.00	0.00	0.00	6.83		* BR hand tripped for voltage regulation. NR2502-1181
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	17-02-2025	09:15:00	17-02-2025	18:00:00	0.37	0.00	0.00	0.00	8.75		* SVRD BR hand tripped for voltage regulation. NR2502-6809
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	15-02-2025	09:24:00	15-02-2025	17:09:00	0.32	0.00	0.00	0.00	7.75		* SVRD BR hand tripped for voltage regulation. NR2502-5983
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	14-02-2025	09:21:00	14-02-2025	16:36:00	0.30	0.00	0.00	0.00	7.25		* BR hand tripped for voltage regulation. NR2502-5511
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	25-02-2025	09:20:00	25-02-2025	16:54:00	0.32	0.00	0.00	0.00	7.57		* 80MVAR,BUS REACTOR-1 AT KAITHAL manually opened on Voltage Reg. (NR-10183)
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	22-02-2025	09:49:00	22-02-2025	13:24:00	0.15	0.00	0.00	0.00	3.58		* BR hand tripped for voltage regulation. NR2502-9081
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	24-02-2025	09:34:00	24-02-2025	13:20:00	0.16	0.00	0.00	0.00	3.77		* 80MVAR,BUS REACTOR-1 AT KAITHAL manually opened on Voltage Reg. (NR-9754)
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	26-02-2025	10:05:00	26-02-2025	16:15:00	0.26	0.00	0.00	0.00	6.17		* BR hand tripped for voltage regulation.NR2502-10526
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	21-02-2025	09:58:00	21-02-2025	16:01:00	0.25	0.00	0.00	0.00	6.05		* BR hand tripped for voltage regulation. NR2502-8625
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	18-02-2025	09:30:00	18-02-2025	17:57:00	0.35	0.00	0.00	0.00	8.45		* Bus reactor hand tripped for voltage reg.NR2502-7292
							7.01	0.00	0.00	0.00	167.82	100.00	
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	17-02-2025	09:15:00	17-02-2025	18:00:00	0.37	0.00	0.00	0.00	8.75		* SVRD BR hand tripped for voltage regulation. NR2502-6808
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL												

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE To ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	01-02-2025	10:21:00	01-02-2025	16:44:00	0.27	0.00	0.00	0.00	6.38		* 125MVAR.BUS REACTOR-2 AT KAITHAL manually opened on Voltage Reg. (NR-152)
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	06-02-2025	08:54:00	06-02-2025	15:55:00	0.29	0.00	0.00	0.00	7.02		* BR hand tripped for voltage regulation. NR2502-2012
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	13-02-2025	09:45:00	13-02-2025	16:12:00	0.27	0.00	0.00	0.00	6.45		* BR hand tripped for voltage regulation. NR2502-5102
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	07-02-2025	09:19:00	07-02-2025	15:35:00	0.26	0.00	0.00	0.00	6.27		* BR hand tripped for voltage regulation. NR2502-2550
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	09-02-2025	09:07:00	09-02-2025	17:12:00	0.34	0.00	0.00	0.00	8.08		* 125MVAR.BUS REACTOR-2 AT KAITHAL BR manually opened on VR (NR-3402)
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	11-02-2025	09:29:00	11-02-2025	17:30:00	0.33	0.00	0.00	0.00	8.02		* BR hand tripped for voltage regulation. NR2502-4184
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	10-02-2025	09:08:00	10-02-2025	18:11:00	0.38	0.00	0.00	0.00	9.05		* BR hand tripped for voltage regulation. NR2502-3762
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	02-02-2025	09:26:00	02-02-2025	15:50:00	0.27	0.00	0.00	0.00	6.40		* BR hand tripped for voltage regulation.NR2502-491
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	15-02-2025	09:24:00	15-02-2025	17:09:00	0.32	0.00	0.00	0.00	7.75		* SVRD BR hand tripped for voltage regulation. NR2502-5954
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	04-02-2025	09:20:00	04-02-2025	16:10:00	0.29	0.00	0.00	0.00	6.83		* BR hand tripped for voltage regulation. NR2502-1181
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	14-02-2025	09:21:00	14-02-2025	16:36:00	0.30	0.00	0.00	0.00	7.25		* BR hand tripped for voltage regulation. NR2502-5510
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	26-02-2025	10:05:00	26-02-2025	16:15:00	0.26	0.00	0.00	0.00	6.17		* BR hand tripped for voltage regulation.NR2502-10525
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	22-02-2025	09:49:00	22-02-2025	13:24:00	0.15	0.00	0.00	0.00	3.58		* BR hand tripped for voltage regulation. NR2502-9063
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	24-02-2025	09:34:00	24-02-2025	13:20:00	0.16	0.00	0.00	0.00	3.77		* 125MVAR.BUS REACTOR-2 AT KAITHAL manually opened on Voltage Reg. (NR-9753)
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	21-02-2025	09:58:00	21-02-2025	16:01:00	0.25	0.00	0.00	0.00	6.05		* BR hand tripped for voltage regulation. NR2502-8626
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	19-02-2025	09:55:00	19-02-2025	19:49:00	0.41	0.00	0.00	0.00	9.90		* Bus reactor hand tripped for voltage reg.NR2502-7763
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	18-02-2025	09:30:00	18-02-2025	17:57:00	0.35	0.00	0.00	0.00	8.45		* Bus reactor hand tripped for voltage reg.NR2502-7293
BSR	125MVAR.BUS REACTOR-2 AT KAITHAL	SVRD	25-02-2025	09:20:00	25-02-2025	16:54:00	0.32	0.00	0.00	0.00	7.57		* 125MVAR.BUS REACTOR-2 AT KAITHAL manually opened on Voltage Reg. (NR-10182)
							7.01	0.00	0.00	0.00	167.82	100.00	
BSR	25MVAR.BUS REACTOR-1 AT KARGIL GIS	SVRD	07-02-2025	08:30:00	15-02-2025	01:18:00	7.70	0.00	0.00	0.00	184.80		* BR hand tripped for voltage regulation. NR2502-2473
BSR	25MVAR.BUS REACTOR-1 AT KARGIL GIS	SVRD	15-02-2025	09:45:00	17-02-2025	02:00:00	1.68	0.00	0.00	0.00	40.25		* BR hand tripped for voltage regulation. NR2502-6007
BSR	25MVAR.BUS REACTOR-1 AT KARGIL GIS	SVRD	27-02-2025	09:18:00	27-02-2025	23:48:00	0.60	0.00	0.00	0.00	14.50		* BR hand tripped for voltage regulation. NR2502-10752
BSR	25MVAR.BUS REACTOR-1 AT KARGIL GIS	SVRD	28-02-2025	12:46:00	28-02-2025	23:59:59	0.47	0.00	0.00	0.00	11.23		* SVRD BR hand tripped for voltage regulation. NR2502-11144
BSR	25MVAR.BUS REACTOR-1 AT KARGIL GIS	SVRD	25-02-2025	09:15:00	26-02-2025	02:56:00	0.74	0.00	0.00	0.00	17.68		* 25MVAR.BUS REACTOR-1 AT KARGIL GIS manually opened on Voltage Reg.(NR-10184)
BSR	25MVAR.BUS REACTOR-1 AT KARGIL GIS	SVRD	26-02-2025	09:36:00	27-02-2025	04:35:00	0.79	0.00	0.00	0.00	18.98		* BR hand tripped for voltage regulation.NR2502-10501
BSR	25MVAR.BUS REACTOR-1 AT KARGIL GIS	SVRD	17-02-2025	08:21:00	24-02-2025	00:49:00	6.69	0.00	0.00	0.00	160.47		* SVRD BR hand tripped for voltage regulation. NR2502-6769
BSR	25MVAR.BUS REACTOR-1 AT KARGIL GIS	SVRD	06-02-2025	09:03:00	07-02-2025	02:46:00	0.74	0.00	0.00	0.00	17.72		* BR hand tripped for voltage regulation. NR2502-2026
BSR	25MVAR.BUS REACTOR-1 AT KARGIL GIS	SVRD	01-02-2025	00:00:01	06-02-2025	02:01:00	5.08	0.00	0.00	0.00	122.02		* SVRD BR hand tripped for voltage regulation. NR2501-12038
							24.49	0.00	0.00	0.00	587.65	100.00	
BSR	25MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	01-02-2025	10:21:00	28-02-2025	23:59:59	27.57	0.00	0.00	0.00	661.65		* 25MVAR.BUS REACTOR-1 AT KISHENPUR manually opened on Voltage Reg. (NR-154)
BSR	25MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	01-02-2025	00:00:01	01-02-2025	06:15:00	0.26	0.00	0.00	0.00	6.25		* BR hand tripped for voltage regulation.NR2501-10453
							27.83	0.00	0.00	0.00	667.90	100.00	
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	01-02-2025	00:00:01	16-02-2025	21:08:00	15.88	0.00	0.00	0.00	381.13		* BR hand tripped for voltage regulation.NR2501-10038
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	17-02-2025	09:07:00	19-02-2025	02:31:00	1.73	0.00	0.00	0.00	41.40		* SVRD BR hand tripped for voltage regulation. NR2502-6790
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	26-02-2025	09:41:00	26-02-2025	16:20:00	0.28	0.00	0.00	0.00	6.65		* BR hand tripped for voltage regulation.NR2502-10499
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	25-02-2025	09:08:00	26-02-2025	03:03:00	0.75	0.00	0.00	0.00	17.92		* 63MVAR.BUS REACTOR-1 AT KISHENPUR manually opened on Voltage Reg. (NR-10150)
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	21-02-2025	08:56:00	21-02-2025	17:57:00	0.38	0.00	0.00	0.00	9.02		* BR hand tripped for voltage regulation. NR2502-8571
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	22-02-2025	08:47:00	24-02-2025	18:39:00	2.41	0.00	0.00	0.00	57.87		* BR hand tripped for voltage regulation. NR2502-8997
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	20-02-2025	10:10:00	20-02-2025	16:48:00	0.28	0.00	0.00	0.00	6.63		* Line hand tripped on voltage regulation. NR2502-8260
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	19-02-2025	08:54:00	20-02-2025	00:30:00	0.65	0.00	0.00	0.00	15.60		* Bus reactor hand tripped for voltage reg.NR 2502-7681
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	27-02-2025	09:29:00	27-02-2025	16:38:00	0.30	0.00	0.00	0.00	7.15		* BR hand tripped for voltage regulation. NR2502-10784
							22.66	0.00	0.00	0.00	543.37	100.00	
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	01-02-2025	00:00:01	16-02-2025	21:08:00	15.88	0.00	0.00	0.00	381.13		* BR hand tripped for voltage regulation.NR2501-10039
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	17-02-2025	09:07:00	19-02-2025	02:31:00	1.73	0.00	0.00	0.00	41.40		* SVRD BR hand tripped for voltage regulation. NR2502-6791
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	26-02-2025	09:41:00	26-02-2025	16:20:00	0.28	0.00	0.00	0.00	6.65		* BR hand tripped for voltage regulation.NR2502-10500
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	25-02-2025	09:08:00	26-02-2025	03:03:00	0.75	0.00	0.00	0.00	17.92		* 80MVAR.BUS REACTOR-2 AT KISHENPUR manually opened on Voltage Reg. (NR-10151)
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	21-02-2025	08:56:00	21-02-2025	17:57:00	0.38	0.00	0.00	0.00	9.02		* BR hand tripped for voltage regulation. NR2502-8570
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	27-02-2025	09:29:00	27-02-2025	16:38:00	0.30	0.00	0.00	0.00	7.15		* BR hand tripped for voltage regulation. NR2502-10784
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	22-02-2025	08:47:00	24-02-2025	18:39:00	2.41	0.00	0.00	0.00	57.87		* BR hand tripped for voltage regulation. NR2502-8998
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	20-02-2025	10:10:00	20-02-2025	16:48:00	0.28	0.00	0.00	0.00	6.63		* Line hand tripped on voltage regulation. NR2502-8261
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	19-02-2025	08:54:00	20-02-2025	00:30:00	0.65	0.00	0.00	0.00	15.60		* Bus reactor hand tripped for voltage reg.NR2502-7682
							22.66	0.00	0.00	0.00	543.37	100.00	
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	21-02-2025	08:59:00	21-02-2025	17:55:00	0.37	0.00	0.00	0.00	8.93		* BR hand tripped for voltage regulation. NR2502-8569
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	25-02-2025	09:09:00	26-02-2025	03:02:00	0.75	0.00	0.00	0.00	17.88		* 125MVAR.BUS REACTOR-3 AT KISHENPUR manually opened on Voltage Reg. (NR-10149)
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	24-02-2025	09:13:00	24-02-2025	17:37:00	0.35	0.00	0.00	0.00	8.40		* 125MVAR.BUS REACTOR-3 AT KISHENPUR manually opened on Voltage Reg. (NR-9720)
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	22-02-2025	08:48:00	24-02-2025	02:53:00	1.75	0.00	0.00	0.00	42.08		* BR hand tripped for voltage regulation. NR2502-8996
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	17-02-2025	09:09:00	19-02-2025	02:33:00	1.73	0.00	0.00	0.00	41.40		* SVRD BR hand tripped for voltage regulation. NR2502-6792
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	01-02-2025	00:00:01	16-02-2025	21:06:00	15.88	0.00	0.00	0.00	381.10		* BR hand tripped for voltage regulation.NR2501-10009
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	20-02-2025	07:44:00	20-02-2025	17:01:00	0.39	0.00	0.00	0.00	9.28		* Line hand tripped on voltage regulation. NR2502-8175
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	19-02-2025	08:53:00	20-02-2025	00:30:00	0.65	0.00	0.00	0.00	15.62		* Bus reactor hand tripped for voltage reg.NR2502-7680
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	26-02-2025	09:37:00	26-02-2025	16:19:00	0.28	0.00	0.00	0.00	6.70		* BR hand tripped for voltage regulation.NR2502-10498
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	27-02-2025	09:30:00	27-02-2025	21:02:00	0.48	0.00	0.00	0.00	11.53		* BR hand tripped for voltage regulation. NR2502-10786
							22.63	0.00	0.00	0.00	542.92	100.00	
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	16-02-2025	09:45:00	16-02-2025	16:33:00	0.28	0.00	0.00	0.00	6.80		* SVRD BR hand tripped for voltage regulation. NR2502-6412
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	18-02-2025	09:58:00	18-02-2025	15:45:00	0.24	0.00	0.00	0.00	5.78		* Bus reactor hand tripped for voltage reg.NR2502-7324
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	02-02-2025	09:28:00	02-02-2025	15:52:00	0.27	0.00	0.00	0.00	6.40		* BR hand tripped for voltage regulation.NR2502-499
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	07-02-2025	08:40:00	07-02-2025	17:20:00	0.36	0.00	0.00	0.00	8.67		* BR hand tripped for voltage regulation. NR2502-2476
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	01-02-2025	10:19:00	01-02-2025	20:39:00	0.43	0.00	0.00	0.00	10.33		* 80MVAR.BUS REACTOR-1 AT LUDHIANA manually opened on Voltage Reg. (NR-151)
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	06-02-2025	08:53:00	06-02-2025	17:29:00	0.36	0.00	0.00	0.00	8.60		* BR hand tripped for voltage regulation. NR2502-2014
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	12-02-2025	09:49:00	12-02-2025	15:49:00	0.25	0.00	0.00	0.00	6.00		* BR hand tripped for voltage regulation. NR2502-4680
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	05-02-2025	09:35:00	05-02-2025	16:21:00	0.28	0.00	0.00	0.00	6.77		* BR hand tripped for voltage regulation. NR2502-1602
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	04-02-2025	09:30:00	04-02-2025	16:14:00	0.28	0.00	0.00	0.00	6.73		* BR hand tripped for voltage regulation. NR2502-1189
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	11-02-2025	09:23:00	11-02-2025	17:34:00	0.34	0.00	0.00	0.00	8.18		* BR hand tripped for voltage regulation. NR2502-4181

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE To ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR,BUS REACTOR-1 AT LUDHIANA	SVRD	15-02-2025	09:37:00	15-02-2025	22:30:00	0.54	0.00	0.00	0.00	12.88		* BR hand tripped for voltage regulation. NR2502-5959
BSR	80MVAR,BUS REACTOR-1 AT LUDHIANA	SVRD	10-02-2025	09:11:00	10-02-2025	18:38:00	0.39	0.00	0.00	0.00	9.45		* BR hand tripped for voltage regulation. NR2502-3723
BSR	80MVAR,BUS REACTOR-1 AT LUDHIANA	SVRD	21-02-2025	09:21:00	21-02-2025	17:43:00	0.35	0.00	0.00	0.00	8.37		* BR hand tripped for voltage regulation. NR2502-8591
BSR	80MVAR,BUS REACTOR-1 AT LUDHIANA	SVRD	19-02-2025	09:53:00	19-02-2025	17:18:00	0.31	0.00	0.00	0.00	7.42		* Bus reactor hand tripped for voltage reg.NR2502-7772
							6.04	0.00	0.00	0.00	145.13	100.00	
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	07-02-2025	08:39:00	07-02-2025	17:10:00	0.36	0.00	0.00	0.00	8.52		* BR hand tripped for voltage regulation. NR2502-2478
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	05-02-2025	09:45:00	05-02-2025	15:58:00	0.26	0.00	0.00	0.00	6.22		* BR hand tripped for voltage regulation. NR2502-1605
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	09-02-2025	09:12:00	09-02-2025	17:23:00	0.34	0.00	0.00	0.00	8.18		* 50MVAR,BUS REACTOR-1 AT MALERKOTLA BR manually opened on VR (NR-3412)
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	17-02-2025	09:52:00	17-02-2025	16:31:00	0.28	0.00	0.00	0.00	6.65		* SVRD BR hand tripped for voltage regulation. NR2502-6856
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	08-02-2025	09:15:00	08-02-2025	18:14:00	0.37	0.00	0.00	0.00	8.98		* 50MVAR,BUS REACTOR-1 AT MALERKOTLA BR manually opened on Voltage Reg. (NR-2966)
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	04-02-2025	11:33:00	04-02-2025	16:00:00	0.19	0.00	0.00	0.00	4.45		* BR hand tripped for voltage regulation. NR2502-1246
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	12-02-2025	09:42:00	12-02-2025	15:55:00	0.26	0.00	0.00	0.00	6.22		* BR hand tripped for voltage regulation. NR2502-4622
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	10-02-2025	09:15:00	10-02-2025	21:00:00	0.49	0.00	0.00	0.00	11.75		
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	11-02-2025	09:33:00	11-02-2025	17:30:00	0.33	0.00	0.00	0.00	7.95		* BR hand tripped for voltage regulation. NR2502-4192
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	13-02-2025	09:52:00	13-02-2025	16:01:00	0.26	0.00	0.00	0.00	6.15		* BR hand tripped for voltage regulation. NR2502-5114
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	16-02-2025	09:07:00	16-02-2025	16:44:00	0.32	0.00	0.00	0.00	7.62		* SVRD BR hand tripped for voltage regulation. NR2502-6388
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	06-02-2025	09:28:00	06-02-2025	16:43:00	0.30	0.00	0.00	0.00	7.25		* BR hand tripped for voltage regulation. NR2502-2086
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	15-02-2025	09:34:00	15-02-2025	18:02:00	0.35	0.00	0.00	0.00	8.47		* BR hand tripped for voltage regulation. NR2502-5957
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	14-02-2025	09:19:00	14-02-2025	16:28:00	0.30	0.00	0.00	0.00	7.15		* SVRD BR hand tripped for voltage regulation. NR2502-5513
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	18-02-2025	10:14:00	18-02-2025	15:19:00	0.21	0.00	0.00	0.00	5.08		* Bus reactor hand tripped for voltage reg.NR2502-7339
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	19-02-2025	09:39:00	19-02-2025	17:10:00	0.31	0.00	0.00	0.00	7.52		* Bus reactor hand tripped for voltage reg.NR2502-7749
							4.93	0.00	0.00	0.00	118.16	100.00	
BSR	50MVAR,BUS REACTOR-1 AT MOGA	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR hand tripped for voltage regulation. NR2409-2549
							28.00	0.00	0.00	0.00	672.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	25-02-2025	09:01:00	25-02-2025	16:26:00	0.31	0.00	0.00	0.00	7.42		* 240MVAR,BUS REACTOR-1 AT MOGA manually opened on Voltage Reg. (NR-10146)
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	19-02-2025	09:06:00	19-02-2025	13:41:00	0.19	0.00	0.00	0.00	4.58		* Bus reactor hand tripped for voltage reg.NR2502-7692,NL-2616
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	20-02-2025	09:21:00	20-02-2025	13:10:00	0.16	0.00	0.00	0.00	3.82		* Line hand tripped on voltage regulation. NR2502-8200, NL-2770
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	18-02-2025	09:03:00	18-02-2025	15:13:00	0.26	0.00	0.00	0.00	6.17		* Bus reactor hand tripped for voltage reg.NR2502-7261,NL-2447
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	16-02-2025	09:13:00	16-02-2025	15:05:00	0.24	0.00	0.00	0.00	5.87		* SVRD BR hand tripped for voltage regulation. NR2502-6395, NL-2189
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	13-02-2025	09:07:00	13-02-2025	16:03:00	0.29	0.00	0.00	0.00	6.93		* BR hand tripped for voltage regulation. NR2502-5026 NL-1733
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	10-02-2025	09:12:00	10-02-2025	15:38:00	0.27	0.00	0.00	0.00	6.43		* BR hand tripped for voltage regulation. NR2502-3752 NL-1255
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	04-02-2025	09:16:00	04-02-2025	15:54:00	0.28	0.00	0.00	0.00	6.63		* BR hand tripped for voltage regulation. NR2502-1155,NL-395
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	09-02-2025	09:01:00	09-02-2025	15:11:00	0.26	0.00	0.00	0.00	6.17		* 240MVAR,BUS REACTOR-1 AT MOGA BR manually opened on VR (NR-3382, NL-1139)
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	08-02-2025	09:27:00	08-02-2025	16:15:00	0.28	0.00	0.00	0.00	6.80		* 240MVAR,BUS REACTOR-1 AT MOGA BR manually opened on Voltage Reg. (NR-3012, NL-1022)
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	02-02-2025	09:12:00	02-02-2025	15:54:00	0.28	0.00	0.00	0.00	6.70		* BR hand tripped for voltage regulation.NR2502-453,NL-153
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	01-02-2025	09:26:00	01-02-2025	15:07:00	0.24	0.00	0.00	0.00	5.68		* 240MVAR,BUS REACTOR-1 AT MOGA manually opened on Voltage Reg. (NR-110, NL-35)
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	05-02-2025	08:57:00	05-02-2025	15:37:00	0.28	0.00	0.00	0.00	6.67		* BR hand tripped for voltage regulation. NR2502-1500,NL-528
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	12-02-2025	09:12:00	12-02-2025	15:28:00	0.26	0.00	0.00	0.00	6.27		* BR hand tripped for voltage regulation. NR2502-4584 NL-1585
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	03-02-2025	09:03:00	03-02-2025	15:35:00	0.27	0.00	0.00	0.00	6.53		* BR hand tripped for voltage regulation.NR2502-781, NL-239
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	11-02-2025	09:05:00	11-02-2025	15:44:00	0.28	0.00	0.00	0.00	6.65		* BR hand tripped for voltage regulation. NR2502-4136 NL-1436
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	07-02-2025	09:15:00	07-02-2025	15:21:00	0.25	0.00	0.00	0.00	6.10		* BR hand tripped for voltage regulation. NR2502-2542 NL-853
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	17-02-2025	09:14:00	17-02-2025	15:35:00	0.27	0.00	0.00	0.00	6.35		* SVRD BR hand tripped for voltage regulation. NR2502-6800, NL-2304
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	14-02-2025	08:51:00	14-02-2025	14:43:00	0.24	0.00	0.00	0.00	5.87		* BR hand tripped for voltage regulation. NR2502-5436 NL-1894
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	06-02-2025	08:56:00	06-02-2025	16:16:00	0.31	0.00	0.00	0.00	7.33		* BR hand tripped for voltage regulation. NR2502-2007 NL-659
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	15-02-2025	08:47:00	15-02-2025	15:05:00	0.26	0.00	0.00	0.00	6.30		* BR hand tripped for voltage regulation. NR2502-5897 NL-2060
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	26-02-2025	09:09:00	26-02-2025	14:37:00	0.23	0.00	0.00	0.00	5.47		* BR hand tripped for voltage regulation.NR2502-10475,NL-3601
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	24-02-2025	09:06:00	24-02-2025	15:40:00	0.27	0.00	0.00	0.00	6.57		* 240MVAR,BUS REACTOR-1 AT MOGA manually opened on Voltage Reg. (NR-9710, NL-3339)
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	22-02-2025	08:53:00	22-02-2025	16:34:00	0.32	0.00	0.00	0.00	7.68		* BR hand tripped for voltage regulation. NR2502-9019 NL-3100
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	21-02-2025	09:15:00	21-02-2025	15:54:00	0.28	0.00	0.00	0.00	6.65		* BR hand tripped for voltage regulation. NR2502-8588 NL-2948
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	23-02-2025	09:12:00	23-02-2025	14:58:00	0.24	0.00	0.00	0.00	5.77		* BR hand tripped for voltage regulation. NR2502-9399 NL-3236
							6.82	0.00	0.00	0.00	163.41	100.00	
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	07-02-2025	09:18:00	07-02-2025	16:16:00	0.29	0.00	0.00	0.00	6.97		* BR hand tripped for voltage regulation. NR2502-2520
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	04-02-2025	08:58:00	04-02-2025	16:18:00	0.31	0.00	0.00	0.00	7.33		* BR hand tripped for voltage regulation. NR2502-1143
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	06-02-2025	09:27:00	06-02-2025	17:39:00	0.34	0.00	0.00	0.00	8.20		* BR hand tripped for voltage regulation. NR2502-2072
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	09-02-2025	09:23:00	09-02-2025	17:18:00	0.33	0.00	0.00	0.00	7.92		* 125MVAR,BUS REACTOR-2 AT MOGA BR manually opened on VR (NR-3418)
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	08-02-2025	09:14:00	08-02-2025	17:13:00	0.33	0.00	0.00	0.00	7.98		* 125MVAR,BUS REACTOR-2 AT MOGA BR manually opened on Voltage Reg. (NR-2969)
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	19-02-2025	10:02:00	19-02-2025	17:19:00	0.30	0.00	0.00	0.00	7.28		* Bus reactor hand tripped for voltage reg.NR2502-7766
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	18-02-2025	09:36:00	18-02-2025	18:02:00	0.35	0.00	0.00	0.00	8.43		* Bus reactor hand tripped for voltage reg.NR2502-7301
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	20-02-2025	09:39:00	20-02-2025	16:45:00	0.30	0.00	0.00	0.00	7.10		* Line hand tripped on voltage regulation. NR2502-8240
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	21-02-2025	09:39:00	21-02-2025	16:16:00	0.28	0.00	0.00	0.00	6.62		* BR hand tripped for voltage regulation. NR2502-8606 NL-2965
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	24-02-2025	09:33:00	24-02-2025	11:04:00	0.06	0.00	0.00	0.00	1.52		* 125MVAR,BUS REACTOR-2 AT MOGA manually opened on Voltage Reg. (NR-9752)
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	22-02-2025	09:21:00	22-02-2025	15:55:00	0.27	0.00	0.00	0.00	6.57		* BR hand tripped for voltage regulation. NR2502-9050
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	26-02-2025	10:09:00	26-02-2025	15:28:00	0.22	0.00	0.00	0.00	5.32		* BR hand tripped for voltage regulation.NR2502-10510
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	14-02-2025	09:16:00	14-02-2025	18:19:00	0.38	0.00	0.00	0.00	9.05		* BR hand tripped for voltage regulation. NR2502-5496
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	17-02-2025	09:39:00	17-02-2025	16:38:00	0.29	0.00	0.00	0.00	6.98		* SVRD BR hand tripped for voltage regulation. NR2502-6849
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	15-02-2025	09:42:00	15-02-2025	18:01:00	0.35	0.00	0.00	0.00	8.32		* BR hand tripped for voltage regulation. NR2502-5962
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	05-02-2025	09:26:00	05-02-2025	16:23:00	0.29	0.00	0.00	0.00	6.95		* BR hand tripped for voltage regulation. NR2502-1567,NL-538
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	11-02-2025	09:12:00	11-02-2025	17:26:00	0.34	0.00	0.00	0.00	8.23		* BR hand tripped for voltage regulation. NR2502-4157
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	10-02-2025	09:24:00	10-02-2025	21:01:00	0.48	0.00	0.00	0.00	11.62		* BR hand tripped for voltage regulation. NR2502-3739
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	13-02-2025	09:47:00	13-02-2025	16:07:00	0.26	0.00	0.00	0.00	6.33		* BR hand tripped for voltage regulation. NR2502-5100
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	01-02-2025	10:07:00	01-02-2025	20:52:00	0.45	0.00	0.00	0.00	10.75		* 125MVAR,BUS REACTOR-2 AT MOGA manually opened on Voltage Reg. (NR-143)
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	12-02-2025	09:47:00	12-02-2025	15:51:00	0.25	0.00	0.00	0.00	6.07		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE To ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	17-02-2025	09:01:00	17-02-2025	15:38:00	0.28	0.00	0.00	0.00	6.62		* SVRD BR hand tripped for voltage regulation. NR2502-6783, NL-2297
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	15-02-2025	08:48:00	15-02-2025	16:12:00	0.31	0.00	0.00	0.00	7.40		* SVRD BR hand tripped for voltage regulation. NR2502-5898 NL-2061
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	09-02-2025	09:47:00	09-02-2025	16:05:00	0.26	0.00	0.00	0.00	6.30		* 240MVAR,BUS REACTOR-2 AT MOGA BR manually opened on VR (NR-3443, NL-1158)
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	14-02-2025	08:51:00	14-02-2025	18:13:00	0.39	0.00	0.00	0.00	9.37		* BR hand tripped for voltage regulation. NR2502-5437 NL-1895
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	21-02-2025	09:36:00	21-02-2025	15:40:00	0.25	0.00	0.00	0.00	6.07		* BR hand tripped for voltage regulation. NR2502-8606 NL-2965
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	22-02-2025	08:54:00	22-02-2025	15:53:00	0.29	0.00	0.00	0.00	6.98		* BR hand tripped for voltage regulation. NR2502-9020 NL-3102
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	25-02-2025	09:02:00	25-02-2025	16:27:00	0.31	0.00	0.00	0.00	7.42		* 240MVAR,BUS REACTOR-2 AT MOGA manually opened on Voltage Reg. (NR-10147)
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	26-02-2025	09:11:00	26-02-2025	14:38:00	0.23	0.00	0.00	0.00	5.45		* BR hand tripped for voltage regulation.NR2502-10476,NL-3602
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	24-02-2025	09:22:00	24-02-2025	15:42:00	0.26	0.00	0.00	0.00	6.33		* 240MVAR,BUS REACTOR-2 AT MOGA BR manually opened on Voltage Reg. (NR-9733)
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	23-02-2025	09:13:00	23-02-2025	15:51:00	0.28	0.00	0.00	0.00	6.63		* BR hand tripped for voltage regulation. NR2502-9400 NL-3237
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	19-02-2025	09:07:00	19-02-2025	13:45:00	0.19	0.00	0.00	0.00	4.63		* Bus reactor hand tripped for voltage reg.NR2502-7693,NL-2617
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	16-02-2025	09:49:00	16-02-2025	15:07:00	0.22	0.00	0.00	0.00	5.30		* SVRD BR hand tripped for voltage regulation. NR2502-6423, NL-2204
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	18-02-2025	09:04:00	18-02-2025	15:16:00	0.26	0.00	0.00	0.00	6.20		* Bus reactor hand tripped for voltage reg.NR2502-7262,NL-2449
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	20-02-2025	09:23:00	20-02-2025	15:48:00	0.27	0.00	0.00	0.00	6.42		* Line hand tripped on voltage regulation. NR2502-8201, NL-2771
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	08-02-2025	09:12:00	08-02-2025	17:10:00	0.33	0.00	0.00	0.00	7.97		* 240MVAR,BUS REACTOR-2 AT MOGA BR manually opened on Voltage Reg. (NR-2977, NL-1008)
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	04-02-2025	09:17:00	04-02-2025	15:55:00	0.28	0.00	0.00	0.00	6.63		* BR hand tripped for voltage regulation. NR2502-1156,NL-396
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	05-02-2025	09:14:00	05-02-2025	15:38:00	0.27	0.00	0.00	0.00	6.40		* BR hand tripped for voltage regulation. NR2502-1567,NL-538
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	02-02-2025	09:14:00	02-02-2025	15:59:00	0.28	0.00	0.00	0.00	6.75		* BR hand tripped for voltage regulation.NR2502-454 NL-154
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	06-02-2025	08:57:00	06-02-2025	16:38:00	0.32	0.00	0.00	0.00	7.68		* BR hand tripped for voltage regulation. NR2502-2017 NL-664
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	11-02-2025	09:08:00	11-02-2025	15:45:00	0.28	0.00	0.00	0.00	6.62		* BR hand tripped for voltage regulation. NR2502-4144 NL-1444
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	12-02-2025	09:14:00	12-02-2025	15:30:00	0.26	0.00	0.00	0.00	6.27		* BR hand tripped for voltage regulation. NR2502-4585 NL-1586
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	03-02-2025	09:06:00	03-02-2025	15:36:00	0.27	0.00	0.00	0.00	6.50		* BR hand tripped for voltage regulation.NR2502-782,NL-240
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	07-02-2025	08:55:00	07-02-2025	15:59:00	0.29	0.00	0.00	0.00	7.07		* BR hand tripped for voltage regulation. NR2502-2505 NL-833
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	10-02-2025	09:13:00	10-02-2025	15:39:00	0.27	0.00	0.00	0.00	6.43		* BR hand tripped for voltage regulation. NR2502-3754 NL-1256
							7.19	0.00	0.00	0.00	172.24	100.00	
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	08-02-2025	09:20:00	08-02-2025	21:22:00	0.50	0.00	0.00	0.00	12.03		* 50MVAR,BUS REACTOR-1 AT NALAGARH BR manually opened on Voltage Reg. (NR-2987)
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	05-02-2025	11:06:00	05-02-2025	15:57:00	0.20	0.00	0.00	0.00	4.85		* BR hand tripped for voltage regulation. NR2502-1681
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	07-02-2025	09:16:00	07-02-2025	17:27:00	0.34	0.00	0.00	0.00	8.18		* BR hand tripped for voltage regulation. NR2502-2534
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	06-02-2025	09:48:00	06-02-2025	16:45:00	0.29	0.00	0.00	0.00	6.95		* BR hand tripped for voltage regulation. NR2502-2101
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	12-02-2025	09:44:00	12-02-2025	15:47:00	0.25	0.00	0.00	0.00	6.05		* BR hand tripped for voltage regulation. NR2502-4647
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	13-02-2025	09:51:00	13-02-2025	16:17:00	0.27	0.00	0.00	0.00	6.43		* BR hand tripped for voltage regulation. NR2502-5111
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	17-02-2025	09:55:00	17-02-2025	16:15:00	0.26	0.00	0.00	0.00	6.33		* SVRD BR hand tripped for voltage regulation. NR2502-6878
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	14-02-2025	08:57:00	14-02-2025	20:56:00	0.50	0.00	0.00	0.00	11.98		* BR hand tripped for voltage regulation. NR2502-5454
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	16-02-2025	10:03:00	16-02-2025	13:17:00	0.14	0.00	0.00	0.00	3.23		* SVRD BR hand tripped for voltage regulation. NR2502-6457
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	26-02-2025	10:19:00	26-02-2025	15:27:00	0.21	0.00	0.00	0.00	5.13		* BR hand tripped for voltage regulation.NR2502-10528
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	19-02-2025	09:48:00	19-02-2025	17:12:00	0.31	0.00	0.00	0.00	7.40		* Bus reactor hand tripped for voltage reg.NR2502-7750
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	18-02-2025	10:11:00	18-02-2025	15:20:00	0.22	0.00	0.00	0.00	5.15		* Bus reactor hand tripped for voltage reg.NR2502-7335
							3.49	0.00	0.00	0.00	83.71	100.00	
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	16-02-2025	09:54:00	16-02-2025	16:42:00	0.28	0.00	0.00	0.00	6.80		* SVRD BR hand tripped for voltage regulation. NR2502-6422
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	15-02-2025	09:42:00	15-02-2025	17:13:00	0.31	0.00	0.00	0.00	7.52		* BR hand tripped for voltage regulation. NR2502-5970
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	08-02-2025	09:21:00	08-02-2025	21:22:00	0.50	0.00	0.00	0.00	12.02		* 125MVAR,BUS REACTOR-2 AT NALAGARH BR manually opened on Voltage Reg. (NR-2984)
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	04-02-2025	11:31:00	04-02-2025	16:09:00	0.19	0.00	0.00	0.00	4.63		* BR hand tripped for voltage regulation. NR2502-1244
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	05-02-2025	11:06:00	05-02-2025	15:57:00	0.20	0.00	0.00	0.00	4.85		* BR hand tripped for voltage regulation. NR2502-1680
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	12-02-2025	09:42:00	12-02-2025	15:47:00	0.25	0.00	0.00	0.00	6.08		* BR hand tripped for voltage regulation. NR2502-4648
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	13-02-2025	09:50:00	13-02-2025	16:03:00	0.26	0.00	0.00	0.00	6.22		* BR hand tripped for voltage regulation. NR2502-5113
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	07-02-2025	08:35:00	07-02-2025	17:50:00	0.39	0.00	0.00	0.00	9.25		* BR hand tripped for voltage regulation. NR2502-2482
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	17-02-2025	10:02:00	17-02-2025	16:35:00	0.27	0.00	0.00	0.00	6.55		* SVRD BR hand tripped for voltage regulation. NR2502-6855
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	06-02-2025	09:19:00	06-02-2025	17:00:00	0.32	0.00	0.00	0.00	7.68		* BR hand tripped for voltage regulation. NR2502-2062
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	14-02-2025	08:58:00	14-02-2025	18:25:00	0.39	0.00	0.00	0.00	9.45		* BR hand tripped for voltage regulation. NR2502-5454
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	19-02-2025	10:10:00	19-02-2025	17:21:00	0.30	0.00	0.00	0.00	7.18		* Bus reactor hand tripped for voltage reg.NR2502-7775
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	18-02-2025	10:01:00	18-02-2025	15:45:00	0.24	0.00	0.00	0.00	5.73		* Bus reactor hand tripped for voltage reg.NR2502-7325
							3.90	0.00	0.00	0.00	93.96	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	19-02-2025	09:52:00	19-02-2025	17:13:00	0.31	0.00	0.00	0.00	7.35		* Bus reactor hand tripped for voltage reg.NR2502-7756
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	24-02-2025	09:38:00	24-02-2025	13:20:00	0.15	0.00	0.00	0.00	3.70		* 125MVAR,BUS REACTOR-1 AT PATIALA manually opened on Voltage Reg. (NR-9757)
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	21-02-2025	09:48:00	21-02-2025	16:01:00	0.26	0.00	0.00	0.00	6.22		* BR hand tripped for voltage regulation. NR2502-8635
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	10-02-2025	09:18:00	10-02-2025	18:16:00	0.37	0.00	0.00	0.00	8.97		* BR hand tripped for voltage regulation. NR2502-3733
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	14-02-2025	09:14:00	14-02-2025	18:18:00	0.38	0.00	0.00	0.00	9.07		* BR hand tripped for voltage regulation. NR2502-5495
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	15-02-2025	09:45:00	15-02-2025	17:26:00	0.32	0.00	0.00	0.00	7.68		* BR hand tripped for voltage regulation. NR2502-5965
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	12-02-2025	09:47:00	12-02-2025	15:51:00	0.25	0.00	0.00	0.00	6.07		* BR hand tripped for voltage regulation. NR2502-4629
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	16-02-2025	09:14:00	16-02-2025	16:35:00	0.31	0.00	0.00	0.00	7.35		* SVRD BR hand tripped for voltage regulation. NR2502-6390
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	18-02-2025	10:06:00	18-02-2025	15:22:00	0.22	0.00	0.00	0.00	5.27		* Bus reactor hand tripped for voltage reg.NR2502-7329
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	09-02-2025	09:20:00	09-02-2025	17:21:00	0.33	0.00	0.00	0.00	8.02		* 125MVAR,BUS REACTOR-1 AT PATIALA BR manually opened on VR (NR-3419)
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	05-02-2025	09:30:00	05-02-2025	16:26:00	0.29	0.00	0.00	0.00	6.93		* BR hand tripped for voltage regulation. NR2502-1605
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	02-02-2025	09:40:00	02-02-2025	15:48:00	0.26	0.00	0.00	0.00	6.13		* BR hand tripped for voltage regulation.NR2502-493
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	08-02-2025	09:16:00	08-02-2025	18:51:00	0.40	0.00	0.00	0.00	9.58		* 125MVAR,BUS REACTOR-1 AT PATIALA BR manually opened on Voltage Reg. (NR-2959)
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	04-02-2025	09:25:00	04-02-2025	16:12:00	0.28	0.00	0.00	0.00	6.78		* BR hand tripped for voltage regulation. NR2502-1190
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	11-02-2025	09:29:00	11-02-2025	17:35:00	0.34	0.00	0.00	0.00	8.10		* BR hand tripped for voltage regulation. NR2502-4173
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	07-02-2025	08:38:00	07-02-2025	17:37:00	0.37	0.00	0.00	0.00	8.98		* BR hand tripped for voltage regulation. NR2502-2479
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	01-02-2025	09:29:00	01-02-2025	20:41:00	0.47	0.00	0.00	0.00	11.20		* 125MVAR,BUS REACTOR-1 AT PATIALA manually opened on Voltage Reg. (NR-117)
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	13-02-2025	09:46:00	13-02-2025	16:14:00	0.27	0.00	0.00	0.00	6.47		* BR hand tripped for voltage regulation. NR2502-5099
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	17-02-2025	09:59:00	17-02-2025	16:28:00	0.27	0.00	0.00	0.00	6.48		* SVRD BR hand tripped for voltage regulation. NR2502-6859
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	06-02-2025	09:22:00	06-02-2025	17:44:00	0.35	0					

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	10-02-2025	09:18:00	10-02-2025	18:16:00	0.37	0.00	0.00	0.00	8.97		* BR hand tripped for voltage regulation. NR2502-3734
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	07-02-2025	08:37:00	07-02-2025	17:37:00	0.38	0.00	0.00	0.00	9.00		* BR hand tripped for voltage regulation. NR2502-2480
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	03-02-2025	09:26:00	03-02-2025	15:43:00	0.26	0.00	0.00	0.00	6.28		* BR hand tripped for voltage regulation.NR2502-805
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	02-02-2025	09:40:00	02-02-2025	15:48:00	0.26	0.00	0.00	0.00	6.13		* BR hand tripped for voltage regulation.NR2502-494
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	11-02-2025	09:28:00	11-02-2025	17:36:00	0.34	0.00	0.00	0.00	8.13		* BR hand tripped for voltage regulation. NR2502-4174
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	13-02-2025	09:46:00	13-02-2025	16:14:00	0.27	0.00	0.00	0.00	6.47		* BR hand tripped for voltage regulation. NR2502-5101
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	12-02-2025	09:47:00	12-02-2025	15:51:00	0.25	0.00	0.00	0.00	6.07		* BR hand tripped for voltage regulation. NR2502-4631
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	18-02-2025	10:06:00	18-02-2025	15:22:00	0.22	0.00	0.00	0.00	5.27		* Bus reactor hand tripped for voltage reg.NR2502-7333
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	19-02-2025	09:49:00	19-02-2025	17:13:00	0.31	0.00	0.00	0.00	7.40		* Bus reactor hand tripped for voltage reg.Nr2502-7757
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	23-02-2025	09:15:00	24-02-2025	02:16:00	0.71	0.00	0.00	0.00	17.02		* BR hand tripped for voltage regulation. NR2502-9410
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	24-02-2025	09:11:00	25-02-2025	01:22:00	0.67	0.00	0.00	0.00	16.18		* 125MVAR.BUS REACTOR-2 AT PATIALA manually opened on Voltage Reg. (NR-9721)
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	21-02-2025	09:48:00	21-02-2025	16:01:00	0.26	0.00	0.00	0.00	6.22		* BR hand tripped for voltage regulation. NR2502-8636
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	17-02-2025	09:58:00	17-02-2025	16:28:00	0.27	0.00	0.00	0.00	6.50		* SVRD BR hand tripped for voltage regulation. NR2502-6858
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	05-02-2025	09:30:00	05-02-2025	16:25:00	0.29	0.00	0.00	0.00	6.92		* BR hand tripped for voltage regulation. NR2502-1607
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	04-02-2025	09:25:00	04-02-2025	16:12:00	0.28	0.00	0.00	0.00	6.78		* BR hand tripped for voltage regulation. NR2502-1191
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	06-02-2025	09:22:00	06-02-2025	17:44:00	0.35	0.00	0.00	0.00	8.37		* BR hand tripped for voltage regulation. NR2502-2070
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	09-02-2025	09:20:00	09-02-2025	17:22:00	0.34	0.00	0.00	0.00	8.03		* 125MVAR.BUS REACTOR-2 AT PATIALA BR manually opened on VR (NR-0920)
BSR	125MVAR.BUS REACTOR-2 AT PATIALA	SVRD	16-02-2025	09:13:00	16-02-2025	16:36:00	0.31	0.00	0.00	0.00	7.38		* SVRD BR hand tripped for voltage regulation. NR2502-6391
							7.71	0.00	0.00	0.00	184.70	100.00	
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	16-02-2025	07:31:00	18-02-2025	01:40:00	1.76	0.00	0.00	0.00	42.15		* SVRD BR hand tripped for voltage regulation. NR2502-6358
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	20-02-2025	10:08:00	21-02-2025	00:50:00	0.61	0.00	0.00	0.00	14.70		* Line hand tripped on voltage regulation. NR2502-8259
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	01-02-2025	00:00:01	01-02-2025	01:55:00	0.08	0.00	0.00	0.00	1.92		* 25MVAR.BUS REACTOR-1 AT LEH GIS anually opened on Voltage Reg. (NR-12474)
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	09-02-2025	08:56:00	10-02-2025	01:43:00	0.70	0.00	0.00	0.00	16.78		* 25MVAR.BUS REACTOR-1 AT LEH GIS BR manually opened on VR (NR-3380)
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	04-02-2025	09:02:00	05-02-2025	01:33:00	0.69	0.00	0.00	0.00	16.52		* BR hand tripped for voltage regulation. NR2502-1146
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	05-02-2025	09:13:00	09-02-2025	02:04:00	3.70	0.00	0.00	0.00	88.85		* BR hand tripped for voltage regulation. NR2502-1571
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	01-02-2025	10:56:00	02-02-2025	01:40:00	0.61	0.00	0.00	0.00	14.73		* 25MVAR.BUS REACTOR-1 AT LEH GIS manually opened on Voltage Reg. (NR-168)
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	LVRD	11-02-2025	20:26:00	11-02-2025	23:31:00	0.13	0.00	0.00	0.00	3.08		* BR hand tripped for voltage regulation. NR2502-4441
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	02-02-2025	09:19:00	03-02-2025	02:37:00	0.72	0.00	0.00	0.00	17.30		* BR hand tripped for voltage regulation.NR2502-471
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	11-02-2025	08:59:00	11-02-2025	17:25:00	0.35	0.00	0.00	0.00	8.43		* BR hand tripped for voltage regulation. NR2502-4132
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	10-02-2025	09:07:00	10-02-2025	20:59:00	0.49	0.00	0.00	0.00	11.87		* BR hand tripped for voltage regulation. NR2502-3764
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	03-02-2025	09:11:00	04-02-2025	03:03:00	0.74	0.00	0.00	0.00	17.87		* BR hand tripped for voltage regulation.NR2502-801
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	12-02-2025	09:17:00	13-02-2025	02:21:00	0.71	0.00	0.00	0.00	17.07		* BR hand tripped for voltage regulation. NR2502-4601
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	13-02-2025	07:01:00	16-02-2025	01:12:00	2.76	0.00	0.00	0.00	66.18		* Line hand tripped for voltage regulation.NR2502-4951* 13.02.2025 07:04:57 INDIA (60016609) Phone 7589275148* BR hand tripped for voltage regulation.NR 2502-4999
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	26-02-2025	09:08:00	27-02-2025	00:56:00	0.66	0.00	0.00	0.00	15.80		* BR hand tripped for voltage regulation.NR2502-10474
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	23-02-2025	22:12:00	26-02-2025	01:03:00	2.12	0.00	0.00	0.00	50.85		* BR hand tripped for voltage regulation. NR2502-9599
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	21-02-2025	09:46:00	22-02-2025	02:11:00	0.68	0.00	0.00	0.00	16.42		* BR hand tripped for voltage regulation. NR2502-8633
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	19-02-2025	08:59:00	20-02-2025	01:05:00	0.67	0.00	0.00	0.00	16.10		* BR hand tripped for voltage regulation. NR2502-7688
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	18-02-2025	08:37:00	19-02-2025	01:18:00	0.70	0.00	0.00	0.00	16.68		* Bus reactor hand tripped for voltage reg.NR2502-7248
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	28-02-2025	10:40:00	28-02-2025	23:59:59	0.56	0.00	0.00	0.00	13.33		* BR hand tripped for voltage regulation. NR2502-11120
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	22-02-2025	09:10:00	23-02-2025	01:09:00	0.67	0.00	0.00	0.00	15.98		* BR hand tripped for voltage regulation. NR2502-9032
BSR	25MVAR.BUS REACTOR-1 AT LEH GIS	SVRD	27-02-2025	09:17:00	27-02-2025	19:07:00	0.41	0.00	0.00	0.00	9.83		* BR hand tripped for voltage regulation. NR2502-10751
							20.52	0.00	0.00	0.00	492.44	100.00	
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	12-02-2025	09:49:00	12-02-2025	15:46:00	0.25	0.00	0.00	0.00	5.95		* BR hand tripped for voltage regulation. NR2502-4636
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	16-02-2025	09:01:00	16-02-2025	16:47:00	0.32	0.00	0.00	0.00	7.77		* SVRD BR hand tripped for voltage regulation. NR2502-6368
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	11-02-2025	09:25:00	11-02-2025	17:27:00	0.34	0.00	0.00	0.00	8.03		* BR hand tripped for voltage regulation. NR2502-4171
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	18-02-2025	09:33:00	18-02-2025	16:19:00	0.28	0.00	0.00	0.00	6.77		* Bus reactor hand tripped for voltage reg.NR2502-7296
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	08-02-2025	10:17:00	08-02-2025	18:12:00	0.33	0.00	0.00	0.00	7.92		* 125MVAR.BUS REACTOR-1 AT PANCHKULA BR manually opened on Voltage Reg. (NR-3048)
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	10-02-2025	09:20:00	10-02-2025	18:27:00	0.38	0.00	0.00	0.00	9.12		* BR hand tripped for voltage regulation. NR2502-3737
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	09-02-2025	09:19:00	09-02-2025	17:15:00	0.33	0.00	0.00	0.00	7.93		* 125MVAR.BUS REACTOR-1 AT PANCHKULA BR manually opened on VR (NR-3421)
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	13-02-2025	09:48:00	13-02-2025	13:49:00	0.17	0.00	0.00	0.00	4.02		* BR hand tripped for voltage regulation. NR2502-5095
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	14-02-2025	09:14:00	14-02-2025	18:23:00	0.38	0.00	0.00	0.00	9.15		* BR hand tripped for voltage regulation. NR2502-5494
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	17-02-2025	09:31:00	17-02-2025	16:49:00	0.30	0.00	0.00	0.00	7.30		* SVRD BR hand tripped for voltage regulation. NR2502-6831
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	15-02-2025	09:26:00	15-02-2025	21:52:00	0.52	0.00	0.00	0.00	12.43		* BR hand tripped for voltage regulation. NR2502-5964
BSR	125MVAR.BUS REACTOR-1 AT PANCHKULA	SVRD	19-02-2025	09:59:00	19-02-2025	17:17:00	0.30	0.00	0.00	0.00	7.30		* Bus reactor hand tripped for voltage reg.NR2502-7764
							3.90	0.00	0.00	0.00	93.69	100.00	
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	16-02-2025	09:58:00	16-02-2025	13:22:00	0.14	0.00	0.00	0.00	3.40		* SVRD BR hand tripped for voltage regulation. NR2502-6446
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	14-02-2025	09:33:00	14-02-2025	16:26:00	0.29	0.00	0.00	0.00	6.88		* SVRD BR hand tripped for voltage regulation. NR2502-5522
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	06-02-2025	09:49:00	06-02-2025	16:43:00	0.29	0.00	0.00	0.00	6.90		* BR hand tripped for voltage regulation. NR2502-2102
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	08-02-2025	09:39:00	08-02-2025	18:16:00	0.36	0.00	0.00	0.00	8.62		* 125MVAR.BUS REACTOR-2 AT PANCHKULA BR manually opened on Voltage Reg. (NR-3025)
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	07-02-2025	09:15:00	07-02-2025	15:39:00	0.27	0.00	0.00	0.00	6.40		* BR hand tripped for voltage regulation. NR2502-2535
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	05-02-2025	11:15:00	05-02-2025	15:56:00	0.20	0.00	0.00	0.00	4.68		* BR hand tripped for voltage regulation. NR2502-1682
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	13-02-2025	09:49:00	13-02-2025	13:50:00	0.17	0.00	0.00	0.00	4.02		* BR hand tripped for voltage regulation. NR2502-5088
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	04-02-2025	11:32:00	04-02-2025	16:09:00	0.19	0.00	0.00	0.00	4.62		* BR hand tripped for voltage regulation. NR2502-1245
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	12-02-2025	09:52:00	12-02-2025	15:45:00	0.25	0.00	0.00	0.00	5.88		* BR hand tripped for voltage regulation. NR2502-4634
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	11-02-2025	09:26:00	11-02-2025	17:33:00	0.34	0.00	0.00	0.00	8.12		* BR hand tripped for voltage regulation. NR2502-4190
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	10-02-2025	09:22:00	10-02-2025	21:29:00	0.51	0.00	0.00	0.00	12.12		* BR hand tripped for voltage regulation. NR2502-3738
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	09-02-2025	09:21:00	09-02-2025	17:12:00	0.33	0.00	0.00	0.00	7.85		* 125MVAR.BUS REACTOR-2 AT PANCHKULA BR manually opened on VR (NR-3422)
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	15-02-2025	09:25:00	15-02-2025	15:22:00	0.25	0.00	0.00	0.00	5.95		* SVRD BR hand tripped for voltage regulation. NR2502-5949
BSR	125MVAR.BUS REACTOR-2 AT PANCHKULA	SVRD	19-02-2025	10:19:00	19-02-2025	17:20:00	0.29	0.00	0.00	0.00	7.02		* Bus reactor hand tripped for voltage reg.NR2502-7794
							3.88	0.00	0.00	0.00	92.46	100.00	
BSR	80MVAR.BUS REACTOR-1 AT SAMBA	SVRD	20-02-2025	10:12:00	20-02-2025	17:20:00	0.30	0.00	0.00	0.00	7.13		* Line hand tripped on voltage regulation. NR2502-8262
BSR	80MVAR.BUS REACTOR-1 AT SAMBA	SVRD	22-02-2025	08:50:00	24-02-2025	18:14:00	2.39	0.00	0.00	0.00	57.40		* BR hand tripped for voltage regulation. NR2502-8999
BSR	80MVAR.BUS REACTOR-1 AT SAMBA	SVRD	26-02-2025	10:10:00	26-02-2025	16:15:00	0						

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE To ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	220kV KISHANGANGA(NHPC)-DELINA(JKPDD)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KISHENPUR-SARNA(PSTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KISHENPUR-SARNA(PSTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-PHYANG KHALTSE CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV PANCHKULA-CHANDIGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV PANCHKULA CHANDIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SALAL(NHPC)-JAMMU(JKPDD)-1	OSPD	16-02-2025	10:45:00	16-02-2025	15:45:00	0.21	0.00	0.00	0.00	5.00		* OSPD Shut down by JKPTCL for safe working/crane movement in their yard. NR2502-6468
							0.21	0.00	0.00	0.00	5.00	100.00	
CKT	220KV-SALAL(NHPC)-JAMMU(JKPDD)-2	SRMU	03-02-2025	02:51:00	03-02-2025	04:57:00	0.09	0.00	2.10	0.00	0.00		* Line Auto-reclosed on R-N fault from Jammu but tripped from Salal(NHPC) due to Auto-reclose Relay maloperation at Salal(NHPC). Bay at Salal(NHPC) is owned and maintained by Salal(NHPC). FLR Jammu: R-N fault , 4.71 kA,FL=8km. FLR Salal : 2.3 kA, FL=55.78 km* 10.02.2025 12:24:42 INDIA (60003416)* Flashover observed on R-Ph insulator string (Top) at 154. Birds excreta was found on the string and weather was cloudy along with dense fog at the time of tripping
CKT	220KV-SALAL(NHPC)-JAMMU(JKPDD)-2	OSPD	16-02-2025	10:45:00	16-02-2025	15:47:00	0.21	0.00	0.00	0.00	5.03		* OSPD Shut down by JKPTCL for safe working/crane movement in their yard. NR2502-6470
							0.30	0.00	2.10	0.00	5.03	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-1	LCSD	24-02-2025	10:38:00	24-02-2025	19:27:00	0.37	0.00	0.00	0.00	8.82		* 220KV-SALAL(NHPC)-KISHENPUR-1 taken under SD for facilitating construction work of "400KV Kishenpur-Kishtwar line"
							0.37	0.00	0.00	0.00	8.82	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-2	OSPD	12-02-2025	10:42:00	12-02-2025	17:02:00	0.26	0.00	0.00	0.00	6.33		* Quarterly Maintenance Repairing of conductor at Salal Powerhouse Bus-2 NR2502-4583
CKT	220KV-SALAL(NHPC)-KISHENPUR-2	LCSD	24-02-2025	10:39:00	24-02-2025	19:28:00	0.37	0.00	0.00	0.00	8.82		* 220KV-SALAL(NHPC)-KISHENPUR-2 taken under SD for facilitating construction work of "400KV Kishenpur-Kishtwar line"
							0.63	0.00	0.00	0.00	15.15	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-4	LART	27-02-2025	13:15:00	27-02-2025	13:15:00	0.00	0.00	0.00	0.00	0.00		* Line sucessfully auto-reclosed on R-N fault. FLR Kishenpur: Ir=3.64kA, 40.86kM; Salal: Ir=4.13kA, FL=15.70kM* 04.03.2025 17:02:30 INDIA (60003416)* Flashover sound observed near tower location 35 due to lightning and thunderstrom* 05.03.2025 14:31:52 INDIA (60003416)* Flashover on insulator at tower location 44 due to lightning and thunderstrom
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SARNA(PSTCL)-DASUYA(PSTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SARNA(PSTCL)-DASUYA(PSTCL)-2	OSPT	07-02-2025	12:03:00	07-02-2025	16:30:00	0.19	4.45	0.00	0.00	0.00		* SD taken by Amritsar SS for AMP works of bay <(>&<)> Line equipments. NR2502-2604
							0.19	4.45	0.00	0.00	0.00	99.34	
CKT	220kV SARNA(PSTCL)-HIRANAGAR(JKPDD)	OSFT	06-02-2025	14:52:00	06-02-2025	16:36:00	0.07	1.73	0.00	0.00	0.00		* 220kV SARNA(PSTCL)-HIRANAGAR(JKPDD) taken under emeregency shutdown for rectification of hotspot at Sarna end (NR-2170)
							0.07	1.73	0.00	0.00	0.00	99.74	
CKT	220kV UDHAMPUR(JKPDD)-KISHENPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV UDHAMPUR(JKPDD)-KISHENPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-WAGOORA-KISHENGANGA(NHPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-WAGOORA-KISHENGANGA(NHPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV WAGOORA-PAMPORE(JKPDD)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV WAGOORA-PAMPORE(JKPDD)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ABDULLAPUR-BAWANA(DTL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	OSPT	15-02-2025	09:13:00	15-02-2025	19:36:00	0.43	10.38	0.00	0.00	0.00		* SD taken for AMP works and rectification of SD nature defects. NR2502-5899
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	28-02-2025	00:02:00	28-02-2025	07:47:00	0.32	0.00	0.00	0.00	7.75		* Line hand tripped for voltage regulation.NR2502-10977
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	25-02-2025	01:27:00	25-02-2025	05:43:00	0.18	0.00	0.00	0.00	4.27		* LVRD Line hand tripped on voltage regulation. NR2502-10061
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	23-02-2025	17:49:00	24-02-2025	07:24:00	0.57	0.00	0.00	0.00	13.58		* SVRD BR hand tripped for voltage regulation. NR2502-9546
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	20-02-2025	22:09:00	21-02-2025	05:54:00	0.32	0.00	0.00	0.00	7.75		* 400kV ABDULLAPUR-DEPALPUR(HVPNL) Line manually opened on voltage reg. (NR-8465)
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	25-02-2025	21:54:00	26-02-2025	05:47:00	0.33	0.00	0.00	0.00	7.88		* Line hand tripped on voltage regulation. NR2502-10385
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	20-02-2025	02:07:00	20-02-2025	05:48:00	0.15	0.00	0.00	0.00	3.68		* LVRD Line hand tripped on voltage regulation. NR2502-8089
							2.30	10.38	0.00	0.00	44.91	98.45	
CKT	400kV ABDULLAPUR-KURUKSHETRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ABDULLAPUR-KURUKSHETRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	16-02-2025	20:34:00	17-02-2025	05:35:00	0.38	0.00	0.00	0.00	9.02		* Line hand tripped on voltage regulation. NR2502-6657
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	28-02-2025	21:37:00	28-02-2025	23:59:59	0.10	0.00	0.00	0.00	2.38		* Line hand tripped for voltage regulation.NR2502-11286
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	24-02-2025	23:47:00	25-02-2025	06:44:00	0.29	0.00	0.00	0.00	6.95		* LVRD Line hand tripped on voltage regulation. NR2502-10053
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	26-02-2025	20:55:00	27-02-2025	06:18:00	0.39	0.00	0.00	0.00	9.38		* Line hand tripped on voltage regulation. NR2502-10654
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	27-02-2025	21:02:00	28-02-2025	08:39:00	0.48	0.00	0.00	0.00	11.62		* Line hand tripped on voltage regulation. NR2502-10950
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	19-02-2025	01:22:00	19-02-2025	06:30:00	0.21	0.00	0.00	0.00	5.13		* LVRD Line hand tripped on voltage regulation. NR2502-7610
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	20-02-2025	00:27:00	20-02-2025	06:54:00	0.27	0.00	0.00	0.00	6.45		* LVRD Line hand tripped on voltage regulation. NR2502-8081
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	14-02-2025	23:14:00	15-02-2025	07:21:00	0.34	0.00	0.00	0.00	8.12		* Line hand tripped on voltage regulation. NR2502-5784
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	01-02-2025	20:47:00	02-02-2025	06:41:00	0.41	0.00	0.00	0.00	9.90		* Line hand tripped for voltage regulation.NR2502-347
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	04-02-2025	21:26:00	05-02-2025	05:59:00	0.36	0.00	0.00	0.00	8.55		* Line hand tripped for voltage regulation.NR2502-1445
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	10-02-2025	01:06:00	10-02-2025	05:14:00	0.17	0.00	0.00	0.00	4.13		* LVRD Line hand tripped on voltage regulation. NR2502-3639
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	11-02-2025	23:23:00	12-02-2025	06:00:00	0.28	0.00	0.00	0.00	6.62		* LVRD Line hand tripped on voltage regulation. NR2502-4477
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	02-02-2025	21:45:00	03-02-2025	06:02:00	0.35	0.00	0.00	0.00	8.28		* Line hand tripped on voltage regulation. NR2502-673
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	07-02-2025	23:01:00	08-02-2025	05:40:00	0.28	0.00	0.00	0.00	6.65		* Line hand tripped on voltage regulation. NR2502-2851

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	10-02-2025	22:00:00	11-02-2025	06:15:00	0.34	0.00	0.00	0.00	8.25		* 400kV AMRITSAR-JALANDHAR-1 Line manually opened on voltage reg. (NR-4033)
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	15-02-2025	22:07:00	16-02-2025	06:54:00	0.37	0.00	0.00	0.00	8.78		* Line hand tripped on voltage regulation. NR2502-6255
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	03-02-2025	21:33:00	04-02-2025	06:26:00	0.37	0.00	0.00	0.00	8.88		* 400kV AMRITSAR-JALANDHAR-1 Line manually opened on voltage reg. (NR-1024)
							5.39	0.00	0.00	0.00	129.09	100.00	
CKT	400kV AMRITSAR-JALANDHAR-2	LART	27-02-2025	20:27:00	27-02-2025	20:27:00	0.00	0.00	0.00	0.00	0.00		* Line successfully auto-reclosed on R-N fault.FLR Amritsar ; Fi=73.04 km= 6.03 km, FLR Jalandhar: 4.894 km.23.517.* 04.03.2025 17:25:50 INDIA (60003416)* Flashover observed on R-Ph pilot corona ring and crossarm members at tloc 32 due to jumper swing caused by inclement weather at the time of tripping
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANALA-AMRITSAR-1	LVRD	19-02-2025	20:43:00	20-02-2025	07:01:00	0.43	0.00	0.00	0.00	10.30		* Line hand tripped on voltage regulation. NR2502-8057
CKT	400kV BANALA-AMRITSAR-1	LVRD	17-02-2025	23:34:00	18-02-2025	05:05:00	0.23	0.00	0.00	0.00	5.52		* Line hand tripped on voltage regulation. NR2502-7181
CKT	400kV BANALA-AMRITSAR-1	LVRD	02-02-2025	23:41:00	03-02-2025	05:54:00	0.26	0.00	0.00	0.00	6.22		* Line hand tripped on voltage regulation. NR2502-682
CKT	400kV BANALA-AMRITSAR-1	LVRD	15-02-2025	22:12:00	16-02-2025	06:49:00	0.36	0.00	0.00	0.00	8.62		* Line hand tripped on voltage regulation. NR2502-6256
CKT	400kV BANALA-AMRITSAR-1	LVRD	09-02-2025	22:35:00	10-02-2025	05:11:00	0.28	0.00	0.00	0.00	6.60		* LVRD Line hand tripped on voltage regulation. NR2502-3636
CKT	400kV BANALA-AMRITSAR-1	LVRD	02-02-2025	00:09:00	02-02-2025	05:45:00	0.23	0.00	0.00	0.00	5.60		* Line hand tripped on voltage regulation. NR2502-378
CKT	400kV BANALA-AMRITSAR-1	LVRD	16-02-2025	23:45:00	17-02-2025	05:16:00	0.23	0.00	0.00	0.00	5.52		* Line hand tripped on voltage regulation. NR2502-6698
CKT	400kV BANALA-AMRITSAR-1	LVRD	14-02-2025	23:12:00	15-02-2025	05:59:00	0.28	0.00	0.00	0.00	6.78		* Line hand tripped on voltage regulation. NR2502-5785
CKT	400kV BANALA-AMRITSAR-1	LVRD	28-02-2025	21:40:00	28-02-2025	23:59:59	0.10	0.00	0.00	0.00	2.33		* Line hand tripped for voltage regulation.NR2502-11301
CKT	400kV BANALA-AMRITSAR-1	LVRD	24-02-2025	23:42:00	25-02-2025	05:36:00	0.25	0.00	0.00	0.00	5.90		* LVRD Line hand tripped on voltage regulation. NR2502-10050
CKT	400kV BANALA-AMRITSAR-1	LVRD	26-02-2025	20:48:00	27-02-2025	06:14:00	0.39	0.00	0.00	0.00	9.43		* Line hand tripped on voltage regulation. NR2502-10656
CKT	400kV BANALA-AMRITSAR-1	LVRD	20-02-2025	20:55:00	21-02-2025	05:58:00	0.38	0.00	0.00	0.00	9.05		* 400kV BANALA-AMRITSAR-1 Line manually opened on voltage reg. (NR-8437)
CKT	400kV BANALA-AMRITSAR-1	LVRD	27-02-2025	21:00:00	28-02-2025	07:51:00	0.45	0.00	0.00	0.00	10.85		* Line hand tripped on voltage regulation. NR2502-10951
CKT	400kV BANALA-AMRITSAR-1	LVRD	23-02-2025	21:27:00	24-02-2025	06:14:00	0.37	0.00	0.00	0.00	8.78		* Line hand tripped on voltage regulation. NR2502-9593
CKT	400kV BANALA-AMRITSAR-1	LVRD	26-02-2025	01:31:00	26-02-2025	05:40:00	0.17	0.00	0.00	0.00	4.15		* LVRD Line hand tripped on voltage regulation. NR2502-10398
CKT	400kV BANALA-AMRITSAR-1	LVRD	19-02-2025	01:19:00	19-02-2025	06:44:00	0.23	0.00	0.00	0.00	5.42		* LVRD Line hand tripped on voltage regulation. NR2502-7612
CKT	400kV BANALA-AMRITSAR-1	LVRD	10-02-2025	21:58:00	11-02-2025	06:12:00	0.34	0.00	0.00	0.00	8.23		* 400kV BANALA-AMRITSAR-1 Line manually opened on voltage reg. (NR-4034)
CKT	400kV BANALA-AMRITSAR-1	LVRD	11-02-2025	23:22:00	12-02-2025	06:08:00	0.28	0.00	0.00	0.00	6.77		* LVRD Line hand tripped on voltage regulation. NR2502-4475
CKT	400kV BANALA-AMRITSAR-1	LVRD	01-02-2025	00:59:00	01-02-2025	06:19:00	0.22	0.00	0.00	0.00	5.33		* LVRD Line hand tripped on voltage regulation. NR2502-5
CKT	400kV BANALA-AMRITSAR-1	LVRD	08-02-2025	23:34:00	09-02-2025	05:18:00	0.24	0.00	0.00	0.00	5.73		* LVRD Line hand tripped on voltage regulation. NR2502-3310
							5.72	0.00	0.00	0.00	137.13	100.00	
CKT	400kV BANALA-HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANALA-KOLDAM(NTPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NALAGARH-BANALA	LVRD	27-02-2025	20:08:00	28-02-2025	07:41:00	0.48	0.00	0.00	0.00	11.55		* Line hand tripped on voltage regulation. NR2502-10933
CKT	400kV NALAGARH-BANALA	LVRD	20-02-2025	02:03:00	20-02-2025	06:48:00	0.20	0.00	0.00	0.00	4.75		* LVRD Line hand tripped on voltage regulation. NR2502-8096
CKT	400kV NALAGARH-BANALA	LVRD	28-02-2025	21:45:00	28-02-2025	23:59:59	0.09	0.00	0.00	0.00	2.25		* Line hand tripped for voltage regulation.NR2502-11298
CKT	400kV NALAGARH-BANALA	LVRD	24-02-2025	23:44:00	25-02-2025	05:33:00	0.24	0.00	0.00	0.00	5.82		* LVRD Line hand tripped on voltage regulation. NR2502-10052
CKT	400kV NALAGARH-BANALA	OSFT	28-02-2025	07:42:00	28-02-2025	16:28:00	0.37	8.77	0.00	0.00	0.00		* Line taken under emergency shutdown to attend operating mechanism issue in Y Ph (405CB) at Banala end NR2502-11107
CKT	400kV NALAGARH-BANALA	LVRD	26-02-2025	20:49:00	27-02-2025	07:22:00	0.44	0.00	0.00	0.00	10.55		* Line hand tripped on voltage regulation. NR2502-10657
							1.82	8.77	0.00	0.00	34.92	98.70	
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	26-02-2025	20:55:00	27-02-2025	06:44:00	0.41	0.00	0.00	0.00	9.82		* Line hand tripped on voltage regulation. NR2502-10648
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	27-02-2025	20:36:00	28-02-2025	08:20:00	0.49	0.00	0.00	0.00	11.73		* Line hand tripped on voltage regulation. NR2502-10925
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	24-02-2025	20:22:00	25-02-2025	05:43:00	0.39	0.00	0.00	0.00	9.35		* Line hand tripped for voltage regulation.NR2502-10022
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	10-02-2025	01:10:00	10-02-2025	05:30:00	0.18	0.00	0.00	0.00	4.33		* LVRD Line hand tripped on voltage regulation. NR2502-3637
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	16-02-2025	21:32:00	17-02-2025	05:53:00	0.35	0.00	0.00	0.00	8.35		* Line hand tripped on voltage regulation. NR2502-6680
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	14-02-2025	23:15:00	15-02-2025	05:54:00	0.28	0.00	0.00	0.00	6.65		* Line hand tripped on voltage regulation. NR2502-5783
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	15-02-2025	22:07:00	16-02-2025	05:54:00	0.32	0.00	0.00	0.00	7.78		* Line hand tripped on voltage regulation. NR2502-6254
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	03-02-2025	21:24:00	04-02-2025	06:38:00	0.39	0.00	0.00	0.00	9.23		* 400kV BHIWANI(BBMB)-RAJPURA(PSTCL) Line manually opened on voltage reg. (NR-1015)
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	06-02-2025	21:35:00	07-02-2025	06:30:00	0.37	0.00	0.00	0.00	8.92		* Line hand tripped on voltage regulation. NR2502-2364
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	05-02-2025	21:44:00	06-02-2025	07:09:00	0.39	0.00	0.00	0.00	9.42		* Line hand tripped for voltage regulation.NR2502-1896
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	13-02-2025	01:46:00	13-02-2025	06:51:00	0.21	0.00	0.00	0.00	5.08		* Line hand tripped for voltage regulation.NR2502-4947
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	11-02-2025	23:48:00	12-02-2025	06:32:00	0.28	0.00	0.00	0.00	6.73		* LVRD Line hand tripped on voltage regulation. NR2502-4488
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	13-02-2025	22:50:00	14-02-2025	06:35:00	0.32	0.00	0.00	0.00	7.75		* Line hand tripped for voltage regulation.NR2502-5362
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	07-02-2025	23:08:00	08-02-2025	05:42:00	0.27	0.00	0.00	0.00	6.57		* Line hand tripped on voltage regulation. NR2502-2853
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	01-02-2025	00:00:01	01-02-2025	07:08:00	0.30	0.00	0.00	0.00	7.13		* LVRD Line hand tripped on voltage regulation. NR2501-12768
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	02-02-2025	21:40:00	03-02-2025	06:02:00	0.35	0.00	0.00	0.00	8.37		* Line hand tripped on voltage regulation. NR2502-671
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	04-02-2025	21:30:00	05-02-2025	06:02:00	0.36	0.00	0.00	0.00	8.53		* Line hand tripped for voltage regulation.NR2502-1439
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	01-02-2025	23:42:00	02-02-2025	06:52:00	0.30	0.00	0.00	0.00	7.17		* Line hand tripped on voltage regulation. NR2502-368
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	08-02-2025	21:45:00	09-02-2025	05:50:00	0.34	0.00	0.00	0.00	8.08		* LVRD Line hand tripped on voltage regulation. NR2502-3294.
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	17-02-2025	22:29:00	18-02-2025	06:15:00	0.32	0.00	0.00	0.00	7.77		* Line hand tripped on voltage regulation. NR2502-7175
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	18-02-2025	21:20:00	19-02-2025	06:33:00	0.38	0.00	0.00	0.00	9.22		* LVRD Line hand tripped on voltage regulation. NR2502-7591
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	19-02-2025	21:48:00	20-02-2025	07:12:00	0.39	0.00	0.00	0.00	9.40		* LVRD Line hand tripped on voltage regulation. NR2502-8066
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	21-02-2025	21:46:00	22-02-2025	06:34:00	0.37	0.00	0.00	0.00	8.80		* 400kV BHIWANI(BBMB)-RAJPURA(PSTCL) Line manually opened on voltage reg.(NR-8892)
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	25-02-2025	21:19:00	26-02-2025	07:05:00	0.41	0.00	0.00	0.00	9.77		* Line hand tripped on voltage regulation. NR2502-10373
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	28-02-2025	20:09:00	28-02-2025	23:59:59	0.16	0.00	0.00	0.00	3.85		* Line hand tripped on voltage regulation. NR2502-11263
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	22-02-2025	21:24:00	23-02-2025	06:40:00	0.39	0.00	0.00	0.00	9.27		* Line hand tripped on voltage regulation. NR2502-9273
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	23-02-2025	18:00:00	24-02-2025	06:33:00	0.52	0.00	0.00	0.00	12.55		* SVRD BR hand tripped for voltage regulation. NR2502-9550
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	20-02-2025	21:02:00	21-02-2025	06:56:00	0.41	0.00	0.00	0.00	9.90		* 400kV BHIWANI(BBMB)-RAJPURA(PSTCL) Line manually opened on voltage reg. (NR-8445)
							9.65	0.00	0.00	0.00	231.52	100.00	
CKT	400kV CHAMBA-JALLANDHAR-1	LVRD	16-02-2025	20:49:00	17-02-2025	05:38:00	0.37	0.00	0.00	0.00	8.82		* Line hand tripped on voltage regulation. NR2502-6671
CKT	400kV CHAMBA-JALLANDHAR-1	LVRD	27-02-2025	22:59:00	28-02-2025	23:59:59	1.04	0.00	0.00	0.00	25.02		* Line hand tripped for voltage regulation.NR2502-10969
CKT	400kV CHAMBA-JALLANDHAR-1	LVRD	20-02-2025	21:01:00	22-02-2025	09:01:00	1.50	0.00	0.00	0.00	36.00		* 400kV CHAMBA-JALLANDHAR-1 Line manually opened on voltage reg. (NR-8439)
CKT	400kV CHAMBA-JALLANDHAR-1	LVRD	17-02-2025	21:15:00	18-02-2025	05:08:00	0.33	0.00	0.00	0.00	7.88		* Line hand tripped on voltage regulation. NR2502-7153
CKT	400kV CHAMBA-JALLANDHAR-1	LVRD	23-02-2025	20:57:00	24-02-2025	06:20:00	0.39	0.00	0.00	0.00	9.38		* LVRD Line hand tripped on voltage regulation. NR2502-9581
							3.63	0.00	0.00	0.00	87.10	100.00	

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE To ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV CHAMBA-JALLANDHAR-2	LART	28-02-2025	20:48:00	28-02-2025	20:48:00	0.00	0.00	0.00	0.00	0.00		* Line successfully Auto Reclosed on B-N fault. FLR Jalandhar: 144.547km, 3.448 kA <(>&<)> Chamba: 14.659km, 8.416 kA* 04.03.2025 17:35:14 INDIA (60003416)* Flashover on arcing horn of pilot insulator of B Ph and R-Ph at tower no. 39 due to lightning and thunderstrom
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHAMERA1(NHPC)-JALLANDHAR-1	SRMU	08-02-2025	17:48:00	08-02-2025	19:36:00	0.08	0.00	1.80	0.00	0.00		* Line tripped due to DT received at Jalandhar (PG) caused by maloperation of vibration sensor of Line Reactor at Chamera 1 NHPC end.Bay at Chamera1 NHPC is owned and maintained by NHPC. NR2502-3248
CKT	400kV CHAMERA1(NHPC)-JALLANDHAR-1	SRMU	07-02-2025	16:20:00	07-02-2025	18:19:00	0.08	0.00	1.98	0.00	0.00		* 400KV CHAMERA1(NHPC)-JALLANDHAR-1 line tripped from Chamera1 end due relay mal operation at Chamera1 end (NR-2764)* 08.02.2025 15:06:18 INDIA (60003416)* Maloperation of Auxiliary Relay of Line Reactor low oil level trip at Chamera1
							0.16	0.00	3.78	0.00	0.00	100.00	
CKT	400kV CHAMERA1(NHPC)-JALLANDHAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHAMERA2(NHPC)-CHAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHAMERA1(NHPC)-CHAMERA2(NHPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHAMERA2(NHPC)-KISHENPUR	OSPT	04-02-2025	13:04:00	04-02-2025	17:49:00	0.20	4.75	0.00	0.00	0.00		* Shutdown taken for Replacement of damaged insulators at Loc No. 271 and at Loc No. 249 rectification of shutdown nature defects NR2502-1260** By Banikhet TL
							0.20	4.75	0.00	0.00	0.00	99.29	
CKT	400kV DEHAR(BMB)-RAJPURA(PSTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DEPALPUR(HVPNL)-BAWANA(DTL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JALLANDHAR-DHANANSU (PSTCL) Line			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DULHASTI(NHPC)-KISHENPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DULHASTI(NHPC)-KISHENPUR-2	LCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SD taken for stringing of 2nd circuit being executed for evacuation of Power from Pakal Dul HEP in Chenab Valley HEPs. NR2410-3730
CKT	400kV DULHASTI(NHPC)-KISHENPUR-2	LCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* To carryout stringing on circuit 2
							56.00	0.00	0.00	0.00	1,344.00	100.00	
CKT	400kV JALANDHAR-HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JALANDHAR-LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JALLANDHAR-MOGA-1	LVRD	17-02-2025	02:07:00	17-02-2025	05:44:00	0.15	0.00	0.00	0.00	3.62		* LVRD Line hand tripped on voltage regulation. NR2502-6703
CKT	400kV JALLANDHAR-MOGA-1	LVRD	28-02-2025	00:10:00	28-02-2025	08:26:00	0.34	0.00	0.00	0.00	8.27		* Line hand tripped for voltage regulation.NR2502-10976
CKT	400kV JALLANDHAR-MOGA-1	LVRD	21-02-2025	00:26:00	21-02-2025	06:53:00	0.27	0.00	0.00	0.00	6.45		* 400KV JALLANDHAR-MOGA-1 Line manually opened on voltage reg. (NR-8482)
							0.76	0.00	0.00	0.00	18.34	100.00	
CKT	400kV JALLANDHAR-MOGA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-BAGPAT-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-BAGPAT-2	LVRD	28-02-2025	00:33:00	28-02-2025	07:49:00	0.30	0.00	0.00	0.00	7.27		* Line hand tripped for voltage regulation.NR2502-10982
							0.30	0.00	0.00	0.00	7.27	100.00	
CKT	400kV KAITHAL-DADR(NTPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-MALERKOTLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-PATRAN(TECHNO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-PATRAN(TECHNO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-BAGLIHAR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-SAMBA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-SAMBA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-NEW WANPOH-1	LART	26-02-2025	10:49:00	26-02-2025	10:49:00	0.00	0.00	0.00	0.00	0.00		* Line successfully auto-reclosed on R-N fault. FLR Kishenpur: Ir=3.82kA, 112.5KM; New Wanpo: Ir=6.7kA, 17.5km* 04.03.2025 16:47:10 INDIA (60003416)* Flashover on conductor in the span L21-L22 due to lightning in the Pirpanjal Area
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-NEW WANPOH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-NEW WANPOH-4	LART	27-02-2025	04:58:00	27-02-2025	04:58:00	0.00	0.00	0.00	0.00	0.00		* Line autoreclosed from both ends on B-N fault. FLR Kishenpur: FL= 117.863KM, Ib=3.956KA, FLR Newwanpo: FL=19.96KM, Ib=6.930KA* 04.03.2025 16:52:28 INDIA (60003416)* Galloping of OPGW in the span 320-321 may be the cause of fault
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLDAM(NTPC)-NALAGARH-1	OSPT	01-02-2025	09:37:00	01-02-2025	17:59:00	0.35	8.37	0.00	0.00	0.00		* 400KV KOLDAM(NTPC)-NALAGARH-1 taken under SD by Nalagarh TLM for rectification of SD nature defects (NR-124)
							0.35	8.37	0.00	0.00	0.00	98.75	
CKT	400kV KURUKSHETRA-DHANANSU (PSTCL) LINE	OSFT	18-02-2025	13:53:00	18-02-2025	18:02:00	0.17	4.15	0.00	0.00	0.00		* Line taken under shutdown by NR-1 to attend hotspot on Y-Ph wavetrap at Kurukshetra NR2502-7401
							0.17	4.15	0.00	0.00	0.00	99.38	
CKT	400kV KURUKSHETRA-JIND-1	LVRD	18-02-2025	21:21:00	19-02-2025	06:36:00	0.39	0.00	0.00	0.00	9.25		* LVRD Line hand tripped on voltage regulation. NR2502-7592
CKT	400kV KURUKSHETRA-JIND-1	LVRD	28-02-2025	21:21:00	28-02-2025	23:59:59	0.11	0.00	0.00	0.00	2.65		* Line hand tripped for voltage regulation.NR2502-11277
CKT	400kV KURUKSHETRA-JIND-1	LVRD	24-02-2025	21:41:00	25-02-2025	05:40:00	0.33	0.00	0.00	0.00	7.98		* LVRD Line hand tripped on voltage regulation. NR2502-10034
CKT	400kV KURUKSHETRA-JIND-1	LVRD	26-02-2025	20:49:00	27-02-2025	06:32:00	0.41	0.00	0.00	0.00	9.72		* Line hand tripped on voltage regulation. NR2502-10659
CKT	400kV KURUKSHETRA-JIND-1	LVRD	14-02-2025	21:28:00	15-02-2025	07:26:00	0.42	0.00	0.00	0.00	9.97		* Line hand tripped on voltage regulation. NR2502-5763
CKT	400kV KURUKSHETRA-JIND-1	LVRD	15-02-2025	22:21:00	16-02-2025	06:59:00	0.36	0.00	0.00	0.00	8.63		* Line hand tripped on voltage regulation. NR2502-6270
CKT	400kV KURUKSHETRA-JIND-1	LVRD	02-02-2025	21:21:00	03-02-2025	06:16:00	0.37	0.00	0.00	0.00	8.92		* Line hand tripped on voltage regulation. NR2502-668
CKT	400kV KURUKSHETRA-JIND-1	LVRD	05-02-2025	21:20:00	06-02-2025	07:13:00	0.41	0.00	0.00	0.00	9.88		* Line hand tripped for voltage regulation
CKT	400kV KURUKSHETRA-JIND-1	LVRD	11-02-2025	23:35:00	12-02-2025	05:38:00	0.25	0.00	0.00	0.00	6.05		* LVRD Line hand tripped on voltage regulation. NR2502-4479

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE To ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV KURUKSHETRA-JIND-1	LVRD	01-02-2025	21:08:00	02-02-2025	06:59:00	0.41	0.00	0.00	0.00	9.85		* LVRD Line hand tripped on voltage regulation. NR2502-354
CKT	400kV KURUKSHETRA-JIND-1	LVRD	10-02-2025	22:30:00	11-02-2025	06:11:00	0.32	0.00	0.00	0.00	7.68		* 400kV KURUKSHETRA-JIND-1 Line manually opened on voltage reg. (NR-4032)
CKT	400kV KURUKSHETRA-JIND-1	LVRD	06-02-2025	21:43:00	07-02-2025	06:43:00	0.38	0.00	0.00	0.00	9.00		* Line hand tripped on voltage regulation. NR2502-2368
CKT	400kV KURUKSHETRA-JIND-1	LVRD	04-02-2025	21:43:00	05-02-2025	05:45:00	0.34	0.00	0.00	0.00	8.03		* Line hand tripped for voltage regulation.NR2402-1433
CKT	400kV KURUKSHETRA-JIND-1	LVRD	03-02-2025	21:47:00	04-02-2025	06:58:00	0.38	0.00	0.00	0.00	9.18		* 400kV KURUKSHETRA-JIND-1 Line manually opened on voltage reg. (NR-1016)
CKT	400kV KURUKSHETRA-JIND-1	LVRD	07-02-2025	21:33:00	08-02-2025	05:29:00	0.33	0.00	0.00	0.00	7.93		* Line hand tripped on voltage regulation. NR2502-2819
							5.21	0.00	0.00	0.00	124.72	100.00	
CKT	400kV KURUKSHETRA-JIND-2	LVRD	22-02-2025	21:28:00	23-02-2025	07:03:00	0.40	0.00	0.00	0.00	9.58		* Line hand tripped on voltage regulation. NR2502-9279
CKT	400kV KURUKSHETRA-JIND-2	LVRD	19-02-2025	21:35:00	20-02-2025	06:59:00	0.39	0.00	0.00	0.00	9.40		* LVRD Line hand tripped on voltage regulation. NR2502-8054
CKT	400kV KURUKSHETRA-JIND-2	LVRD	25-02-2025	21:28:00	26-02-2025	07:16:00	0.41	0.00	0.00	0.00	9.80		* Line hand tripped on voltage regulation. NR2502-10367
CKT	400kV KURUKSHETRA-JIND-2	LVRD	27-02-2025	21:26:00	28-02-2025	07:56:00	0.44	0.00	0.00	0.00	10.50		* Line hand tripped on voltage regulation. NR2502-10948
CKT	400kV KURUKSHETRA-JIND-2	LVRD	23-02-2025	21:17:00	24-02-2025	06:20:00	0.38	0.00	0.00	0.00	9.05		* Line hand tripped on voltage regulation. NR2502-9583
CKT	400kV KURUKSHETRA-JIND-2	LVRD	20-02-2025	22:16:00	21-02-2025	06:52:00	0.36	0.00	0.00	0.00	8.60		* 400kV KURUKSHETRA-JIND-2 Line manually opened on voltage reg. (NR-8443)
CKT	400kV KURUKSHETRA-JIND-2	LVRD	21-02-2025	22:16:00	22-02-2025	05:47:00	0.31	0.00	0.00	0.00	7.52		* 400kV KURUKSHETRA-JIND-2 Line manually opened on voltage reg. (NR-8897)
CKT	400kV KURUKSHETRA-JIND-2	LVRD	16-02-2025	21:00:00	17-02-2025	05:21:00	0.35	0.00	0.00	0.00	8.35		* Line hand tripped on voltage regulation. NR2502-6655
CKT	400kV KURUKSHETRA-JIND-2	LVRD	13-02-2025	01:42:00	13-02-2025	06:47:00	0.21	0.00	0.00	0.00	5.08		* Line hand tripped for voltage regulation.NR2502-4951
							3.25	0.00	0.00	0.00	77.88	100.00	
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	11-02-2025	23:58:00	12-02-2025	06:34:00	0.28	0.00	0.00	0.00	6.60		* LVRD Line hand tripped on voltage regulation. NR2502-4480
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	18-02-2025	00:47:00	18-02-2025	06:09:00	0.22	0.00	0.00	0.00	5.37		* LVRD Line hand tripped on voltage regulation. NR2502-7186
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	07-02-2025	21:05:00	08-02-2025	05:33:00	0.35	0.00	0.00	0.00	8.47		* Line hand tripped on voltage regulation. NR2502-2820
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	09-02-2025	00:46:00	09-02-2025	05:40:00	0.20	0.00	0.00	0.00	4.90		* LVRD Line hand tripped on voltage regulation. NR2502-3314
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	OMSU	04-02-2025	16:11:00	04-02-2025	17:54:00	0.07	0.00	1.72	0.00	0.00		* Emergency SD taken by Patiala TLM for removing of kite thread from conductor and earth wire at Loc No-267 NR2502-1351
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	10-02-2025	22:06:00	11-02-2025	06:17:00	0.34	0.00	0.00	0.00	8.18		* 400kV KURUKSHETRA-NAKODAR(PSTCL) Line manually opened on voltage reg. (NR-4031)
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	13-02-2025	22:52:00	14-02-2025	07:00:00	0.34	0.00	0.00	0.00	8.13		* Line hand tripped for voltage regulation.NR2502-5357
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	01-02-2025	00:00:01	01-02-2025	07:04:00	0.29	0.00	0.00	0.00	7.07		* LVRD Line hand tripped on voltage regulation. NR2501-12778
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	02-02-2025	21:06:00	03-02-2025	07:02:00	0.41	0.00	0.00	0.00	9.93		* Line hand tripped on voltage regulation. NR2502-665
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	01-02-2025	23:41:00	02-02-2025	07:24:00	0.32	0.00	0.00	0.00	7.72		* Line hand tripped on voltage regulation. NR2502-369
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	06-02-2025	23:13:00	07-02-2025	06:43:00	0.31	0.00	0.00	0.00	7.50		* Line hand tripped on voltage regulation. NR2502-2384
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	03-02-2025	22:28:00	04-02-2025	06:35:00	0.34	0.00	0.00	0.00	8.12		* 400kV KURUKSHETRA-NAKODAR(PSTCL) Line manually opened on voltage reg. (NR-1041)
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	05-02-2025	21:18:00	06-02-2025	07:09:00	0.41	0.00	0.00	0.00	9.85		* Line hand tripped for voltage regulation.NR2502-1886
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	15-02-2025	22:08:00	16-02-2025	05:51:00	0.32	0.00	0.00	0.00	7.72		* Line hand tripped on voltage regulation. NR2502-6257
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	14-02-2025	23:04:00	15-02-2025	05:48:00	0.28	0.00	0.00	0.00	6.73		* Line hand tripped on voltage regulation. NR2502-5764
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	04-02-2025	21:45:00	05-02-2025	05:54:00	0.34	0.00	0.00	0.00	8.15		* Line hand tripped for voltage regulation.NR2502-1461
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	16-02-2025	21:32:00	17-02-2025	05:44:00	0.34	0.00	0.00	0.00	8.20		* Line hand tripped on voltage regulation. NR2502-6682
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	10-02-2025	01:08:00	10-02-2025	05:45:00	0.19	0.00	0.00	0.00	4.62		* LVRD Line hand tripped on voltage regulation. NR2502-3638
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	28-02-2025	21:08:00	28-02-2025	23:59:59	0.12	0.00	0.00	0.00	2.87		* Line hand tripped for voltage regulation.NR2502-11278
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	24-02-2025	21:36:00	25-02-2025	06:58:00	0.39	0.00	0.00	0.00	9.37		* LVRD Line hand tripped on voltage regulation. NR2502-10033
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	26-02-2025	20:52:00	27-02-2025	08:13:00	0.47	0.00	0.00	0.00	11.35		* Line hand tripped on voltage regulation. NR2502-10661
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	21-02-2025	00:18:00	21-02-2025	07:05:00	0.28	0.00	0.00	0.00	6.78		* 400kV KURUKSHETRA-NAKODAR(PSTCL) Line manually opened on voltage reg. (NR-8479)
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	25-02-2025	21:20:00	26-02-2025	07:05:00	0.41	0.00	0.00	0.00	9.75		* Line hand tripped on voltage regulation. NR2502-10369
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	23-02-2025	17:57:00	24-02-2025	07:10:00	0.55	0.00	0.00	0.00	13.22		* SVRD BR hand tripped for voltage regulation. NR2502-9549
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	22-02-2025	20:46:00	23-02-2025	06:33:00	0.41	0.00	0.00	0.00	9.78		* LVRD Line hand tripped on voltage regulation. NR2502-9267
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	19-02-2025	21:27:00	20-02-2025	07:05:00	0.40	0.00	0.00	0.00	9.63		* LVRD Line hand tripped on voltage regulation. NR2502-8056
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	18-02-2025	21:16:00	19-02-2025	06:38:00	0.39	0.00	0.00	0.00	9.37		* LVRD Line hand tripped on voltage regulation. NR2502-7597
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	19-02-2025	21:27:00	20-02-2025	07:05:00	0.40	0.00	0.00	0.00	9.63		* LVRD Line hand tripped on voltage regulation. NR2502-8056
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	27-02-2025	20:21:00	28-02-2025	08:07:00	0.49	0.00	0.00	0.00	11.77		* Line hand tripped on voltage regulation. NR2502-10926
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	21-02-2025	21:33:00	22-02-2025	06:16:00	0.36	0.00	0.00	0.00	8.72		* 400kV KURUKSHETRA-NAKODAR(PSTCL) Line manually opened on voltage reg. (NR-8895)
							10.02	0.00	1.72	0.00	239.50	100.00	
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	10-02-2025	23:59:00	11-02-2025	06:10:00	0.26	0.00	0.00	0.00	6.18		* 400kV KURUKSHETRA-SONIPAT-1 Line manually opened on voltage reg. (NR-4047)
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	11-02-2025	23:35:00	12-02-2025	05:36:00	0.25	0.00	0.00	0.00	6.02		* LVRD Line hand tripped on voltage regulation. NR2502-4478
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	07-02-2025	21:34:00	08-02-2025	05:30:00	0.33	0.00	0.00	0.00	7.93		* Line hand tripped on voltage regulation. NR2502-2833
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	16-02-2025	21:01:00	17-02-2025	05:22:00	0.35	0.00	0.00	0.00	8.35		* Line hand tripped on voltage regulation. NR2502-6670
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	05-02-2025	22:31:00	06-02-2025	07:14:00	0.36	0.00	0.00	0.00	8.72		* Line hand tripped for voltage regulation
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	03-02-2025	21:48:00	04-02-2025	06:57:00	0.38	0.00	0.00	0.00	9.15		* 400kV KURUKSHETRA-SONIPAT-1 Line manually opened on voltage reg. (NR-1017)
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	02-02-2025	21:20:00	03-02-2025	06:15:00	0.37	0.00	0.00	0.00	8.92		* Line hand tripped on voltage regulation. NR2502-667
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	01-02-2025	21:09:00	02-02-2025	07:17:00	0.42	0.00	0.00	0.00	10.13		* LVRD Line hand tripped on voltage regulation. NR2502-353
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	24-02-2025	21:40:00	25-02-2025	05:42:00	0.34	0.00	0.00	0.00	8.03		* LVRD Line hand tripped on voltage regulation. NR2502-10035
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	28-02-2025	21:21:00	28-02-2025	23:59:59	0.11	0.00	0.00	0.00	2.65		* Line hand tripped for voltage regulation.NR2502-11276
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	22-02-2025	21:28:00	23-02-2025	07:05:00	0.40	0.00	0.00	0.00	9.62		* Line hand tripped on voltage regulation. NR2502-9280
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	21-02-2025	22:16:00	22-02-2025	05:46:00	0.31	0.00	0.00	0.00	7.50		* 400kV KURUKSHETRA-SONIPAT-1 Line manually opened on voltage reg. (NR-8898)
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	25-02-2025	21:35:00	26-02-2025	07:14:00	0.40	0.00	0.00	0.00	9.65		* Line hand tripped on voltage regulation. NR2502-10368
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	26-02-2025	20:49:00	27-02-2025	06:35:00	0.41	0.00	0.00	0.00	9.77		* Line hand tripped on voltage regulation. NR2502-10658
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	27-02-2025	20:38:00	28-02-2025	07:55:00	0.47	0.00	0.00	0.00	11.28		* Line hand tripped on voltage regulation. NR2502-10937
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	27-02-2025	20:38:00	28-02-2025	07:55:00	0.47	0.00	0.00	0.00	11.28		* Line hand tripped on voltage regulation. NR2502-10937
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	20-02-2025	22:14:00	21-02-2025	06:52:00	0.36	0.00	0.00	0.00	8.63		* 400kV KURUKSHETRA-SONIPAT-1 Line manually opened on voltage reg. (NR-8444)
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	23-02-2025	21:16:00	24-02-2025	06:22:00	0.38	0.00	0.00	0.00	9.10		* Line hand tripped on voltage regulation. NR2502-9582
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	17-02-2025	21:42:00	18-02-2025	05:29:00	0.32	0.00	0.00	0.00	7.78		* Line hand tripped on voltage regulation. NR2502-7171
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	20-02-2025	02:05:00	20-02-2025	06:58:00	0.20	0.00	0.00	0.00	4.88		* LVRD Line hand tripped on voltage regulation. NR2502-8093
							6.89	0.00	0.00	0.00	165.57	100.00	
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	13-02-2025	01:40:00	13-02-2025	06:44:00	0.21	0.00	0.00	0.00	5.07		* Line hand tripped for voltage regulation.NR2502-4949
							0.21	0.00	0.00	0.00	5.07	100.00	
CKT	400kV MALERKOTLA-LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE To ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV MOGA-HISAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MOGA-HISAR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAKODAR(PSTCL)-JALLANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NALAGARH-PATIALA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NALAGARH-PATIALA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NATPAJHAKRI(SJVNL)-GUMMA(HPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NATPAJHAKRI(SJVNL)-GUMMA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-1	OSPD	06-02-2025	09:45:00	06-02-2025	16:18:00	0.27	0.00	0.00	0.00	6.55		* SD taken by SJVNL for Replacement <(>&<)> Calibration of sensor of Gas monitoring system of GIS of Rampur HPS. NR2502-2097
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-1	OSPD	05-02-2025	10:35:00	05-02-2025	16:33:00	0.25	0.00	0.00	0.00	5.97		* SD taken by SJVNL for Replacement <(>&<)> Calibration of sensor of Gas monitoring system of GIS of Rampur HPS NR2502-1655
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-1	OSPD	08-02-2025	09:39:00	08-02-2025	16:11:00	0.27	0.00	0.00	0.00	6.53		* 400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-1 taken under SD by SJVNL (NR-3009)
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-1	OSPD	07-02-2025	09:52:00	07-02-2025	16:12:00	0.26	0.00	0.00	0.00	6.33		* SD taken by SJVNL for Replacement <(>&<)> Calibration of sensor of Gas monitoring system of GIS of Rampur HPS. NR2502-2575
							1.05	0.00	0.00	0.00	25.38	100.00	
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-2	OSPD	05-02-2025	10:36:00	05-02-2025	16:34:00	0.25	0.00	0.00	0.00	5.97		* SD taken by SJVNL for Replacement <(>&<)> Calibration of sensor of Gas monitoring system of GIS of Rampur HPS NR2502-1656
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-2	OSPD	08-02-2025	09:45:00	08-02-2025	16:15:00	0.27	0.00	0.00	0.00	6.50		* 400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-2 TUSD by SJVNL (NR-3008)
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-2	OSPD	07-02-2025	09:52:00	07-02-2025	16:14:00	0.27	0.00	0.00	0.00	6.37		* SD taken by SJVNL for Replacement <(>&<)> Calibration of sensor of Gas monitoring system of GIS of Rampur HPS. NR2502-2574
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-2	OSPD	06-02-2025	09:46:00	06-02-2025	16:21:00	0.27	0.00	0.00	0.00	6.58		* SD taken by SJVNL for Replacement <(>&<)> Calibration of sensor of Gas monitoring system of GIS of Rampur HPS. NR2502-2098
							1.06	0.00	0.00	0.00	25.42	100.00	
CKT	400kV ABDULLAPUR-PANCHKULA-1	OSPT	16-02-2025	09:25:00	16-02-2025	19:49:00	0.43	10.40	0.00	0.00	0.00		* OSPT For Rectification of S/D nature defects of the line. NR2502-6394
							0.43	10.40	0.00	0.00	0.00	98.45	
CKT	400kV ABDULLAPUR-PANCHKULA-2	OSPT	17-02-2025	09:41:00	17-02-2025	19:29:00	0.41	9.80	0.00	0.00	0.00		* OSPT SD taken for Rectification of S/D nature defects of the line. NR2502-6852
							0.41	9.80	0.00	0.00	0.00	98.54	
CKT	400kV PANCHKULA-DEHAR(BBMB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PANCHKULA-GUMMA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	01-02-2025	00:00:01	01-02-2025	06:44:00	0.28	0.00	0.00	0.00	6.73		* LVRD Line hand tripped on voltage regulation. NR2501-12764
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	04-02-2025	21:29:00	05-02-2025	05:39:00	0.34	0.00	0.00	0.00	8.17		* Line hand tripped for voltage regulation.NR2502-1453
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	01-02-2025	21:00:00	02-02-2025	05:47:00	0.37	0.00	0.00	0.00	8.78		* Line hand tripped for voltage regulation.NR2502-349
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	02-02-2025	22:41:00	03-02-2025	05:50:00	0.30	0.00	0.00	0.00	7.15		* Line hand tripped on voltage regulation. NR2502-677
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	07-02-2025	21:10:00	08-02-2025	05:45:00	0.36	0.00	0.00	0.00	8.58		* Line hand tripped on voltage regulation. NR2502-2823
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	03-02-2025	21:39:00	04-02-2025	05:41:00	0.34	0.00	0.00	0.00	8.03		* 400kV PANCHKULA-GUMMA(HPPTCL)-2 Line manually opened on voltage reg. (NR-1018)
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	09-02-2025	22:47:00	10-02-2025	05:44:00	0.29	0.00	0.00	0.00	6.95		* LVRD Line hand tripped on voltage regulation. NR2502-3633
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	18-02-2025	21:15:00	19-02-2025	05:14:00	0.33	0.00	0.00	0.00	7.98		* LVRD Line hand tripped on voltage regulation. NR2502-7594
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	17-02-2025	21:25:00	18-02-2025	05:39:00	0.34	0.00	0.00	0.00	8.23		* Line hand tripped on voltage regulation. NR2502-7158
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	19-02-2025	21:16:00	20-02-2025	05:43:00	0.35	0.00	0.00	0.00	8.45		* LVRD Line hand tripped on voltage regulation. NR2502-8057
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	28-02-2025	21:23:00	28-02-2025	23:59:59	0.11	0.00	0.00	0.00	2.62		* Line hand tripped for voltage regulation.NR2502-11289
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	27-02-2025	21:21:00	28-02-2025	09:15:00	0.50	0.00	0.00	0.00	11.90		* Line hand tripped on voltage regulation. NR2502-10952
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	23-02-2025	21:33:00	24-02-2025	05:39:00	0.34	0.00	0.00	0.00	8.10		* Line hand tripped on voltage regulation. NR2502-9592
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	24-02-2025	21:35:00	25-02-2025	05:41:00	0.34	0.00	0.00	0.00	8.10		* LVRD Line hand tripped on voltage regulation. NR2502-10028
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	21-02-2025	23:17:00	22-02-2025	06:18:00	0.29	0.00	0.00	0.00	7.02		* 400kV PANCHKULA-GUMMA(HPPTCL)-2 Line manually opened on voltage reg. (NR-8913)
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	22-02-2025	21:37:00	23-02-2025	05:30:00	0.33	0.00	0.00	0.00	7.88		* Line hand tripped on voltage regulation. NR2502-9278
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	26-02-2025	21:04:00	27-02-2025	05:39:00	0.36	0.00	0.00	0.00	8.58		* Line hand tripped on voltage regulation. NR2502-10662
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	20-02-2025	21:21:00	21-02-2025	05:57:00	0.36	0.00	0.00	0.00	8.60		* 400kV PANCHKULA-GUMMA(HPPTCL)-2 Line manually opened on voltage reg. (NR-8448)
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LART	24-02-2025	06:47:00	24-02-2025	06:47:00	0.00	0.00	0.00	0.00	0.00		* Line successfully auto reclosure on Y-N fault. FLR Panchkula : Fc - 19.451KA, FL - 6.672 km. * 04.03.2025 16:43:07 INDIA (60003416)* Flashover observed on jumper and crossarm of location of tower loc no. 47 due to bird excreta
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	16-02-2025	21:19:00	17-02-2025	05:42:00	0.35	0.00	0.00	0.00	8.38		* Line hand tripped on voltage regulation. NR2502-6668
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	14-02-2025	22:58:00	15-02-2025	05:52:00	0.29	0.00	0.00	0.00	6.90		* Line hand tripped on voltage regulation. NR2502-5781
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	15-02-2025	22:24:00	16-02-2025	05:51:00	0.31	0.00	0.00	0.00	7.45		* Line hand tripped on voltage regulation. NR2502-6259
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	06-02-2025	21:52:00	07-02-2025	06:03:00	0.34	0.00	0.00	0.00	8.18		* Line hand tripped on voltage regulation. NR2502-2366
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	05-02-2025	21:33:00	06-02-2025	07:00:00	0.39	0.00	0.00	0.00	9.45		* Line hand tripped for voltage regulation
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	10-02-2025	21:51:00	11-02-2025	05:11:00	0.31	0.00	0.00	0.00	7.33		* 400kV PANCHKULA-GUMMA(HPPTCL)-2 Line manually opened on voltage reg. (NR-4017)
							7.92	0.00	0.00	0.00	189.54	100.00	
CKT	400kV PANCHKULA-PANIPAT(BBMB)	LART	01-02-2025	07:14:00	01-02-2025	07:14:00	0.00	0.00	0.00	0.00	0.00		* 400kV PANCHKULA-PANIPAT(BBMB) line auto reclosed on B-N fault. FLR Panchkula(Afas): Ib=3.52KA, 128.630KM* 02.02.2025 07:46:05 INDIA (60003416)* Fault in BBMB Jurisdiction
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATIALA-LUDHIANA-1	LVRD	28-02-2025	21:52:00	28-02-2025	23:59:59	0.09	0.00	0.00	0.00	2.13		* Line hand tripped for voltage regulation.NR2502-11300
CKT	400kV PATIALA-LUDHIANA-1	LVRD	28-02-2025	00:26:00	28-02-2025	08:56:00	0.35	0.00	0.00	0.00	8.50		* Line hand tripped for voltage regulation.NR2502-10980
CKT	400kV PATIALA-LUDHIANA-1	OSFT	20-02-2025	19:21:00	20-02-2025	20:01:00	0.03	0.67	0.00	0.00	0.00		* Emergency Shutdown taken by Patiala SS for rectification of 418-89A isolator towards line side contact is getting stuck and not closing properly NR2502-8419
CKT	400kV PATIALA-LUDHIANA-1	SVRD	03-02-2025	10:05:00	03-02-2025	20:20:00	0.43	0.00	0.00	0.00	10.25		* SD taken for rectification of SD nature defects of line NR2502-821
							0.90	0.67	0.00	0.00	20.88	99.90	
CKT	400kV PATIALA-LUDHIANA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATIALA-MALERKOTLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATIALA-PANCHKULA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATIALA-PANCHKULA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATIALA-PATRAN(TECHNO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATIALA-PATRAN(TECHNO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARBATI2(NHPC)-BANALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARBATI3(NHPC)-BANALA	OMSU	03-02-2025	19:35:00	03-02-2025	23:24:00	0.16	0.00	3.82	0.00	0.00		* Line tripped on DT recieve at Banala end.* 03.02.2025 23:33:42 INDIA (60003796)* 400kV Parbat3-Banala line tripped on receipt of DT at Banala.RY- N fault. On patrolling of line By Banala TL , Forest fire found B/W Tloc loc no 06 and 07. FLR Banala(Alfas): RY Phase to Ground Fault, 14.861 kA, FL: 6.900km (100.000%).
							0.16	0.00	3.82	0.00	0.00	100.00	
CKT	400kV PARBATI3(NHPC)-SAINJ(HPSEB)	OMSU	03-02-2025	19:35:00	04-02-2025	00:16:00	0.20	0.00	4.68	0.00	0.00		* 400kV PARBATI3(NHPC)-SAINJ(HPSEB) line tripped from Sainj end and remain closed from Parbat3 due forest fire near location no 06 and 07
							0.20	0.00	4.68	0.00	0.00	100.00	
CKT	400kV RAMPUR(SJVNL)-NALAGARH-1	OSPD	06-02-2025	09:54:00	06-02-2025	16:23:00	0.27	0.00	0.00	0.00	6.48		* SD taken by SJVNL for Replacement <(>&<) Calibration of sensor of Gas monitoring system of GIS of Rampur HPS. NR2502-2096
CKT	400kV RAMPUR(SJVNL)-NALAGARH-1	OSPD	05-02-2025	10:43:00	05-02-2025	16:49:00	0.25	0.00	0.00	0.00	6.10		* SD taken by SJVNL for Replacement <(>&<) Calibration of sensor of Gas monitoring system of GIS of Rampur HPS NR2502-1658
CKT	400kV RAMPUR(SJVNL)-NALAGARH-1	OSPD	08-02-2025	09:47:00	08-02-2025	16:21:00	0.27	0.00	0.00	0.00	6.57		* 400kV RAMPUR(SJVNL)-NALAGARH-1 Line TUSD by SJVNL (NR-3034)
CKT	400kV RAMPUR(SJVNL)-NALAGARH-1	OSPD	07-02-2025	09:56:00	07-02-2025	16:21:00	0.27	0.00	0.00	0.00	6.42		* SD taken by SJVNL for Replacement <(>&<) Calibration of sensor of Gas monitoring system of GIS of Rampur HPS. NR2502-2572
							1.06	0.00	0.00	0.00	25.57	100.00	
CKT	400kV RAMPUR(SJVNL)-NALAGARH-2	OSPD	08-02-2025	09:48:00	08-02-2025	16:22:00	0.27	0.00	0.00	0.00	6.57		* 400kV RAMPUR(SJVNL)-NALAGARH-2 Line TUSD by SJVNL (NR-3033)
CKT	400kV RAMPUR(SJVNL)-NALAGARH-2	OSPD	06-02-2025	09:54:00	06-02-2025	16:24:00	0.27	0.00	0.00	0.00	6.50		* SD taken by SJVNL for Replacement <(>&<) Calibration of sensor of Gas monitoring system of GIS of Rampur HPS. NR2502-2095
CKT	400kV RAMPUR(SJVNL)-NALAGARH-2	OSPD	05-02-2025	10:45:00	05-02-2025	16:51:00	0.25	0.00	0.00	0.00	6.10		* SD taken by SJVNL for Replacement <(>&<) Calibration of sensor of Gas monitoring system of GIS of Rampur HPS NR2502-1657
CKT	400kV RAMPUR(SJVNL)-NALAGARH-2	OSPD	07-02-2025	09:57:00	07-02-2025	16:22:00	0.27	0.00	0.00	0.00	6.42		* SD taken by SJVNL for Replacement <(>&<) Calibration of sensor of Gas monitoring system of GIS of Rampur HPS. NR2502-2571
							1.06	0.00	0.00	0.00	25.59	100.00	
CKT	400kV URI1(NHPC)-AMARGARH(STERLITE)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV URI1(NHPC)-AMARGARH(STERLITE)-2	LEFT	28-02-2025	00:20:00	28-02-2025	13:19:00	0.54	12.98	0.00	0.00	0.00		* Line tripped on B-N fault. FLR Amargarh: FL=43.56KM, lb= 1.605KA. Continous flashing over observed near Pringal Village in the tripped line as per Wagoora TL for quenching the flashing over, line taken under emergency SD at 02:18hrs dated 28.02.2025 vide NRLDC code NR2502-10986* 01.03.2025 22:55:39 INDIA (60003416)* Snapping of Earth Wire(OPGW due to excessive snow loading in span 46-47
CKT	400kV URI1(NHPC)-AMARGARH(STERLITE)-2	LNCC	28-02-2025	19:01:00	28-02-2025	21:22:00	0.10	0.00	0.00	2.35	0.00		* Line tripped on B-N fault. FLR Amargarh: 31.24km, lb=4.70kA, FLR Uri 1: 23.9km, lb=4.8kA.* 04.03.2025 17:31:56 INDIA (60003416)* Flashover on OPGW due to galloping of OPGW at 82-83
							0.64	12.98	0.00	2.35	0.00	98.06	
CKT	400kV URI2(NHPC)-URI1(NHPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV URI2(NHPC)-WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WAGOORA-AMARGARH(STERLITE)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WAGOORA-AMARGARH(STERLITE)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEW WANPOH-BAGLIHAR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEW WANPOH-WAGOORA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEW WANPOH-WAGOORA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-MOGA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-MOGA-2	OSFT	04-02-2025	18:11:00	04-02-2025	19:41:00	0.06	1.50	0.00	0.00	0.00		* Emergency SD taken for attending hot spot (93.6°C) on Y- phase line isolator of 400kV Kishenpur-Moga ckt-2 at Kishenpur end . NR2502-1407
							0.06	1.50	0.00	0.00	0.00	99.78	
CKT	765kV MEERUT-MOGA	LVRD	02-02-2025	23:43:00	03-02-2025	06:38:00	0.29	0.00	0.00	0.00	6.92		* Line hand tripped on voltage regulation. NR2502-683.NL-217
CKT	765kV MEERUT-MOGA	LVRD	26-02-2025	21:19:00	27-02-2025	07:03:00	0.41	0.00	0.00	0.00	9.73		* Line hand tripped on voltage regulation. NR2502-10669 NI-3664
CKT	765kV MEERUT-MOGA	LVRD	22-02-2025	03:15:00	22-02-2025	06:54:00	0.15	0.00	0.00	0.00	3.65		* 765kV MEERUT-MOGA Line manually opened on voltage reg. (NR-8937, NL-3074)
CKT	765kV MEERUT-MOGA	LVRD	22-02-2025	21:24:00	23-02-2025	07:09:00	0.41	0.00	0.00	0.00	9.75		* Line hand tripped on voltage regulation. NR2502-9277 NL-3198
CKT	765kV MEERUT-MOGA	LVRD	28-02-2025	20:59:00	28-02-2025	23:59:59	0.13	0.00	0.00	0.00	3.02		* Line hand tripped on voltage regulation. NR2502-11272 NL-3898
CKT	765kV MEERUT-MOGA	LVRD	27-02-2025	21:08:00	28-02-2025	09:02:00	0.50	0.00	0.00	0.00	11.90		* Line hand tripped on voltage regulation. NR2502-10954 NL-3765
CKT	765kV MEERUT-MOGA	LVRD	18-02-2025	21:24:00	19-02-2025	06:05:00	0.36	0.00	0.00	0.00	8.68		* LVRD Line hand tripped on voltage regulation. NR2502-7579. NL-2572
CKT	765kV MEERUT-MOGA	LVRD	19-02-2025	21:48:00	20-02-2025	08:01:00	0.43	0.00	0.00	0.00	10.22		* LVRD Line hand tripped on voltage regulation. NR2502-8072, NL-2718
CKT	765kV MEERUT-MOGA	LVRD	11-02-2025	21:11:00	12-02-2025	06:34:00	0.39	0.00	0.00	0.00	9.38		* LVRD Line hand tripped on voltage regulation. NR2502-4459 NL-1544
CKT	765kV MEERUT-MOGA	LVRD	10-02-2025	23:46:00	11-02-2025	06:31:00	0.28	0.00	0.00	0.00	6.75		* 765kV MEERUT-MOGA Line manually opened on voltage reg. (NR-4042, NL-1389)
CKT	765kV MEERUT-MOGA	LVRD	15-02-2025	02:08:00	15-02-2025	06:44:00	0.19	0.00	0.00	0.00	4.60		* Line hand tripped on voltage regulation. NR2502-5803 NL-2041
CKT	765kV MEERUT-MOGA	OMSU	08-02-2025	16:38:00	08-02-2025	19:06:00	0.10	0.00	2.47	0.00	0.00		* Emergency SD taken to remove kite/kite thread in span 663-664 and 664-665 NR2502-3159 NL-1074
CKT	765kV MEERUT-MOGA	LVRD	03-02-2025	23:54:00	04-02-2025	06:22:00	0.27	0.00	0.00	0.00	6.47		* 765kV MEERUT-MOGA Line manually opened on voltage reg. (NR-1058, NL-360)
							3.91	0.00	2.47	0.00	91.07	100.00	
CKT	66kV DRASS-DRASS(LPDD) i/C 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66kV-DRASS-DRASS(LPDD) i/C 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66kV KARGIL CHUTAK CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66kV-KARGIL-KARGIL (LPDD) CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66kV KARGIL SHARGOLE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66kV-KHLSTI-KHLSTI (LPDD) INTERCONNECTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66 KV PHYANG KHARU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifying	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66KV-PHYANG LEH (JKPDD) CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66KV-PHYANG-LEH (JKPDD) CKT 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66KV-PHYANG NIMOO			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PANCHKULA-1 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PANCHKULA-2 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,LR OF JALANDHAR AT HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF CHAMBA-2 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF CHAMBA-1 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF BAGPAT-1 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF BAGPAT-2 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	KAITHAL-DADRI LINE REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Kishenpur_400kV_63MVAR_Moga2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	KISHENPUR-MOGA-1 LR-400kV_63MVAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Moga_400kV_63MVAR_Kishenpur1-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Moga_400kV_63MVAR_Kishenpur2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Moga_400kV_63MVAR_Hisar3-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Moga_400kV_63MVAR_Hisar2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BIKANER-1 AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BIKANER-2 AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR, SWLR OF MEERUT AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHIWANI AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Nalagarh_400kV_50MVAR_Rampur2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF GUMMA-1 AT PKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF GUMMA-2 AT PKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	SAMBA-AMARGARH-1 LINE REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	SAMBA-AMARGARH-2 LINE REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	+200/-200MVAR STATCOM AT NALAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
SVC	+600/-400MVAR SVC AT LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
SVC	+300/-200MVAR SVC AT NEW WANPOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT ABDULLAPUR	OSPT	25-02-2025	09:59:00	25-02-2025	18:42:00	0.36	8.72	0.00	0.00	0.00		* 315MVA,400/220kV ICT-3 AT ABDULLAPUR taken under SD for AMP works (NR-10205)
							0.36	8.72	0.00	0.00	0.00	98.70	
XMER	315MVA,400/220kV ICT-4 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT AMRITSAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT AMRITSAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT AMRITSAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT AMRITSAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-1 AT BANALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BANALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT CHAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT CHAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT DEHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,220/66 KV ICT-1 AT DRASS	OSFT	28-02-2025	18:19:00	28-02-2025	19:10:00	0.04	0.85	0.00	0.00	0.00		* Emergency shutdown taken for removal of hanging rainwater gutter of 220kV GIS building roof from Y-ph SF6 Gas to Air Bushing of 220kV GIS. NR2502-11237
							0.04	0.85	0.00	0.00	0.00	99.87	
XMER	315MVA,400/220kV ICT-1 AT FATEHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT FATEHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT FATEHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/66kV ICT-1 AT CHANDIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/66kV ICT-2 AT CHANDIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,220/66kV ICT-1 AT KARGIL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,220/66kV ICT-2 AT KARGIL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KISHENPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KISHENPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT KISHENPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,220/66kV ICT-1 AT KHALSTI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT LUDHIANA	OSPT	17-02-2025	08:59:00	17-02-2025	19:19:00	0.43	10.33	0.00	0.00	0.00		* OSPT SD taken for Amp works. NR2502-6772
							0.43	10.33	0.00	0.00	0.00	98.46	
XMER	315MVA,400/220kV ICT-1 AT MALERKOTLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MALERKOTLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MALERKOTLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT MOGA	OSFT	08-02-2025	19:59:00	09-02-2025	01:36:00	0.23	5.62	0.00	0.00	0.00		* Emergency SD taken to attend hotspot on terminal connector of neutral bushing (102 Degree Celsius) of B-Ph unit of ICT NR2502-3244 NL-1097
							0.23	5.62	0.00	0.00	0.00	99.16	
XMER	500MVA,400/220kV ICT-3 AT MOGA	OSPT	11-02-2025	10:27:00	14-02-2025	14:04:00	3.15	75.62	0.00	0.00	0.00		* SD taken for AMP Works NR2502-4219

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							3.15	75.62	0.00	0.00	0.00	88.75	
XMER	315MVA,400/220kV ICT-4 AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT NALAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT NALAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT NALAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT PANIPAT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PATIALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PATIALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PATIALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT PATIALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,220/66kV ICT-1 AT PHYANG			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,220/66 kV ICT-2 AT PHYANG			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PANCHKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PANCHKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PANCHKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT WAGOORA	OSPT	11-02-2025	10:16:00	11-02-2025	12:47:00	0.11	2.52	0.00	0.00	0.00		* SD taken for maintenace works and replacement of terminal connector of 20989C R-Ph Isolator of ICT NR2502-4220
							0.11	2.52	0.00	0.00	0.00	99.63	
XMER	315MVA,400/220kV ICT-2 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-4 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT NEW WANPOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT NEW WANPOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	