

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR.BUS REACTOR-1 AT ABDULLAPUR	SVRD	16-01-2025	10:36:00	16-01-2025	13:24:00	0.12	0.00	0.00	0.00	2.80		* BR hand tripped for voltage regulation. NR2501-6297
BSR	50MVAR.BUS REACTOR-1 AT ABDULLAPUR	SVRD	29-01-2025	09:27:00	29-01-2025	16:24:00	0.29	0.00	0.00	0.00	6.95		* SVRD BR hand tripped for voltage regulation. NR2501-11687
BSR	50MVAR.BUS REACTOR-1 AT ABDULLAPUR	SVRD	28-01-2025	09:46:00	28-01-2025	16:36:00	0.29	0.00	0.00	0.00	6.83		* BR hand tripped for voltage regulation. NR2501-11240
BSR	50MVAR.BUS REACTOR-1 AT ABDULLAPUR	SVRD	30-01-2025	09:36:00	30-01-2025	17:44:00	0.34	0.00	0.00	0.00	8.13		* SVRD BR hand tripped for voltage regulation. NR2501-12080
							1.04	0.00	0.00	0.00	24.71	100.00	
BSR	125MVAR.BUS REACTOR-2 AT ABDULLAPUR	SVRD	30-01-2025	09:42:00	30-01-2025	17:32:00	0.33	0.00	0.00	0.00	7.83		* SVRD BR hand tripped for voltage regulation. NR2501-12087
BSR	125MVAR.BUS REACTOR-2 AT ABDULLAPUR	SVRD	03-01-2025	09:40:00	03-01-2025	14:45:00	0.21	0.00	0.00	0.00	5.08		* SVRD BR hand tripped for voltage regulation. NR2501-1028
BSR	125MVAR.BUS REACTOR-2 AT ABDULLAPUR	SVRD	28-01-2025	09:47:00	28-01-2025	16:30:00	0.28	0.00	0.00	0.00	6.72		* BR hand tripped for voltage regulation. NR2501-11239
BSR	125MVAR.BUS REACTOR-2 AT ABDULLAPUR	SVRD	16-01-2025	10:35:00	16-01-2025	13:25:00	0.12	0.00	0.00	0.00	2.83		* BR hand tripped for voltage regulation. NR2501-6296
BSR	125MVAR.BUS REACTOR-2 AT ABDULLAPUR	SVRD	29-01-2025	09:27:00	29-01-2025	16:11:00	0.28	0.00	0.00	0.00	6.73		* SVRD BR hand tripped for voltage regulation. NR2501-11688
							1.22	0.00	0.00	0.00	29.19	100.00	
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	31-01-2025	09:19:00	31-01-2025	19:41:00	0.43	0.00	0.00	0.00	10.37		* 80MVAR.BUS REACTOR-1 AT AMRITSAR manually opened on Voltage Reg. (NR-12502)
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	02-01-2025	09:27:00	02-01-2025	13:11:00	0.16	0.00	0.00	0.00	3.73		* Bus reactor hand tripped for voltage reg.NR2501-546
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	03-01-2025	09:30:00	03-01-2025	14:54:00	0.23	0.00	0.00	0.00	5.40		* SVRD BR hand tripped for voltage regulation. NR2501-1005
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	04-01-2025	09:29:00	04-01-2025	14:22:00	0.20	0.00	0.00	0.00	4.88		* SVRD BR hand tripped for voltage regulation. NR2501-1433
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	01-01-2025	09:08:00	01-01-2025	13:20:00	0.18	0.00	0.00	0.00	4.20		* Bus reactor hand tripped for voltage reg.NR2501-109
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	05-01-2025	09:17:00	05-01-2025	13:45:00	0.19	0.00	0.00	0.00	4.47		* BR hand tripped for voltage regulation. NR2501-1831
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	20-01-2025	10:38:00	20-01-2025	16:00:00	0.22	0.00	0.00	0.00	5.37		* SVRD BR hand tripped for voltage regulation. NR2501-7888
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	14-01-2025	10:19:00	14-01-2025	13:25:00	0.13	0.00	0.00	0.00	3.10		* BR hand tripped for voltage regulation. NR2501-5427
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	15-01-2025	09:10:00	15-01-2025	13:33:00	0.18	0.00	0.00	0.00	4.38		* BR hand tripped for voltage regulation. NR2501-5775
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	07-01-2025	08:55:00	09-01-2025	21:21:00	2.52	0.00	0.00	0.00	60.43		* 80MVAR.BUS REACTOR-1 AT AMRITSAR, Bus reactor hand tripped for voltage reg NR2501-2601.
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	11-01-2025	08:42:00	11-01-2025	17:18:00	0.36	0.00	0.00	0.00	8.60		* BR hand tripped for voltage regulation. NR2501-4361
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	24-01-2025	08:59:00	24-01-2025	17:49:00	0.37	0.00	0.00	0.00	8.83		* 80MVAR.BUS REACTOR-1 AT AMRITSAR BR manually opened on Voltage Reg.(NR-9516)
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	21-01-2025	09:28:00	21-01-2025	15:42:00	0.26	0.00	0.00	0.00	6.23		* SVRD BR hand tripped for voltage regulation. NR2501-8279
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	23-01-2025	09:09:00	23-01-2025	16:18:00	0.30	0.00	0.00	0.00	7.15		* 80MVAR.BUS REACTOR-1 AT AMRITSAR BR manually opened on Voltage Reg. (NR-9085)
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	13-01-2025	08:01:00	13-01-2025	13:23:00	0.22	0.00	0.00	0.00	5.37		* BR hand tripped for voltage regulation. NR2501-4997
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	17-01-2025	09:16:00	17-01-2025	20:24:00	0.46	0.00	0.00	0.00	11.13		* BR hand tripped for voltage regulation.NR2501-6686
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	12-01-2025	09:33:00	12-01-2025	15:33:00	0.25	0.00	0.00	0.00	6.00		* BR hand tripped for voltage regulation. NR2501-4765
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	28-01-2025	09:02:00	28-01-2025	17:15:00	0.34	0.00	0.00	0.00	8.22		* BR hand tripped for voltage regulation. NR2501-11199
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	16-01-2025	09:23:00	16-01-2025	13:23:00	0.17	0.00	0.00	0.00	4.00		* BR hand tripped for voltage regulation. NR2501-6245
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	27-01-2025	09:17:00	27-01-2025	16:07:00	0.29	0.00	0.00	0.00	6.83		* BR hand tripped for voltage regulation. NR2501-10771
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	29-01-2025	08:57:00	29-01-2025	18:23:00	0.39	0.00	0.00	0.00	9.43		* SVRD BR hand tripped for voltage regulation. NR2501-11602
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	06-01-2025	10:31:00	06-01-2025	16:56:00	0.27	0.00	0.00	0.00	6.42		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2270.
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	25-01-2025	09:41:00	25-01-2025	15:40:00	0.25	0.00	0.00	0.00	5.98		* BR hand tripped for voltage regulation.NR2501-10040
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	26-01-2025	09:14:00	26-01-2025	16:13:00	0.29	0.00	0.00	0.00	6.98		* BR hand tripped for voltage regulation.NR2501-10442
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	18-01-2025	10:12:00	18-01-2025	15:53:00	0.24	0.00	0.00	0.00	5.68		* BR hand tripped for voltage regulation.NR2501-7171
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	22-01-2025	09:21:00	22-01-2025	15:52:00	0.27	0.00	0.00	0.00	6.52		* SVRD BR hand tripped for voltage regulation. NR2501-8690
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	30-01-2025	09:29:00	30-01-2025	15:49:00	0.26	0.00	0.00	0.00	6.33		* SVRD BR hand tripped for voltage regulation. NR2501-12058
BSR	80MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	10-01-2025	09:18:00	10-01-2025	15:40:00	0.27	0.00	0.00	0.00	6.37		* Bus reactor hand tripped for voltage reg.NR2501-3982
							9.70	0.00	0.00	0.00	232.40	100.00	
BSR	25MVAR.BUS REACTOR-1 AT AMRITSAR	SVRD	01-01-2025	00:00:01	21-01-2025	16:47:00	20.70	0.00	0.00	0.00	496.78		* BR hand tripped for voltage regulation. NR2407-4991
							20.70	0.00	0.00	0.00	496.78	100.00	
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	01-01-2025	10:07:00	01-01-2025	13:20:00	0.13	0.00	0.00	0.00	3.22		* Bus reactor hand tripped for voltage reg.NR2501-166
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	02-01-2025	09:51:00	02-01-2025	13:04:00	0.13	0.00	0.00	0.00	3.22		* Bus reactor hand tripped for voltage reg.NR2501-568
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	03-01-2025	09:32:00	03-01-2025	15:00:00	0.23	0.00	0.00	0.00	5.47		* SVRD BR hand tripped for voltage regulation. NR2501-1007
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	09-01-2025	09:03:00	09-01-2025	15:26:00	0.27	0.00	0.00	0.00	6.38		* Bus reactor hand tripped for voltage reg.NR2501-3517
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	13-01-2025	10:25:00	13-01-2025	13:15:00	0.12	0.00	0.00	0.00	2.83		* BR hand tripped for voltage regulation. NR2501-5056
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	24-01-2025	09:16:00	24-01-2025	15:27:00	0.26	0.00	0.00	0.00	6.18		* 80MVAR.BUS REACTOR-1 AT BANALA BR manually opened on Voltage Reg. (NR-9561)
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	22-01-2025	09:22:00	22-01-2025	15:50:00	0.27	0.00	0.00	0.00	6.47		* SVRD BR hand tripped for voltage regulation. NR2501-8691
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	07-01-2025	10:04:00	07-01-2025	13:17:00	0.13	0.00	0.00	0.00	3.22		* 80MVAR.BUS REACTOR-1 AT BANALA - Bus reactor hand tripped for voltage reg NR2501-2668.
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	27-01-2025	09:30:00	27-01-2025	15:58:00	0.27	0.00	0.00	0.00	6.47		* BR hand tripped for voltage regulation. NR2501-10822
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	17-01-2025	09:27:00	17-01-2025	20:25:00	0.46	0.00	0.00	0.00	10.97		* BR hand tripped for voltage regulation.NR2501-6693
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	10-01-2025	09:05:00	10-01-2025	15:33:00	0.27	0.00	0.00	0.00	6.47		* Bus reactor hand tripped for voltage reg.NR2501-3947
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	28-01-2025	09:40:00	28-01-2025	16:59:00	0.31	0.00	0.00	0.00	7.32		* BR hand tripped for voltage regulation. NR2501-11232
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	26-01-2025	09:19:00	26-01-2025	16:21:00	0.29	0.00	0.00	0.00	7.03		* BR hand tripped for voltage regulation.NR2501-10448
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	18-01-2025	10:11:00	18-01-2025	19:02:00	0.37	0.00	0.00	0.00	8.85		* BR hand tripped for voltage regulation.NR2501-7170
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	08-01-2025	09:33:00	08-01-2025	13:16:00	0.16	0.00	0.00	0.00	3.72		* 80MVAR.BUS REACTOR-1 AT BANALA - Bus reactor hand tripped for voltage reg NR2501-3115.
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	16-01-2025	09:24:00	16-01-2025	20:53:00	0.48	0.00	0.00	0.00	11.48		* BR hand tripped for voltage regulation. NR2501-6246
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	29-01-2025	09:34:00	29-01-2025	16:27:00	0.29	0.00	0.00	0.00	6.88		* SVRD BR hand tripped for voltage regulation. NR2501-11685
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	21-01-2025	09:34:00	21-01-2025	15:41:00	0.26	0.00	0.00	0.00	6.12		* SVRD BR hand tripped for voltage regulation. NR2501-8290
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	15-01-2025	09:09:00	15-01-2025	13:31:00	0.18	0.00	0.00	0.00	4.37		* BR hand tripped for voltage regulation. NR2501-5774
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	30-01-2025	09:23:00	30-01-2025	17:37:00	0.34	0.00	0.00	0.00	8.23		* SVRD BR hand tripped for voltage regulation. NR2501-12076
BSR	80MVAR.BUS REACTOR-1 AT BANALA	SVRD	31-01-2025	09:49:00	31-01-2025	13:12:00	0.14	0.00	0.00	0.00	3.38		* 80MVAR.BUS REACTOR-1 AT BANALA manually opened on Voltage Reg. (NR-12544)
							5.36	0.00	0.00	0.00	128.28	100.00	
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	03-01-2025	09:12:00	03-01-2025	15:13:00	0.25	0.00	0.00	0.00	6.02		* SVRD BR hand tripped for voltage regulation. NR2501-1007
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	04-01-2025	09:29:00	04-01-2025	14:06:00	0.19	0.00	0.00	0.00	4.62		* SVRD BR hand tripped for voltage regulation. NR2501-1438
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	02-01-2025	09:20:00	02-01-2025	16:17:00	0.29	0.00	0.00	0.00	6.95		* Bus reactor hand tripped for voltage reg.NR2501-530
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	01-01-2025	09:27:00	01-01-2025	16:05:00	0.28	0.00	0.00	0.00	6.63		* Bus reactor hand tripped for voltage reg.NR2501-157
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	07-01-2025	09:46:00	07-01-2025	15:34:00	0.24	0.00	0.00	0.00	5.80		* 80MVAR.BUS REACTOR-1 AT CHAMBA - Bus reactor hand tripped for voltage reg NR2501-2662.
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	27-01-2025	09:16:00	27-01-2025	16:17:00	0.29	0.00	0.00	0.00	7.02		* BR hand tripped for voltage regulation. NR2501-10782
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	13-01-2025	08:01:00	13-01-2025	13:14:00	0.22	0.00	0.00	0.00	5.22		* BR hand tripped for voltage regulation. NR2501-4998
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	25-01-2025	11:36:00	25-01-2025	15:33:00	0.17	0.00	0.00	0.00	3.95		* BR hand tripped for voltage regulation.NR2501-10100
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	16-01-2025	09:30:00	16-01-2025	16:20:00	0.29	0.00	0.00	0.00	6.83		* BR hand tripped for voltage regulation. NR2501-6255

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE To ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	15-01-2025	10:10:00	15-01-2025	21:55:00	0.49	0.00	0.00	0.00	11.75		* BR hand tripped for voltage regulation. NR2501-5814
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	28-01-2025	09:43:00	28-01-2025	16:23:00	0.28	0.00	0.00	0.00	6.67		* BR hand tripped for voltage regulation. NR2501-11235
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	30-01-2025	09:21:00	30-01-2025	17:39:00	0.35	0.00	0.00	0.00	8.30		* SVRD BR hand tripped for voltage regulation. NR2501-12053
BSR	80MVAR.BUS REACTOR-1 AT CHAMBA	SVRD	31-01-2025	09:47:00	31-01-2025	18:14:00	0.35	0.00	0.00	0.00	8.45		* 80MVAR.BUS REACTOR-1 AT CHAMBA manually opened on Voltage Reg. (NR-12528)
							4.86	0.00	0.00	0.00	116.12	100.00	
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	31-01-2025	09:30:00	31-01-2025	18:15:00	0.37	0.00	0.00	0.00	8.75		* 80MVAR.BUS REACTOR-2 AT CHAMBA manually opened on Voltage Reg. (NR-12527)
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	30-01-2025	09:24:00	30-01-2025	17:39:00	0.34	0.00	0.00	0.00	8.25		* SVRD BR hand tripped for voltage regulation. NR2501-12052
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	28-01-2025	09:43:00	28-01-2025	16:22:00	0.28	0.00	0.00	0.00	6.65		* BR hand tripped for voltage regulation. NR2501-11233
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	10-01-2025	09:34:00	10-01-2025	16:04:00	0.27	0.00	0.00	0.00	6.50		* Bus reactor hand tripped for voltage reg.NR2501-3995
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	15-01-2025	10:10:00	15-01-2025	16:32:00	0.27	0.00	0.00	0.00	6.37		* BR hand tripped for voltage regulation. NR2501-5815
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	29-01-2025	09:35:00	29-01-2025	18:55:00	0.39	0.00	0.00	0.00	9.33		* SVRD BR hand tripped for voltage regulation. NR2501-11693
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	05-01-2025	09:48:00	05-01-2025	15:14:00	0.23	0.00	0.00	0.00	5.43		* BR hand tripped for voltage regulation. NR2501-1879
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	26-01-2025	09:22:00	26-01-2025	16:26:00	0.29	0.00	0.00	0.00	7.07		* BR hand tripped for voltage regulation. NR2501-10456
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	21-01-2025	09:37:00	21-01-2025	15:38:00	0.25	0.00	0.00	0.00	6.02		* SVRD BR hand tripped for voltage regulation. NR2501-8289
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	08-01-2025	09:32:00	08-01-2025	13:15:00	0.16	0.00	0.00	0.00	3.72		* 80MVAR.BUS REACTOR-2 AT CHAMBA - Bus reactor hand tripped for voltage reg NR2501-3113.
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	25-01-2025	11:37:00	25-01-2025	15:34:00	0.17	0.00	0.00	0.00	3.95		* BR hand tripped for voltage regulation. NR2501-10099
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	27-01-2025	09:25:00	27-01-2025	16:06:00	0.28	0.00	0.00	0.00	6.68		* BR hand tripped for voltage regulation. NR2501-10812
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	16-01-2025	09:44:00	16-01-2025	14:39:00	0.21	0.00	0.00	0.00	4.92		* BR hand tripped for voltage regulation. NR2501-6268
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	07-01-2025	09:51:00	07-01-2025	15:35:00	0.24	0.00	0.00	0.00	5.73		* 80MVAR.BUS REACTOR-2 AT CHAMBA - Bus reactor hand tripped for voltage reg NR2501-2664.
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	13-01-2025	11:14:00	13-01-2025	13:14:00	0.08	0.00	0.00	0.00	2.00		* BR hand tripped for voltage regulation. NR2501-5069
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	01-01-2025	09:28:00	01-01-2025	17:01:00	0.32	0.00	0.00	0.00	7.55		* Bus reactor hand tripped for voltage reg. NR2501-150
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	03-01-2025	09:13:00	03-01-2025	15:14:00	0.25	0.00	0.00	0.00	6.02		* SVRD BR hand tripped for voltage regulation. NR2501-952
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	04-01-2025	09:29:00	04-01-2025	14:05:00	0.19	0.00	0.00	0.00	4.60		* SVRD BR hand tripped for voltage regulation. NR2501-1439
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	02-01-2025	09:11:00	02-01-2025	16:19:00	0.30	0.00	0.00	0.00	7.13		* Bus reactor hand tripped for voltage reg. NR2501-512
BSR	80MVAR.BUS REACTOR-2 AT CHAMBA	SVRD	12-01-2025	09:53:00	12-01-2025	15:25:00	0.23	0.00	0.00	0.00	5.53		* BR hand tripped for voltage regulation. NR2501-4775
							5.12	0.00	0.00	0.00	122.20	100.00	
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	31-01-2025	09:22:00	31-01-2025	19:42:00	0.43	0.00	0.00	0.00	10.33		* 63MVAR.BUS REACTOR-1 AT DEHAR manually opened on Voltage Reg. (NR-12492)
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	30-01-2025	10:10:00	30-01-2025	17:27:00	0.30	0.00	0.00	0.00	7.28		* SVRD BR hand tripped for voltage regulation. NR2501-12118
BSR	63MVAR.BUS REACTOR-1 AT DEHAR	SVRD	27-01-2025	09:29:00	27-01-2025	16:32:00	0.29	0.00	0.00	0.00	7.05		* BR hand tripped for voltage regulation. NR2501-10819
							1.02	0.00	0.00	0.00	24.66	100.00	
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	27-01-2025	09:29:00	27-01-2025	16:32:00	0.29	0.00	0.00	0.00	7.05		* BR hand tripped for voltage regulation. NR2501-10820
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	31-01-2025	09:22:00	31-01-2025	19:42:00	0.43	0.00	0.00	0.00	10.33		* 63MVAR.BUS REACTOR-2 AT DEHAR manually opened on Voltage Reg (NR-12493)
BSR	63MVAR.BUS REACTOR-2 AT DEHAR	SVRD	30-01-2025	10:10:00	30-01-2025	17:27:00	0.30	0.00	0.00	0.00	7.28		* SVRD BR hand tripped for voltage regulation. NR2501-12119
							1.02	0.00	0.00	0.00	24.66	100.00	
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	03-01-2025	09:31:00	03-01-2025	14:47:00	0.22	0.00	0.00	0.00	5.27		* BR hand tripped for voltage regulation. NR2501-1016
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	27-01-2025	09:27:00	27-01-2025	16:08:00	0.28	0.00	0.00	0.00	6.68		* BR hand tripped for voltage regulation. NR2501-10817
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	29-01-2025	09:19:00	29-01-2025	18:53:00	0.40	0.00	0.00	0.00	9.57		* SVRD BR hand tripped for voltage regulation. NR2501-11671
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	30-01-2025	09:25:00	30-01-2025	17:37:00	0.34	0.00	0.00	0.00	8.20		* SVRD BR hand tripped for voltage regulation. NR2501-12054
BSR	80MVAR.BUS REACTOR-1 AT FATEHABAD	SVRD	31-01-2025	09:55:00	31-01-2025	21:02:00	0.46	0.00	0.00	0.00	11.12		* 80MVAR.BUS REACTOR-1 AT FATEHABAD manually opened on Voltage Reg. (NR-12559)
							1.70	0.00	0.00	0.00	40.84	100.00	
BSR	25MVAR. BUS REACTOR-1 AT FATEHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	04-01-2025	09:30:00	04-01-2025	16:04:00	0.27	0.00	0.00	0.00	6.57		* SVRD BR hand tripped for voltage regulation. NR2501-1435
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	03-01-2025	09:34:00	03-01-2025	14:52:00	0.22	0.00	0.00	0.00	5.30		* BR hand tripped for voltage regulation. NR2501-1004
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	02-01-2025	09:17:00	02-01-2025	13:16:00	0.17	0.00	0.00	0.00	3.98		* Bus reactor hand tripped for voltage reg. NR2501-524
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	01-01-2025	09:06:00	01-01-2025	16:09:00	0.29	0.00	0.00	0.00	7.05		* Bus reactor hand tripped for voltage reg. NR2501-116
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	09-01-2025	09:02:00	09-01-2025	17:08:00	0.34	0.00	0.00	0.00	8.10		* Bus reactor hand tripped for voltage reg. NR2501-3516
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	07-01-2025	09:10:00	08-01-2025	00:24:00	0.64	0.00	0.00	0.00	15.23		* 80MVAR.BUS REACTOR-1 AT HAMIRPUR - Bus reactor hand tripped for voltage reg. NR2501-2610.
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	16-01-2025	09:22:00	16-01-2025	21:02:00	0.49	0.00	0.00	0.00	11.67		* BR hand tripped for voltage regulation. NR2501-6235
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	13-01-2025	08:03:00	13-01-2025	13:18:00	0.22	0.00	0.00	0.00	5.25		* BR hand tripped for voltage regulation. NR2501-4996
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	08-01-2025	09:32:00	08-01-2025	13:16:00	0.16	0.00	0.00	0.00	3.73		* 80MVAR.BUS REACTOR-1 AT HAMIRPUR - Bus reactor hand tripped for voltage reg NR2501-3101.
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	11-01-2025	08:43:00	11-01-2025	17:17:00	0.36	0.00	0.00	0.00	8.57		* BR hand tripped for voltage regulation. NR2501-4362
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	25-01-2025	09:22:00	25-01-2025	19:55:00	0.44	0.00	0.00	0.00	10.55		* BR hand tripped for voltage regulation. NR2501-10011
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	22-01-2025	09:23:00	22-01-2025	15:52:00	0.27	0.00	0.00	0.00	6.48		* SVRD BR hand tripped for voltage regulation. NR2501-8692.
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	18-01-2025	10:10:00	18-01-2025	19:03:00	0.37	0.00	0.00	0.00	8.88		* BR hand tripped for voltage regulation. NR2501-7169
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	17-01-2025	09:24:00	17-01-2025	20:24:00	0.46	0.00	0.00	0.00	11.00		* BR hand tripped for voltage regulation. NR2501-6692
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	12-01-2025	09:32:00	12-01-2025	15:34:00	0.25	0.00	0.00	0.00	6.03		* BR hand tripped for voltage regulation. NR2501-4766
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	26-01-2025	09:16:00	26-01-2025	16:22:00	0.30	0.00	0.00	0.00	7.10		* BR hand tripped for voltage regulation. NR2501-10447
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	10-01-2025	09:06:00	10-01-2025	21:20:00	0.51	0.00	0.00	0.00	12.23		* Bus reactor hand tripped for voltage reg. NR2501-3948
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	06-01-2025	10:13:00	06-01-2025	16:55:00	0.28	0.00	0.00	0.00	6.70		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2267.
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	15-01-2025	09:08:00	15-01-2025	16:28:00	0.31	0.00	0.00	0.00	7.33		* BR hand tripped for voltage regulation. NR2501-5773
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	14-01-2025	10:04:00	14-01-2025	13:26:00	0.14	0.00	0.00	0.00	3.37		* BR hand tripped for voltage regulation. NR2501-5414
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	27-01-2025	09:15:00	27-01-2025	16:09:00	0.29	0.00	0.00	0.00	6.90		* BR hand tripped for voltage regulation. NR2501-10787
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	21-01-2025	09:34:00	21-01-2025	15:40:00	0.25	0.00	0.00	0.00	6.10		* SVRD BR hand tripped for voltage regulation. NR2501-8289
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	24-01-2025	08:57:00	24-01-2025	21:55:00	0.54	0.00	0.00	0.00	12.97		* 80MVAR.BUS REACTOR-1 AT HAMIRPUR BR manually opened on Voltage Reg. (NR-9514)
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	30-01-2025	09:43:00	30-01-2025	15:41:00	0.25	0.00	0.00	0.00	5.97		* SVRD BR hand tripped for voltage regulation. NR2501-12122
BSR	80MVAR.BUS REACTOR-1 AT HAMIRPUR	SVRD	31-01-2025	09:14:00	31-01-2025	19:42:00	0.44	0.00	0.00	0.00	10.47		* 80MVAR.BUS REACTOR-1 AT HAMIRPUR manually opened on Voltage Reg. (NR-12497)
							8.26	0.00	0.00	0.00	197.53	100.00	
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	22-01-2025	09:25:00	23-01-2025	17:16:00	1.33	0.00	0.00	0.00	31.85		* SVRD BR hand tripped for voltage regulation. NR2501-8695
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	24-01-2025	09:09:00	24-01-2025	21:12:00	0.50	0.00	0.00	0.00	12.05		* 25MVAR.BUS REACTOR-1 AT JALANDHAR BR manually opened on Voltage Reg. (NR-9525)
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	17-01-2025	09:32:00	18-01-2025	21:56:00	1.52	0.00	0.00	0.00	36.40		* BR hand tripped for voltage regulation. NR2501-6696
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	28-01-2025	09:26:00	28-01-2025	17:11:00	0.32	0.00	0.00	0.00	7.75		* BR hand tripped for voltage regulation. NR2501-11217
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	07-01-2025	09:47:00	07-01-2025	21:16:00	0.48	0.00	0.00	0.00	11.48		* 25MVAR.BUS REACTOR-1 AT JALANDHAR - Bus reactor hand tripped for voltage reg NR2501-2659.
BSR	25MVAR.BUS REACTOR-1 AT JALANDHAR	SVRD	30-01-2025	09:46:00	30-01-2025	17:34:00	0.33	0.00	0.00	0.0			

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE To ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	10-01-2025	09:57:00	10-01-2025	15:52:00	0.25	0.00	0.00	0.00	5.92		* Bus reactor hand tripped for voltage reg.NR2501-4004
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	16-01-2025	09:03:00	16-01-2025	23:53:00	0.62	0.00	0.00	0.00	14.83		* BR hand tripped for voltage regulation. NR2501-6216
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	21-01-2025	09:29:00	21-01-2025	21:24:00	0.50	0.00	0.00	0.00	11.92		* SVRD BR hand tripped for voltage regulation. NR2501-8280
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	02-01-2025	11:14:00	02-01-2025	21:02:00	0.41	0.00	0.00	0.00	9.80		* Bus reactor hand tripped for voltage reg.NR2501-608
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	04-01-2025	09:31:00	04-01-2025	14:02:00	0.19	0.00	0.00	0.00	4.52		* SVRD BR hand tripped for voltage regulation. NR2501-131
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	01-01-2025	10:04:00	01-01-2025	16:14:00	0.26	0.00	0.00	0.00	6.17		* Bus reactor hand tripped for voltage reg.NR2501-163
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	26-01-2025	09:19:00	26-01-2025	16:19:00	0.29	0.00	0.00	0.00	7.00		* BR hand tripped for voltage regulation.NR2501-10445
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	25-01-2025	09:47:00	25-01-2025	15:42:00	0.25	0.00	0.00	0.00	5.92		* BR hand tripped for voltage regulation. NR2501-10044
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	05-01-2025	09:14:00	05-01-2025	15:18:00	0.25	0.00	0.00	0.00	6.07		* BR hand tripped for voltage regulation. NR2501-1826
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	08-01-2025	09:26:00	08-01-2025	21:17:00	0.49	0.00	0.00	0.00	11.85		* 25MVAR,BUS REACTOR-1 AT JALANDHAR - Bus reactor hand tripped for voltage reg NR2501-3087.
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	09-01-2025	09:06:00	09-01-2025	15:41:00	0.27	0.00	0.00	0.00	6.58		* Bus reactor hand tripped for voltage reg.NR2501-3520
							9.76	0.00	0.00	0.00	234.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	31-01-2025	09:22:00	31-01-2025	19:44:00	0.43	0.00	0.00	0.00	10.37		* 125MVAR,BUS REACTOR-1 AT JALANDHAR manually opened on Voltage Reg. (NR-12503)
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	30-01-2025	09:28:00	30-01-2025	15:52:00	0.27	0.00	0.00	0.00	6.40		* SVRD BR hand tripped for voltage regulation. NR2501-12059
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	28-01-2025	09:05:00	28-01-2025	17:10:00	0.34	0.00	0.00	0.00	8.08		* BR hand tripped for voltage regulation. NR2501-11218
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	10-01-2025	09:51:00	10-01-2025	15:48:00	0.25	0.00	0.00	0.00	5.95		* Bus reactor hand tripped for voltage reg.NR2501-3942
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	15-01-2025	10:05:00	15-01-2025	16:33:00	0.27	0.00	0.00	0.00	6.47		* BR hand tripped for voltage regulation. NR2501-5809
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	27-01-2025	09:18:00	27-01-2025	16:44:00	0.31	0.00	0.00	0.00	7.43		* BR hand tripped for voltage regulation. NR2501-10772
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	18-01-2025	10:08:00	18-01-2025	19:13:00	0.38	0.00	0.00	0.00	9.08		* BR hand tripped for voltage regulation.NR2501-7167
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	11-01-2025	09:52:00	11-01-2025	17:08:00	0.30	0.00	0.00	0.00	7.27		* BR hand tripped for voltage regulation. NR2501-4408
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	09-01-2025	09:09:00	09-01-2025	15:56:00	0.28	0.00	0.00	0.00	6.78		* Bus reactor hand tripped for voltage reg.NR2501-0909
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	13-01-2025	10:29:00	13-01-2025	13:22:00	0.12	0.00	0.00	0.00	2.88		* BR hand tripped for voltage regulation. NR2501-5050
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	25-01-2025	09:43:00	25-01-2025	15:39:00	0.25	0.00	0.00	0.00	5.93		* BR hand tripped for voltage regulation.NR2501-10042
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	07-01-2025	09:13:00	07-01-2025	21:15:00	0.50	0.00	0.00	0.00	12.03		* 125MVAR,BUS REACTOR-1 AT JALANDHAR - Bus reactor hand tripped for voltage reg NR2501-2611.
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	08-01-2025	09:18:00	08-01-2025	13:22:00	0.17	0.00	0.00	0.00	4.07		* 125MVAR,BUS REACTOR-1 AT JALANDHAR- Bus reactor hand tripped for voltage reg NR2501-3069.
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	23-01-2025	09:08:00	23-01-2025	17:17:00	0.34	0.00	0.00	0.00	8.15		* 125MVAR,BUS REACTOR-1 AT JALANDHAR BR manually opened on Voltage Reg. (NR-9083)
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	24-01-2025	09:06:00	24-01-2025	17:48:00	0.36	0.00	0.00	0.00	8.70		* 125MVAR,BUS REACTOR-1 AT JALANDHAR BR manually opened on Voltage Reg. (NR-9523)
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	22-01-2025	09:24:00	22-01-2025	15:50:00	0.27	0.00	0.00	0.00	6.43		* SVRD BR hand tripped for voltage regulation. NR2501-8693
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	05-01-2025	09:13:00	05-01-2025	13:47:00	0.19	0.00	0.00	0.00	4.57		* BR hand tripped for voltage regulation. NR2501-1824
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	06-01-2025	10:04:00	06-01-2025	16:27:00	0.27	0.00	0.00	0.00	6.38		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2261.
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	20-01-2025	10:45:00	20-01-2025	16:01:00	0.22	0.00	0.00	0.00	5.27		* BR hand tripped for voltage regulation. NR2501-7894
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	14-01-2025	10:21:00	14-01-2025	13:08:00	0.12	0.00	0.00	0.00	2.78		* BR hand tripped for voltage regulation. NR2501-5429
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	16-01-2025	09:13:00	16-01-2025	20:57:00	0.49	0.00	0.00	0.00	11.73		* BR hand tripped for voltage regulation. NR2501-6223
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	21-01-2025	09:15:00	21-01-2025	15:36:00	0.27	0.00	0.00	0.00	6.35		* SVRD BR hand tripped for voltage regulation. NR2501-8260
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	03-01-2025	09:11:00	03-01-2025	18:30:00	0.39	0.00	0.00	0.00	9.32		* BR hand tripped for voltage regulation. NR2501-945
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	01-01-2025	09:15:00	01-01-2025	20:53:00	0.49	0.00	0.00	0.00	11.63		* Bus reactor hand tripped for voltage reg.NR2501-107
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	04-01-2025	09:31:00	04-01-2025	14:06:00	0.19	0.00	0.00	0.00	4.58		* SVRD BR hand tripped for voltage regulation. NR2501-1429
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	02-01-2025	09:10:00	02-01-2025	16:28:00	0.30	0.00	0.00	0.00	7.30		* Bus reactor hand tripped for voltage reg.NR2501-510
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	17-01-2025	09:24:00	17-01-2025	20:28:00	0.46	0.00	0.00	0.00	11.07		* BR hand tripped for voltage regulation.NR2501-6690
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	26-01-2025	09:16:00	26-01-2025	16:16:00	0.29	0.00	0.00	0.00	7.00		* BR hand tripped for voltage regulation.NR2501-10443
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	29-01-2025	08:48:00	29-01-2025	18:04:00	0.39	0.00	0.00	0.00	9.27		* SVRD BR hand tripped for voltage regulation. NR2501-11606
							8.91	0.00	0.00	0.00	213.27	100.00	
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	01-01-2025	10:03:00	01-01-2025	16:14:00	0.26	0.00	0.00	0.00	6.18		* Bus reactor hand tripped for voltage reg.NR2501-164
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	26-01-2025	09:18:00	26-01-2025	16:19:00	0.29	0.00	0.00	0.00	7.02		* BR hand tripped for voltage regulation.NR2501-10446
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	31-01-2025	09:56:00	31-01-2025	22:43:00	0.53	0.00	0.00	0.00	12.78		* 25MVAR,BUS REACTOR-2 AT JALANDHAR manually opened on Voltage Reg. (NR-12555)
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	30-01-2025	09:46:00	30-01-2025	17:34:00	0.33	0.00	0.00	0.00	7.80		* SVRD BR hand tripped for voltage regulation. NR2501-12106
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	28-01-2025	09:27:00	28-01-2025	17:12:00	0.32	0.00	0.00	0.00	7.75		* BR hand tripped for voltage regulation. NR2501-11218
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	22-01-2025	09:26:00	23-01-2025	17:15:00	1.33	0.00	0.00	0.00	31.82		* SVRD BR hand tripped for voltage regulation. NR2501-8696
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	06-01-2025	10:09:00	06-01-2025	21:39:00	0.48	0.00	0.00	0.00	11.50		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2264.
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	25-01-2025	09:48:00	25-01-2025	15:43:00	0.25	0.00	0.00	0.00	5.92		* BR hand tripped for voltage regulation.NR2501-10045
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	15-01-2025	10:08:00	15-01-2025	21:57:00	0.49	0.00	0.00	0.00	11.82		* BR hand tripped for voltage regulation. NR2501-5812
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	17-01-2025	09:33:00	18-01-2025	21:56:00	1.52	0.00	0.00	0.00	36.38		* BR hand tripped for voltage regulation.NR2501-6697
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	05-01-2025	09:15:00	05-01-2025	15:20:00	0.25	0.00	0.00	0.00	6.08		* BR hand tripped for voltage regulation. NR2501-1827
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	21-01-2025	09:30:00	21-01-2025	21:23:00	0.50	0.00	0.00	0.00	11.88		* SVRD BR hand tripped for voltage regulation. NR2501-8281
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	07-01-2025	09:48:00	07-01-2025	21:17:00	0.48	0.00	0.00	0.00	11.48		* 25MVAR,BUS REACTOR-2 AT JALANDHAR - Bus reactor hand tripped for voltage reg NR2501-2660.
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	08-01-2025	09:26:00	08-01-2025	21:18:00	0.49	0.00	0.00	0.00	11.87		* 25MVAR,BUS REACTOR-2 AT JALANDHAR - Bus reactor hand tripped for voltage reg NR2501-3089.
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	09-01-2025	09:06:00	09-01-2025	15:57:00	0.29	0.00	0.00	0.00	6.85		* Bus reactor hand tripped for voltage reg.NR2501-3518
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	24-01-2025	09:10:00	24-01-2025	21:13:00	0.50	0.00	0.00	0.00	12.05		* 25MVAR,BUS REACTOR-2 AT JALANDHAR BR manually opened on Voltage Reg. (NR-9526)
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	10-01-2025	09:58:00	10-01-2025	15:53:00	0.25	0.00	0.00	0.00	5.92		* Bus reactor hand tripped for voltage reg.NR2501-4005
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	16-01-2025	09:03:00	16-01-2025	23:54:00	0.62	0.00	0.00	0.00	14.85		* BR hand tripped for voltage regulation. NR2501-6217
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	02-01-2025	11:14:00	02-01-2025	21:02:00	0.41	0.00	0.00	0.00	9.80		* Bus reactor hand tripped for voltage reg.NR2501-609
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	04-01-2025	09:32:00	04-01-2025	14:01:00	0.19	0.00	0.00	0.00	4.48		* SVRD BR hand tripped for voltage regulation. NR2501-1432
							9.78	0.00	0.00	0.00	234.23	100.00	
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	06-01-2025	10:07:00	06-01-2025	16:24:00	0.26	0.00	0.00	0.00	6.28		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2262.
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	07-01-2025	09:45:00	07-01-2025	15:39:00	0.25	0.00	0.00	0.00	5.90		* 125MVAR,BUS REACTOR-2 AT JALANDHAR - Bus reactor hand tripped for voltage reg NR2501-2661.
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	09-01-2025	09:11:00	09-01-2025	15:24:00	0.26	0.00	0.00	0.00	6.22		* Bus reactor hand tripped for voltage reg.NR2501-3521
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	24-01-2025	09:08:00	24-01-2025	17:44:00	0.36	0.00	0.00	0.00	8.60		* 125MVAR,BUS REACTOR-2 AT JALANDHAR BR manually opened on Voltage Reg. (NR-9524)
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	22-01-2025	09:24:00	22-01-2025	15:49:00	0.27	0.00	0.00	0.00	6.42		* SVRD BR hand tripped for voltage regulation. NR2501-8694
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	08-01-2025	09:25:00	08-01-2025	13:21:00	0.16	0.00	0.00	0.00	3.93		* 125MVAR,BUS REACTOR-2 AT JALANDHAR - Bus reactor hand tripped for voltage reg NR2501-3086.
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	14-01-2025	10:21:00	14-01-2025	13:10:00	0.12	0.00	0.00	0.00	2.82		* BR hand tripped for voltage regulation. NR2501-5428
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	18-01-2025	10:06:00	18-01-2025	19:14:00	0.38	0.00					

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	05-01-2025	09:14:00	05-01-2025	13:48:00	0.19	0.00	0.00	0.00	4.57		* BR hand tripped for voltage regulation. NR2501-1825
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	27-01-2025	09:18:00	27-01-2025	16:29:00	0.30	0.00	0.00	0.00	7.18		* BR hand tripped for voltage regulation. NR2501-10773
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	26-01-2025	09:18:00	26-01-2025	16:14:00	0.29	0.00	0.00	0.00	6.93		* BR hand tripped for voltage regulation.NR2501-10444
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	10-01-2025	09:03:00	10-01-2025	15:48:00	0.28	0.00	0.00	0.00	6.75		* Bus reactor hand tripped for voltage reg.NR2501-3941
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	13-01-2025	10:30:00	13-01-2025	13:23:00	0.12	0.00	0.00	0.00	2.88		* BR hand tripped for voltage regulation. NR2501-5051
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	11-01-2025	09:51:00	11-01-2025	17:09:00	0.30	0.00	0.00	0.00	7.30		* BR hand tripped for voltage regulation. NR2501-4409
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	28-01-2025	09:06:00	28-01-2025	17:05:00	0.33	0.00	0.00	0.00	7.98		* BR hand tripped for voltage regulation. NR2501-11201
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	21-01-2025	09:15:00	21-01-2025	17:43:00	0.35	0.00	0.00	0.00	8.47		* SVRD BR hand tripped for voltage regulation. NR2501-8259
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	17-01-2025	09:26:00	17-01-2025	20:26:00	0.46	0.00	0.00	0.00	11.00		* BR hand tripped for voltage regulation.NR2501-6691
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	01-01-2025	09:13:00	01-01-2025	16:11:00	0.29	0.00	0.00	0.00	6.97		* Bus reactor hand tripped for voltage reg.NR2501-108
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	29-01-2025	08:49:00	29-01-2025	18:51:00	0.42	0.00	0.00	0.00	10.03		* SVRD BR hand tripped for voltage regulation. NR2501-11605
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	30-01-2025	09:27:00	30-01-2025	15:52:00	0.27	0.00	0.00	0.00	6.42		* SVRD BR hand tripped for voltage regulation. NR2501-12055
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	31-01-2025	09:21:00	31-01-2025	19:45:00	0.43	0.00	0.00	0.00	10.40		* 125MVAR,BUS REACTOR-2 AT JALANDHAR manually opened on Voltage Reg. (NR-12505)
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	20-01-2025	10:48:00	20-01-2025	15:57:00	0.22	0.00	0.00	0.00	5.15		* BR hand tripped for voltage regulation. NR2501-7895
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	23-01-2025	09:06:00	23-01-2025	16:15:00	0.30	0.00	0.00	0.00	7.15		* 125MVAR,BUS REACTOR-2 AT JALANDHAR BR manually opened on Voltage Reg. (NR-9084)
							8.12	0.00	0.00	0.00	194.62	100.00	
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	29-01-2025	09:16:00	29-01-2025	16:14:00	0.29	0.00	0.00	0.00	6.97		* SVRD BR hand tripped for voltage regulation. NR2501-11674
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	31-01-2025	09:13:00	31-01-2025	17:01:00	0.33	0.00	0.00	0.00	7.80		* 80MVAR,BUS REACTOR-1 AT KAITHAL. manually opened on Voltage Reg. (NR-12496)
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	30-01-2025	09:45:00	30-01-2025	15:46:00	0.25	0.00	0.00	0.00	6.02		* SVRD BR hand tripped for voltage regulation. NR2501-12084
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	16-01-2025	09:25:00	16-01-2025	16:30:00	0.30	0.00	0.00	0.00	7.08		* BR hand tripped for voltage regulation. NR2501-6244
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	01-01-2025	10:30:00	01-01-2025	13:25:00	0.12	0.00	0.00	0.00	2.92		* Bus reactor hand tripped for voltage reg.NR2501-174
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	03-01-2025	09:30:00	03-01-2025	14:50:00	0.22	0.00	0.00	0.00	5.33		* BR hand tripped for voltage regulation. NR2501-1006
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	04-01-2025	09:41:00	04-01-2025	17:37:00	0.33	0.00	0.00	0.00	7.93		* SVRD BR hand tripped for voltage regulation. NR2501-1459
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	02-01-2025	09:25:00	02-01-2025	13:08:00	0.16	0.00	0.00	0.00	3.72		* Bus reactor hand tripped for voltage reg.NR2501-545
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	15-01-2025	09:54:00	15-01-2025	13:37:00	0.16	0.00	0.00	0.00	3.72		* BR hand tripped for voltage regulation. NR2501-5802
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	23-01-2025	09:08:00	23-01-2025	16:28:00	0.31	0.00	0.00	0.00	7.33		* 80MVAR,BUS REACTOR-1 AT KAITHAL BR manually opened on Voltage Reg. (NR-9089)
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	08-01-2025	09:24:00	08-01-2025	13:12:00	0.16	0.00	0.00	0.00	3.80		* 80MVAR,BUS REACTOR-1 AT KAITHAL - Bus reactor hand tripped for voltage reg NR2501-3082.
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	17-01-2025	09:29:00	17-01-2025	20:23:00	0.45	0.00	0.00	0.00	10.90		* BR hand tripped for voltage regulation.NR2501-6695
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	06-01-2025	09:10:00	06-01-2025	16:57:00	0.32	0.00	0.00	0.00	7.78		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2203
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	28-01-2025	09:32:00	28-01-2025	17:01:00	0.31	0.00	0.00	0.00	7.48		* BR hand tripped for voltage regulation. NR2501-11226
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	24-01-2025	09:10:00	24-01-2025	17:52:00	0.36	0.00	0.00	0.00	8.70		* 80MVAR,BUS REACTOR-1 AT KAITHAL BR manually opened on Voltage Reg. (NR-9528)
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	14-01-2025	09:41:00	14-01-2025	14:58:00	0.22	0.00	0.00	0.00	5.28		* BR hand tripped for voltage regulation. NR2501-5411
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	07-01-2025	09:06:00	07-01-2025	15:50:00	0.28	0.00	0.00	0.00	6.73		* 80MVAR,BUS REACTOR-1 AT KAITHAL - Bus reactor hand tripped for voltage reg NR2501-2609.
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	05-01-2025	09:30:00	05-01-2025	15:17:00	0.24	0.00	0.00	0.00	5.78		* BR hand tripped for voltage regulation. NR2501-1861
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	25-01-2025	09:42:00	25-01-2025	15:39:00	0.25	0.00	0.00	0.00	5.95		* BR hand tripped for voltage regulation.NR2501-10054
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	18-01-2025	09:54:00	18-01-2025	19:11:00	0.39	0.00	0.00	0.00	9.28		* BR hand tripped for voltage regulation.NR2501-7162
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	27-01-2025	09:18:00	27-01-2025	16:20:00	0.29	0.00	0.00	0.00	7.03		* BR hand tripped for voltage regulation. NR2501-10774
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	21-01-2025	09:36:00	21-01-2025	15:47:00	0.26	0.00	0.00	0.00	6.18		* SVRD BR hand tripped for voltage regulation. NR2501-8291
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	10-01-2025	09:20:00	10-01-2025	16:36:00	0.30	0.00	0.00	0.00	7.27		* Bus reactor hand tripped for voltage reg.NR2501-3984
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	26-01-2025	09:12:00	26-01-2025	16:15:00	0.29	0.00	0.00	0.00	7.05		* BR hand tripped for voltage regulation.NR2501-10455
							6.59	0.00	0.00	0.00	158.03	100.00	
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	17-01-2025	09:29:00	17-01-2025	20:23:00	0.45	0.00	0.00	0.00	10.90		* BR hand tripped for voltage regulation.NR2501-6694
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	14-01-2025	09:41:00	14-01-2025	14:48:00	0.21	0.00	0.00	0.00	5.12		* BR hand tripped for voltage regulation. NR2501-5410
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	21-01-2025	09:36:00	21-01-2025	15:47:00	0.26	0.00	0.00	0.00	6.18		* SVRD BR hand tripped for voltage regulation. NR2501-8292
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	23-01-2025	09:08:00	23-01-2025	16:28:00	0.31	0.00	0.00	0.00	7.33		* 125MVAR,BUS REACTOR-2 AT KAITHAL BR manually opened on Voltage Reg. (NR-9088)
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	06-01-2025	09:10:00	06-01-2025	16:57:00	0.32	0.00	0.00	0.00	7.78		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2202
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	01-01-2025	10:30:00	01-01-2025	13:25:00	0.12	0.00	0.00	0.00	2.92		* Bus reactor hand tripped for voltage reg.NR2501-173
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	02-01-2025	09:25:00	02-01-2025	13:08:00	0.16	0.00	0.00	0.00	3.72		* Bus reactor hand tripped for voltage reg.NR2501-544
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	04-01-2025	09:41:00	04-01-2025	17:37:00	0.33	0.00	0.00	0.00	7.93		* SVRD BR hand tripped for voltage regulation. NR2501-1458
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	03-01-2025	09:30:00	03-01-2025	14:50:00	0.22	0.00	0.00	0.00	5.33		* BR hand tripped for voltage regulation. NR2501-993
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	25-01-2025	09:42:00	25-01-2025	15:39:00	0.25	0.00	0.00	0.00	5.95		* BR hand tripped for voltage regulation.NR2501-10053
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	05-01-2025	09:30:00	05-01-2025	15:17:00	0.24	0.00	0.00	0.00	5.78		* BR hand tripped for voltage regulation. NR2501-1835
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	31-01-2025	09:13:00	31-01-2025	17:01:00	0.33	0.00	0.00	0.00	7.80		* 125MVAR,BUS REACTOR-2 AT KAITHAL manually opened on Voltage Reg. (NR-12495)
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	30-01-2025	09:45:00	30-01-2025	15:46:00	0.25	0.00	0.00	0.00	6.02		* SVRD BR hand tripped for voltage regulation. NR2501-12083
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	29-01-2025	09:16:00	29-01-2025	16:14:00	0.29	0.00	0.00	0.00	6.97		* SVRD BR hand tripped for voltage regulation. NR2501-11648
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	10-01-2025	09:20:00	10-01-2025	16:36:00	0.30	0.00	0.00	0.00	7.27		* Bus reactor hand tripped for voltage reg.NR2501-3983
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	16-01-2025	09:25:00	16-01-2025	16:30:00	0.30	0.00	0.00	0.00	7.08		* BR hand tripped for voltage regulation. NR2501-6243
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	07-01-2025	09:06:00	07-01-2025	15:50:00	0.28	0.00	0.00	0.00	6.73		* 125MVAR,BUS REACTOR-2 AT KAITHAL - Bus reactor hand tripped for voltage reg NR2501-2608.
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	26-01-2025	09:12:00	26-01-2025	16:15:00	0.29	0.00	0.00	0.00	7.05		* BR hand tripped for voltage regulation.NR2501-10454
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	27-01-2025	09:18:00	27-01-2025	16:20:00	0.29	0.00	0.00	0.00	7.03		* BR hand tripped for voltage regulation. NR2501-10775
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	24-01-2025	09:10:00	24-01-2025	17:52:00	0.36	0.00	0.00	0.00	8.70		* 125MVAR,BUS REACTOR-2 AT KAITHAL BR manually opened on Voltage Reg. (NR-9527)
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	15-01-2025	09:54:00	15-01-2025	13:37:00	0.16	0.00	0.00	0.00	3.72		* BR hand tripped for voltage regulation. NR2501-5801
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	28-01-2025	09:32:00	28-01-2025	17:01:00	0.31	0.00	0.00	0.00	7.48		* BR hand tripped for voltage regulation. NR2501-11224
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	08-01-2025	09:24:00	08-01-2025	13:12:00	0.16	0.00	0.00	0.00	3.80		* 125MVAR,BUS REACTOR-2 AT KAITHAL - Bus reactor hand tripped for voltage reg NR2501-3081.
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	18-01-2025	09:54:00	18-01-2025	19:11:00	0.39	0.00	0.00	0.00	9.28		* BR hand tripped for voltage regulation.NR2501-7163
							6.58	0.00	0.00	0.00	157.87	100.00	
BSR	25MVAR,BUS REACTOR-1 AT KARGIL GIS	SVRD	30-01-2025	09:12:00	31-01-2025	23:59:59	1.62	0.00	0.00	0.00	38.80		* SVRD BR hand tripped for voltage regulation. NR2501-12038
BSR	25MVAR,BUS REACTOR-1 AT KARGIL GIS	SVRD	22-01-2025	09:03:00	30-01-2025	04:02:00	7.79	0.00	0.00	0.00	186.98		* SVRD BR hand tripped for voltage regulation. NR2501-8672
BSR	25MVAR,BUS REACTOR-1 AT KARGIL GIS	SVRD	01-01-2025	00:00:01	22-01-2025	02:32:00	21.11	0.00	0.00	0.00	506.53		* BR hand tripped for voltage regulation. NR2412-12121
							30.52	0.00	0.00	0.00	732.31	100.00	
BSR	25MVAR,BUS REACTOR-1 AT KISHENPUR	SVRD	24-01-2025	08:43:00	24-01-2025	21:20:00	0.53	0.00	0.00	0.00	12.62		* 25MVAR,BUS REACTOR-1 AT KISHENPUR BR manually opened on Voltage Reg. (NR-9495)
BSR	25MVAR,BUS REACTOR-1 AT KISHENPUR	SVRD	17-01-2025	09:36:00	18-01-2025	21:55:00	1.51	0.00	0.00	0.00	36.32		* BR hand tripped for voltage regulation.NR2501-6708
BSR	25MVAR,BUS REACTOR-1 AT KISHENPUR	SVRD	16-01-2025										

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	25MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	01-01-2025	09:04:00	06-01-2025	01:22:00	4.68	0.00	0.00	0.00	112.30		* Bus reactor hand tripped for voltage reg.NR2501-117
BSR	25MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	26-01-2025	09:20:00	31-01-2025	23:59:59	5.61	0.00	0.00	0.00	134.67		* BR hand tripped for voltage regulation NR2501-10453
							26.07	0.00	0.00	0.00	625.86	100.00	
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	16-01-2025	09:05:00	16-01-2025	23:46:00	0.61	0.00	0.00	0.00	14.68		* BR hand tripped for voltage regulation. NR2501-6214
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	25-01-2025	09:40:00	31-01-2025	23:59:59	6.60	0.00	0.00	0.00	158.33		* BR hand tripped for voltage regulation.NR2501-10038
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	19-01-2025	08:16:00	20-01-2025	21:29:00	1.55	0.00	0.00	0.00	37.22		* SVRD BR hand tripped for voltage regulation. NR2501-7512
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	05-01-2025	09:17:00	06-01-2025	01:19:00	0.67	0.00	0.00	0.00	16.03		* BR hand tripped for voltage regulation. NR2501-1828
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	21-01-2025	10:00:00	23-01-2025	22:03:00	2.50	0.00	0.00	0.00	60.05		* SVRD BR hand tripped for voltage regulation. NR2501-8313
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	12-01-2025	09:32:00	16-01-2025	02:21:00	3.70	0.00	0.00	0.00	88.82		* BR hand tripped for voltage regulation. NR2501-4764
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	24-01-2025	08:42:00	24-01-2025	21:18:00	0.53	0.00	0.00	0.00	12.60		* 63MVAR.BUS REACTOR-1 AT KISHENPUR BR manually opened on Voltage Reg. (NR-9496)
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	06-01-2025	09:08:00	08-01-2025	21:16:00	2.51	0.00	0.00	0.00	60.13		* B/R Hand Trip for Voltage Regulation NR2501-2196
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	01-01-2025	09:00:00	03-01-2025	20:54:00	2.50	0.00	0.00	0.00	59.90		* Bus reactor hand tripped for voltage reg.NR2501-113
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	04-01-2025	09:38:00	04-01-2025	17:29:00	0.33	0.00	0.00	0.00	7.85		* SVRD BR hand tripped for voltage regulation. NR2501-1454
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	17-01-2025	09:19:00	18-01-2025	21:53:00	1.52	0.00	0.00	0.00	36.57		* BR hand tripped for voltage regulation.NR2501-6688
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	09-01-2025	08:56:00	11-01-2025	01:41:00	1.70	0.00	0.00	0.00	40.75		* Bus reactor hand tripped for voltage reg.NR2501-3498
BSR	63MVAR.BUS REACTOR-1 AT KISHENPUR	SVRD	11-01-2025	08:07:00	11-01-2025	17:19:00	0.38	0.00	0.00	0.00	9.20		* BR hand tripped for voltage regulation. NR2501-4355
							25.10	0.00	0.00	0.00	602.13	100.00	
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	06-01-2025	09:08:00	08-01-2025	21:16:00	2.51	0.00	0.00	0.00	60.13		* B/R Hand Trip for Voltage Regulation NR2501-2197
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	25-01-2025	09:40:00	31-01-2025	23:59:59	6.60	0.00	0.00	0.00	158.33		* BR hand tripped for voltage regulation.NR2501-10039
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	16-01-2025	09:05:00	16-01-2025	23:46:00	0.61	0.00	0.00	0.00	14.68		* BR hand tripped for voltage regulation. NR2501-6215
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	05-01-2025	09:17:00	06-01-2025	01:19:00	0.67	0.00	0.00	0.00	16.03		* BR hand tripped for voltage regulation. NR2501-1829
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	24-01-2025	08:42:00	24-01-2025	21:18:00	0.53	0.00	0.00	0.00	12.60		* 80MVAR.BUS REACTOR-2 AT KISHENPUR BR manually opened on Voltage Reg. (NR-9497)
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	11-01-2025	08:07:00	11-01-2025	17:19:00	0.38	0.00	0.00	0.00	9.20		* BR hand tripped for voltage regulation. NR2501-4356
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	09-01-2025	08:56:00	11-01-2025	01:41:00	1.70	0.00	0.00	0.00	40.75		* Bus reactor hand tripped for voltage reg.NR2501-3499
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	19-01-2025	08:16:00	20-01-2025	21:29:00	1.55	0.00	0.00	0.00	37.22		* SVRD BR hand tripped for voltage regulation. NR2501-7513
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	17-01-2025	09:19:00	18-01-2025	21:53:00	1.52	0.00	0.00	0.00	36.57		* BR hand tripped for voltage regulation.NR2501-6689
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	12-01-2025	09:32:00	16-01-2025	02:21:00	3.70	0.00	0.00	0.00	88.82		* BR hand tripped for voltage regulation. NR2501-4764
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	01-01-2025	09:00:00	03-01-2025	20:54:00	2.50	0.00	0.00	0.00	59.90		* Bus reactor hand tripped for voltage reg.NR2501-119
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	04-01-2025	09:38:00	04-01-2025	17:29:00	0.33	0.00	0.00	0.00	7.85		* SVRD BR hand tripped for voltage regulation. NR2501-1455
BSR	80MVAR.BUS REACTOR-2 AT KISHENPUR	SVRD	21-01-2025	10:00:00	23-01-2025	22:03:00	2.50	0.00	0.00	0.00	60.05		* SVRD BR hand tripped for voltage regulation. NR2501-8314
							25.10	0.00	0.00	0.00	602.13	100.00	
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	09-01-2025	08:52:00	11-01-2025	01:49:00	1.71	0.00	0.00	0.00	40.95		* Bus reactor hand tripped for voltage reg.NR2501-3496
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	16-01-2025	09:06:00	16-01-2025	23:48:00	0.61	0.00	0.00	0.00	14.70		* BR hand tripped for voltage regulation. NR2501-6213
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	06-01-2025	10:10:00	07-01-2025	22:24:00	1.51	0.00	0.00	0.00	36.23		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2265.
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	21-01-2025	09:51:00	24-01-2025	21:56:00	3.50	0.00	0.00	0.00	84.08		* SVRD BR hand tripped for voltage regulation. NR2501-8312
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	17-01-2025	09:21:00	18-01-2025	21:54:00	1.52	0.00	0.00	0.00	36.55		* BR hand tripped for voltage regulation.NR2501-6687
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	05-01-2025	09:20:00	06-01-2025	01:16:00	0.66	0.00	0.00	0.00	15.93		* BR hand tripped for voltage regulation. NR2501-1830
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	08-01-2025	09:27:00	08-01-2025	21:17:00	0.49	0.00	0.00	0.00	11.83		* 125MVAR.BUS REACTOR-3 AT KISHENPUR - Bus reactor hand tripped for voltage reg NR2501-3090.
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	11-01-2025	06:41:00	11-01-2025	17:20:00	0.44	0.00	0.00	0.00	10.65		* 125MVAR.BUS REACTOR-3 AT KISHENPUR manually opened on Voltage Reg. (NR-4327)
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	01-01-2025	09:09:00	03-01-2025	20:51:00	2.49	0.00	0.00	0.00	59.70		* Bus reactor hand tripped for voltage reg.NR2501-112
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	04-01-2025	09:39:00	04-01-2025	18:15:00	0.36	0.00	0.00	0.00	8.60		* SVRD BR hand tripped for voltage regulation. NR2501-1453
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	25-01-2025	09:23:00	31-01-2025	23:59:59	6.61	0.00	0.00	0.00	158.62		* BR hand tripped for voltage regulation.NR2501-10009
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	19-01-2025	08:17:00	20-01-2025	21:17:00	1.54	0.00	0.00	0.00	37.00		* SVRD BR hand tripped for voltage regulation. NR2501-7511
BSR	125MVAR.BUS REACTOR-3 AT KISHENPUR	SVRD	12-01-2025	09:34:00	16-01-2025	02:45:00	3.72	0.00	0.00	0.00	89.18		* BR hand tripped for voltage regulation. NR2501-4762
							25.16	0.00	0.00	0.00	604.02	100.00	
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	03-01-2025	09:37:00	03-01-2025	14:59:00	0.22	0.00	0.00	0.00	5.37		* BR hand tripped for voltage regulation. NR2501-999
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	01-01-2025	09:12:00	01-01-2025	16:10:00	0.29	0.00	0.00	0.00	6.97		* Bus reactor hand tripped for voltage reg.NR2501-115
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	02-01-2025	09:16:00	02-01-2025	13:21:00	0.17	0.00	0.00	0.00	4.08		* Bus reactor hand tripped for voltage reg.NR2501-522
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	11-01-2025	10:26:00	11-01-2025	17:07:00	0.28	0.00	0.00	0.00	6.68		* BR hand tripped for voltage regulation. NR2501-4425
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	21-01-2025	09:18:00	21-01-2025	15:44:00	0.27	0.00	0.00	0.00	6.43		* SVRD BR hand tripped for voltage regulation. NR2501-8267
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	18-01-2025	10:13:00	18-01-2025	15:55:00	0.24	0.00	0.00	0.00	5.70		* BR hand tripped for voltage regulation.NR2501-7172
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	15-01-2025	10:15:00	15-01-2025	16:30:00	0.26	0.00	0.00	0.00	6.25		* BR hand tripped for voltage regulation. NR2501-5818
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	13-01-2025	10:27:00	13-01-2025	13:17:00	0.12	0.00	0.00	0.00	2.83		* BR hand tripped for voltage regulation. NR2501-5055
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	10-01-2025	10:05:00	10-01-2025	16:06:00	0.25	0.00	0.00	0.00	6.02		* Bus reactor hand tripped for voltage reg.NR2501-4006
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	25-01-2025	09:49:00	25-01-2025	15:37:00	0.24	0.00	0.00	0.00	5.80		* BR hand tripped for voltage regulation.NR2501-10046
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	26-01-2025	08:58:00	26-01-2025	16:09:00	0.30	0.00	0.00	0.00	7.18		* BR hand tripped for voltage regulation.NR2501-10436
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	06-01-2025	10:17:00	08-01-2025	13:24:00	2.13	0.00	0.00	0.00	51.12		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2268.
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	20-01-2025	10:40:00	20-01-2025	15:58:00	0.22	0.00	0.00	0.00	5.30		* BR hand tripped for voltage regulation. NR2501-7893
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	29-01-2025	09:22:00	29-01-2025	16:28:00	0.30	0.00	0.00	0.00	7.10		* SVRD BR hand tripped for voltage regulation. NR2501-11669
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	27-01-2025	09:28:00	27-01-2025	16:00:00	0.27	0.00	0.00	0.00	6.53		* BR hand tripped for voltage regulation. NR2501-10805
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	24-01-2025	09:33:00	24-01-2025	16:26:00	0.29	0.00	0.00	0.00	6.88		* 80MVAR.BUS REACTOR-1 AT LUDHIANA BR manually opened on Voltage Reg.(NR-9581)
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	16-01-2025	09:33:00	16-01-2025	20:51:00	0.47	0.00	0.00	0.00	11.30		* BR hand tripped for voltage regulation. NR2501-6261
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	14-01-2025	10:24:00	14-01-2025	13:07:00	0.11	0.00	0.00	0.00	2.72		* BR hand tripped for voltage regulation. NR2501-5433
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	22-01-2025	09:29:00	22-01-2025	15:48:00	0.26	0.00	0.00	0.00	6.32		* SVRD BR hand tripped for voltage regulation. NR2501-8698
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	28-01-2025	09:13:00	28-01-2025	16:32:00	0.31	0.00	0.00	0.00	7.32		* BR hand tripped for voltage regulation. NR2501-11203
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	30-01-2025	09:33:00	30-01-2025	15:53:00	0.26	0.00	0.00	0.00	6.33		* SVRD BR hand tripped for voltage regulation. NR2501-12074
BSR	80MVAR.BUS REACTOR-1 AT LUDHIANA	SVRD	31-01-2025	09:57:00	31-01-2025	18:12:00	0.34	0.00	0.00	0.00	8.25		* 80MVAR.BUS REACTOR-1 AT LUDHIANA manually opened on Voltage Reg. (NR-12553)
							7.60	0.00	0.00	0.00	182.48	100.00	
BSR	50MVAR.BUS REACTOR-1 AT MALERKOTLA	SVRD	04-01-2025	09:32:00	04-01-2025	14:24:00	0.20	0.00	0.00	0.00	4.87		* SVRD BR hand tripped for voltage regulation. NR2501-1434
BSR	50MVAR.BUS REACTOR-1 AT MALERKOTLA	SVRD	03-01-2025	09:31:00	03-01-2025	14:51:00	0.22	0.00	0.00	0.00	5.33		* BR hand tripped for voltage regulation. NR2501-1001
BSR	50MVAR.BUS REACTOR-1 AT MALERKOTLA	SVRD	02-01-2025	09:29:00	02-01-2025	13:20:00	0.16	0.00	0.00	0.00	3.85		* Bus reactor hand tripped for voltage reg.NR2501-551
BSR	50MVAR.BUS REACTOR-1 AT MALERKOTLA	SVRD	27-01-2025	09:25:00	27-01-2025	15:59:00	0.27	0.00	0.00	0.00	6.57		* BR hand tripped for voltage regulation. NR2501-10812
BSR	50MVAR.BUS REACTOR-1 AT MALERKOTLA	SVRD	18-01-2025	09:57:00	18-01-2025	19:07:00	0.38	0.00	0.00	0.00</			

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE To ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	14-01-2025	10:22:00	14-01-2025	13:06:00	0.11	0.00	0.00	0.00	2.73		* BR hand tripped for voltage regulation. NR2501-5430
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	29-01-2025	09:21:00	29-01-2025	16:16:00	0.29	0.00	0.00	0.00	6.92		* SVRD BR hand tripped for voltage regulation. NR2501-11651
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	25-01-2025	09:53:00	25-01-2025	15:41:00	0.24	0.00	0.00	0.00	5.80		* BR hand tripped for voltage regulation.NR2501-10047
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	16-01-2025	09:22:00	16-01-2025	13:22:00	0.17	0.00	0.00	0.00	4.00		* BR hand tripped for voltage regulation. NR2501-6247
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	05-01-2025	09:25:00	05-01-2025	14:30:00	0.21	0.00	0.00	0.00	5.08		* BR hand tripped for voltage regulation. NR2501-1847
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	30-01-2025	09:43:00	30-01-2025	15:46:00	0.25	0.00	0.00	0.00	6.05		* SVRD BR hand tripped for voltage regulation. NR2501-12082
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	31-01-2025	09:55:00	31-01-2025	18:15:00	0.35	0.00	0.00	0.00	8.33		* 50MVAR,BUS REACTOR-1 AT MALERKOTLA manually opened on Voltage Reg. (NR-12557)
							3.70	0.00	0.00	0.00	89.21	100.00	
BSR	50MVAR,BUS REACTOR-1 AT MOGA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR hand tripped for voltage regulation. NR2409-2549
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	08-01-2025	09:09:00	08-01-2025	15:44:00	0.27	0.00	0.00	0.00	6.58		* 240MVAR,BUS REACTOR-1 AT MOGA - Bus reactor hand tripped for voltage reg NR2501-3041.
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	27-01-2025	08:56:00	27-01-2025	15:51:00	0.29	0.00	0.00	0.00	6.92		* BR hand tripped for voltage regulation. NR2501-10748,NL-3603
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	11-01-2025	09:15:00	11-01-2025	15:02:00	0.24	0.00	0.00	0.00	5.78		* BR hand tripped for voltage regulation. NR2501-4380, NL-1442
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	24-01-2025	08:56:00	24-01-2025	16:48:00	0.33	0.00	0.00	0.00	7.87		* 240MVAR,BUS REACTOR-1 AT MOGA BR manually opened on Voltage Reg. (NR-9511, NL-3218)
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	25-01-2025	08:53:00	25-01-2025	15:31:00	0.28	0.00	0.00	0.00	6.63		* BR hand tripped for voltage regulation.NR2501-9983,NL-3368
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	30-01-2025	09:47:00	30-01-2025	15:39:00	0.24	0.00	0.00	0.00	5.87		* SVRD BR hand tripped for voltage regulation. NR2501-12094
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	31-01-2025	09:43:00	31-01-2025	16:02:00	0.26	0.00	0.00	0.00	6.32		* 240MVAR,BUS REACTOR-1 AT MOGA manually opened on Voltage Reg. (NR-12538, NL-4252)
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	29-01-2025	09:03:00	29-01-2025	16:20:00	0.30	0.00	0.00	0.00	7.28		* SVRD BR hand tripped for voltage regulation. NR2501-11628
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	06-01-2025	09:17:00	06-01-2025	15:35:00	0.26	0.00	0.00	0.00	6.30		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2210.
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	02-01-2025	09:05:00	02-01-2025	15:16:00	0.26	0.00	0.00	0.00	6.18		* Bus reactor hand tripped for voltage reg.NR2501-509,NL-144
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	03-01-2025	09:03:00	03-01-2025	14:46:00	0.24	0.00	0.00	0.00	5.72		* BR hand tripped for voltage regulation. NR2501-920,NL-282
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	04-01-2025	08:59:00	04-01-2025	19:56:00	0.46	0.00	0.00	0.00	10.95		* SVRD BR hand tripped for voltage regulation. NR2501-1384,NL-421
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	01-01-2025	09:17:00	01-01-2025	15:14:00	0.25	0.00	0.00	0.00	5.95		* Bus reactor hand tripped for voltage reg.NR2501-144,NL-26
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	23-01-2025	08:58:00	23-01-2025	15:54:00	0.29	0.00	0.00	0.00	6.93		* 240MVAR,BUS REACTOR-1 AT MOGA BR manually opened on Voltage Reg. (NR-9070, NL-3066)
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	21-01-2025	09:01:00	21-01-2025	15:29:00	0.27	0.00	0.00	0.00	6.47		* SVRD BR hand tripped for voltage regulation. NR2501-8233, NL-2781
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	16-01-2025	09:12:00	16-01-2025	15:33:00	0.27	0.00	0.00	0.00	6.35		* BR hand tripped for voltage regulation. NR2501-6225 NL-2079
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	15-01-2025	09:05:00	15-01-2025	15:34:00	0.27	0.00	0.00	0.00	6.48		* BR hand tripped for voltage regulation. NR2501-5771 NL-1945
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	17-01-2025	08:58:00	17-01-2025	15:11:00	0.26	0.00	0.00	0.00	6.22		* BR hand tripped for voltage regulation.NR2501-6676,NL-2217
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	19-01-2025	09:42:00	19-01-2025	15:04:00	0.22	0.00	0.00	0.00	5.37		* SVRD BR hand tripped for voltage regulation. NR2501-7535
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	20-01-2025	09:10:00	20-01-2025	15:30:00	0.26	0.00	0.00	0.00	6.33		* BR hand tripped for voltage regulation. NR2501-7847 NL-2647
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	13-01-2025	10:23:00	13-01-2025	13:25:00	0.13	0.00	0.00	0.00	3.03		* BR hand tripped for voltage regulation. NR2501-5045 NL-1693
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	14-01-2025	10:18:00	14-01-2025	15:21:00	0.21	0.00	0.00	0.00	5.05		* BR hand tripped for voltage regulation. NR2501-5422 NL-1836
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	26-01-2025	09:00:00	26-01-2025	15:04:00	0.25	0.00	0.00	0.00	6.07		* BR hand tripped for voltage regulation.NR2501-10409,NL-3499
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	09-01-2025	08:59:00	09-01-2025	15:33:00	0.27	0.00	0.00	0.00	6.57		* Bus reactor hand tripped for voltage reg.NR2501-3509,NL-1102
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	18-01-2025	09:19:00	18-01-2025	16:01:00	0.28	0.00	0.00	0.00	6.70		* BR hand tripped for voltage regulation.NR2501-7130,NL-2385
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	28-01-2025	08:52:00	28-01-2025	16:14:00	0.31	0.00	0.00	0.00	7.37		* BR hand tripped for voltage regulation. NR2501-11185,NL-3761
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	05-01-2025	09:22:00	05-01-2025	14:11:00	0.20	0.00	0.00	0.00	4.82		* BR hand tripped for voltage regulation. NR2501-1852 NL-562
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	07-01-2025	09:16:00	07-01-2025	15:35:00	0.26	0.00	0.00	0.00	6.32		* 240MVAR,BUS REACTOR-1 AT MOGA - Bus reactor hand tripped for voltage reg NR2501-2619.
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	10-01-2025	09:08:00	10-01-2025	15:25:00	0.26	0.00	0.00	0.00	6.28		* Bus reactor hand tripped for voltage reg.NR2501-3958,NL-1280
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	22-01-2025	09:08:00	22-01-2025	15:19:00	0.26	0.00	0.00	0.00	6.18		* SVRD BR hand tripped for voltage regulation. NR2501-8675, NL-2936.
							7.95	0.00	0.00	0.00	190.89	100.00	
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	30-01-2025	09:57:00	30-01-2025	16:13:00	0.26	0.00	0.00	0.00	6.27		* SVRD BR hand tripped for voltage regulation. NR2501-12085
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	31-01-2025	09:11:00	31-01-2025	16:57:00	0.32	0.00	0.00	0.00	7.77		* 125MVAR,BUS REACTOR-2 AT MOGA manually opened on Voltage Reg. (NR-12488)
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	29-01-2025	09:07:00	29-01-2025	16:13:00	0.30	0.00	0.00	0.00	7.10		* SVRD BR hand tripped for voltage regulation. NR2501-11638
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	24-01-2025	08:55:00	24-01-2025	18:01:00	0.38	0.00	0.00	0.00	9.10		* 125MVAR,BUS REACTOR-2 AT MOGA BR manually opened on Voltage Reg. (NR-9498)
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	15-01-2025	09:42:00	15-01-2025	13:41:00	0.17	0.00	0.00	0.00	3.98		* BR hand tripped for voltage regulation. NR2501-5791
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	17-01-2025	09:34:00	17-01-2025	15:03:00	0.23	0.00	0.00	0.00	5.48		* BR hand tripped for voltage regulation.NR2501-6698
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	16-01-2025	09:28:00	16-01-2025	16:21:00	0.29	0.00	0.00	0.00	6.88		* BR hand tripped for voltage regulation. NR2501-6241
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	20-01-2025	08:53:00	20-01-2025	16:02:00	0.30	0.00	0.00	0.00	7.15		* BR hand tripped for voltage regulation. NR2501-7836
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	18-01-2025	09:34:00	18-01-2025	16:03:00	0.27	0.00	0.00	0.00	6.48		* BR hand tripped for voltage regulation.NR2501-7148
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	26-01-2025	09:02:00	26-01-2025	16:11:00	0.30	0.00	0.00	0.00	7.15		* BR hand tripped for voltage regulation.NR2501-10440
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	28-01-2025	09:21:00	28-01-2025	16:41:00	0.31	0.00	0.00	0.00	7.33		* BR hand tripped for voltage regulation. NR2501-11202
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	07-01-2025	10:00:00	07-01-2025	15:24:00	0.23	0.00	0.00	0.00	5.40		* 125MVAR,BUS REACTOR-2 AT MOGA - Bus reactor hand tripped for voltage reg NR2501-2667.
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	25-01-2025	09:29:00	25-01-2025	18:39:00	0.38	0.00	0.00	0.00	9.17		* BR hand tripped for voltage regulation.NR2501-10025
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	10-01-2025	08:56:00	10-01-2025	21:23:00	0.52	0.00	0.00	0.00	12.45		* Bus reactor hand tripped for voltage reg.NR2501-3929
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	22-01-2025	09:33:00	22-01-2025	15:35:00	0.25	0.00	0.00	0.00	6.03		* SVRD BR hand tripped for voltage regulation. NR2501-8712
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	27-01-2025	09:33:00	27-01-2025	16:28:00	0.29	0.00	0.00	0.00	6.92		* BR hand tripped for voltage regulation. NR2501-10749,NL-3604* 27.01.2025 10:51:23 INDIA (60018170)* BR hand tripped for voltage regulation. NR2501-10803
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	23-01-2025	08:55:00	23-01-2025	15:58:00	0.29	0.00	0.00	0.00	7.05		* 125MVAR,BUS REACTOR-2 AT MOGA BR manually opened on Voltage Reg. (NR-9069)
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	09-01-2025	09:45:00	09-01-2025	15:22:00	0.23	0.00	0.00	0.00	5.62		* Bus reactor hand tripped for voltage reg.NR2501-3567
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	08-01-2025	09:16:00	08-01-2025	18:31:00	0.39	0.00	0.00	0.00	9.25		* 125MVAR,BUS REACTOR-2 AT MOGA - Bus reactor hand tripped for voltage reg NR2501-3075.
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	14-01-2025	10:24:00	14-01-2025	15:21:00	0.21	0.00	0.00	0.00	4.95		* BR hand tripped for voltage regulation. NR2501-5434
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	05-01-2025	09:24:00	05-01-2025	13:46:00	0.18	0.00	0.00	0.00	4.37		* BR hand tripped for voltage regulation. NR2501-1848
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	19-01-2025	09:37:00	19-01-2025	15:09:00	0.23	0.00	0.00	0.00	5.53		* SVRD BR hand tripped for voltage regulation. NR2501-7547
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	11-01-2025	09:48:00	11-01-2025	17:10:00	0.31	0.00	0.00	0.00	7.37		* BR hand tripped for voltage regulation. NR2501-4407
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	21-01-2025	09:13:00	21-01-2025	15:32:00	0.26	0.00	0.00	0.00	6.32		* SVRD BR hand tripped for voltage regulation. NR2501-8253
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	02-01-2025	09:19:00	02-01-2025	13:39:00	0.18	0.00	0.00	0.00	4.33		* Bus reactor hand tripped for voltage reg.NR2501-529
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	01-01-2025	10:33:00	01-01-2025	16:25:00	0.24	0.00	0.00	0.00	5.87		* Bus reactor hand tripped for voltage reg.NR2501-175
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	03-01-2025	09:17:00	03-01-2025	15:13:00	0.25	0.00	0.00	0.00	5.93		* BR hand tripped for voltage regulation. NR2501-960
BSR	125MVAR,BUS REACTOR-2 AT MOGA	SVRD	04-01-2025	09:32:00	04-01-2025	14:07:00	0.19	0.00	0.00	0.00	4.58		* SVRD BR hand tripped for voltage regulation. NR2501-1427
							7.76	0.00	0.00	0.00	185.83	100.00	
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	20-01-2025	09:11:00	20-01-2025	15:34:00	0.27	0.00	0.00	0.00	6.38		* BR hand tripped for voltage regulation. NR2501-7848 NL-2648
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD											

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	17-01-2025	09:44:00	17-01-2025	15:12:00	0.23	0.00	0.00	0.00	5.47		* BR hand tripped for voltage regulation.NR2501-6702.NL-2226
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	28-01-2025	08:55:00	28-01-2025	16:15:00	0.31	0.00	0.00	0.00	7.33		* BR hand tripped for voltage regulation. NR2501-11186,NL-3762
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	24-01-2025	09:12:00	24-01-2025	16:50:00	0.32	0.00	0.00	0.00	7.63		* 240MVAR,BUS REACTOR-2 AT MOGA BR manually opened on Voltage Reg. (NR-9544, NL-3228)
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	29-01-2025	09:04:00	29-01-2025	17:58:00	0.37	0.00	0.00	0.00	8.90		* SVRD BR hand tripped for voltage regulation. NR2501-11629
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	31-01-2025	09:24:00	31-01-2025	17:05:00	0.32	0.00	0.00	0.00	7.68		* 240MVAR,BUS REACTOR-2 AT MOGA manually opened on Voltage Reg. (NR-12519, NL-4246)
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	30-01-2025	09:11:00	30-01-2025	15:55:00	0.28	0.00	0.00	0.00	6.73		* SVRD BR hand tripped for voltage regulation. NR2501-12037
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	18-01-2025	09:30:00	18-01-2025	16:02:00	0.27	0.00	0.00	0.00	6.53		* BR hand tripped for voltage regulation.NR2501-7140.NL-2395
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	26-01-2025	08:58:00	26-01-2025	15:06:00	0.26	0.00	0.00	0.00	6.13		* BR hand tripped for voltage regulation.NR2501-10410,NL-3500
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	03-01-2025	09:04:00	03-01-2025	14:47:00	0.24	0.00	0.00	0.00	5.72		* BR hand tripped for voltage regulation. NR2501-921,NL-283
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	04-01-2025	09:00:00	04-01-2025	13:30:00	0.19	0.00	0.00	0.00	4.50		* SVRD BR hand tripped for voltage regulation. NR2501-1385,NL-422
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	02-01-2025	09:43:00	02-01-2025	15:18:00	0.23	0.00	0.00	0.00	5.58		* Bus reactor hand tripped for voltage reg.NR2501-523,NL-148
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	01-01-2025	10:08:00	01-01-2025	15:25:00	0.22	0.00	0.00	0.00	5.28		* Bus reactor hand tripped for voltage reg.NR2501-165,NL-36
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	23-01-2025	09:25:00	23-01-2025	15:56:00	0.27	0.00	0.00	0.00	6.52		* 240MVAR,BUS REACTOR-2 AT MOGA BR manually opened on Voltage Reg. (NR-9105, NL-3083)
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	21-01-2025	09:02:00	21-01-2025	15:30:00	0.27	0.00	0.00	0.00	6.47		* SVRD BR hand tripped for voltage regulation. NR2501-8234, NL-2782
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	10-01-2025	09:30:00	10-01-2025	15:37:00	0.26	0.00	0.00	0.00	6.12		* Bus reactor hand tripped for voltage reg.NR2501-3960,NL-1281
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	15-01-2025	09:38:00	15-01-2025	16:48:00	0.30	0.00	0.00	0.00	7.17		* BR hand tripped for voltage regulation. NR2501-5789,NL-1959
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	06-01-2025	09:43:00	06-01-2025	15:48:00	0.25	0.00	0.00	0.00	6.08		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2226.
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	25-01-2025	08:55:00	25-01-2025	15:32:00	0.28	0.00	0.00	0.00	6.62		* BR hand tripped for voltage regulation.NR2501-9984,NL-3369
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	11-01-2025	10:36:00	11-01-2025	15:08:00	0.19	0.00	0.00	0.00	4.53		* BR hand tripped for voltage regulation. NR2501-4426, NL-1460
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	27-01-2025	08:57:00	27-01-2025	15:54:00	0.29	0.00	0.00	0.00	6.95		* BR hand tripped for voltage regulation. NR2501-10749,NL-3604
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	14-01-2025	10:18:00	14-01-2025	16:02:00	0.24	0.00	0.00	0.00	5.73		* BR hand tripped for voltage regulation. NR2501-5423,NL-1837
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	08-01-2025	09:30:00	08-01-2025	15:46:00	0.26	0.00	0.00	0.00	6.27		* 240MVAR,BUS REACTOR-2 AT MOGA - Bus reactor hand tripped for voltage reg. NR2501-3097.
BSR	240MVAR,BUS REACTOR-2 AT MOGA	SVRD	22-01-2025	09:09:00	22-01-2025	17:44:00	0.36	0.00	0.00	0.00	8.58		* SVRD BR hand tripped for voltage regulation. NR2501-8689, NL-2946
							7.74	0.00	0.00	0.00	185.04	100.00	
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	26-01-2025	09:09:00	26-01-2025	16:19:00	0.30	0.00	0.00	0.00	7.17		* BR hand tripped for voltage regulation.NR2501-10452
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	03-01-2025	09:34:00	03-01-2025	14:48:00	0.22	0.00	0.00	0.00	5.23		* BR hand tripped for voltage regulation. NR2501-1015
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	04-01-2025	09:37:00	04-01-2025	16:01:00	0.27	0.00	0.00	0.00	6.40		* SVRD BR hand tripped for voltage regulation. NR2501-1449
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	24-01-2025	09:20:00	24-01-2025	17:11:00	0.33	0.00	0.00	0.00	7.85		* 0MVAR,BUS REACTOR-1 AT NALAGARH BR manually opened on Voltage Reg. (NR-9558)
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	27-01-2025	09:19:00	27-01-2025	16:01:00	0.28	0.00	0.00	0.00	6.70		* BR hand tripped for voltage regulation. NR2501-10789
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	10-01-2025	10:19:00	10-01-2025	15:44:00	0.23	0.00	0.00	0.00	5.42		* Bus reactor hand tripped for voltage reg.NR2501-4014
BSR	50MVAR,BUS REACTOR-1 AT NALAGARH	SVRD	31-01-2025	09:58:00	31-01-2025	18:17:00	0.35	0.00	0.00	0.00	8.32		* 50MVAR,BUS REACTOR-1 AT NALAGARH manually opened on Voltage Reg. (NR-12552)
							1.98	0.00	0.00	0.00	47.09	100.00	
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	03-01-2025	09:35:00	03-01-2025	14:48:00	0.22	0.00	0.00	0.00	5.22		* BR hand tripped for voltage regulation. NR2501-998
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	02-01-2025	10:54:00	02-01-2025	13:24:00	0.10	0.00	0.00	0.00	2.50		* Bus reactor hand tripped for voltage reg.NR2501-602
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	04-01-2025	09:38:00	04-01-2025	16:02:00	0.27	0.00	0.00	0.00	6.40		* SVRD BR hand tripped for voltage regulation. NR2501-1448
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	10-01-2025	10:21:00	10-01-2025	15:44:00	0.22	0.00	0.00	0.00	5.38		* Bus reactor hand tripped for voltage reg.NR2501-4012
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	24-01-2025	09:21:00	24-01-2025	17:10:00	0.33	0.00	0.00	0.00	7.82		* 125MVAR,BUS REACTOR-2 AT NALAGARH BR manually opened on Voltage Reg. (NR-9557)
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	26-01-2025	09:07:00	26-01-2025	16:21:00	0.30	0.00	0.00	0.00	7.23		* BR hand tripped for voltage regulation.NR2501-10451
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	27-01-2025	09:28:00	27-01-2025	16:02:00	0.27	0.00	0.00	0.00	6.57		* BR hand tripped for voltage regulation. NR2501-10788
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	30-01-2025	09:44:00	30-01-2025	15:43:00	0.25	0.00	0.00	0.00	5.98		* SVRD BR hand tripped for voltage regulation. NR2501-12121
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	31-01-2025	10:01:00	31-01-2025	18:20:00	0.35	0.00	0.00	0.00	8.32		* 125MVAR,BUS REACTOR-2 AT NALAGARH manually opened on Voltage Reg. (NR-12549)
							2.31	0.00	0.00	0.00	55.42	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	14-01-2025	10:23:00	14-01-2025	13:16:00	0.12	0.00	0.00	0.00	2.88		* BR hand tripped for voltage regulation. NR2501-5431
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	10-01-2025	08:59:00	10-01-2025	21:27:00	0.52	0.00	0.00	0.00	12.47		* Bus reactor hand tripped for voltage reg.NR2501-3938
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	18-01-2025	10:18:00	18-01-2025	15:51:00	0.23	0.00	0.00	0.00	5.55		* BR hand tripped for voltage regulation.NR2501-7173
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	24-01-2025	09:34:00	24-01-2025	17:56:00	0.35	0.00	0.00	0.00	8.37		* 125MVAR,BUS REACTOR-1 AT PATIALA BR manually opened on Voltage Reg. (NR-9579)
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	16-01-2025	09:28:00	16-01-2025	16:41:00	0.30	0.00	0.00	0.00	7.22		* BR hand tripped for voltage regulation. NR2501-6242
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	27-01-2025	09:21:00	27-01-2025	16:19:00	0.29	0.00	0.00	0.00	6.97		* BR hand tripped for voltage regulation. NR2501-10784
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	11-01-2025	09:17:00	11-01-2025	17:16:00	0.33	0.00	0.00	0.00	7.98		* BR hand tripped for voltage regulation. NR2501-4370
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	07-01-2025	09:20:00	07-01-2025	15:40:00	0.26	0.00	0.00	0.00	6.33		* 125MVAR,BUS REACTOR-1 AT PATIALA - Bus reactor hand tripped for voltage reg NR2501-2637.
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	21-01-2025	09:32:00	21-01-2025	15:43:00	0.26	0.00	0.00	0.00	6.18		* SVRD BR hand tripped for voltage regulation. NR2501-8282
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	25-01-2025	09:56:00	25-01-2025	15:35:00	0.24	0.00	0.00	0.00	5.65		* BR hand tripped for voltage regulation.NR2501-10048
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	28-01-2025	09:36:00	28-01-2025	16:38:00	0.29	0.00	0.00	0.00	7.03		* BR hand tripped for voltage regulation. NR2501-11227
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	13-01-2025	10:27:00	13-01-2025	13:21:00	0.12	0.00	0.00	0.00	2.90		* BR hand tripped for voltage regulation. NR2501-5053
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	20-01-2025	10:33:00	20-01-2025	16:03:00	0.23	0.00	0.00	0.00	5.50		* BR hand tripped for voltage regulation. NR2501-7891
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	22-01-2025	09:30:00	22-01-2025	15:38:00	0.26	0.00	0.00	0.00	6.13		* SVRD BR hand tripped for voltage regulation. NR2501-8699
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	09-01-2025	09:13:00	09-01-2025	15:32:00	0.26	0.00	0.00	0.00	6.32		* Bus reactor hand tripped for voltage reg.NR-2501-3524
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	26-01-2025	09:15:00	26-01-2025	16:22:00	0.30	0.00	0.00	0.00	7.12		* BR hand tripped for voltage regulation.NR2501-10449
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	29-01-2025	09:18:00	29-01-2025	16:26:00	0.30	0.00	0.00	0.00	7.13		* SVRD BR hand tripped for voltage regulation. NR2501-11664
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	06-01-2025	09:46:00	06-01-2025	15:49:00	0.25	0.00	0.00	0.00	6.05		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2233.
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	05-01-2025	09:23:00	05-01-2025	14:28:00	0.21	0.00	0.00	0.00	5.08		* BR hand tripped for voltage regulation. NR2501-1844
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	23-01-2025	09:11:00	23-01-2025	16:24:00	0.30	0.00	0.00	0.00	7.22		* 125MVAR,BUS REACTOR-1 AT PATIALA BR manually opened on Voltage Reg. (NR-9086)
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	30-01-2025	09:34:00	30-01-2025	15:50:00	0.26	0.00	0.00	0.00	6.27		* SVRD BR hand tripped for voltage regulation. NR2501-12078
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	31-01-2025	09:16:00	31-01-2025	19:47:00	0.44	0.00	0.00	0.00	10.52		* 125MVAR,BUS REACTOR-1 AT PATIALA manually opened on Voltage Reg. (NR-12500)
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	08-01-2025	09:22:00	08-01-2025	13:18:00	0.16	0.00	0.00	0.00	3.93		* 125MVAR,BUS REACTOR-1 AT PATIALA - Bus reactor hand tripped for voltage reg NR-2501-3072.
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	03-01-2025	09:17:00	03-01-2025	15:09:00	0.24	0.00	0.00	0.00	5.87		* BR hand tripped for voltage regulation. NR2501-961
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	04-01-2025	09:42:00	04-01-2025	15:11:00	0.23	0.00	0.00	0.00	5.48		* SVRD BR hand tripped for voltage regulation. NR2501-1456
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	02-01-2025	09:21:00	02-01-2025	13:32:00	0.17	0.00	0.00	0.00	4.18		* Bus reactor hand tripped for voltage reg.NR2501-532
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	01-01-2025	09:56:00	01-01-2025	13:28:00	0.15	0.00	0.00	0.00	3.53		* Bus reactor hand tripped for voltage reg.NR2501-153
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	15-01-2025	09:53:00	15-01-2025	13:39:00	0.16	0.00	0.00	0.00	3.77		* BR hand tripped for voltage regulation. NR2501-5803
							7.23	0.00	0.00	0.00	173.63	100.00	
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	31-01-2025	09:16:00	31-01-2025	20:01:00	0.45	0.00	0.0				

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	15-01-2025	09:53:00	15-01-2025	13:39:00	0.16	0.00	0.00	0.00	3.77		* BR hand tripped for voltage regulation. NR2501-5804
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	16-01-2025	09:28:00	16-01-2025	16:41:00	0.30	0.00	0.00	0.00	7.22		* BR hand tripped for voltage regulation. NR2501-6248
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	25-01-2025	09:54:00	25-01-2025	15:35:00	0.24	0.00	0.00	0.00	5.68		* BR hand tripped for voltage regulation.NR2501-10049
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	11-01-2025	09:17:00	11-01-2025	17:16:00	0.33	0.00	0.00	0.00	7.98		* BR hand tripped for voltage regulation. NR2501-4372
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	26-01-2025	09:14:00	26-01-2025	16:13:00	0.29	0.00	0.00	0.00	6.98		* BR hand tripped for voltage regulation.NR2501-10450
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	14-01-2025	10:23:00	14-01-2025	13:16:00	0.12	0.00	0.00	0.00	2.88		* BR hand tripped for voltage regulation. NR2501-5432
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	06-01-2025	09:45:00	06-01-2025	15:49:00	0.25	0.00	0.00	0.00	6.07		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2234.
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	21-01-2025	09:32:00	21-01-2025	15:43:00	0.26	0.00	0.00	0.00	6.18		* SVRD BR hand tripped for voltage regulation. NR2501-8283
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	23-01-2025	09:10:00	23-01-2025	16:25:00	0.30	0.00	0.00	0.00	7.25		* 125MVAR,BUS REACTOR-2 AT PATIALA BR manually opened on Voltage Reg. (NR-9087)
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	13-01-2025	10:27:00	13-01-2025	13:21:00	0.12	0.00	0.00	0.00	2.90		* BR hand tripped for voltage regulation. NR2501-5054
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	24-01-2025	09:34:00	24-01-2025	17:56:00	0.35	0.00	0.00	0.00	8.37		* 125MVAR,BUS REACTOR-2 AT PATIALA BR manually opened on Voltage Reg. (NR-9580)
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	27-01-2025	09:21:00	27-01-2025	16:19:00	0.29	0.00	0.00	0.00	6.97		* BR hand tripped for voltage regulation. NR2501-10785
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	10-01-2025	08:58:00	10-01-2025	21:27:00	0.52	0.00	0.00	0.00	12.48		* Bus reactor hand tripped for voltage reg.NR2501-3939
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	22-01-2025	09:30:00	22-01-2025	15:38:00	0.26	0.00	0.00	0.00	6.13		* SVRD BR hand tripped for voltage regulation. NR2501-8700
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	18-01-2025	10:15:00	18-01-2025	15:51:00	0.23	0.00	0.00	0.00	5.60		* BR hand tripped for voltage regulation.NR2501-7174
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	05-01-2025	09:23:00	05-01-2025	14:28:00	0.21	0.00	0.00	0.00	5.08		* BR hand tripped for voltage regulation. NR2501-1845
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	01-01-2025	09:54:00	01-01-2025	13:28:00	0.15	0.00	0.00	0.00	3.57		* Bus reactor hand tripped for voltage reg.NR2501-152
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	02-01-2025	09:21:00	02-01-2025	13:33:00	0.18	0.00	0.00	0.00	4.20		* Bus reactor hand tripped for voltage reg.NR2501-533
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	04-01-2025	09:42:00	04-01-2025	15:11:00	0.23	0.00	0.00	0.00	5.48		* SVRD BR hand tripped for voltage regulation. NR2501-1457
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	03-01-2025	09:17:00	03-01-2025	15:09:00	0.24	0.00	0.00	0.00	5.87		* BR hand tripped for voltage regulation. NR2501-962
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	08-01-2025	09:21:00	08-01-2025	13:18:00	0.17	0.00	0.00	0.00	3.95		* 125MVAR,BUS REACTOR-2 AT PATIALA - Bus reactor hand tripped for voltage reg NR2501-3076.
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	29-01-2025	09:18:00	29-01-2025	16:26:00	0.30	0.00	0.00	0.00	7.13		* SVRD BR hand tripped for voltage regulation. NR2501-11665
							7.25	0.00	0.00	0.00	173.97	100.00	
BSR	25MVAR,BUS REACTOR-1 AT LEH GIS	SVRD	01-01-2025	00:00:01	06-01-2025	00:58:00	5.04	0.00	0.00	0.00	120.97		* Bus reactor hand tripped for voltage reg.NR2412-13100
BSR	25MVAR,BUS REACTOR-1 AT LEH GIS	SVRD	23-01-2025	08:59:00	24-01-2025	02:09:00	0.72	0.00	0.00	0.00	17.17		* 25MVAR,BUS REACTOR-1 AT LEH GIS BR manually opened on Voltage Reg. (NR-9074)
BSR	25MVAR,BUS REACTOR-1 AT LEH GIS	SVRD	31-01-2025	07:29:00	31-01-2025	23:59:59	0.69	0.00	0.00	0.00	16.52		* 25MVAR,BUS REACTOR-1 AT LEH GIS anually opened on Voltage Reg. (NR-12474)
BSR	25MVAR,BUS REACTOR-1 AT LEH GIS	SVRD	24-01-2025	08:51:00	31-01-2025	01:28:00	6.69	0.00	0.00	0.00	160.62		* 25MVAR,BUS REACTOR-1 AT LEH GIS BR manually opened on Voltage Reg. (NR-9512)
BSR	25MVAR,BUS REACTOR-1 AT LEH GIS	SVRD	15-01-2025	09:18:00	23-01-2025	01:43:00	7.68	0.00	0.00	0.00	184.42		* BR hand tripped for voltage regulation. NR2501-5781
BSR	25MVAR,BUS REACTOR-1 AT LEH GIS	SVRD	06-01-2025	10:58:00	15-01-2025	03:12:00	8.68	0.00	0.00	0.00	208.23		* Bus Reactor Hand Trip for Voltage Regulation NR2501-2293.
							29.50	0.00	0.00	0.00	707.93	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PANCHKULA	SVRD	04-01-2025	09:33:00	04-01-2025	14:22:00	0.20	0.00	0.00	0.00	4.82		* SVRD BR hand tripped for voltage regulation. NR2501-1440
BSR	125MVAR,BUS REACTOR-1 AT PANCHKULA	SVRD	08-01-2025	09:21:00	08-01-2025	13:13:00	0.16	0.00	0.00	0.00	3.87		* 125MVAR,BUS REACTOR-1 AT PANCHKULA - Bus reactor hand tripped for voltage reg NR2501-3071.
BSR	125MVAR,BUS REACTOR-1 AT PANCHKULA	SVRD	25-01-2025	09:45:00	25-01-2025	15:42:00	0.25	0.00	0.00	0.00	5.95		* BR hand tripped for voltage regulation.NR2501-10050
BSR	125MVAR,BUS REACTOR-1 AT PANCHKULA	SVRD	27-01-2025	09:23:00	27-01-2025	16:09:00	0.28	0.00	0.00	0.00	6.77		* BR hand tripped for voltage regulation. NR2501-10811
BSR	125MVAR,BUS REACTOR-1 AT PANCHKULA	SVRD	28-01-2025	09:49:00	28-01-2025	16:25:00	0.28	0.00	0.00	0.00	6.60		* BR hand tripped for voltage regulation. NR2501-11243
BSR	125MVAR,BUS REACTOR-1 AT PANCHKULA	SVRD	29-01-2025	09:31:00	29-01-2025	16:30:00	0.29	0.00	0.00	0.00	6.98		* SVRD BR hand tripped for voltage regulation. NR2501-11689
BSR	125MVAR,BUS REACTOR-1 AT PANCHKULA	SVRD	31-01-2025	10:03:00	31-01-2025	16:03:00	0.25	0.00	0.00	0.00	6.00		* 125MVAR,BUS REACTOR-1 AT PANCHKULA manually opened on Voltage Reg. (NR-12565)
BSR	125MVAR,BUS REACTOR-1 AT PANCHKULA	SVRD	30-01-2025	09:31:00	30-01-2025	16:07:00	0.28	0.00	0.00	0.00	6.60		* SVRD BR hand tripped for voltage regulation. NR2501-12073
							1.99	0.00	0.00	0.00	47.59	100.00	
BSR	125MVAR,BUS REACTOR-2 AT PANCHKULA	SVRD	31-01-2025	10:09:00	31-01-2025	17:40:00	0.31	0.00	0.00	0.00	7.52		* 125MVAR,BUS REACTOR-2 AT PANCHKULA manually opened on Voltage Reg. (NR-12566)
BSR	125MVAR,BUS REACTOR-2 AT PANCHKULA	SVRD	03-01-2025	09:33:00	03-01-2025	14:49:00	0.22	0.00	0.00	0.00	5.27		* BR hand tripped for voltage regulation. NR2501-996
							0.53	0.00	0.00	0.00	12.79	100.00	
BSR	80MVAR,BUS REACTOR-1 AT SAMBA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR hand tripped for voltage regulation. NR2412-12131
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	50MVAR,BUS REACTOR-1 AT WAGOORA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR hand tripped for voltage regulation. NR2412-12108
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	50MVAR,BUS REACTOR-2 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR,BUS REACTOR-3 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT NEW WANPOH	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR hand tripped for voltage regulation. NR2412-12107
BSR	125MVAR,BUS REACTOR-1 AT NEW WANPOH	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* B/R hand tripped for voltage regulation. NR 2311-425
							62.00	0.00	0.00	0.00	1,488.00	100.00	
CKT	132kV MAHANPUR(JKPDD)-KATHUA(JKPDD)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV SEWA2(NHPC)-HIRANAGAR(JKPDD)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV SEWA2(NHPC)-HIRANAGAR(JKPDD)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kV SEWA2(NHPC)-KATHUA(JKPDD)	OSFT	11-01-2025	23:04:00	12-01-2025	01:01:00	0.08	1.95	0.00	0.00	0.00		* Line taken under emergency shutdown to attend hotspot on B-Ph line isolator (line side) at Kathua SS NR2501-4641
							0.08	1.95	0.00	0.00	0.00	99.74	
CKT	132kV SEWA2(NHPC)-MAHANPUR(JKPDD)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV BAIRASIUL(NHPC)-JESSORE(HPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV BAIRASIUL(NHPC)-PONG(BBMB)	GOVC	16-01-2025	02:02:00	16-01-2025	08:25:00	0.27	0.00	0.00	6.38	0.00		* Line tripped on Overvoltage from Bairasuil end only and remains charged from Pong end. NR2501-6201
							0.27	0.00	0.00	6.38	0.00	100.00	
CKT	220kV CHAMERA3(NHPC)-CHAMBA-1	OSPD	31-01-2025	09:40:00	31-01-2025	16:58:00	0.30	0.00	0.00	0.00	7.30		* 220kV CHAMERA3(NHPC)-CHAMBA-1 taken under SD by Chamera_3 NHPC for dismantling of old gantry structure at Chamera_3 (NR-12512)
							0.30	0.00	0.00	0.00	7.30	100.00	
CKT	220kV CHAMERA3(NHPC)-CHAMBA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV CHOWADHI(JKPDD)-SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-DRASS ALUSTENG CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-DRASS KARGIL CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV HAMIRPUR-HAMIRPUR(HPSEB)-1	OSFT	08-01-2025	12:26:00	08-01-2025	16:43:00	0.18	4.28	0.00	0.00	0.00		* 220kV HAMIRPUR-HAMIRPUR(HPSEB)-1 - Forced Shutdown (e.g. E/W snappings/hots NR2501-3170.* Insulator broken . Emergency shutdown for replacement of broken CLR polymer insulator at Loc. no. 05.
							0.18	4.28	0.00	0.00	0.00	99.42	
CKT	220kV HAMIRPUR-HAMIRPUR(HPSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-HAMIRPUR(PG)-NEHRIAN(HP)-1	SRMU	25-01-2025	20:11:08	25-01-2025	21:02:00	0.04	0.00	0.85	0.00	0.00		* Line sucessfully Autoreclosed from Hamirpur end on R-N but tripped from Nehrian end. FLR Hamirpur (AFAS): R-N fault ,FL= 7.149 km,8.9616 kA.* 01.02.2025 19:28:09 INDIA (60003416)* Flashover marks observed on jumper conductors and hardware fittings at 343.Probable cause of tripping may be migratory birds
							0.04	0.00	0.85	0.00	0.00	100.00	
CKT	220KV-HAMIRPUR(PG)-NEHRIAN(HP)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-HIRANAGAR(JKPDD)-SAMBA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV JALLANDHAR-DASUA PSTCL-1	OSPT	07-01-2025	10:52:00	07-01-2025	18:56:00	0.34	8.07	0.00	0.00	0.00		* 220KV JALLANDHAR-DASUA PSTCL-1 - Planned Shutdown for maintenance work NR2501-2686.
							0.34	8.07	0.00	0.00	0.00	98.92	
CKT	220KV JALLANDHAR-DASUA PSTCL-2	OSPT	06-01-2025	10:50:00	06-01-2025	18:29:00	0.32	7.65	0.00	0.00	0.00		* OSPT SD taken for AMP and Insulator washing works. NR2501-2286
							0.32	7.65	0.00	0.00	0.00	98.97	
CKT	220KV-JALANDHAR-NEHRIAN(HPSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-JALANDHAR-NEHRIAN(HPSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV JAMMU(JKPDD)-CHOWADHI (JKPDD)	OSFD	28-01-2025	18:07:00	28-01-2025	18:39:00	0.02	0.00	0.00	0.00	0.53		* OSFD Emergency SD taken by JKPTCL for rectification of sparking on Y-Phase line isolator at Chowadhi SS. NR2501-11459
							0.02	0.00	0.00	0.00	0.53	100.00	
CKT	220kV JESSORE(HPTCL)-PONG(BBMB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-KARGIL KHALSTI CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KISHANGANGA(NHPC)-DELINA(JKPDD)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KISHANGANGA(NHPC)-DELINA(JKPDD)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KISHENPUR-SARNA(PSTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KISHENPUR-SARNA(PSTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-PHYANG KHALTSE CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV PANCHKULA-CHANDIGARH-1	OMSU	05-01-2025	12:45:00	05-01-2025	18:58:00	0.26	0.00	6.22	0.00	0.00		* Line tripped on R-Y fault.FLR Panchkula: 10.732kA, FL=11.474km (Line Length: 23.84 km), FLR Chandigarh: 11.47km. Kite Thread found at Earth wire in span between location no. 33-34 .
							0.26	0.00	6.22	0.00	0.00	100.00	
CKT	220kV PANCHKULA CHANDIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SALAL(NHPC)-JAMMU(JKPDD)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-SALAL(NHPC)-JAMMU(JKPDD)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-1	LCSD	27-01-2025	10:40:00	27-01-2025	21:03:00	0.43	0.00	0.00	0.00	10.38		* Shutdown taken for stringing of 400KV Kishtwar-Kishenpur line and Maintenance work. NR2501-10860
							0.43	0.00	0.00	0.00	10.38	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-2	LCSD	27-01-2025	10:40:00	27-01-2025	21:04:00	0.43	0.00	0.00	0.00	10.40		* Shutdown taken for stringing of 400KV Kishtwar- Kishenpur line and Maintenance work. NR2501-10859
							0.43	0.00	0.00	0.00	10.40	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SARNA(PSTCL)-DASUYA(PSTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SARNA(PSTCL)-DASUYA(PSTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SARNA(PSTCL)-HIRANAGAR(JKPDD)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV UDHAMPUR(JKPDD)-KISHENPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV UDHAMPUR(JKPDD)-KISHENPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-WAGOORA-KISHENGANGA(NHPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-WAGOORA-KISHENGANGA(NHPC)-2	SBBU	13-01-2025	21:36:00	14-01-2025	00:54:00	0.14	0.00	3.30	0.00	0.00		* Line tripped from Kisgenganga (NHPC) end only due to Bus Bar relay maloperation and remain charged from Wagoora(PG) end. NR2501-5266
							0.14	0.00	3.30	0.00	0.00	100.00	
CKT	220kV WAGOORA-PAMPORE(JKPDD)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV WAGOORA-PAMPORE(JKPDD)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ABDULLAPUR-BAWANA(DTL)	LCSD	14-01-2025	10:53:00	15-01-2025	18:04:00	1.30	0.00	0.00	0.00	31.18		* SD taken by NR-1 for 41189L isolator retrofitting work at Bawana end under ADD CAP work. NR2501-5442
CKT	400kV ABDULLAPUR-BAWANA(DTL)	LCSD	05-01-2025	11:00:00	07-01-2025	20:44:00	2.41	0.00	0.00	0.00	57.73		* SD taken by NR-1 for 41289A isolator retrofitting work under ADD CAP work. NR2501-1896
							3.71	0.00	0.00	0.00	88.91	100.00	

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	03-01-2025	23:55:00	04-01-2025	05:57:00	0.25	0.00	0.00	0.00	6.03		* Line hand tripped for voltage regulation.NR2501-1299
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	03-01-2025	00:22:00	03-01-2025	06:02:00	0.24	0.00	0.00	0.00	5.67		* 400kV ABDULLAPUR-DEPALPUR(HVPNL) Line manually opened on voltage reg. (NR-828)
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	05-01-2025	00:10:00	05-01-2025	06:13:00	0.25	0.00	0.00	0.00	6.05		* Line hand tripped for voltage regulation.NR2501-1718
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	01-01-2025	00:18:00	01-01-2025	06:03:00	0.24	0.00	0.00	0.00	5.75		* LVRD Line hand tripped on voltage regulation. NR2501-5
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	01-01-2025	21:12:00	02-01-2025	06:40:00	0.39	0.00	0.00	0.00	9.47		* 400kV ABDULLAPUR-DEPALPUR(HVPNL) Line manually opened on voltage reg. (NR-382)
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	11-01-2025	22:03:00	12-01-2025	06:09:00	0.34	0.00	0.00	0.00	8.10		* Line hand tripped for voltage regulation.NR2501-4631
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	23-01-2025	23:45:00	24-01-2025	06:25:00	0.28	0.00	0.00	0.00	6.67		* LVRD Line hand tripped on voltage regulation. NR2501-9401
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	08-01-2025	00:02:00	08-01-2025	09:19:00	0.39	0.00	0.00	0.00	9.28		* Line hand tripped on voltage regulation. NR2501-2918
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	06-01-2025	21:44:00	07-01-2025	05:57:00	0.34	0.00	0.00	0.00	8.22		* Line hand tripped on voltage regulation. NR2501-2465
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	21-01-2025	21:55:00	22-01-2025	06:30:00	0.36	0.00	0.00	0.00	8.58		* Line hand tripped on voltage regulation. NR2501-8538
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	19-01-2025	21:25:00	20-01-2025	06:05:00	0.36	0.00	0.00	0.00	8.67		* Line hand tripped for voltage regulation.NR2501-7687
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	19-01-2025	00:04:00	19-01-2025	05:25:00	0.22	0.00	0.00	0.00	5.35		* Line hand tripped on voltage regulation. NR2501-7407
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	11-01-2025	00:46:00	11-01-2025	07:18:00	0.27	0.00	0.00	0.00	6.53		* 400kV ABDULLAPUR-DEPALPUR(HVPNL) Line manually opened on voltage reg. (NR-4268)
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	27-01-2025	00:12:00	27-01-2025	07:22:00	0.30	0.00	0.00	0.00	7.17		* 400kV ABDULLAPUR-DEPALPUR(HVPNL) Line manually opened on voltage reg. (NR-10658)
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	29-01-2025	22:58:00	30-01-2025	06:21:00	0.31	0.00	0.00	0.00	7.38		* Line hand tripped on voltage regulation. NR2501-11935
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	09-01-2025	00:00:01	09-01-2025	05:59:00	0.25	0.00	0.00	0.00	5.98		* LVRD Line hand tripped on voltage regulation. NR2501-3396
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	05-01-2025	22:05:00	06-01-2025	06:45:00	0.36	0.00	0.00	0.00	8.67		* Line hand tripped on voltage regulation. NR2501-2047
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	16-01-2025	01:43:00	16-01-2025	05:42:00	0.17	0.00	0.00	0.00	3.98		* LVRD Line hand tripped on voltage regulation. NR2501-6107
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	09-01-2025	21:01:00	10-01-2025	05:33:00	0.36	0.00	0.00	0.00	8.53		* Line hand tripped on voltage regulation. NR2501-3789
CKT	400kV ABDULLAPUR-DEPALPUR(HVPNL)	LVRD	30-01-2025	23:03:00	31-01-2025	07:00:00	0.33	0.00	0.00	0.00	7.95		* Line hand tripped on voltage regulation. NR2501-12385
							6.01	0.00	0.00	0.00	144.03	100.00	
CKT	400kV ABDULLAPUR-KURUKSHETRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ABDULLAPUR-KURUKSHETRA-2	LHWT	16-01-2025	02:02:00	16-01-2025	04:40:00	0.11	2.63	0.00	0.00	0.00		* "Line tripped on Y-N fault. FLR Kurukshetra: 800Mtr, 25kA and Abdullapur: 10.042kA, 51.65kM (100%), Zone-2 Optd.* Charging attempt taken from Abdullapur SS at 04:40 Hrs. dt. 16.01.2025 wide NRLDC charging code: NR2501-6121 but Line not Hold, FLR Abdullapur (M-2) Y-N fault, 12 kA, SOTF Optd." NR2501-6121" 16.01.2025 14:53:58 INDIA (60003416)" Y-Ph Insulator decapped at loc 05
CKT	400kV ABDULLAPUR-KURUKSHETRA-2	OSFT	16-01-2025	04:40:00	16-01-2025	16:59:00	0.51	12.32	0.00	0.00	0.00		* Line then taken under shutdown for fault identification after Charging attempt. On Patrolling by Abdullapur TLM Y-Phase Insulator found Decapped at Tloc 05. NR2501-6204
							0.62	14.95	0.00	0.00	0.00	97.99	
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	17-01-2025	21:37:00	18-01-2025	06:22:00	0.37	0.00	0.00	0.00	8.75		* Line hand tripped on voltage regulation. NR2501-6972
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	02-01-2025	21:54:00	03-01-2025	06:28:00	0.36	0.00	0.00	0.00	8.57		* 400kV AMRITSAR-JALANDHAR-1 Line manually opened on voltage reg. (NR-802)
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	02-01-2025	21:54:00	03-01-2025	06:22:00	0.35	0.00	0.00	0.00	8.47		* 400kV AMRITSAR-JALANDHAR-1 Line manually opened on voltage reg. (NR-802)
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	01-01-2025	20:54:00	02-01-2025	08:14:00	0.47	0.00	0.00	0.00	11.33		* 400kV AMRITSAR-JALANDHAR-1 Line manually opened on voltage reg. (NR-378)
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	21-01-2025	22:15:00	22-01-2025	06:06:00	0.33	0.00	0.00	0.00	7.85		* Line hand tripped on voltage regulation. NR2501-8537
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	20-01-2025	21:21:00	21-01-2025	06:20:00	0.37	0.00	0.00	0.00	8.98		* Line hand tripped for voltage regulation.NR2501-8097
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	19-01-2025	21:55:00	20-01-2025	06:06:00	0.34	0.00	0.00	0.00	8.18		* Line hand tripped for voltage regulation.NR2501-7701
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	25-01-2025	23:05:00	26-01-2025	06:23:00	0.30	0.00	0.00	0.00	7.30		* 400kV AMRITSAR-JALANDHAR-1 Line manually opened on voltage reg. (NR-10316)
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	11-01-2025	00:27:00	11-01-2025	06:03:00	0.23	0.00	0.00	0.00	5.60		* 400kV AMRITSAR-JALANDHAR-1 Line manually opened on voltage reg. (NR-4264)
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	09-01-2025	22:39:00	10-01-2025	06:34:00	0.33	0.00	0.00	0.00	7.92		* 400kV AMRITSAR-JALANDHAR-1 Line manually opened on voltage reg. (NR-3818)
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	26-01-2025	21:49:00	27-01-2025	06:46:00	0.37	0.00	0.00	0.00	8.95		* 400kV AMRITSAR-JALANDHAR-1 Line manually opened on voltage reg. (NR-10636)
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	16-01-2025	23:22:00	17-01-2025	06:24:00	0.29	0.00	0.00	0.00	7.03		* LVRD Line hand tripped on voltage regulation. NR2501-6552
CKT	400kV AMRITSAR-JALANDHAR-1	LVRD	23-01-2025	21:27:00	24-01-2025	06:13:00	0.37	0.00	0.00	0.00	8.77		* LVRD Line hand tripped on voltage regulation. NR2501-9357
							4.48	0.00	0.00	0.00	107.70	100.00	
CKT	400kV AMRITSAR-JALANDHAR-2	LVRD	06-01-2025	01:13:00	06-01-2025	06:56:00	0.24	0.00	0.00	0.00	5.72		* Line hand tripped on voltage regulation. NR2501-2078
CKT	400kV AMRITSAR-JALANDHAR-2	LVRD	12-01-2025	00:40:00	12-01-2025	07:34:00	0.29	0.00	0.00	0.00	6.90		* Line hand tripped for voltage regulation.NR2501-4657
CKT	400kV AMRITSAR-JALANDHAR-2	LVRD	01-01-2025	00:00:01	01-01-2025	06:08:00	0.26	0.00	0.00	0.00	6.13		* Line hand tripped on voltage regulation. NR2412-13372
CKT	400kV AMRITSAR-JALANDHAR-2	LVRD	03-01-2025	21:30:00	04-01-2025	09:04:00	0.48	0.00	0.00	0.00	11.57		* Line hand tripped for voltage regulation.NR2501-1271
CKT	400kV AMRITSAR-JALANDHAR-2	LVRD	04-01-2025	20:59:00	05-01-2025	08:21:00	0.47	0.00	0.00	0.00	11.37		* Line hand tripped on voltage regulation. NR2501-1692
CKT	400kV AMRITSAR-JALANDHAR-2	LVRD	08-01-2025	20:56:00	09-01-2025	05:55:00	0.37	0.00	0.00	0.00	8.98		* Line hand tripped for voltage regulation.NR2501-3352
CKT	400kV AMRITSAR-JALANDHAR-2	LVRD	07-01-2025	21:19:00	08-01-2025	06:30:00	0.38	0.00	0.00	0.00	9.18		* Line hand tripped on voltage regulation. NR2501-2894
							2.49	0.00	0.00	0.00	59.85	100.00	
CKT	400kV BANALA-AMRITSAR-1	LEFT	19-01-2025	21:02:00	19-01-2025	22:36:00	0.07	1.57	0.00	0.00	0.00		* 400KV AMRITSAR-BANALA-1 1/19/2025 21:02 STILL OUT LEFT Line tripped on Y-N persisting fault. FLR Amritsar:182.5kM, ly=2.65kA; Banala: 95.4kM, ly=3.88kA. Charging attempt taken from Amritsar end at 22:36hrs dtd. 19.01.2024 vide NRLDC Code-NR2501-7703.Line tripped again on operation of Overvoltage protection. Banala: DT Send and Overvoltage-1 OPTD; Amritsar: DT Received NR2501-7703* 23.01.2025 15:03:06 INDIA (60003416)" Flashover marks observed on jumper conductors and hardware fittings at 216.Probable cause of tripping may be migratory birds
CKT	400kV BANALA-AMRITSAR-1	LVRD	12-01-2025	22:00:00	13-01-2025	06:17:00	0.35	0.00	0.00	0.00	8.28		* Line hand tripped for voltage regulation.NR2501-4887
CKT	400kV BANALA-AMRITSAR-1	LVRD	02-01-2025	21:50:00	03-01-2025	05:54:00	0.34	0.00	0.00	0.00	8.07		* 400kV BANALA-AMRITSAR-1 Line manually opened on voltage reg. (NR-804)
CKT	400kV BANALA-AMRITSAR-1	LVRD	25-01-2025	01:57:00	25-01-2025	05:18:00	0.14	0.00	0.00	0.00	3.35		* Line hand tripped for voltage regulation.NR2501-9906
CKT	400kV BANALA-AMRITSAR-1	LVRD	19-01-2025	22:36:00	20-01-2025	06:14:00	0.32	0.00	0.00	0.00	7.63		* Line hand tripped for voltage regulation.NR2501-7715
CKT	400kV BANALA-AMRITSAR-1	LVRD	06-01-2025	21:47:00	07-01-2025	05:49:00	0.34	0.00	0.00	0.00	8.03		* Line hand tripped on voltage regulation. NR2501-2469
CKT	400kV BANALA-AMRITSAR-1	LVRD	11-01-2025	23:32:00	12-01-2025	07:35:00	0.34	0.00	0.00	0.00	8.05		* Line hand tripped for voltage regulation.NR2501-4646
CKT	400kV BANALA-AMRITSAR-1	LVRD	26-01-2025	21:46:00	27-01-2025	06:44:00	0.37	0.00	0.00	0.00	8.97		* 400kV BANALA-AMRITSAR-1 Line manually opened on voltage reg. (NR-10637)
CKT	400kV BANALA-AMRITSAR-1	LVRD	25-01-2025	23:36:00	26-01-2025	06:19:00	0.28	0.00	0.00	0.00	6.72		* 400kV BANALA-AMRITSAR-1 Line manually opened on voltage reg. (NR-10322)
CKT	400kV BANALA-AMRITSAR-1	LVRD	09-01-2025	22:36:00	10-01-2025	05:28:00	0.29	0.00	0.00	0.00	6.87		* 400kV BANALA-AMRITSAR-1 Line manually opened on voltage reg. (NR-3816)
CKT	400kV BANALA-AMRITSAR-1	LVRD	20-01-2025	23:17:00	21-01-2025	05:30:00	0.26	0.00	0.00	0.00	6.22		* Line hand tripped for voltage regulation.NR2501-8134
CKT	400kV BANALA-AMRITSAR-1	LVRD	11-01-2025	00:26:00	11-01-2025	05:45:00	0.22	0.00	0.00	0.00	5.32		* 400kV BANALA-AMRITSAR-1 Line manually opened on voltage reg. (NR-4263)
CKT	400kV BANALA-AMRITSAR-1	LVRD	17-01-2025	23:42:00	18-01-2025	05:42:00	0.25	0.00	0.00	0.00	6.00		* Line hand tripped on voltage regulation. NR2501-7015
CKT	400kV BANALA-AMRITSAR-1	LVRD	01-01-2025	20:58:00	02-01-2025	06:32:00	0.40	0.00	0.00	0.00	9.57		* 400kV BANALA-AMRITSAR-1 Line manually opened on voltage reg. (NR-392)
CKT	400kV BANALA-AMRITSAR-1	LVRD	05-01-2025	23:14:00	06-01-2025	05:47:00	0.27	0.00	0.00	0.00	6.55		* Line hand tripped on voltage regulation. NR2501-2059
CKT	400kV BANALA-AMRITSAR-1	LVRD	16-01-2025	01:08:00	16-01-2025	05:46:00	0.19	0.00	0.00	0.00	4.63		* LVRD Line hand tripped on voltage regulation. NR2501-6103
CKT	400kV BANALA-AMRITSAR-1	LVRD	08-01-2025	02:06:00	08-01-2025	05:37:00	0.15	0.00	0.00	0.00	3.52		* Line hand tripped on voltage regulation. NR2501-2938
CKT	400kV BANALA-AMRITSAR-1	LVRD	04-01-2025	20:58:00	05-01-2025	08:03:00	0.46	0.00	0.00	0.00	11.08		* Line hand tripped on voltage regulation. NR2501-1694
CKT	400kV BANALA-AMRITSAR-1	LVRD	04-01-2025	02:21:00	04-01-2025	05:39:00	0.14	0.00	0.00	0.00	3.30		* Line hand tripped for voltage regulation.NR2501-1308
CKT	400kV BANALA-AMRITSAR-1	LVRD	01-01-2025	00:40:00	01-01-2025	05:17:00	0.19	0.00	0.00	0.00	4.62		* LVRD Line hand tripped on voltage regulation. NR2501-7
							5.37	1.57	0.00	0.00	126.78	99.79	
CKT	400kV BANALA-HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE TO Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANALA-KOLDAM(NTPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NALAGARH-BANALA	LVRD	01-01-2025	00:00:01	01-01-2025	05:19:00	0.22	0.00	0.00	0.00	5.32		* Line hand tripped on voltage regulation. NR2412-13391
CKT	400kV NALAGARH-BANALA	LVRD	25-01-2025	22:41:00	26-01-2025	06:31:00	0.33	0.00	0.00	0.00	7.83		* 400kV NALAGARH-BANALA Line manually opened on voltage reg. (NR-10307)
CKT	400kV NALAGARH-BANALA	LVRD	03-01-2025	23:42:00	04-01-2025	05:41:00	0.25	0.00	0.00	0.00	5.98		* Line hand tripped for voltage regulation.NR2501-1300
CKT	400kV NALAGARH-BANALA	LVRD	04-01-2025	23:56:00	05-01-2025	05:38:00	0.24	0.00	0.00	0.00	5.70		* Line hand tripped for voltage regulation.NR2501-1721
CKT	400kV NALAGARH-BANALA	LVRD	15-01-2025	22:00:00	16-01-2025	05:48:00	0.33	0.00	0.00	0.00	7.80		* LVRD Line hand tripped on voltage regulation. NR2501-6057
CKT	400kV NALAGARH-BANALA	LVRD	08-01-2025	23:51:00	09-01-2025	05:22:00	0.23	0.00	0.00	0.00	5.52		* LVRD Line hand tripped on voltage regulation. NR2501-3400
CKT	400kV NALAGARH-BANALA	LVRD	12-01-2025	22:03:00	13-01-2025	05:49:00	0.32	0.00	0.00	0.00	7.77		* Line hand tripped for voltage regulation.NR2501-4902
CKT	400kV NALAGARH-BANALA	LVRD	07-01-2025	23:35:00	08-01-2025	05:35:00	0.25	0.00	0.00	0.00	6.00		* Line hand tripped on voltage regulation. NR2501-2914
CKT	400kV NALAGARH-BANALA	LVRD	16-01-2025	21:55:00	17-01-2025	05:37:00	0.32	0.00	0.00	0.00	7.70		* LVRD Line hand tripped on voltage regulation. NR2501-6538
CKT	400kV NALAGARH-BANALA	LVRD	20-01-2025	01:21:00	20-01-2025	05:58:00	0.19	0.00	0.00	0.00	4.62		* Line hand tripped for voltage regulation.NR2501-7722
CKT	400kV NALAGARH-BANALA	LVRD	24-01-2025	23:10:00	25-01-2025	05:21:00	0.26	0.00	0.00	0.00	6.18		* Line hand tripped for voltage regulation.NR2501-9893
CKT	400kV NALAGARH-BANALA	LVRD	23-01-2025	23:37:00	24-01-2025	05:34:00	0.25	0.00	0.00	0.00	5.95		* LVRD Line hand tripped on voltage regulation. NR2501-9393
CKT	400kV NALAGARH-BANALA	LVRD	06-01-2025	01:09:00	06-01-2025	05:50:00	0.20	0.00	0.00	0.00	4.68		* Line hand tripped on voltage regulation. NR2501-2079
CKT	400kV NALAGARH-BANALA	LVRD	11-01-2025	23:35:00	12-01-2025	05:59:00	0.27	0.00	0.00	0.00	6.40		* Line hand tripped for voltage regulation.NR2501-4647
CKT	400kV NALAGARH-BANALA	LVRD	18-01-2025	23:12:00	19-01-2025	05:08:00	0.25	0.00	0.00	0.00	5.93		* Line hand tripped on voltage regulation. NR2501-7386
CKT	400kV NALAGARH-BANALA	LVRD	17-01-2025	23:35:00	18-01-2025	05:49:00	0.26	0.00	0.00	0.00	6.23		* Line hand tripped on voltage regulation. NR2501-7007
							4.17	0.00	0.00	0.00	99.61	100.00	
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	17-01-2025	23:18:00	18-01-2025	06:32:00	0.30	0.00	0.00	0.00	7.23		* Line hand tripped on voltage regulation. NR2501-6992
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	16-01-2025	21:20:00	17-01-2025	06:42:00	0.39	0.00	0.00	0.00	9.37		* LVRD Line hand tripped on voltage regulation. NR2501-6525
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	10-01-2025	01:07:00	10-01-2025	06:44:00	0.23	0.00	0.00	0.00	5.62		* 400kV BHIWANI(BBMB)-RAJPURA(PSTCL) Line manually opened on voltage reg. (NR-3836)
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	28-01-2025	21:27:00	29-01-2025	07:11:00	0.41	0.00	0.00	0.00	9.73		* Line hand tripped for voltage regulation.NR2501-11522
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	26-01-2025	21:30:00	27-01-2025	06:33:00	0.38	0.00	0.00	0.00	9.05		* 400kV BHIWANI(BBMB)-RAJPURA(PSTCL) Line manually opened on voltage reg. (NR-10630)
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	05-01-2025	21:35:00	06-01-2025	06:46:00	0.38	0.00	0.00	0.00	9.18		* LVRD Line hand tripped on voltage regulation. NR2501-2044
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	11-01-2025	21:51:00	12-01-2025	08:50:00	0.46	0.00	0.00	0.00	10.98		* Line hand tripped for voltage regulation.NR2501-4613
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	24-01-2025	21:02:00	25-01-2025	06:08:00	0.38	0.00	0.00	0.00	9.10		* Line hand tripped for voltage regulation.NR2501-9839
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	27-01-2025	21:31:00	28-01-2025	06:31:00	0.38	0.00	0.00	0.00	9.00		* Line hand tripped for voltage regulation.NR2501-11087
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	07-01-2025	21:23:00	08-01-2025	06:36:00	0.38	0.00	0.00	0.00	9.22		* Line hand tripped on voltage regulation. NR2501-2884
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	30-01-2025	01:33:00	30-01-2025	06:49:00	0.22	0.00	0.00	0.00	5.27		* Line hand tripped on voltage regulation. NR2501-11948
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	23-01-2025	21:10:00	24-01-2025	07:15:00	0.42	0.00	0.00	0.00	10.08		* LVRD Line hand tripped on voltage regulation. NR2501-9348
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	14-01-2025	21:40:00	15-01-2025	06:21:00	0.36	0.00	0.00	0.00	8.68		* Line hand tripped on voltage regulation. NR2501-5625
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	08-01-2025	21:12:00	09-01-2025	06:10:00	0.37	0.00	0.00	0.00	8.97		* Line hand tripped on voltage regulation. NR2501-3361
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	20-01-2025	21:58:00	21-01-2025	05:55:00	0.33	0.00	0.00	0.00	7.95		* Line hand tripped for voltage regulation.NR2501-8123
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	21-01-2025	22:38:00	22-01-2025	06:18:00	0.32	0.00	0.00	0.00	7.67		* Line hand tripped on voltage regulation. NR2501-8547
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	31-01-2025	21:24:00	31-01-2025	23:59:59	0.11	0.00	0.00	0.00	2.60		* LVRD Line hand tripped on voltage regulation. NR2501-12768
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	30-01-2025	23:04:00	31-01-2025	06:46:00	0.32	0.00	0.00	0.00	7.70		* Line hand tripped on voltage regulation. NR2501-12382
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	18-01-2025	21:29:00	19-01-2025	06:42:00	0.38	0.00	0.00	0.00	9.22		* Line hand tripped on voltage regulation. NR2501-7350
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	03-01-2025	21:39:00	04-01-2025	08:11:00	0.44	0.00	0.00	0.00	10.53		* Line hand tripped for voltage regulation.NR2501-1280
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	01-01-2025	21:12:00	02-01-2025	09:51:00	0.53	0.00	0.00	0.00	12.65		* 400kV BHIWANI(BBMB)-RAJPURA(PSTCL) Line manually opened on voltage reg. (NR-381)
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	04-01-2025	21:42:00	05-01-2025	08:15:00	0.44	0.00	0.00	0.00	10.55		* Line hand tripped for voltage regulation.NR2501-1702
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	02-01-2025	21:59:00	03-01-2025	06:15:00	0.34	0.00	0.00	0.00	8.27		* 400kV BHIWANI(BBMB)-RAJPURA(PSTCL) Line manually opened on voltage reg. (NR-801)
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	01-01-2025	00:00:01	01-01-2025	07:44:00	0.32	0.00	0.00	0.00	7.73		* Line hand tripped on voltage regulation. NR2412-13378
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	22-01-2025	21:12:00	23-01-2025	06:33:00	0.39	0.00	0.00	0.00	9.35		* Line hand tripped on voltage regulation. NR2501-8943
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	15-01-2025	22:03:00	16-01-2025	06:14:00	0.34	0.00	0.00	0.00	8.18		* LVRD Line hand tripped on voltage regulation. NR2501-6066
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	10-01-2025	21:41:00	11-01-2025	07:30:00	0.41	0.00	0.00	0.00	9.82		* 400kV BHIWANI(BBMB)-RAJPURA(PSTCL) Line manually opened on voltage reg. (NR-4223)
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	19-01-2025	21:08:00	20-01-2025	06:18:00	0.38	0.00	0.00	0.00	9.17		* Line hand tripped for voltage regulation.NR2501-7679
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	13-01-2025	22:35:00	14-01-2025	07:04:00	0.35	0.00	0.00	0.00	8.48		* Line hand tripped on voltage regulation. NR2501-5240
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	25-01-2025	23:09:00	26-01-2025	07:08:00	0.33	0.00	0.00	0.00	7.98		* 400kV BHIWANI(BBMB)-RAJPURA(PSTCL) Line manually opened on voltage reg. (NR-10313)
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	12-01-2025	21:57:00	13-01-2025	06:36:00	0.36	0.00	0.00	0.00	8.65		* Line hand tripped for voltage regulation.NR2501-4894
CKT	400kV BHIWANI(BBMB)-RAJPURA(PSTCL)	LVRD	06-01-2025	21:13:00	07-01-2025	05:48:00	0.36	0.00	0.00	0.00	8.58		* Line hand tripped on voltage regulation. NR2501-2447
							11.51	0.00	0.00	0.00	276.56	100.00	
CKT	400kV CHAMBA-JALLANDHAR-1	LVRD	20-01-2025	23:08:00	21-01-2025	05:18:00	0.26	0.00	0.00	0.00	6.17		* Line hand tripped for voltage regulation.NR2501-8133
CKT	400kV CHAMBA-JALLANDHAR-1	LVRD	19-01-2025	21:21:00	20-01-2025	06:18:00	0.37	0.00	0.00	0.00	8.95		* Line hand tripped for voltage regulation.NR2501-7688
CKT	400kV CHAMBA-JALLANDHAR-1		27-01-2025	02:10:00	28-01-2025	08:29:00	1.26	0.00	0.00	0.00	30.32		* 400kV CHAMBA-JALLANDHAR-1 Line manually opened on voltage reg. (NR-10661)
							1.89	0.00	0.00	0.00	45.44	100.00	
CKT	400kV CHAMBA-JALLANDHAR-2	LVRD	01-01-2025	00:48:00	01-01-2025	05:57:00	0.22	0.00	0.00	0.00	5.15		* LVRD Line hand tripped on voltage regulation. NR2501-8
CKT	400kV CHAMBA-JALLANDHAR-2	LVRD	01-01-2025	23:52:00	02-01-2025	06:47:00	0.29	0.00	0.00	0.00	6.92		* 400kV CHAMBA-JALLANDHAR-2 Line manually opened on voltage reg. (NR-398)
CKT	400kV CHAMBA-JALLANDHAR-2	LVRD	16-01-2025	23:20:00	17-01-2025	05:35:00	0.26	0.00	0.00	0.00	6.25		* LVRD Line hand tripped on voltage regulation. NR2501-6556
CKT	400kV CHAMBA-JALLANDHAR-2	LVRD	06-01-2025	01:25:00	06-01-2025	05:56:00	0.19	0.00	0.00	0.00	4.52		
CKT	400kV CHAMBA-JALLANDHAR-2	LVRD	15-01-2025	22:06:00	16-01-2025	06:01:00	0.33	0.00	0.00	0.00	7.92		* LVRD Line hand tripped on voltage regulation. NR2501-6073
CKT	400kV CHAMBA-JALLANDHAR-2	LVRD	08-01-2025	02:04:00	08-01-2025	06:23:00	0.18	0.00	0.00	0.00	4.32		* Line hand tripped on voltage regulation. NR2501-2939
							1.47	0.00	0.00	0.00	35.08	100.00	
CKT	400kV CHAMERA1(NHPC)-JALLANDHAR-1	LART	26-01-2025	22:45:00	26-01-2025	22:45:00	0.00	0.00	0.00	0.00	0.00		* 400kV CHAMERA1(NHPC)-JALLANDHAR-1 Line auto reclosed on RN fault. FLR JLD: FL= 71.380Km, Ir=4.326* 01.02.2025 19:17:08 INDIA (60003416)* Kite thread is found hanging from Earthwire to top phase conductor upto ground in span 215-216
CKT	400kV CHAMERA1(NHPC)-JALLANDHAR-1	LART	09-01-2025	21:43:00	09-01-2025	21:43:00	0.00	0.00	0.00	0.00	0.00		* 400kV CHAMERA1(NHPC)-JALLANDHAR-1 Line auto reclosed on RN fault. FLR Jalandhr: FL=79.4KM, Ir=4.25KA, FLR chamaera: FL=61.25KM, Ir=3.0KA* 12.01.2025 06:48:55 INDIA (60003416)* Kite thread found hanging on cross arm and VD at 213
CKT	400kV CHAMERA1(NHPC)-JALLANDHAR-1	LVRD	16-01-2025	02:00:00	16-01-2025	05:39:00	0.15	0.00	0.00	0.00	3.65		* LVRD Line hand tripped on voltage regulation. NR2501-6113
CKT	400kV CHAMERA1(NHPC)-JALLANDHAR-1	OSPD	31-01-2025	10:21:00	31-01-2025	14:54:00	0.19	0.00	0.00	0.00	4.55		* 400kV CHAMERA1(NHPC)-JALLANDHAR-1 taken under SD by Chamera 1 NHPC for isolator alignment (NR-12541)
							0.34	0.00	0.00	0.00	8.20	100.00	
CKT	400kV CHAMERA1(NHPC)-JALLANDHAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHAMERA2(NHPC)-CHAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHAMERA1(NHPC)-CHAMERA2(NHPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV CHAMERA2(NHPC)-KISHENPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DEHAR(BMB)-RAJPURA(PSTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DEPALPUR(HVPNL)-BAWANA(DTL)	OSFD	04-01-2025	13:57:00	04-01-2025	18:59:00	0.21	0.00	0.00	0.00	5.03		* Line taken under emergency S/D by Bawana DTL to attend the damaged isolator clamp R phase towards CB Side of jack bus isolator at Bawana(DTL).
CKT	400kV DEPALPUR(HVPNL)-BAWANA(DTL)	LCSD	22-01-2025	11:19:00	23-01-2025	20:34:00	1.39	0.00	0.00	0.00	33.25		* LCSD SD taken by NR-1 for Retrofitting of 41389L isolator at DTL Bawana under ADD CAP works. NR2501-8753.
CKT	400kV DEPALPUR(HVPNL)-BAWANA(DTL)	LCSD	10-01-2025	11:13:00	11-01-2025	19:52:00	1.36	0.00	0.00	0.00	32.65		* SD taken by NR-1 for 41389A isolator retrofitting worksunder ADD CAP work. NR2501-4032
							2.96	0.00	0.00	0.00	70.93	100.00	
CKT	400kV JALLANDHAR-DHANANSU (PSTCL) Line			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DULHASTI(NHPC)-KISHENPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DULHASTI(NHPC)-KISHENPUR-2	LCSD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* To carryout stringing on circuit 2
CKT	400kV DULHASTI(NHPC)-KISHENPUR-2	LCSD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SD taken for stringing of 2nd circuit being executed for evacuation of Power from Pakal Dul HEP in Chenab Valley HEPs. NR2410-3730
							62.00	0.00	0.00	0.00	1,488.00	100.00	
CKT	400kV JALANDHAR-HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JALANDHAR-LUDHIANA	OSFT	14-01-2025	13:18:00	14-01-2025	16:22:00	0.13	3.07	0.00	0.00	0.00		* ESD taken by Jalandhar TLM for replacement of damage 01 no R-Ph. polymer insulator at Loc no 156. NR2501-5476
CKT	400kV JALANDHAR-LUDHIANA	LEFT	09-01-2025	06:40:00	09-01-2025	07:52:00	0.05	1.20	0.00	0.00	0.00		* Line tripped on Y-N fault from Jalandhar end only . Line remains charged from Ludhiana SS. FLR Jalandhar: 7.775 kA FL: 52.203km (= 61.630%) Vry=236kV Vyb=236kV <(>8<)> Vbr=405kV, Ludhiana: No CB event, Vry=411kV, Vyb=410kV, Vbr=409kV.* 10.01.2025 07:51:36 INDIA (60003416)* Y Ph Conductor snapped due to failure of tension insulator and tower beam got bent at 146
CKT	400kV JALANDHAR-LUDHIANA	OSFT	09-01-2025	07:52:00	14-01-2025	03:37:00	4.82	115.75	0.00	0.00	0.00		* 400KV JALANDHAR-LUDHIANA 1/9/2025 7:52 STILL OUT OSFT Line taken under emergency shutdown for rectification of snapped conductor at NR2501-3489
							5.00	120.02	0.00	0.00	0.00	83.87	
CKT	400kV JALLANDHAR-MOGA-1	LVRD	17-01-2025	00:48:00	17-01-2025	06:17:00	0.23	0.00	0.00	0.00	5.48		* LVRD Line hand tripped on voltage regulation. NR2501-6579
CKT	400kV JALLANDHAR-MOGA-1	LVRD	18-01-2025	23:17:00	19-01-2025	06:06:00	0.28	0.00	0.00	0.00	6.82		* Line hand tripped on voltage regulation. NR2501-7390
CKT	400kV JALLANDHAR-MOGA-1	LVRD	25-01-2025	02:04:00	25-01-2025	05:50:00	0.16	0.00	0.00	0.00	3.77		* Line hand tripped for voltage regulation.NR2501-9907
CKT	400kV JALLANDHAR-MOGA-1	LVRD	15-01-2025	22:29:00	16-01-2025	06:00:00	0.31	0.00	0.00	0.00	7.52		* LVRD Line hand tripped on voltage regulation. NR2501-6075
CKT	400kV JALLANDHAR-MOGA-1	LVRD	07-01-2025	23:38:00	08-01-2025	06:25:00	0.28	0.00	0.00	0.00	6.78		* Line hand tripped on voltage regulation. NR2501-2911
CKT	400kV JALLANDHAR-MOGA-1	LVRD	14-01-2025	21:44:00	15-01-2025	06:10:00	0.35	0.00	0.00	0.00	8.43		* Line hand tripped on voltage regulation. NR2501-5634
CKT	400kV JALLANDHAR-MOGA-1	LVRD	12-01-2025	00:45:00	12-01-2025	08:40:00	0.33	0.00	0.00	0.00	7.92		* Line hand tripped for voltage regulation.NR2501-4658
CKT	400kV JALLANDHAR-MOGA-1	OMSU	07-01-2025	15:12:00	07-01-2025	17:28:00	0.09	0.00	2.27	0.00	0.00		* "Line tripped on Y-B-N fault from both end due to kite/kite thread found in span 634-635.* FLR Jalandhar: 76.86 kM,IF =5.39kA* FLR Moga: 4.6 kM, IF=18.3 kA.* NR2501-2818
CKT	400kV JALLANDHAR-MOGA-1	LVRD	01-01-2025	00:00:01	01-01-2025	06:04:00	0.25	0.00	0.00	0.00	6.07		* Line hand tripped on voltage regulation. NR2412-13394
CKT	400kV JALLANDHAR-MOGA-1	LVRD	23-01-2025	23:39:00	24-01-2025	06:43:00	0.29	0.00	0.00	0.00	7.07		* LVRD Line hand tripped on voltage regulation. NR2501-9391
							2.57	0.00	2.27	0.00	59.86	100.00	
CKT	400kV JALLANDHAR-MOGA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-BAGPAT-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-BAGPAT-2	LVRD	14-01-2025	00:28:00	14-01-2025	05:58:00	0.23	0.00	0.00	0.00	5.50		* Line hand tripped on voltage regulation. NR2501-5264
							0.23	0.00	0.00	0.00	5.50	100.00	
CKT	400kV KAITHAL-DADRI(NTPC)	LVRD	14-01-2025	23:51:00	15-01-2025	07:46:00	0.33	0.00	0.00	0.00	7.92		* Line hand tripped on voltage regulation. NR2501-5661
CKT	400kV KAITHAL-DADRI(NTPC)	LVRD	12-01-2025	00:14:00	12-01-2025	08:55:00	0.36	0.00	0.00	0.00	8.68		* Line hand tripped for voltage regulation.NR2501-4653
CKT	400kV KAITHAL-DADRI(NTPC)	LVRD	20-01-2025	01:31:00	20-01-2025	08:17:00	0.28	0.00	0.00	0.00	6.77		* Line hand tripped for voltage regulation.NR2501-7722
CKT	400kV KAITHAL-DADRI(NTPC)	OMSU	26-01-2025	14:40:00	26-01-2025	17:33:00	0.12	0.00	2.88	0.00	0.00		* Line tripped on R-N fault due to Bush fire in span Loc. 18 to Loc.19 . FLR Kaithal: 1.8 kA, FL=203 km FLR Dadri: 22.0 kA, FL=7 km.* 01.02.2025 19:24:28 INDIA (60003416)* Bush fire found in span 18-19.Fault in jurisdiction of NR-1
CKT	400kV KAITHAL-DADRI(NTPC)	LVRD	03-01-2025	00:26:00	03-01-2025	06:10:00	0.24	0.00	0.00	0.00	5.73		* 400kV KAITHAL-DADRI(NTPC) Line manually opened on voltage reg. (NR-832)
CKT	400kV KAITHAL-DADRI(NTPC)	LVRD	12-01-2025	23:49:00	13-01-2025	06:27:00	0.28	0.00	0.00	0.00	6.63		* Line hand tripped for voltage regulation.NR2501-4912
							1.61	0.00	2.88	0.00	35.73	100.00	
CKT	400kV KAITHAL-MALERKOTLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-PATRA(TECHNO)-1	LART	12-01-2025	03:05:00	12-01-2025	03:05:00	0.00	0.00	0.00	0.00	0.00		* Line Auto reclosed on Y-N fault. from both end.FLR Kaithal: 16.6kM ,ly= 11.9 kA* 14.01.2025 18:29:58 INDIA (60003416)* Kite thread found at tower 61
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-PATRA(TECHNO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-BAGLIHAR-3	OSPD	29-01-2025	13:58:00	29-01-2025	20:56:00	0.29	0.00	0.00	0.00	6.97		* OSPD SD taken by JKPTCL for Bypass arrangement of LILO scheme and implementation of 400 KV Tie Breaker Scheme at Baglihar (BHEP-II). NR2501-11747
CKT	400kV KISHENPUR-BAGLIHAR-3	OSPD	30-01-2025	14:40:00	30-01-2025	20:34:00	0.25	0.00	0.00	0.00	5.90		* 400kV KISHENPUR-BAGLIHAR-3 taken under SD by JKPTCL for Bypass arrangement of LILO scheme and implementation of 400 KV Tie Breaker Scheme at BHEP-II (NR-12171)
							0.54	0.00	0.00	0.00	12.87	100.00	
CKT	400kV KISHENPUR-SAMBA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-SAMBA-2	SPLT	23-01-2025	12:44:00	23-01-2025	13:04:00	0.01	0.33	0.00	0.00	0.00		* 400kV KISHENPUR-SAMBA-2 tripped on DT received at kishenpur end due to pal operation of PLCC
							0.01	0.33	0.00	0.00	0.00	99.96	
CKT	400kV KISHENPUR-NEW WANPOH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-NEW WANPOH-3	OMSU	02-01-2025	04:24:00	02-01-2025	06:01:00	0.07	0.00	1.62	0.00	0.00		* 400kV KISHENPUR-NEW WANPOH-3 Line tripped on R-N fault. FLR Kishenpur: FL=117.535KM, Ir=3.529KA, FLR New= Wanpoh:5.445km, Ir=8.731 kA.* 08.01.2025 17:42:50 INDIA (60003416)* Flashover on tower members and corona ring found due to bird infringement/ bird residue at 373
CKT	400kV KISHENPUR-NEW WANPOH-3	LART	02-01-2025	02:55:00	02-01-2025	02:55:00	0.00	0.00	0.00	0.00	0.00		* 400kV KISHENPUR-NEW WANPOH-3 Line autoreclosed from both ends on R-N fault.FLR kishenpur:118.536km,3.601 kA.FLR New Wanpoh:4.873km,Ir=9.257 kA.* 08.01.2025 17:40:39 INDIA (60003416)* Flashover on tower members and corona ring found due to bird infringement/ bird residue at 373
CKT	400kV KISHENPUR-NEW WANPOH-3	OSFT	01-01-2025	14:07:00	01-01-2025	17:07:00	0.13	3.00	0.00	0.00	0.00		* Emergency SD by TL Batote to attend galloping issue in span Loc. No. 224 to ERS-1.
CKT	400kV KISHENPUR-NEW WANPOH-3	LART	01-01-2025	22:57:00	01-01-2025	22:57:00	0.00	0.00	0.00	0.00	0.00		* 400kV KISHENPUR-NEW WANPOH-3 autoreclosed on RN fault. FLR Kishenpur: FL=117.552KM, Ir=3.442KA, FLR Newwanpoh: FL=5.1KM, Ir=8.4KA* 08.01.2025 17:35:08 INDIA (60003416)* Flashover on tower members and corona ring found due to bird infringement/ bird defecation at 373

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE TO Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.20	3.00	1.62	0.00	0.00	99.60	
CKT	400kV KISHENPUR-NEW WANPOH-4	LART	04-01-2025	00:45:00	04-01-2025	00:45:00	0.00	0.00	0.00	0.00	0.00		* Line Auto reclosed successfully on R-G Fault. FLR Kishenpur: (Main-I- Rph, 3.34KA, 94.71KM) (Main-II- R-ph, 3.40KA, 137 KM), TWFL- 131 KM. FLR New Wanpoh: (Main-I - Rph, 8.4KA, 6.2KM), TWFL- 3.86 KM.* 08.01.2025 17:47:00 INDIA (60003416)* Flashover on tower members and corona ring found due to bird infringement/ bird residue at 373
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLDAM(NTPC)-NALAGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KURUKSHETRA-DHANANSU (PSTCL) LINE	LART	12-01-2025	13:54:00	12-01-2025	13:54:00	0.00	0.00	0.00	0.00	0.00		* "Line Auto reclosed on B-N fault from both end.FLR Kurukshetra:" Main 1 = FL : 20.6kM ,Ib= 13.6 kA.* Main-2 = FL : 20.9kM ,Ib= 14 kA.** 14.01.2025 15:50:38 INDIA (60003416)* Flashover on arcing horn and jumper sub-conductor at 53 due to thunderstorm and lightning
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KURUKSHETRA-JIND-1	LVRD	30-01-2025	23:04:00	31-01-2025	07:03:00	0.33	0.00	0.00	0.00	7.98		* Line hand tripped on voltage regulation. NR2501-12383
CKT	400kV KURUKSHETRA-JIND-1	LVRD	03-01-2025	21:30:00	04-01-2025	08:18:00	0.45	0.00	0.00	0.00	10.80		* Line hand tripped for voltage regulation.NR2501-1273
CKT	400kV KURUKSHETRA-JIND-1	LVRD	01-01-2025	21:45:00	02-01-2025	08:17:00	0.44	0.00	0.00	0.00	10.53		* 400kV KURUKSHETRA-JIND-1 Line manually opened on voltage reg. (NR-373)
CKT	400kV KURUKSHETRA-JIND-1	LVRD	04-01-2025	21:13:00	05-01-2025	08:08:00	0.46	0.00	0.00	0.00	10.92		* Line hand tripped for voltage regulation.NR2501-1696
CKT	400kV KURUKSHETRA-JIND-1	LVRD	10-01-2025	21:48:00	11-01-2025	07:49:00	0.42	0.00	0.00	0.00	10.02		* 400kV KURUKSHETRA-JIND-1 Line manually opened on voltage reg. (NR-4241)
CKT	400kV KURUKSHETRA-JIND-1	LVRD	16-01-2025	23:34:00	17-01-2025	06:11:00	0.28	0.00	0.00	0.00	6.62		* LVRD Line hand tripped on voltage regulation. NR2501-6557.
CKT	400kV KURUKSHETRA-JIND-1	LVRD	08-01-2025	21:01:00	09-01-2025	05:48:00	0.37	0.00	0.00	0.00	8.78		* Line hand tripped on voltage regulation. NR2501-3351
CKT	400kV KURUKSHETRA-JIND-1	LVRD	06-01-2025	21:38:00	07-01-2025	05:48:00	0.34	0.00	0.00	0.00	8.17		* Line hand tripped on voltage regulation. NR2501-2455
CKT	400kV KURUKSHETRA-JIND-1	LVRD	23-01-2025	21:25:00	24-01-2025	06:05:00	0.36	0.00	0.00	0.00	8.67		* LVRD Line hand tripped on voltage regulation. NR2501-9343
CKT	400kV KURUKSHETRA-JIND-1	LVRD	26-01-2025	21:41:00	27-01-2025	07:53:00	0.43	0.00	0.00	0.00	10.20		* 400kV KURUKSHETRA-JIND-1 Line manually opened on voltage reg. (NR-10626)
CKT	400kV KURUKSHETRA-JIND-1	LVRD	20-01-2025	21:35:00	21-01-2025	06:15:00	0.36	0.00	0.00	0.00	8.67		* Line hand tripped for voltage regulation.NR2501-8107
CKT	400kV KURUKSHETRA-JIND-1	LVRD	25-01-2025	22:57:00	26-01-2025	05:42:00	0.28	0.00	0.00	0.00	6.75		* 400kV KURUKSHETRA-JIND-1 Line manually opened on voltage reg. (NR-10305)
CKT	400kV KURUKSHETRA-JIND-1	LVRD	05-01-2025	22:04:00	06-01-2025	06:41:00	0.36	0.00	0.00	0.00	8.62		* Line hand tripped on voltage regulation. NR2501-2046
CKT	400kV KURUKSHETRA-JIND-1	LVRD	18-01-2025	23:15:00	19-01-2025	06:14:00	0.29	0.00	0.00	0.00	6.98		* Line hand tripped on voltage regulation. NR2501-7398
							5.17	0.00	0.00	0.00	123.71	100.00	
CKT	400kV KURUKSHETRA-JIND-2	LVRD	02-01-2025	21:05:00	03-01-2025	06:22:00	0.39	0.00	0.00	0.00	9.28		* 400kV KURUKSHETRA-JIND-2 Line manually opened on voltage reg. (NR-787)
CKT	400kV KURUKSHETRA-JIND-2	LVRD	01-01-2025	00:00:01	01-01-2025	06:13:00	0.26	0.00	0.00	0.00	6.22		* 400kV KURUKSHETRA-JIND-2 Line manually open on VR (NR-13357)
CKT	400kV KURUKSHETRA-JIND-2	LVRD	19-01-2025	21:08:00	20-01-2025	06:13:00	0.38	0.00	0.00	0.00	9.08		* Line hand tripped for voltage regulation.NR2501-7684
CKT	400kV KURUKSHETRA-JIND-2	LVRD	02-01-2025	21:05:00	03-01-2025	06:22:00	0.39	0.00	0.00	0.00	9.28		* 400kV KURUKSHETRA-JIND-2 Line manually opened on voltage reg. (NR-787)
CKT	400kV KURUKSHETRA-JIND-2	LVRD	13-01-2025	22:34:00	14-01-2025	06:51:00	0.35	0.00	0.00	0.00	8.28		* Line hand tripped on voltage regulation. NR2501-5245
CKT	400kV KURUKSHETRA-JIND-2	LVRD	15-01-2025	21:25:00	16-01-2025	05:52:00	0.35	0.00	0.00	0.00	8.45		* LVRD Line hand tripped on voltage regulation. NR2501-6039
CKT	400kV KURUKSHETRA-JIND-2	LVRD	21-01-2025	21:32:00	22-01-2025	06:03:00	0.36	0.00	0.00	0.00	8.52		* Line hand tripped on voltage regulation. NR2501-8531
CKT	400kV KURUKSHETRA-JIND-2	LVRD	09-01-2025	22:36:00	10-01-2025	06:42:00	0.34	0.00	0.00	0.00	8.10		* 400kV KURUKSHETRA-JIND-2 Line manually opened on voltage reg. (NR-3827)
CKT	400kV KURUKSHETRA-JIND-2	LVRD	07-01-2025	21:02:00	08-01-2025	05:46:00	0.36	0.00	0.00	0.00	8.73		* Line hand tripped on voltage regulation. NR2501-2868
CKT	400kV KURUKSHETRA-JIND-2	LVRD	14-01-2025	21:44:00	15-01-2025	06:13:00	0.35	0.00	0.00	0.00	8.48		* Line hand tripped on voltage regulation. NR2501-5631
CKT	400kV KURUKSHETRA-JIND-2	LVRD	24-01-2025	20:51:00	25-01-2025	05:45:00	0.37	0.00	0.00	0.00	8.90		* Line hand tripped for voltage regulation.NR2501-9836
CKT	400kV KURUKSHETRA-JIND-2	LVRD	12-01-2025	21:56:00	13-01-2025	06:42:00	0.37	0.00	0.00	0.00	8.77		* Line hand tripped for voltage regulation.NR2501-4888
CKT	400kV KURUKSHETRA-JIND-2	LVRD	11-01-2025	21:54:00	12-01-2025	07:48:00	0.41	0.00	0.00	0.00	9.90		* Line hand tripped for voltage regulation.NR2501-4615
CKT	400kV KURUKSHETRA-JIND-2	LVRD	17-01-2025	23:30:00	18-01-2025	05:36:00	0.25	0.00	0.00	0.00	6.10		* Line hand tripped on voltage regulation. NR2501-6998
CKT	400kV KURUKSHETRA-JIND-2	LVRD	27-01-2025	21:31:00	28-01-2025	06:15:00	0.36	0.00	0.00	0.00	8.73		* Line hand tripped for voltage regulation.NR2501-11081
							5.29	0.00	0.00	0.00	126.82	100.00	
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	26-01-2025	21:47:00	27-01-2025	07:46:00	0.42	0.00	0.00	0.00	9.98		* 400kV KURUKSHETRA-NAKODAR(PSTCL) Line manually opened on voltage reg. (NR-10635)
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	12-01-2025	21:54:00	13-01-2025	07:28:00	0.40	0.00	0.00	0.00	9.57		* Line hand tripped for voltage regulation.NR2501-4883
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	05-01-2025	02:36:00	05-01-2025	09:44:00	0.30	0.00	0.00	0.00	7.13		* Line hand tripped for voltage regulation.NR2501-1733
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	04-01-2025	00:20:00	04-01-2025	08:21:00	0.33	0.00	0.00	0.00	8.02		* Line hand tripped for voltage regulation.NR2501-1302
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	02-01-2025	20:53:00	03-01-2025	06:07:00	0.39	0.00	0.00	0.00	9.23		* 400kV KURUKSHETRA-NAKODAR(PSTCL) Line manually opened on voltage reg. (NR-791)
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	15-01-2025	21:16:00	16-01-2025	06:02:00	0.37	0.00	0.00	0.00	8.77		* LVRD Line hand tripped on voltage regulation. NR2501-6040.
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	22-01-2025	22:33:00	23-01-2025	06:36:00	0.34	0.00	0.00	0.00	8.05		* Line hand tripped on voltage regulation. NR2501-8970
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	23-01-2025	23:31:00	24-01-2025	06:12:00	0.28	0.00	0.00	0.00	6.68		* LVRD Line hand tripped on voltage regulation. NR2501-9389
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	13-01-2025	22:36:00	14-01-2025	06:54:00	0.35	0.00	0.00	0.00	8.30		* Line hand tripped on voltage regulation. NR2501-5240
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	10-01-2025	21:45:00	11-01-2025	08:08:00	0.43	0.00	0.00	0.00	10.38		* 400kV KURUKSHETRA-NAKODAR(PSTCL) Line manually opened on voltage reg. (NR-4239)
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	21-01-2025	04:00:00	21-01-2025	05:33:00	0.07	0.00	0.00	0.00	1.55		* Line hand tripped for voltage regulation.NR2501-8155
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	19-01-2025	21:16:00	20-01-2025	06:22:00	0.38	0.00	0.00	0.00	9.10		* Line hand tripped for voltage regulation.NR2501-7691
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	06-01-2025	21:49:00	07-01-2025	05:51:00	0.34	0.00	0.00	0.00	8.03		* Line hand tripped on voltage regulation. NR2501-2464
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	26-01-2025	01:45:00	26-01-2025	05:53:00	0.17	0.00	0.00	0.00	4.13		* 400kV KURUKSHETRA-NAKODAR(PSTCL) Line manually opened on voltage reg. (NR-10334)
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	17-01-2025	23:27:00	18-01-2025	05:42:00	0.26	0.00	0.00	0.00	6.25		* Line hand tripped on voltage regulation. NR2501-6996
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	09-01-2025	23:14:00	10-01-2025	08:31:00	0.39	0.00	0.00	0.00	9.28		* 400kV KURUKSHETRA-NAKODAR(PSTCL) Line manually opened on voltage reg. (NR-3822)
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	21-01-2025	04:00:00	21-01-2025	05:33:00	0.07	0.00	0.00	0.00	1.55		* Line hand tripped for voltage regulation.NR2501-8155
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	21-01-2025	21:27:00	22-01-2025	06:24:00	0.37	0.00	0.00	0.00	8.95		* Line hand tripped on voltage regulation. NR2501-8529
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	05-01-2025	22:23:00	06-01-2025	06:43:00	0.35	0.00	0.00	0.00	8.33		* Line hand tripped on voltage regulation. NR2501-2052
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	08-01-2025	00:37:00	08-01-2025	06:01:00	0.23	0.00	0.00	0.00	5.40		* Line hand tripped on voltage regulation. NR2501-2929
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	24-01-2025	22:05:00	25-01-2025	05:43:00	0.32	0.00	0.00	0.00	7.63		* Line hand tripped for voltage regulation.NR2501-9879
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	14-01-2025	22:34:00	15-01-2025	06:16:00	0.32	0.00	0.00	0.00	7.70		* Line hand tripped on voltage regulation. NR2501-5652
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	09-01-2025	00:13:00	09-01-2025	05:42:00	0.23	0.00	0.00	0.00	5.48		* LVRD Line hand tripped on voltage regulation. NR2501-3402
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	19-01-2025	02:00:00	19-01-2025	07:24:00	0.23	0.00	0.00	0.00	5.40		* Line hand tripped on voltage regulation. NR2501-7416
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	27-01-2025	22:52:00	28-01-2025	06:16:00	0.31	0.00	0.00	0.00	7.40		* Line hand tripped for voltage regulation.NR2501-11094
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	11-01-2025	21:57:00	12-01-2025	08:45:00	0.45	0.00	0.00	0.00	10.80		* Line hand tripped for voltage regulation.NR2501-4618
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	29-01-2025	00:09:00	29-01-2025	07:06:00	0.29	0.00	0.00	0.00	6.95		* Line hand tripped for voltage regulation.NR2501-11537
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	16-01-2025	21:41:00	17-01-2025	06:23:00	0.36	0.00	0.00	0.00	8.70		* LVRD Line hand tripped on voltage regulation. NR2501-6528
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	30-01-2025	23:05:00	31-01-2025	06:53:00	0.33	0.00	0.00	0.00	7.80		* Line hand tripped on voltage regulation. NR2501-12378
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	31-01-2025	21:40:00	31-01-2025	23:59:59	0.10	0.00	0.00	0.00	2.33		* LVRD Line hand tripped on voltage regulation. NR2501-12778
							9.18	0.00	0.00	0.00	218.87	100.00	
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	19-01-2025	01:24:00	19-01-2025	05:09:00	0.16	0.00	0.00	0.00	3.75		* Line hand tripped on voltage regulation. NR2501-7414
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	26-01-2025	21:41:00	27-01-2025	07:48:00	0.42	0.00	0.00	0.00	10.12		* 400kV KURUKSHETRA-SONIPAT-1 Line manually opened on voltage reg. (NR-10625)
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	01-01-2025	00:00:01	01-01-2025	06:11:00	0.26	0.00	0.00	0.00	6.18		

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	04-01-2025	21:11:00	06-01-2025	07:54:00	1.45	0.00	0.00	0.00	34.72		* Line hand tripped for voltage regulation.NR2501-1695
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	01-01-2025	20:59:00	02-01-2025	06:55:00	0.41	0.00	0.00	0.00	9.93		* 400kV KURUKSHETRA-SONIPAT-1 Line manually opened on voltage reg. (NR-374)
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	10-01-2025	21:50:00	11-01-2025	06:33:00	0.36	0.00	0.00	0.00	8.72		* 400kV KURUKSHETRA-SONIPAT-1 Line manually opened on voltage reg. (NR-4240)
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	06-01-2025	21:37:00	07-01-2025	05:49:00	0.34	0.00	0.00	0.00	8.20		* Line hand tripped on voltage regulation. NR2501-2453
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	23-01-2025	21:27:00	24-01-2025	06:06:00	0.36	0.00	0.00	0.00	8.65		* LVRD Line hand tripped on voltage regulation. NR2501-9344
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	20-01-2025	21:53:00	21-01-2025	06:09:00	0.34	0.00	0.00	0.00	8.27		* Line hand tripped for voltage regulation.NR2501-8108
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	25-01-2025	22:56:00	26-01-2025	05:43:00	0.28	0.00	0.00	0.00	6.78		* 400kV KURUKSHETRA-SONIPAT-1 Line manually opened on voltage reg. (NR-10304)
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	16-01-2025	21:31:00	17-01-2025	06:25:00	0.37	0.00	0.00	0.00	8.90		* LVRD Line hand tripped on voltage regulation. NR2501-6521
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	17-01-2025	23:35:00	18-01-2025	06:13:00	0.28	0.00	0.00	0.00	6.63		* Line hand tripped on voltage regulation. NR2501-6995
CKT	400kV KURUKSHETRA-SONIPAT-1	OSFT	16-01-2025	11:44:00	16-01-2025	16:43:00	0.21	4.98	0.00	0.00	0.00		* ESD taken for attending the De capped Insulator of 400kv Abdullapur. Kurukshetra ckt-2.(Multi Circuit Tower). NR2501-6315
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	08-01-2025	21:02:00	09-01-2025	05:49:00	0.37	0.00	0.00	0.00	8.78		* Line hand tripped on voltage regulation. NR2501-3350
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	30-01-2025	23:03:00	31-01-2025	07:01:00	0.33	0.00	0.00	0.00	7.97		* Line hand tripped on voltage regulation. NR2501-12384
							6.80	4.98	0.00	0.00	158.25	99.33	
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	12-01-2025	21:57:00	13-01-2025	06:44:00	0.37	0.00	0.00	0.00	8.78		* Line hand tripped for voltage regulation.NR2501-4889
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	02-01-2025	21:57:00	03-01-2025	06:20:00	0.35	0.00	0.00	0.00	8.38		* 400kV KURUKSHETRA-SONIPAT-2 Line manually opened on voltage reg. (NR-805)
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	11-01-2025	21:56:00	12-01-2025	07:49:00	0.41	0.00	0.00	0.00	9.88		* Line hand tripped for voltage regulation.NR2501-4616
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	14-01-2025	23:57:00	15-01-2025	06:10:00	0.26	0.00	0.00	0.00	6.22		* Line hand tripped on voltage regulation. NR2501-5667
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	13-01-2025	22:46:00	14-01-2025	06:53:00	0.34	0.00	0.00	0.00	8.12		* Line hand tripped on voltage regulation. NR2501-5244
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	21-01-2025	21:31:00	22-01-2025	06:05:00	0.36	0.00	0.00	0.00	8.57		* Line hand tripped on voltage regulation. NR2501-8530
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	27-01-2025	21:32:00	28-01-2025	06:16:00	0.36	0.00	0.00	0.00	8.73		* Line hand tripped for voltage regulation.NR2501-11079
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	15-01-2025	22:46:00	16-01-2025	05:53:00	0.30	0.00	0.00	0.00	7.12		* LVRD Line hand tripped on voltage regulation. NR2501-6086
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	09-01-2025	22:37:00	10-01-2025	06:43:00	0.34	0.00	0.00	0.00	8.10		* 400kV KURUKSHETRA-SONIPAT-2 Line manually opened on voltage reg. (NR-3826)
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	24-01-2025	21:48:00	25-01-2025	05:47:00	0.33	0.00	0.00	0.00	7.98		* Line hand tripped for voltage regulation.NR2501-9837
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	19-01-2025	21:08:00	20-01-2025	06:11:00	0.38	0.00	0.00	0.00	9.05		* Line hand tripped for voltage regulation.NR2501-7685
CKT	400kV KURUKSHETRA-SONIPAT-2	LVRD	07-01-2025	21:04:00	08-01-2025	05:48:00	0.36	0.00	0.00	0.00	8.73		* Line hand tripped on voltage regulation. NR2501-2867
							4.16	0.00	0.00	0.00	99.66	100.00	
CKT	400kV MALERKOTLA-LUDHIANA	OSFT	03-01-2025	11:01:00	03-01-2025	14:12:00	0.13	3.18	0.00	0.00	0.00		* Emergency Sd by Malerkotla S/S to rectify the broken terminal connector
							0.13	3.18	0.00	0.00	0.00	99.57	
CKT	400kV MOGA-FATEHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MOGA-HISAR-1	LCSD	18-01-2025	10:04:00	18-01-2025	21:38:00	0.48	0.00	0.00	0.00	11.57		* 400kV Moga-Bhiwani-1 (bypassed at Hisar) taken under shutdown by NR-1 for retrofitment of 70789R isolator under ADD CAP Works NR2501-7123
CKT	400kV MOGA-HISAR-1	LVRD	18-01-2025	21:41:00	19-01-2025	09:21:00	0.49	0.00	0.00	0.00	11.67		* Line hand tripped on voltage regulation. NR2501-7360
CKT	400kV MOGA-HISAR-1	LCSD	20-01-2025	14:50:00	20-01-2025	22:31:00	0.32	0.00	0.00	0.00	7.68		* LCSD 400kV Moga-Bhiwani (bypassed at Hisar) taken under shutdown by NR-1 for retrofitment of 40789R isolator under ADD CAP Works NR2501-7923
CKT	400kV MOGA-HISAR-1	LVRD	20-01-2025	22:31:00	21-01-2025	06:39:00	0.34	0.00	0.00	0.00	8.13		* Line hand tripped for voltage regulation.NR2501-8129
							1.63	0.00	0.00	0.00	39.05	100.00	
CKT	400kV MOGA-HISAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MOGA-HISAR-3	OSFT	09-01-2025	16:41:00	09-01-2025	22:09:00	0.23	5.47	0.00	0.00	0.00		* Line taken under emergency basis by TL Moga for replacement of Decapped polymer at TNO-30. NR2501-3694
CKT	400kV MOGA-HISAR-3	OSFT	15-01-2025	18:46:00	15-01-2025	19:04:00	0.01	0.30	0.00	0.00	0.00		* Line taken under shutdown to facilitate charging of 400kV Bus-4 (GIS Bus-2) at Moga on No load NR2501-5995
							0.24	5.77	0.00	0.00	0.00	99.22	
CKT	400kV NAKODAR(PSTCL)-JALLANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NALAGARH-PATIALA-1	OSPT	30-01-2025	09:36:00	30-01-2025	18:25:00	0.37	8.82	0.00	0.00	0.00		* 400kV NALAGARH-PATIALA-1 line taken under SD by Nalagarh TLM for rectification of SD nature defects (NR-12025)
							0.37	8.82	0.00	0.00	0.00	98.81	
CKT	400kV NALAGARH-PATIALA-2	OSPT	31-01-2025	10:00:00	31-01-2025	18:20:00	0.35	8.33	0.00	0.00	0.00		* 400kV NALAGARH-PATIALA-2 taken under SD by nalagarh TLM for rectification of SD nature defects (NR-12567)
							0.35	8.33	0.00	0.00	0.00	98.88	
CKT	400kV NATPAJHAKRI(SJVNL)-GUMMA(HPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NATPAJHAKRI-GUMMA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-1	OSPD	03-01-2025	10:08:00	03-01-2025	16:26:00	0.26	0.00	0.00	0.00	6.30		* S/D taken by SJVNL
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-1	OSPD	04-01-2025	10:07:00	04-01-2025	17:11:00	0.29	0.00	0.00	0.00	7.07		* S/D taken by SJVNL NR2501-1478
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-1	OSPD	02-01-2025	11:04:00	02-01-2025	17:23:00	0.26	0.00	0.00	0.00	6.32		* OSPD Line taken under Shut down by Rampur SJVNL for 400kV Double Bus Bar System (Busbar-1, Busbar-2 <(>&<)> Bus Coupler) including Shutdown on all Generating Units (i.e. U#01 to U#06) <(>&<)> 80 MVAR Bus Reactor for inspection of isolator <(>&<)> earth switch alignment <(>&<)> testing of interlocks, inspection of SF-6 Gas Compartment G1, G2 <(>&<)> G9 and also testing of busbar protection. NR2501-590
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-1	OSPD	05-01-2025	09:38:00	05-01-2025	16:01:00	0.27	0.00	0.00	0.00	6.38		* S/D taken by SJVNL NR2501-1866
							1.08	0.00	0.00	0.00	26.07	100.00	
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-2	OSPD	02-01-2025	11:05:00	02-01-2025	17:24:00	0.26	0.00	0.00	0.00	6.32		* Line taken under Shut down by Rampur SJVNL for 400kV Double Bus Bar System (Busbar-1, Busbar-2 <(>&<)> Bus Coupler) including Shutdown on all Generating Units (i.e. U#01 to U#06) <(>&<)> 80 MVAR Bus Reactor for inspection of isolator <(>&<)> earth switch alignment <(>&<)> testing of interlocks, inspection of SF-6 Gas Compartment G1, G2 <(>&<)> G9 and also testing of busbar protection. NR2501-589
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-2	OSPD	04-01-2025	10:08:00	04-01-2025	16:53:00	0.28	0.00	0.00	0.00	6.75		* S/D taken by SJVNL NR2501-1477
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-2	OSPD	03-01-2025	10:09:00	03-01-2025	16:27:00	0.26	0.00	0.00	0.00	6.30		* S/D taken by SJVNL
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-2	OSPD	05-01-2025	09:39:00	05-01-2025	15:53:00	0.26	0.00	0.00	0.00	6.23		* S/D taken by SJVNL NR2501-1867
							1.06	0.00	0.00	0.00	25.60	100.00	
CKT	400kV ABDULLAPUR-PANCHKULA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ABDULLAPUR-PANCHKULA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PANCHKULA-DEHAR(BBMB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PANCHKULA-GUMMA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PANCHKULA-GUMMA(HPTCL)-2	LVRD	12-01-2025	21:59:00	13-01-2025	05:52:00	0.33	0.00	0.00	0.00	7.88		* Line hand tripped for voltage regulation.NR2501-4895
CKT	400kV PANCHKULA-GUMMA(HPTCL)-2	LVRD	11-01-2025	21:52:00	12-01-2025	06:07:00	0.34	0.00	0.00	0.00	8.25		* Line hand tripped for voltage regulation.NR2501-4619

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	18-01-2025	23:37:00	19-01-2025	05:38:00	0.25	0.00	0.00	0.00	6.02		* Line hand tripped on voltage regulation. NR2501-7396
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	10-01-2025	21:56:00	11-01-2025	05:56:00	0.33	0.00	0.00	0.00	8.00		* 400kV PANCHKULA-GUMMA(HPPTCL)-2 Line manually opened on voltage reg. (NR-4235)
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	15-01-2025	23:10:00	16-01-2025	05:27:00	0.26	0.00	0.00	0.00	6.28		* LVRD Line hand tripped on voltage regulation. NR2501-6088
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	26-01-2025	21:57:00	27-01-2025	06:24:00	0.35	0.00	0.00	0.00	8.45		* 400kV PANCHKULA-GUMMA(HPPTCL)-2 Line manually opened on voltage reg. (NR-10641)
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	24-01-2025	20:57:00	25-01-2025	05:20:00	0.35	0.00	0.00	0.00	8.38		* Line hand tripped for voltage regulation.NR2501-9842
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	25-01-2025	22:47:00	26-01-2025	05:47:00	0.29	0.00	0.00	0.00	7.00		* 400kV PANCHKULA-GUMMA(HPPTCL)-2 Line manually opened on voltage reg. (NR-10308)
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	23-01-2025	21:09:00	24-01-2025	05:37:00	0.35	0.00	0.00	0.00	8.47		* LVRD Line hand tripped on voltage regulation. NR2501-9345
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	31-01-2025	21:25:00	31-01-2025	23:59:59	0.11	0.00	0.00	0.00	2.58		* LVRD Line hand tripped on voltage regulation. NR2501-12764
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	06-01-2025	01:14:00	06-01-2025	05:46:00	0.19	0.00	0.00	0.00	4.53		* Line hand tripped on voltage regulation. NR2501-2076
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	03-01-2025	23:48:00	04-01-2025	07:10:00	0.31	0.00	0.00	0.00	7.37		* Line hand tripped for voltage regulation.NR2501-1296
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	01-01-2025	20:55:00	02-01-2025	05:44:00	0.37	0.00	0.00	0.00	8.82		* 400kV PANCHKULA-GUMMA(HPPTCL)-2 Line manually opened on voltage reg. (NR-384)
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	03-01-2025	00:23:00	03-01-2025	05:45:00	0.22	0.00	0.00	0.00	5.37		* 400kV PANCHKULA-GUMMA(HPPTCL)-2 Line manually opened on voltage reg. (NR-827)
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	01-01-2025	00:00:01	01-01-2025	05:34:00	0.23	0.00	0.00	0.00	5.57		* Line hand tripped on voltage regulation. NR2412-13375
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	21-01-2025	22:13:00	22-01-2025	05:37:00	0.31	0.00	0.00	0.00	7.40		* Line hand tripped on voltage regulation. NR2501-8533
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	13-01-2025	22:44:00	14-01-2025	05:56:00	0.30	0.00	0.00	0.00	7.20		* Line hand tripped on voltage regulation. NR2501-5243
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	17-01-2025	23:37:00	18-01-2025	06:01:00	0.27	0.00	0.00	0.00	6.40		* Line hand tripped on voltage regulation. NR2501-7002
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	16-01-2025	22:24:00	17-01-2025	05:41:00	0.30	0.00	0.00	0.00	7.28		* LVRD Line hand tripped on voltage regulation. NR2501-6542
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	07-01-2025	21:05:00	08-01-2025	05:32:00	0.35	0.00	0.00	0.00	8.45		* Line hand tripped on voltage regulation. NR2501-2869
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	08-01-2025	21:00:00	09-01-2025	05:29:00	0.35	0.00	0.00	0.00	8.48		* Line hand tripped for voltage regulation.NR2501-3347
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	06-01-2025	21:40:00	07-01-2025	05:44:00	0.34	0.00	0.00	0.00	8.07		* LVRD Line hand tripped on voltage regulation. NR2501-2466
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	LVRD	20-01-2025	21:25:00	21-01-2025	05:23:00	0.33	0.00	0.00	0.00	7.97		* Line hand tripped for voltage regulation.NR2501-8103
							6.83	0.00	0.00	0.00	164.22	100.00	
CKT	400kV PANCHKULA-PANIPAT(BBMB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATIALA-LUDHIANA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATIALA-LUDHIANA-2	SVRD	21-01-2025	09:44:00	21-01-2025	22:10:00	0.52	0.00	0.00	0.00	12.43		* OSPT SD taken for rectification of Shut down nature defects. NR2501-8304
							0.52	0.00	0.00	0.00	12.43	100.00	
CKT	400kV PATIALA-MALERKOTLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATIALA-PANCHKULA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATIALA-PANCHKULA-2	OMSU	11-01-2025	15:53:00	11-01-2025	16:33:00	0.03	0.00	0.67	0.00	0.00		* BR hand tripped for voltage regulation. NR2501-4327* 11.01.2025 16:52:55 INDIA (60020868) Phone 9001890844* Emergency SD taken for removing of kite thread from conductor and earth wire at Loc no-18. NR2501-4509
							0.03	0.00	0.67	0.00	0.00	100.00	
CKT	400kV PATIALA-PATRAN(TECHNO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PATIALA-PATRAN(TECHNO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARBATI2(NHPC)-BANALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARBATI3(NHPC)-BANALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARBATI3(NHPC)-SAINJ(HPSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAMPUR(SJVNL)-NALAGARH-1	OSPD	04-01-2025	10:23:00	04-01-2025	18:13:00	0.33	0.00	0.00	0.00	7.83		* S/D taken by SJVNL NR2501-1479
CKT	400kV RAMPUR(SJVNL)-NALAGARH-1	OSPD	03-01-2025	10:26:00	03-01-2025	16:50:00	0.27	0.00	0.00	0.00	6.40		* S/D taken by SJVNL
CKT	400kV RAMPUR(SJVNL)-NALAGARH-1	OSPD	02-01-2025	10:42:00	02-01-2025	16:35:00	0.25	0.00	0.00	0.00	5.88		* Line taken under Shut down by Rampur SJVNL for 400KV Double Bus Bar System (Busbar-1, Busbar-2 <=> Bus Coupler) including Shutdown on all Generating Units (i.e. U#01 to U#06) <=> 80 MVAR Bus Reactor for inspection of isolator <=> earth switch alignment <=> testing of interlocks, inspection of SF-6 Gas Compartment G1, G2 <=> G9 and also testing of busbar protection. NR2501-592
CKT	400kV RAMPUR(SJVNL)-NALAGARH-1	OSPD	05-01-2025	09:55:00	05-01-2025	16:29:00	0.27	0.00	0.00	0.00	6.57		* S/D taken by SJVNL NR2501-1864
							1.12	0.00	0.00	0.00	26.68	100.00	
CKT	400kV RAMPUR(SJVNL)-NALAGARH-2	OSPD	04-01-2025	10:23:00	04-01-2025	17:28:00	0.30	0.00	0.00	0.00	7.08		* S/D taken by SJVNL NR2501-1480
CKT	400kV RAMPUR(SJVNL)-NALAGARH-2	OSPD	02-01-2025	10:43:00	02-01-2025	16:39:00	0.25	0.00	0.00	0.00	5.93		* Line taken under Shut down by Rampur SJVNL for 400KV Double Bus Bar System (Busbar-1, Busbar-2 <=> Bus Coupler) including Shutdown on all Generating Units (i.e. U#01 to U#06) <=> 80 MVAR Bus Reactor for inspection of isolator <=> earth switch alignment <=> testing of interlocks, inspection of SF-6 Gas Compartment G1, G2 <=> G9 and also testing of busbar protection. NR2501-591
CKT	400kV RAMPUR(SJVNL)-NALAGARH-2	OSPD	03-01-2025	10:27:00	03-01-2025	16:51:00	0.27	0.00	0.00	0.00	6.40		* S/D taken by SJVNL
CKT	400kV RAMPUR(SJVNL)-NALAGARH-2	OSPD	05-01-2025	08:55:00	05-01-2025	16:31:00	0.32	0.00	0.00	0.00	7.60		* S/D taken by SJVNL NR2501-1865
							1.14	0.00	0.00	0.00	27.01	100.00	
CKT	400kV URI1(NHPC)-AMARGARH(STERLITE)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV URI1(NHPC)-AMARGARH(STERLITE)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV URI2(NHPC)-URI1(NHPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV URI2(NHPC)-WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WAGOORA-AMARGARH(STERLITE)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WAGOORA-AMARGARH(STERLITE)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEW WANPOH-BAGLIHAR-1	OSPD	29-01-2025	13:59:00	29-01-2025	20:59:00	0.29	0.00	0.00	0.00	7.00		* OSPD SD taken by JKPTCL for Bypass arrangement of LILO scheme and implementation of 400 KV Tie Breaker Scheme at Baglihar (BHEP-II). NR2501-11746
CKT	400kV NEW WANPOH-BAGLIHAR-1	OSPD	30-01-2025	14:42:00	30-01-2025	20:37:00	0.25	0.00	0.00	0.00	5.92		* 400kV NEW WANPOH-BAGLIHAR-1 line taken under SD by JKPTCL for Bypass arrangement of LILO scheme and implementation of 400 KV Tie Breaker Scheme at BHEP-II (NR-12172)
							0.54	0.00	0.00	0.00	12.92	100.00	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV NEW WANPOH-WAGOORA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEW WANPOH-WAGOORA-2	LART	06-01-2025	23:39:00	06-01-2025	23:39:00	0.00	0.00	0.00	0.00	0.00		* Line autoreclosed on Y-N Fault. FLR Wagoora: 40.997 km,5.154 kA.* 08.01.2025 18:01:47 INDIA (60003416)* Flashover on conductor due to bird infringement at 300
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-MOGA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-MOGA-2	OSFT	17-01-2025	13:41:00	17-01-2025	23:21:00	0.40	9.67	0.00	0.00	0.00		* Line taken under shutdown to attend hotspot in Gantry dropper of middle phase of span 725-726 <*> Gantry at Moga* 17.01.2025 20:39:41 INDIA (60016675)* NR2501-6798
CKT	400kV KISHENPUR-MOGA-2	OSFT	29-01-2025	18:27:00	29-01-2025	18:41:00	0.01	0.23	0.00	0.00	0.00		* OSFT SD taken to take out 63 MVAR Non Switcable Line Reactor out of service for Carrying out C <*> Tan delta testing of bushings at variable frequency. NR2501-11747
CKT	400kV KISHENPUR-MOGA-2	OMST	30-01-2025	11:52:00	30-01-2025	12:12:00	0.01	0.33	0.00	0.00	0.00		* OMST Line tripped due to Line Reactor PRV trip optd.at Kishenpur end and DT received at Moga end. NR2501-12156
							0.42	10.23	0.00	0.00	0.00	98.62	
CKT	765kV MEERUT-MOGA	LVRD	13-01-2025	01:06:00	13-01-2025	06:48:00	0.24	0.00	0.00	0.00	5.70		* Line hand tripped for voltage regulation.NR2501-4916
CKT	765kV MEERUT-MOGA	LVRD	06-01-2025	23:27:00	07-01-2025	07:31:00	0.34	0.00	0.00	0.00	8.07		* Line hand tripped on voltage regulation. NR2501-2495, NL-794
CKT	765kV MEERUT-MOGA	LVRD	10-01-2025	01:08:00	10-01-2025	06:18:00	0.22	0.00	0.00	0.00	5.17		* 765kV MEERUT-MOGA Line manually opened on voltage reg. (NR-3840, NL-1250)
CKT	765kV MEERUT-MOGA	LVRD	29-01-2025	23:36:00	30-01-2025	07:39:00	0.34	0.00	0.00	0.00	8.05		* Line hand tripped on voltage regulation. NR2501-11943,NL-4034
CKT	765kV MEERUT-MOGA	LVRD	10-01-2025	22:44:00	11-01-2025	06:52:00	0.34	0.00	0.00	0.00	8.13		* 765kV MEERUT-MOGA Line manually opened on voltage reg. (NR-4251, NL-1389)
CKT	765kV MEERUT-MOGA	LVRD	14-01-2025	00:05:00	14-01-2025	08:20:00	0.34	0.00	0.00	0.00	8.25		* Line hand tripped on voltage regulation. NR2501-5258,NL-1778
CKT	765kV MEERUT-MOGA	LVRD	22-01-2025	01:41:00	22-01-2025	06:18:00	0.19	0.00	0.00	0.00	4.62		* Line hand tripped on voltage regulation. NR2501-8571,NL-2905
CKT	765kV MEERUT-MOGA	LVRD	30-01-2025	23:53:00	31-01-2025	07:25:00	0.31	0.00	0.00	0.00	7.53		* Line hand tripped on voltage regulation. NR2501-12388, NL-4200
CKT	765kV MEERUT-MOGA	LVRD	05-01-2025	23:25:00	06-01-2025	08:03:00	0.36	0.00	0.00	0.00	8.63		* Line hand tripped on voltage regulation. NR2501-2062,NL-632
CKT	765kV MEERUT-MOGA	LVRD	03-01-2025	00:10:00	03-01-2025	07:40:00	0.31	0.00	0.00	0.00	7.50		* 765kV MEERUT-MOGA Line manually opened on voltage reg. (NR-819, NL-253)
CKT	765kV MEERUT-MOGA	LVRD	01-01-2025	23:32:00	02-01-2025	05:38:00	0.25	0.00	0.00	0.00	6.10		* 765kV MEERUT-MOGA Line manually opened on voltage reg. (NR-406, NL-103)
CKT	765kV MEERUT-MOGA	LVRD	22-01-2025	22:11:00	23-01-2025	06:26:00	0.34	0.00	0.00	0.00	8.25		* Line hand tripped on voltage regulation. NR2501-8965, NL-3025
CKT	765kV MEERUT-MOGA	LVRD	16-01-2025	01:41:00	16-01-2025	06:51:00	0.22	0.00	0.00	0.00	5.17		* LVRD Line hand tripped on voltage regulation. NR2501-6106
CKT	765kV MEERUT-MOGA	LVRD	20-01-2025	23:16:00	21-01-2025	06:07:00	0.29	0.00	0.00	0.00	6.85		* Line hand tripped for voltage regulation.NR2501-8135,NL-2748
CKT	765kV MEERUT-MOGA	LVRD	11-01-2025	21:52:00	12-01-2025	08:57:00	0.46	0.00	0.00	0.00	11.08		* Line hand tripped for voltage regulation.NR2501-4625,NL-1537
CKT	765kV MEERUT-MOGA	LVRD	17-01-2025	23:07:00	18-01-2025	06:08:00	0.29	0.00	0.00	0.00	7.02		* Line hand tripped on voltage regulation. NR2501-6988 NL-2339
CKT	765kV MEERUT-MOGA	LVRD	27-01-2025	00:11:00	27-01-2025	07:27:00	0.30	0.00	0.00	0.00	7.27		* 765kV MEERUT-MOGA Line manually opened on voltage reg. (NR-10659, NL-3568)
							5.14	0.00	0.00	0.00	123.39	100.00	
CKT	66KV DRASS-DRASS(LPDD) I/C 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66KV-DRASS-DRASS(LPDD) I/C 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66KV KARGIL CHUTAK CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66KV-KARGIL-KARGIL (LPDD) CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66KV KARGIL SHARGOLE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66KV-KHLSTI-KHLSTI (LPDD) INTERCONNECTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66 KV PHYANG KHARU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66KV-PHYANG LEH (JKPDD) CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66KV-PHYANG-LEH (JKPDD) CKT 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	66KV-PHYANG NIMOO			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PANCHKULA-1 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PANCHKULA-2 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,LR OF JALANDHAR AT HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF CHAMBA-2 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF CHAMBA-1 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF BAGPAT-1 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF BAGPAT-2 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	KAITHAL-DADRI LINE REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Kishenpur 400kV 63MVAR Moga2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	KISHENPUR-MOGA-1 LR-400kV 63MVAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Moga 400kV 63MVAR Kishenpur1-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Moga 400kV 63MVAR Kishenpur2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	Moga 400kV 63MVAR Hisar3-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Moga 400kV 63MVAR Hisar2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BIKANER-1 AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BIKANER-2 AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR, SWLR OF MEERUT AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHIWANI AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Nalagarh 400kV 50MVAR Rampur2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF GUMMA-1 AT PKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF GUMMA-2 AT PKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	SAMBA-AMARGARH-1 LINE REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	SAMBA-AMARGARH-2 LINE REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	+200/-200MVAR STATCOM AT NALAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
SVC	+600/-400MVAR SVC AT LUDHIANA	OSPD	24-01-2025	15:00:00	24-01-2025	18:10:00	0.13	0.00	0.00	0.00	3.17		* LUDHIANA -400/+600 MVAR SVC 1/24/2025 15:00 STILL OUT OSPD SD taken on request of INDIGRID to facilitate OPGW stringing of 400 kV Koldam – Ludhiana line in last span (from DDE tower to the gantry) which is within the PGCIL Ludhiana substation premises NR2501-9669
							0.13	0.00	0.00	0.00	3.17	100.00	
SVC	+300/-200MVAR SVC AT NEW WANPOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-4 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT AMRITSAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT AMRITSAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT AMRITSAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT AMRITSAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BANALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BANALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT CHAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT CHAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT DEHAR	OMST	10-01-2025	09:15:00	10-01-2025	11:19:00	0.09	2.07	0.00	0.00	0.00		* ICT tripped on difrential protection.
XMER	315MVA,400/220kV ICT-1 AT DEHAR	OSFT	11-01-2025	12:34:00	11-01-2025	16:34:00	0.17	4.00	0.00	0.00	0.00		* Emergency SD for Tertiary side insulation coating (On Terminal connector) and FRA test.
XMER	315MVA,400/220kV ICT-1 AT DEHAR	OSFT	10-01-2025	11:19:00	10-01-2025	16:23:00	0.21	5.07	0.00	0.00	0.00		* ICT taken under emergency shutdown after tripping for restoration works NR2501-4036
							0.47	11.14	0.00	0.00	0.00	98.50	
XMER	50MVA,220/66 KV ICT-1 AT DRASS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT FATEHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT FATEHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT FATEHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/66kV ICT-1 AT CHANDIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	160MVA,220/66kV ICT-2 AT CHANDIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HAMIRPUR	OSFT	08-01-2025	11:26:00	08-01-2025	12:02:00	0.03	0.60	0.00	0.00	0.00		* 315MVA,400/220kV ICT-1 AT HAMIRPUR - Forced Shutdown (e.g. E/W snappings/hots NR2501-3164. (Hot Spot in CT wire found loose).
							0.03	0.60	0.00	0.00	0.00	99.92	
XMER	315MVA,400/220kV ICT-2 AT HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage In Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyfn	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-1 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,220/66kV ICT-1 AT KARGIL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,220/66kV ICT-2 AT KARGIL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KISHENPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KISHENPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT KISHENPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	50MVA,220/66kV ICT-1 AT KHALSTI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MALERKOTLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MALERKOTLA	OSPD	17-01-2025	09:36:00	17-01-2025	18:54:00	0.39	0.00	0.00	0.00	9.30		* ICT taken under shutdown on request of PSTCL for General maintenance of 220 KV MALERKOTLA(PS)-MALERKOTLA(PG) (PSTCL) CKT-2 NR2501-67

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-II

[illegible]