









Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.06	1.52	0.00	0.00	0.00	99.79	
CKT	400kV CHAMERA2(NHPC)-CHAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHAMERA1(NHPC)-CHAMERA2(NHPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHAMERA2(NHPC)-KISHENPUR	LART	19/09/22	12:38:00	19/09/22	12:38:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line Auto reclosed on R-N fault. FLR Kishenpur: M1: 50.5km, Ir: 5.48kA, M2: 49.14km, Ir: 5.7kA
CKT	400kV DEHAR(BBMB)-RAJPURA(PSTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DEPALPUR(HVPNL)-BAWANA(DTL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DULHASTI(NHPC)-KISHENPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DULHASTI(NHPC)-KISHENPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JALANDHAR-HAMIRPUR	OSPT	16/09/22	10:15:00	16/09/22	10:36:00	0.02	0.35	0.00	0.00	0.00	100.00	* SD taken to switch out non-switchable Line Reactor. NR 2209-2807
CKT	400kV JALANDHAR-HAMIRPUR	OSPT	16/09/22	21:32:00	16/09/22	22:09:00	0.03	0.62	0.00	0.00	0.00	100.00	* OSPT SD taken to switch in non-switchable Line Reactor at Hamirpur. NR 2209-2807
CKT	400kV JALANDHAR-LUDHIANA			00:00:00		00:00:00	0.05	0.97	0.00	0.00	0.00	99.87	
CKT	400kV JALLANDHAR-MOGA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JALLANDHAR-MOGA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-BAGPAT-1	OMST	18/09/22	11:19:00	18/09/22	16:08:00	0.20	4.82	0.00	0.00	0.00	99.33	* Line tripped due to DT received at Kaithal due to 400KV Bus-1 tripped at Bagpat SS. FLR Kaithal: 2.56kA, FL-NIL. Charging code NR2209/3146.
CKT	400kV KAITHAL-BAGPAT-2			00:00:00		00:00:00	0.20	4.82	0.00	0.00	0.00	99.33	
CKT	400kV KAITHAL-DADRI(NTPC)	LART	20/09/22	18:34:00	20/09/22	18:34:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line Auto reclosed on B-N fault. FLR Kaithal (AFAS) M1: 72.223KM, Ib: 5.015kA, M2: 72.782KM, Ib: 6.36kA
CKT	400kV KAITHAL-MALERKOTLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-PATRAN(TECHNO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAITHAL-PATRAN(TECHNO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-BAGLIHAR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-SAMBA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-SAMBA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-NEW WANPOH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-NEW WANPOH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-NEW WANPOH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KISHENPUR-NEW WANPOH-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLDAM(NTPC)-NALAGARH-2	OSFD	12/09/22	17:51:00	13/09/22	18:22:00	1.02	0.00	0.00	0.00	24.52	100.00	* NR2209-2124 , SD taken by NTPC for replacement of failure LA at Koldam S/S.
CKT	400kV KURUKSHETRA-JALANDHAR			00:00:00		00:00:00	1.02	0.00	0.00	0.00	24.52	100.00	
CKT	400kV KURUKSHETRA-JIND-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KURUKSHETRA-JIND-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KURUKSHETRA-NAKODAR(PSTCL)	LVRD	24/09/22	14:34:00	30/09/22	09:46:00	5.80	0.00	0.00	0.00	139.20	100.00	* Line opened on Voltage Regulation NR-2209-4114, RT-426

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							5.80	0.00	0.00	0.00	139.20	100.00	
CKT	400kV KURUKSHETRA-SONIPAT-1	LVRD	23/09/22	03:16:00	25/09/22	21:05:00	2.74	0.00	0.00	0.00	65.82	100.00	* Line hand tripped for voltage regulation. "NR 2209-3886" *
							2.74	0.00	0.00	0.00	65.82	100.00	
CKT	400kV KURUKSHETRA-SONIPAT-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MALERKOTLA-LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MOGA-FATEHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MOGA-HISAR-1	LCSD	13/09/22	08:54:00	13/09/22	23:14:00	0.60	0.00	0.00	0.00	14.33	100.00	* SD taken for SS 34 by-passing works at Hisar SS. NR 2209-2191
							0.60	0.00	0.00	0.00	14.33	100.00	
CKT	400kV MOGA-HISAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MOGA-HISAR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAKODAR(PSTCL)-JALLANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NALAGARH-PATIALA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NALAGARH-PATIALA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV_ NAPTHAJHAKRI-GUMMA-2	OSFD	17/09/22	14:54:00	17/09/22	17:41:00	0.12	0.00	0.00	0.00	2.78	100.00	* SD taken by HPPTCL to attend sparking in HPPTCL LILO portion of line at tower no. 6. NR 2209-3011
							0.12	0.00	0.00	0.00	2.78	100.00	
CKT	400kV NATHPAJHAKRI(SJVNL)-PANCHKULA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NATPAJHAKRI(SJVNL)-RAMPUR(SJVNL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ABDULLAPUR-PANCHKULA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ABDULLAPUR-PANCHKULA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PANCHKULA-DEHAR(BBMB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	OMSU	17/09/22	17:02:00	17/09/22	17:02:00	0.00	0.00	0.00	0.00	0.00	100.00	* SD taken by HPPTCL for safety purpose to attend sparking at tower no. 6 in HPPTCL LILO portion of 400kV Nathpajhakri-Gumma ckt-2 as both 400kV Panchkula-Gumma ckt-2 <-> 400kV Gumma-Nathpajhakri ckt-2 are on same tower. After return of shut down by HPPTCL, charging attempt taken at 17:02 Hrs dated 17.09.2022 from Panchkula end vide NRLDC code NR 2209-3044 but line tripped of SOTF. FLR Panchkula: R-N fault, FL= 92kM, Ir=4kA. Again charging attempt taken at 18:47 Hrs dated 17.09.2022 on same code but line tripped on SOTF. FLR Gumma: R-N fault, Ir=8.8kA, FL=9.471kM. ----* 20.10.2022 13:31:57 INDIA Parvinder Kumar (60016809)* Duplicate entry

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	OSFD	17/09/22	14:54:00	22/09/22	17:26:00	5.11	0.00	0.00	122.53		* SD taken by HPPTCL for safety purpose to attend sparking in HPPTCL LILO portion at tower no. 6 of 400kV Nathpajhaki-Gumma ckt-2 as both 400kV Panchkula-Gumma ckt-2 <(>&<)> 400kV Gumma-Nathpajhaki ckt-2 are on same tower. NR 2209-3010* 05.10.2022 23:28:29 INDIA Parvinder Kumar (60016809)* 17.09.2022, 1702 Hrs:* After returning of Shutdown by HPPTCL, attempt was taken to charge the Line from Panchkulla but line did not hold and SOTF sensed by relay at Panchkulla end.* 17.06.2022, 1847 Hrs:* Attempt was taken to charge the Line from HPPTCL Gumma but again line tripped and SOTF was sensed by relay at Gumma* In the mean time, POWERGRID had submitted in writing clearance for POWERGRID portion of the Line.* 18.09.2022, 1732hrs:* Line successfully charged from Panchkulla after opening faulty phase jumpera at 110km from Panchkulla, segregating POWERGRID Line from HPPTCL portion of the line. R-Ph of the Line remain chared upto 111.00km from Panchkulla (POWERGRID portion) and Y <(>&<)> B remain charged upto HPPTCL Gumma.* 19.09.2022, at 2058 Hrs: (NRLDC code NR 2209-3357* Line succssfullay charged from Panchkulla after opening Line Jumpers at HPPTCL S/S Gumma.* Conclusion : As per mail recieved from NRLDC on 20.09.2022, line could not be charged due to high SO2 content in in R-Phase of G-13 compartment of 89B Isolator at Gumma(HP) .
CKT	400kV PANCHKULA-GUMMA(HPPTCL)-2	SRMU	10/09/22	14:31:00	10/09/22	15:11:00	0.03	0.00	0.67	0.00	0.00	* Line A/R on Y-N fault from Panchkula end and tripped from HPPTCL Gumma SS. FLR Panchkula: FL=32.2kM, ly=5.983kA <(>&<)> FLR Gumma: FL=83.17, ly=2.803kA.
							5.14	0.00	0.67	0.00	122.53	100.00
CKT	400kV PANCHKULA-PANIPAT(BBMB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV PATIALA-LUDHIANA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV PATIALA-LUDHIANA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV PATIALA-MALERKOTLA	OSFT	23/09/22	12:58:00	23/09/22	17:43:00	0.20	4.75	0.00	0.00	0.00	* OSFT SD taken to attend the hot spot in R phase line isolator at Malerkotla S/S. NR 2209-3954
CKT	400kV PATIALA-MALERKOTLA	SRMT	11/09/22	05:33:00	11/09/22	05:52:00	0.01	0.32	0.00	0.00	0.00	* Line tripped on Y-N Fault . FLR Patiala ly=27.78 kA , 0.568 kM NR 2209-1836
							0.21	5.07	0.00	0.00	0.00	99.30
CKT	400kV PATIALA-PANCHKULA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV PATIALA-PANCHKULA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV PATIALA-PATRAN(TECHNO)-1	OSFD	20/09/22	10:39:00	30/09/22	23:59:59	10.56	0.00	0.00	0.00	253.35	* Line handtripped due to protester climbed at tower as per NRLDC instruction. "NR 2209-3431" * 05.10.2022 23:26:45 INDIA Parvinder Kumar (60016809)* Forced Shutdown on request of PSTCL Patiala and NRLDC instruction in view of Human Safety as protesters climbed at tower no. 311.
							10.56	0.00	0.00	0.00	253.35	100.00
CKT	400kV PATIALA-PATRAN(TECHNO)-2	OSFD	20/09/22	10:40:00	30/09/22	23:59:59	10.56	0.00	0.00	0.00	253.33	* Line handtripped due to protester climbed at tower as per NRLDC instruction. "NR 2209-3431" * 05.10.2022 23:27:19 INDIA Parvinder Kumar (60016809)* Forced Shutdown on request of PSTCL Patiala and NRLDC instruction in view of Human Safety as protesters climbed at tower no. 311.
							10.56	0.00	0.00	0.00	253.33	100.00
CKT	400kV PARBATI2(NHPC)-BANALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV PARBATI3(NHPC)-BANALA	OSFD	28/09/22	12:05:00	28/09/22	15:21:00	0.14	0.00	0.00	0.00	3.27	* SD taken by NHPC for testing of cable at Parbati3. NR 2209-4816
CKT	400kV PARBATI3(NHPC)-BANALA	OSPD	16/09/22	11:04:00	16/09/22	15:35:00	0.19	0.00	0.00	0.00	4.52	* SD taken by NHPC for replacement of R-Phase pole of Unit#1 Bay at Parbati3 S/S. NR 2209-2826





Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	66KV-PHYANG NIMU CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PANCHKULA-1 AT ABDULLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PANCHKULA-1 AT ABDULLA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,LR OF JALANDHAR AT HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF CHAMBA-2 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF CHAMBA-1 AT JALANDHAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF BAGPAT-1 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF BAGPAT-2 AT KAITHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	KAITHAL-DADRI LINE REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Kishenpur 400kV 63MVAR Moga2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	KISHENPUR-MOGA-1 LR-400kV 63MVAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Moga 400kV 63MVAR Kishenpur1-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Moga 400kV 63MVAR Kishenpur2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Moga 400kV 63MVAR Hisar3-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Moga 400kV 63MVAR Hisar2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BIKANER-1 AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BIKANER-2 AT MOGA	SICT	07/09/22	03:09:00	07/09/22	09:02:00	0.25	5.88	0.00	0.00	0.00		* LR (Y-Ph) tripped on Buckholz protection operation as LR was in service after converted into bus reactor (765kV Moga-Bikaner ckt-2 was in opened condition on voltage regulation).
							0.25	5.88	0.00	0.00	0.00	99.18	
LNR	240MVAR, SWLR OF MEERUT AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHIWANI AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	Nalagarh 400kV 50MVAR Rampur2-LR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NAPTAJHAKRI-1 AT P'KULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NAPTAJHAKRI-2 AT P'KULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	SAMBA-AMARGARH-1 LINE REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	SAMBA-AMARGARH-2 LINE REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCG	+200/-200MVAR STATCOM AT NALAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
SVC	+600/-400MVAR SVC AT LUDHIANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
SVC	+300/-200MVAR SVC AT NEW WANPOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT ABDULLAPUR	OSPT	29/09/22	10:08:00	29/09/22	17:45:00	0.32	7.62	0.00	0.00	0.00		* SD taken for AMP works. NR 2209-4996
							0.32	7.62	0.00	0.00	0.00	98.94	
XMER	315MVA,400/220kV ICT-3 AT ABDULLAPUR	OSPT	30/09/22	10:19:00	30/09/22	17:27:00	0.30	7.13	0.00	0.00	0.00		* OSPT SD taken for AMP works. NR 2209-5177
							0.30	7.13	0.00	0.00	0.00	99.01	
XMER	315MVA,400/220kV ICT-4 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT AMRITSAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	



Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	250MVA,400/220kV ICT-2 AT MOGA	OMST	14/09/22	10:48:00	14/09/22	12:11:00	0.06	1.38	0.00	0.00	0.00		* OMST ICT tripped on TRF back-up E/F relay optd during charge over of 220kV Bus isolators on shut down of 220kV Bus-2. NR 2209-2421
							0.06	1.38	0.00	0.00	0.00	99.81	
XMER	1500MVA,765/400kV ICT-2 AT MOGA	OSPT	26/09/22	10:24:00	26/09/22	21:45:00	0.47	11.35	0.00	0.00	0.00		* SD taken for AMP Works NR-2209-4362, NL-2025
							0.47	11.35	0.00	0.00	0.00	98.42	
XMER	500MVA,400/220kV ICT-3 AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-4 AT MOGA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT NALAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT NALAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT NALAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT PANIPAT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PATIALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PATIALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PATIALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PANCHKULA	OSPT	08/09/22	09:28:00	08/09/22	18:06:00	0.36	8.63	0.00	0.00	0.00		* SD taken for AMP works.
							0.36	8.63	0.00	0.00	0.00	98.80	
XMER	315MVA,400/220kV ICT-2 AT PANCHKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PANCHKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-4 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT NEW WANPOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT NEW WANPOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
							725.11	144.75	734.71	10.70	16,510.36		