

Standard of Performance data for the month of Jun-2023
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR,BUS REACTOR-1 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT ABDULLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT AMRITSAR	SVRD	10-06-2023	10:30:00	30-06-2023	23:59:59	20.56	0.00	0.00	0.00	493.50	100.00	* B/R hand tripped for voltage regulation. NR2306-1923
BSR	25MVAR, BUS REACTOR-1 AT AMRITSAR			00:00:00		00:00:00	20.56	0.00	0.00	0.00	493.50	100.00	
BSR	80MVAR,BUS REACTOR-1 AT BANALA	SVRD	22-06-2023	12:26:00	30-06-2023	23:59:59	8.48	0.00	0.00	0.00	203.57	100.00	* B/R manually open on voltage regulation.NR2306-4222
BSR	80MVAR,BUS REACTOR-1 AT CHAMBA			00:00:00		00:00:00	8.48	0.00	0.00	0.00	203.57	100.00	
BSR	63MVAR,BUS REACTOR-1 AT DEHAR	SVRD	22-06-2023	13:10:00	30-06-2023	23:59:59	8.45	0.00	0.00	0.00	202.83	100.00	* B/R manually open on voltage regulation.NR2306-4214
BSR	63MVAR,BUS REACTOR-2 AT DEHAR	SVRD	22-06-2023	13:10:00	30-06-2023	23:59:59	8.45	0.00	0.00	0.00	202.83	100.00	* B/R manually open on voltage regulation.NR2306-4215
BSR	80MVAR,BUS REACTOR-1 AT FATEHABAD	SVRD	01-06-2023	00:00:01	30-06-2023	23:59:59	30.00	0.00	0.00	0.00	720.00	100.00	* B/R hand tripped for voltage regulation. NR 2305-6316
BSR	25MVAR, BUS REACTOR-1 AT FATEHABAD			00:00:00		00:00:00	30.00	0.00	0.00	0.00	720.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT HAMIRPUR	SVRD	22-06-2023	12:33:00	30-06-2023	23:59:59	8.48	0.00	0.00	0.00	203.45	100.00	* B/R manually open on voltage regulation.NR2306-4223
BSR	25MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	10-06-2023	10:32:00	30-06-2023	23:59:59	20.56	0.00	0.00	0.00	493.47	100.00	* B/R hand tripped for voltage regulation. NR2306-1926
BSR	125MVAR,BUS REACTOR-1 AT JALANDHAR	SVRD	10-06-2023	10:31:00	30-06-2023	23:59:59	20.56	0.00	0.00	0.00	493.48	100.00	* B/R hand tripped for voltage regulation. NR2306-1924
BSR	25MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	10-06-2023	10:33:00	30-06-2023	23:59:59	20.56	0.00	0.00	0.00	493.45	100.00	* B/R hand tripped for voltage regulation. NR2306-1927
BSR	125MVAR,BUS REACTOR-2 AT JALANDHAR	SVRD	10-06-2023	10:31:00	30-06-2023	23:59:59	20.56	0.00	0.00	0.00	493.48	100.00	* B/R hand tripped for voltage regulation. NR2306-1925
BSR	80MVAR,BUS REACTOR-1 AT KAITHAL	SVRD	16-06-2023	10:40:00	30-06-2023	23:59:59	14.56	0.00	0.00	0.00	349.33	100.00	* B/R hand tripped for voltage regulation. NR 2306-3143
BSR	125MVAR,BUS REACTOR-2 AT KAITHAL	SVRD	16-06-2023	10:40:00	30-06-2023	23:59:59	14.56	0.00	0.00	0.00	349.33	100.00	* B/R hand tripped for voltage regulation. NR 2306-3140
BSR	25MVAR,BUS REACTOR-1 AT KARGIL GIS	SVRD	01-06-2023	07:42:00	15-06-2023	15:59:00	14.35	0.00	0.00	0.00	344.28	100.00	* B/R hand tripped for voltage regulation. NR 2306-29
BSR	25MVAR,BUS REACTOR-1 AT KISHENPUR	SVRD	01-06-2023	00:00:01	30-06-2023	23:59:59	30.00	0.00	0.00	0.00	720.00	100.00	* SVRD B/R hand tripped for voltage regulation. NR 2305-5186
BSR	63MVAR,BUS REACTOR-1 AT KISHENPUR	SVRD	22-06-2023	12:23:00	30-06-2023	23:59:59	8.48	0.00	0.00	0.00	203.62	100.00	* B/R manually open on voltage regulation.NR2306-4219
BSR	80MVAR,BUS REACTOR-2 AT KISHENPUR	SVRD	22-06-2023	12:23:00	30-06-2023	23:59:59	8.48	0.00	0.00	0.00	203.62	100.00	* B/R manually open on voltage regulation.NR2306-4220
BSR	125MVAR,BUS REACTOR-3 AT KISHENPUR	SVRD	21-06-2023	08:41:00	30-06-2023	23:59:59	9.64	0.00	0.00	0.00	231.32	100.00	* SVRD B/R hand tripped for voltage regulation. NR 2306-3870
BSR	80MVAR,BUS REACTOR-1 AT LUDHIANA	SVRD	10-06-2023	10:43:00	30-06-2023	23:59:59	20.55	0.00	0.00	0.00	493.28	100.00	* B/R hand tripped for voltage regulation. NR2306-1938
BSR	50MVAR,BUS REACTOR-1 AT MALERKOTLA	SVRD	21-06-2023	08:37:00	30-06-2023	23:59:59	9.64	0.00	0.00	0.00	231.38	100.00	* SVRD B/R hand tripped for voltage regulation. NR 2306-3869
BSR	50MVAR,BUS REACTOR-1 AT MOGA			00:00:00		00:00:00	9.64	0.00	0.00	0.00	231.38	100.00	
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	08-06-2023	09:14:00	08-06-2023	15:20:00	0.25	0.00	0.00	0.00	6.10	100.00	* B/R hand tripped for voltage regulation. *NR2306-1390* NLDC-750"
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	05-06-2023	10:42:00	05-06-2023	15:33:00	0.20	0.00	0.00	0.00	4.85	100.00	* B/R hand tripped on voltage regulation.NR 2306-788,NL-417
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	09-06-2023	09:20:00	09-06-2023	15:49:00	0.27	0.00	0.00	0.00	6.48	100.00	* B/R hand tripped for voltage regulation. *NR2306-1678* NLDC-870"
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	06-06-2023	10:55:00	06-06-2023	15:16:00	0.18	0.00	0.00	0.00	4.35	100.00	* B/R hand tripped on voltage regulation.NR 2306-1008,NL-529
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	29-06-2023	10:05:00	29-06-2023	15:18:00	0.22	0.00	0.00	0.00	5.22	100.00	* B/R hand tripped on voltage regulation.NR2306-5493,NL-3116
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	24-06-2023	09:42:00	24-06-2023	16:16:00	0.27	0.00	0.00	0.00	6.57	100.00	* SVRD B/R hand tripped for voltage regulation. NRLDC 4607/2599
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	21-06-2023	09:51:00	21-06-2023	16:52:00	0.29	0.00	0.00	0.00	7.02	100.00	* B/R manually open on voltage regulation.NR2306-3979,NL-2260
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	27-06-2023	11:57:00	27-06-2023	16:10:00	0.18	0.00	0.00	0.00	4.22	100.00	* Bus Reactor hand tripped on VR
BSR	240MVAR,BUS REACTOR-1 AT MOGA	SVRD	20-06-2023	09:58:00	20-06-2023	16:05:00	0.26	0.00	0.00	0.00	6.12	100.00	* B/R hand tripped for voltage regulation. *NR2306-3810* NLDC-2142"

Standard of Performance data for the month of Jun-2023
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-2 AT NALAGARH	SVRD	10-06-2023	10:41:00	30-06-2023	23:59:59	20.56	0.00	0.00	0.00	493.40	100.00	* B/R hand tripped for voltage regulation. NR2306-1942
BSR	125MVAR,BUS REACTOR-1 AT PATIALA	SVRD	10-06-2023	10:36:00	30-06-2023	23:59:59	20.56	0.00	0.00	0.00	493.40	100.00	* B/R hand tripped for voltage regulation. NR2306-1939
BSR	125MVAR,BUS REACTOR-2 AT PATIALA	SVRD	10-06-2023	10:36:00	30-06-2023	23:59:59	20.56	0.00	0.00	0.00	493.40	100.00	* B/R hand tripped for voltage regulation. NR2306-1940
BSR	25MVAR,BUS REACTOR-1 AT LEH GIS	SVRD	01-06-2023	00:00:01	01-06-2023	23:51:00	0.99	0.00	0.00	0.00	23.85	100.00	* B/R hand tripped for voltage regulation. NR 2305-7011
BSR	25MVAR,BUS REACTOR-1 AT LEH GIS	LVRD	02-06-2023	06:52:00	02-06-2023	13:43:00	0.29	0.00	0.00	0.00	6.85	100.00	* B/R hand tripped for voltage regulation. NR 2306-198
BSR	25MVAR,BUS REACTOR-1 AT LEH GIS	SVRD	03-06-2023	07:21:00	03-06-2023	13:20:00	0.25	0.00	0.00	0.00	5.98	100.00	* B/R hand tripped for voltage regulation. NR 2306-368
BSR	25MVAR,BUS REACTOR-1 AT LEH GIS	SVRD	15-06-2023	16:33:00	30-06-2023	23:59:59	15.31	0.00	0.00	0.00	367.45	100.00	* B/R hand tripped for voltage regulation. NR 2306-3032
BSR	125MVAR,BUS REACTOR-1 AT PANCHKULA	SVRD	19-06-2023	10:13:00	30-06-2023	23:59:59	11.57	0.00	0.00	0.00	277.78	100.00	* Bus Reactor hand tripped on VR
BSR	125MVAR,BUS REACTOR-2 AT PANCHKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR,BUS REACTOR-1 AT WAGOORA	SVRD	01-06-2023	00:00:01	30-06-2023	23:59:59	30.00	0.00	0.00	0.00	720.00	100.00	* to open 50 mvar bus reactor no 1 at 400kv wagoora(pg) NR2304-2881** (14-Apr-23 08:21)
BSR	50MVAR,BUS REACTOR-2 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR,BUS REACTOR-3 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT NEW WANPOH	SVRD	01-06-2023	00:00:01	30-06-2023	23:59:59	30.00	0.00	0.00	0.00	720.00	100.00	* B/R hand tripped for voltage regulation. NR 2305-1437
CKT	132kv MAHANPUR(JKPDD)-KATHUA(JKPDD)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132kv SEWA2(NHPC)-HIRANAGAR(JKPDD)-1	OSFD	28-06-2023	19:07:00	28-06-2023	20:29:00	0.06	0.00	0.00	0.00	1.37	97.17	* Emergency SD taken by JKTCL for isolator alignment rectification. Complete SD of 132kV S/Y at Hiranagar. NR 2306-5401
CKT	132kv SEWA2(NHPC)-HIRANAGAR(JKPDD)-1	OSFT	01-06-2023	00:00:01	01-06-2023	20:23:00	0.85	20.38	0.00	0.00	0.00	97.16	* 132KV SEWA2 - HIRANAGAR -I 28-05-2023 08:19 STILL OUT LCSD SD taken for Erection/Destringing/Stringing work of diversion of Line between tower no 47-49, due to land slide near Tower no 48 rerouting of line.NR-6443* 09.08.2023 16:58:51 INDIA Parvinder Kumar (60016809)* NRLDC Comments- LNCC/LMAC includes line outages due to natural calamities or breakdown caused by miscreants/ Militant activities. Such tripping may not be considered in LNCC category.
CKT	132kv SEWA2(NHPC)-HIRANAGAR(JKPDD)-2	OSFD	28-06-2023	19:07:00	28-06-2023	20:29:00	0.06	0.00	0.00	0.00	1.37	97.17	* Emergency SD taken by JKTCL for isolator alignment rectification. Complete SD of 132kV S/Y at Hiranagar. NR 2306-5400
CKT	132kv SEWA2(NHPC)-HIRANAGAR(JKPDD)-2	OSFT	01-06-2023	00:00:01	01-06-2023	20:25:00	0.85	20.42	0.00	0.00	0.00	97.16	* SD taken for Erection/Destringing/Stringing work of diversion of Line between tower no 47-49, due to land slide near Tower no 48 rerouting of line.
CKT	132kv SEWA2(NHPC)-KATHUA(JKPDD)	SRMU	25-06-2023	15:20:00	25-06-2023	16:16:00	0.04	0.00	0.93	0.00	0.00	100.00	* Line Auto reclosed on R-N fault from kathua and tripped from Sewa 2.FLR Sewa2: 11.37km,Ir= 3.13kA
CKT	132kv SEWA2(NHPC)-MAHANPUR(JKPDD)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kv BAIRASIUL(NHPC)-JESSORE(HPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kv BAIRASIUL(NHPC)-PONG(BMB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kv CHAMERA3(NHPC)-CHAMBA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kv CHAMERA3(NHPC)-CHAMBA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kv CHOWADHI(JKPDD)-SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-DRASS ALUSTENG CKT 1	OSFT	15-06-2023	12:00:00	15-06-2023	15:44:00	0.16	3.73	0.00	0.00	0.00	99.48	* SD taken for attending hotspot in Y Ph jumper at loc No 425 near by Drass SS. NR 2306-2969
CKT	220KV-DRASS KARGIL CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kv HAMIRPUR-HAMIRPUR(HPSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kv HAMIRPUR-HAMIRPUR(HPSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-HAMIRPUR(PG)-NEHRIAN(HP)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-HAMIRPUR(PG)-NEHRIAN(HP)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-HIRANAGAR(JKPDD)-SAMBA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV JALLANDHAR-DASUA PSTCL-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV JALLANDHAR-DASUA PSTCL-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-JALANDHAR-NEHRIAN(HPSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-JALANDHAR-NEHRIAN(HPSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kv JAMMU(JKPDD)-CHOWADHI (JKPDD)	LEFT	18-06-2023	17:20:00	18-06-2023	20:19:00	0.12	2.98	0.00	0.00	0.00	99.59	* Line tripped on persistant fault due to exceptionally adverse weather conditions and localized cyclone in the area on B-N fault .FLR Chowadi:Fl=8.09km Ib=3.1KA. NR2306-3525* 11.08.2023 11:13:43 INDIA Parvinder Kumar (60016809)* NRLDC Comments- LNCC/LMAC includes line outages due to natural calamities or breakdown caused by miscreants/ Militant activities. Such tripping may not be considered in LNCC category.

Standard of Performance data for the month of Jun-2023
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	220kV JESSORE(HPTCL)-PONG(BBMB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-KARGIL KHALSTI CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KISHANGANGA(NHPC)-DELINA(JKPDD)-1	OSFD	01-06-2023	00:00:01	30-06-2023	23:59:59	30.00	0.00	0.00	0.00	720.00	100.00	* Line remains charged from Delina but tripped from NHPC Kishanganga end only due to tripping of 220KV Bus 2 caused by failure of CT of unit 3 at NHPC Kishanganga. * Later on S/D (NRLDC code NR/2339) was taken by NHPC to attend problem in operating mechanism of CB.* Line Anti theft Charged from Delina (JKPTCL) at 13:35Hrs dtd 13.09.2023 vide code NR 2309-2218.
CKT	220kV KISHANGANGA(NHPC)-DELINA(JKPDD)-1	SBBU	09-06-2023	15:30:00	12-06-2023	11:25:00	2.83	0.00	67.92	0.00	0.00	100.00	* Line tripped from Kishanganga end only due to 220KV Bus 2 tripping on CT failure of unit 3 at NHPC Kishanganga. * 22.09.2023 21:44:02 INDIA Parvinder Kumar (60016809)* Line remains charged from Delina but tripped from NHPC Kishanganga end only due to tripping of 220KV Bus 2 caused by failure of CT of unit 3 at NHPC Kishanganga. * Later on S/D (NRLDC code NR/2339) was taken by NHPC to attend problem in operating mechanism of CB.
CKT	220kV KISHANGANGA(NHPC)-DELINA(JKPDD)-2			00:00:00		00:00:00	32.83	0.00	67.92	0.00	720.00	100.00	
CKT	220kV KISHENPUR-SARNA(PSTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KISHENPUR-SARNA(PSTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-PHYANG KHALTSE CKT 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV PANCHKULA-CHANDIGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV PANCHKULA CHANDIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SALAL(NHPC)-JAMMU(JKPDD)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-SALAL(NHPC)-JAMMU(JKPDD)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-SALAL(NHPC)-KISHENPUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SARNA(PSTCL)-DASUYA(PSTCL)-1	OSFT	03-06-2023	10:17:00	03-06-2023	12:21:00	0.09	2.07	0.00	0.00	0.00	99.71	* emergency s/d by pstcl
CKT	220kV SARNA(PSTCL)-DASUYA(PSTCL)-2	OSFT	05-06-2023	13:34:00	05-06-2023	16:56:00	0.14	3.37	0.00	0.00	0.00	99.53	* SD taken by PSTCL to attend hot spot.NR 2306-801
CKT	220kV SARNA(PSTCL)-HIRANAGAR(JKPDD)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV UDHAMPUR(JKPDD)-KISHENPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV UDHAMPUR(JKPDD)-KISHENPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV-WAGOORA-KISHENGANGA(NHPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-WAGOORA-KISHENGANGA(NHPC)-2	SBBU	09-06-2023	14:24:00	09-06-2023	19:31:00	0.21	0.00	5.12	0.00	0.00	100.00	* Line tripped from Kishanganga end only due to 220kV Bus 2 tripping on CT failure of unit 3 at NHPC Kishenganga.
CKT	220kV WAGOORA-PAMPURE(JKPDD)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV WAGOORA-PAMPURE(JKPDD)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ABDULLAPUR-BAWANA(DTL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ABDULLAPUR-DEPALPUR(HVPLN)	LVRD	01-06-2023	03:46:00	01-06-2023	19:51:00	0.67	0.00	0.00	0.00	16.08	100.00	* Line hand tripped for voltage regulation.NR 2306-23
CKT	400kV ABDULLAPUR-KURUKSHETRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ABDULLAPUR-KURUKSHETRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AMRITSAR-JALANDHAR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AMRITSAR-JALANDHAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANALA-AMRITSAR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANALA-HAMIRPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANALA-KOLDAM(NTPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NALAGARH-BANALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHIWANI(BBMB)-RAJUPURA(PSTCL)	LVRD	01-06-2023	02:04:00	02-06-2023	07:46:00	1.24	0.00	0.00	0.00	29.70	100.00	* Line hand tripped for voltage regulation.NR 2306-17
CKT	400kV CHAMBA-JALLANDHAR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHAMBA-JALLANDHAR-2	LART	14-06-2023	18:05:00	14-06-2023	18:05:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line AR optd successfully on Y-N fault. FLR Jalandhar:- 82.077km <(-&c)> 4.239 KA
CKT	400kV CHAMBA-JALLANDHAR-2	LART	06-06-2023	00:07:00	06-06-2023	00:07:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line Auto reclosed successfully on Y-N fault. FLR Jalandhar : l= FLR Chamba :141km,lv=2.33ka.
CKT	400kV CHAMERA1(NHPC)-JALLANDHAR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHAMERA1(NHPC)-JALLANDHAR-2	OSFT	17-06-2023	13:07:00	17-06-2023	16:40:00	0.15	3.55	0.00	0.00	0.00	99.51	* SD taken for fixing of Middle Phase Jumper Pilot Insulator string Bolt at loc no.91. NR2306-3343
CKT	400kV CHAMERA2(NHPC)-CHAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHAMERA1(NHPC)-CHAMERA2(NHPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jun-2023
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD. NORTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifiyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-2 AT PANCHKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PANCHKULA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT SAMBA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT WAGOORA	OSPT	13-06-2023	09:30:00	13-06-2023	21:34:00	0.50	12.07	0.00	0.00	0.00	0.00	* SD taken for AMP_NR-2520
XMER	315MVA,400/220kV ICT-1 AT WAGOORA	SICT	19-06-2023	11:38:00	19-06-2023	16:41:00	0.21	5.05	0.00	0.00	0.00	0.00	* Tripped on differential protection due to PT failure
XMER	315MVA,400/220kV ICT-2 AT WAGOORA	OSPT	19-06-2023	10:33:00	19-06-2023	15:35:00	0.21	17.12	0.00	0.00	0.00	97.62	* S/d taken for AMP works
XMER	315MVA,400/220kV ICT-3 AT WAGOORA			00:00:00		00:00:00	0.21	5.03	0.00	0.00	0.00	99.30	
XMER	315MVA,400/220kV ICT-4 AT WAGOORA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT NEW WANPOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT NEW WANPOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	