

Sr.No.	Unique ID of Transmission Element	ELEMENT NAME	OUTAGE		DURATION OF OUTAGE ATTRIBUTABLE TO				Classification/ Category Code	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	Total Duration Available for Consideration	SIL	Clt. Kms.	Weightage Factor	H-(G*(Z@))/Z	% Availability as certified by certifying agency	
			DATE TIME	DATE TIME	POWER	GRID	OTHERS	System constraints Natural calamity & I C										Deemed Available
					#(T)	#(U)	#(V)	#(W)										#(X)
					Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min										Hrs:Min
#REF!	#REF!	#REF!	#REF!	#REF!														
Z	(E)	(F)	G-E x F	H														
Hrs	E	F	G	H														
11	NR140104	400KV ALLD-FATEHPUR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV ALLD-FATEHPUR-II Total			00:00	00:00	00:00	00:00	36:08		NRPC	744.00	139.730	103959.12	14526207.84	14526207.84	100.00	
		400KV ALLD-FATEHPUR-III			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	155.932	116013.41				
		400KV ALLD-FATEHPUR-III			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV ALLD-FATEHPUR-III			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV ALLD-FATEHPUR-III			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV ALLD-FATEHPUR-III			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV ALLD-FATEHPUR-III Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	155.932	116013.41				
		400KV ALLD-FATEHPUR-III Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	155.932	116013.41	18090202.74	18090202.74	100.00	
		400KV ALLD-KNP-II			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	224.000	166656.00				
12	NR140012	400KV ALLD-KNP-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV ALLD-KNP-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV ALLD-KNP-II Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	224.000	166656.00	37330944	37330944.00	100.00	
		400KV BALLA-MALI			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	13.000	9672.00				
		400KV BALLA-MALI			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BALLA-MALI			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BALLA-MALI Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	13.000	9672.00	125736	125736.00	100.00	
		400KV BALLA-MALI			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BALLA-MALI-II Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	13.000	9672.00	125736	125736.00	100.00	
		400KV BALLA-SOHAWAL-I			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	229.163	170497.27				
13	NR140019	400KV BALLA-SOHAWAL-I			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BALLA-SOHAWAL-I			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BALLA-SOHAWAL-I Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	229.163	170497.27	39071666.34	39071666.34	100.00	
		400KV BALLA-SOHAWAL-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BALLA-SOHAWAL-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BALLA-SOHAWAL-II Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	229.163	170497.27	39071666.34	39071666.34	100.00	
		400KV BALLA-SOHAWAL-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BALLA-SOHAWAL-II Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	229.163	170497.27	39071666.34	39071666.34	100.00	
		400KV BAREILLY-BRILY(UP)-I			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	9.200	6844.80				
		14	NR140140	400KV BAREILLY-BRILY(UP)-I			00:00	00:00	00:00	00:00	00:00		NRPC					
400KV BAREILLY-BRILY(UP)-I					00:00	00:00	00:00	00:00	00:00		NRPC							
400KV BAREILLY-BRILY(UP)-I Total					00:00	00:00	00:00	00:00	00:00		NRPC	744.00	9.200	6844.80	62972.16	62972.16	100.00	
400KV BAREILLY-BRILY(UP)-II					00:00	00:00	00:00	00:00	00:00		NRPC							
400KV BAREILLY-BRILY(UP)-II					00:00	00:00	00:00	00:00	00:00		NRPC							
400KV BAREILLY-BRILY(UP)-II Total					00:00	00:00	00:00	00:00	00:00		NRPC	744.00	9.200	6844.80	62972.16	62972.16	100.00	
400KV BAREILLY-BRILY(UP)-II					00:00	00:00	00:00	00:00	00:00		NRPC							
400KV BAREILLY-BRILY(UP)-II Total					00:00	00:00	00:00	00:00	00:00		NRPC	744.00	9.200	6844.80	62972.16	62972.16	100.00	
400KV BAREILLY-LK(UP)					00:00	00:00	00:00	00:00	00:00		NRPC							
15	NR140023			400KV BAREILLY-LK(UP)			00:00	00:00	00:00	00:00	00:00		NRPC					
		400KV BAREILLY-LK(UP)			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BAREILLY-LK(UP) Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	278.760	207397.44	57814110.37	57814110.37	100.00	
		400KV BAREILLY-SHAHHNPR-I			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	116.920	86988.48				
		400KV BAREILLY-SHAHHNPR-I			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BAREILLY-SHAHHNPR-I Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	116.920	86988.48	10170693.08	10170693.08	100.00	
		400KV BAREILLY-SHAHHNPR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BAREILLY-SHAHHNPR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BAREILLY-SHAHHNPR-II Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	116.920	86988.48	10170693.08	10170693.08	100.00	
		16	NR140152	400KV BAREILLY-SHAHHNPR-II			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	101.841	75769.70		
400KV BAREILLY-SHAHHNPR-II Total					00:00	00:00	00:00	00:00	00:00		NRPC	744.00	101.841	75769.70	7716462.425	761588.25	98.90	
400KV BARLY(765)-KASHIPUR-I	14-03-21 13:15			14-03-21 21:26	08:11	00:00	00:00	00:00	00:00	LHWT	Line tripped on R-N Fault. Bareilly end details FD -102 Km(100% of line length). FC- 5.59 K.A. R-Phase conductor, ammer, snashed at Kahapur (PTCL) Sub-station.	NRPC						
400KV BARLY(765)-KASHIPUR-I					00:00	00:00	00:00	00:00	00:00		NRPC							
400KV BARLY(765)-KASHIPUR-I					00:00	00:00	00:00	00:00	00:00		NRPC							
400KV BARLY(765)-KASHIPUR-I					00:00	00:00	00:00	00:00	00:00		NRPC							
400KV BARLY(765)-KASHIPUR-I Total					08:11	00:00	00:00	00:00	00:00		NRPC	744.00	101.841	75769.70	7716462.425	761588.25	98.90	
400KV BARLY(765)-KASHIPUR-II					00:00	00:00	00:00	00:00	00:00		NRPC							
400KV BARLY(765)-KASHIPUR-II					00:00	00:00	00:00	00:00	00:00		NRPC							
400KV BARLY(765)-KASHIPUR-II Total					00:00	00:00	00:00	00:00	00:00		NRPC	744.00	101.841	75769.70	7716462.425	761588.25	98.90	
17	NR140150	400KV BARLY(765)-KASHIPUR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BARLY(765)-KASHIPUR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BARLY(765)-KASHIPUR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BARLY(765)-KASHIPUR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BARLY(765)-KASHIPUR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BARLY(765)-KASHIPUR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BARLY(765)-KASHIPUR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BARLY(765)-KASHIPUR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BARLY(765)-KASHIPUR-II			00:00	00:00	00:00	00:00	00:00		NRPC							
		400KV BARLY(765)-KASHIPUR-II Total			00:00	00:00	00:00	00:00	00:00		NRPC	744.00	101.841	75769.70	7716462.425	761588.25	98.90	
18	NR140037	400KV BLBGRH-MANPUR-I	02-03-21 04:18	02-03-21 08:31	00:00	00:00	00:00	04:13	LVRD	Hand tripped on Voltage regulation as per NRDC instruction. Maunpur-418KV	NRPC	744.00	235.952	175548.29	41420969.65	41345810.63	99.82	
		400KV BLBGRH-MANPUR-I	09-03-21 21:24	11-03-21 09:29	00:00	00:00	00:00	36:05	LVRD	Hand tripped on Voltage regulation as per NRDC instruction. Maunpur-418KV	NRPC							
		400KV BLBGRH-MANPUR-I	13-03-21 22:27	14-03-21 09:11	00:00	00:00	00:00	10:44	LVRD	Hand tripped on Voltage regulation as per NRDC instruction. Maunpur-408KV	NRPC							
		400KV BLBGRH-MANPUR-I	14-03-21 22:19	15-03-21 07:56	00:00	00:00	00:00	09:37	LVRD	Hand tripped on Voltage regulation as per NRDC instruction. Maunpur-408 KV	NRPC							
		400KV BLBGRH-MANPUR-I	18-03-21 21:27	19-03-21 09:06	00:00	00:00	00:00	11:39	LVRD	Hand tripped on Voltage regulation as per NRDC instruction. Maunpur-418KV	NRPC							
		400KV BLBGRH-MANPUR-I	24-03-21 01:17	24-03-21 02:38	01:21	00:00	00:00	00:00	00:00	OSFT	Emergency hand tripped due to heavy sparking observed in line side isolator (411898) of tie bay at Maunpur end.	NRPC						
		400KV BLBGRH-MANPUR-I	24-03-21 02:38	24-03-21 09:18	00:00	00:00	00:00	06:40	LVRD	Hand tripped on Voltage regulation as per NRDC instruction. Maunpur-420 KV	NRPC							
		400KV BLBGRH-MANPUR-I			00													

Sr.No.	Unique ID of transmission Element	ELEMENT NAME	OUTAGE		DURATION OF OUTAGE ATTRIBUTABLE TO					Classification/ Category Code	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	Total Duration Available for Consideration	SIL	Clt. Kms.	Weightage Factor	H-(G*(Z-@))/Z	% Availability as certified by certifying agency	
			DATE TIME	DATE TIME	POWER GRID		System constraints Natural calamity & I C	Deemed Available											
					# (T)	# (U)													
					Hrs:Min	Hrs:Min													
#REF1	#REF1	#REF1	#REF1	#REF1	#REF1														
58	NR140071	400KV LUCKNOW-GORAKH-IV	20-03-21 13:16	26-03-21 20:52	00:00	00:00	00:00	00:00	151:36	OSPD	S/D taken by UPPTCL for LLO work of 400 KV Gorakhpur-Lucknow Ckt-IV at 400KV Bus(UPTCL) S.S newly commissioned.	NRPC	744.00	263.933	196366.15				
		SUB TOTAL			00:00	00:00	00:00	00:00	151:36			NRPC	744.00	263.933	196366.15	51827507.6	51827507.60	100.00	
59	NR140112	400KV LUCKNOW-LKO(765)-I			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	2.860	2127.84	6085.6224	6085.62	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	2.860	2127.84	6085.6224	6085.62	100.00	
60	NR140113	400KV LUCKNOW-LKO(765)-II			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	2.860	2127.84	6085.6224	6085.62	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	2.860	2127.84	6085.6224	6085.62	100.00	
61	NR140072	400KV LUCKNOW-LKO(LP)	10-03-21 17:04	10-03-21 21:43	00:00	00:00	00:00	00:00	04:39	OSFD	Emergency S/D taken by UPPTCL to attend hot spot on Y Ph Bus-2 isolator at their Lucknow (LP) end.	NRPC	744.00	41.743	31056.79				
		SUB TOTAL			00:00	00:00	00:00	00:00	04:39			NRPC	744.00	41.743	31056.79				
62	NR140074	400KV LUCKNOW-LKO(LP)	30-03-21 13:24	30-03-21 15:49	00:00	02:25	00:00	00:00	04:39	OMSU	Tripped due to B-N Fault, Lucknow end details- FD- 54.86 Kms, FC-5.45 KA, Lucknow(Sarjintnagar -LP) end details- FD- 7.49 Kms, FC-1.116 KA. Fault is in UPCL Jurisdiction. (Total line length-85.27 KM. Powerco. jurisdiction from Lucknow- 41.84 KM)	NRPC	741.58	41.743	30955.91	1292192.68	1292192.68	100.00	
		SUB TOTAL			00:00	02:25	00:00	00:00	04:39			NRPC	744.00	73.826	54926.54	4055007.04	4055007.04	100.00	
63	NR140075	400KV LUCKNOW-LKO(LP)			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	73.826	54926.54	4055007.037	4055007.04	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	73.826	54926.54	4055007.037	4055007.04	100.00	
64	NR140084	400KV RBHAND-ALLD-I	02-03-21 11:51	02-03-21 20:39	00:00	00:00	00:00	00:00	08:48	LCSD	S/D taken for removing Aviation Globe from earth wire in river crossing spans of 400 KV Rhand-Alhabad-1 to facilitate OPGW straining Work	NRPC	744.00	279.245	207758.28	58015460.9	58015460.90	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	08:48			NRPC	744.00	279.245	207758.28	58015460.9	58015460.90	100.00	
65	NR140085	400KV RBHAND-ALLD-II	03-03-21 08:32	04-03-21 09:38	00:00	00:00	00:00	00:00	25:06	LCSD	S/D taken for removing Aviation Globe from earth wire in river crossing spans of 400 KV Rhand-Alhabad-1 to facilitate OPGW straining Work	NRPC	744.00	279.245	207758.28	58015460.9	58015460.90	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	25:06			NRPC	744.00	279.245	207758.28	58015460.9	58015460.90	100.00	
66	NR140091	400KV RBHAND-ALLD-I	02-03-21 11:49	02-03-21 20:41	00:00	00:00	00:00	00:00	08:52	LCSD	S/D taken for removing Aviation Globe from earth wire in river crossing spans of 400 KV Rhand-Alhabad-2 to facilitate OPGW straining Work	NRPC	744.00	279.245	207758.28	58015460.9	58015460.90	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	08:52			NRPC	744.00	279.245	207758.28	58015460.9	58015460.90	100.00	
66	NR140091	400KV RBHAND-ALLD-II	03-03-21 08:30	03-03-21 22:55	00:00	00:00	00:00	00:00	14:25	LCSD	S/D taken for removing Aviation Globe from earth wire in river crossing spans of 400 KV Rhand-Alhabad-2 to facilitate OPGW straining Work	NRPC	744.00	279.245	207758.28	58015460.9	58015460.90	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	23:17			NRPC	744.00	279.245	207758.28	58015460.9	58015460.90	100.00	
66	NR140091	400KV SING-ALLD-I	01-03-21 14:08	01-03-21 16:02	00:00	01:54	00:00	00:00	00:00	OMSU	Tripped due to burning of agriculture residue / jungle bush fire created at Loc no 42G by unknown local villagers below line conductor. Fault details- B-N fault, Allahabad end details- M1- FD-22km, FC-1.806KA, M2- FD-221.08km, FC-1.697KA, Singrauli end details- FD-14.39km, FC-12.9KA.	NRPC	742.10	224.000	166230.40	37235609.6	37235609.60	100.00	
		SUB TOTAL			00:00	01:54	00:00	00:00	00:00			NRPC	742.10	224.000	166230.40	37235609.6	37235609.60	100.00	
67	NR140092	400KV SING-ALLD-II	27-03-21 08:25	27-03-21 21:46	00:00	00:00	00:00	00:00	13:21	LCSD	S/D taken by powergral WR#2 for Powerline crossing of under construction 765 kV DC Vaidhyschil (Pooing Station) -Varanasi GS S/S Transmission Line constructed by by powergral TB/B comman (STS).	NRPC	744.00	202.000	150288.00	30358176	30358176.00	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	13:21			NRPC	744.00	202.000	150288.00	30358176	30358176.00	100.00	
68	NR340018	400KV SINGRALLI-ALLAHABAD-III	27-03-21 08:28	27-03-21 21:13	00:00	00:00	00:00	00:00	12:45	LCSD	S/D taken by Powergral, WR#2 for Powerline crossing of under construction 765 kV DC Vaidhyschil(Pooing Station) -Varanasi GS S/S Transmission Line constructed by Powergral TB/B comman (STS).	NRPC	744.00	214.850	159848.40	34245722.3	34245722.30	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	12:45			NRPC	744.00	214.850	159848.40	34245722.3	34245722.30	100.00	
69	NR140093	400KV SINGRALLI-ALLAHABAD-III	30-03-21 12:56	30-03-21 15:03	00:00	02:07	00:00	00:00	00:00	OMSU	Tripped on R-N fault due to Jungle bush / Agriculture residue fire created by unknown local villagers between Tower No- 124 and 125 below line conductor, Allahabad end details- M-1- FD-207 kms, FC-1.69 KA, M-2- FD-202.7 Kms, FC-1.67 KA.	NRPC	741.88	214.850	159393.63	465720.6117	465720.61	100.00	
		SUB TOTAL			00:00	02:07	00:00	00:00	00:00			NRPC	741.88	214.850	159393.63	465720.6117	465720.61	100.00	
70	NR140096	400KV SING-ANPARA	01-03-21 14:06	01-03-21 16:20	00:00	02:14	00:00	00:00	00:00	OMSU	Tripped due to burning of Agriculture residue / Jungle bush fire created at Loc no 42G by unknown local villagers below the line conductor. Fault details- B-N fault, Singrauli end details- FD-14.7km, FC-4.81KA, Amara end details- FD-12km, FC-6.31KA.	NRPC	741.77	25.057	18586.45	465720.6117	465720.61	100.00	
		SUB TOTAL			00:00	02:14	00:00	00:00	00:00			NRPC	741.77	25.057	18586.45	465720.6117	465720.61	100.00	
71	N-W40001	400KV SING-RHAND-I			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	42.026	31267.34	1314041.399	1314041.40	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	42.026	31267.34	1314041.399	1314041.40	100.00	
71	N-W40002	400KV SING-VNDH-I			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	3.341	2485.70	8304.737064	8304.74	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	3.341	2485.70	8304.737064	8304.74	100.00	
72	N-W40002	400KV SING-VNDH-II			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	3.317	2467.85	8304.737064	8304.74	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	3.317	2467.85	8304.737064	8304.74	100.00	
73	NR340008	400KV ALLAHABAD-MEJA(NTPC)-I			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	3.317	2467.85	8185.851816	8185.85	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	3.317	2467.85	8185.851816	8185.85	100.00	
74	NR340009	400KV ALLAHABAD-MEJA(NTPC)-II	04-03-21 11:31	04-03-21 18:05	00:00	00:00	00:00	00:00	06:34	OSFD	Emergency S/D taken by NTPC Meza thermal Station to attend hot spot in 418.89L R-phase isolator at Meza(NTPC) end	NRPC	744.00	28.190	20973.36	591239.0184	591239.02	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	06:34			NRPC	744.00	28.190	20973.36	591239.0184	591239.02	100.00	
75	NR340012	400KV KANPUR(GS)- ALLAHABAD -I			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	240.390	178850.16	42993789.96	42993789.96	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	240.390	178850.16	42993789.96	42993789.96	100.00	
76	NR340013	400KV KANPUR(GS)- ALLAHABAD -II			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	240.390	178850.16	42993789.96	42993789.96	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	240.390	178850.16	42993789.96	42993789.96	100.00	
77	NR340001	400KV KANPUR(KANPUR)(GS)-I	16-03-21 09:53	16-03-21 18:35	08:42	00:00	00:00	00:00	00:00	OSPT	S/D taken for AMP Work	NRPC	744.00	21.233	15797.35	335425.175	331502.86	98.83	
		SUB TOTAL			08:42	00:00	00:00	00:00	00:00			NRPC	744.00	21.233	15797.35	335425.175	331502.86	98.83	
78	NR340002	400KV KANPUR(KANPUR)(GS)-II	17-03-21 09:56	17-03-21 18:25	08:29	00:00	00:00	00:00	00:00	OSPT	S/D taken for AMP Work	NRPC	744.00	21.233	15797.35	335425.175	331600.55	98.86	
		SUB TOTAL			08:29	00:00	00:00	00:00	00:00			NRPC	744.00	21.233	15797.35	335425.175	331600.55	98.86	
79	NR340010	400KV LUCKNOW(765)-KANPUR(GS)-I			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	159.700	118816.80	18975042.96	18975042.96	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	159.700	118816.80	18975042.96	18975042.96	100.00	
79	NR340010	400KV LUCKNOW(765)-KANPUR(GS)-II			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	159.700	118816.80	18975042.96	18975042.96	100.00	
		SUB TOTAL			00:00	00:00	00:00	00:00	00:00			NRPC	744.00	159.700	118816.80	18975042.96	18975042.96	100.00	

Sr.No.	Unique ID of transmission Element	ELEMENT NAME	OUTAGE DATE TIME	RESTORATION DATE TIME	DURATION OF OUTAGE ATTRIBUTABLE TO				Classification/ Category Code	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	Total Duration Available for Consideration	SIL	Clt. Kms.	Weightage Factor	H-(G*(Z-@))/Z	% Availability as certified by certifying agency	
					POWER GRID		System constraints											Deemed Available
					#(T)	#(U)	Natural calamity	#(C)										
					Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min										
					#REF!	#REF!	#REF!	#REF!										
80	NR340011	400KV LUCKNOW(765)-KANPUR(GS)-II 400KV LUCKNOW(765)-KANPUR(GS)-II 400KV LUCKNOW(765)-KANPUR(GS)-II 400KV LUCKNOW(765)-KANPUR(GS)-II SUB TOTAL			00:00 00:00 00:00 00:00 00:00	00:00 00:00 00:00 00:00 00:00	00:00 00:00 00:00 00:00 00:00	00:00 00:00 00:00 00:00 00:00										
81	NR340016	400KV ORAI-ORAI(UP)-I SUB TOTAL			00:00 00:00	00:00 00:00	00:00 00:00	00:00 00:00			744.00	159.700	118816.80	18975042.96	18975042.96	100.00		
82	NR340017	400KV ORAI-ORAI(UP)-II SUB TOTAL			00:00 00:00	00:00 00:00	00:00 00:00	00:00 00:00			744.00	41.832	31123.01	1301937.671	1301937.671	100.00		
84	NR340004	400KV VARANASI-SARNATH-I SUB TOTAL			00:00 00:00	00:00 00:00	00:00 00:00	00:00 00:00			744.00	69.677	51839.69	1301937.671	1301937.671	100.00		
		400KV Lines			39:11	25:28	12:34	1155:41										
1	NR322002	220 KV RANJAY (UP) - PANKI (UP) 220 KV RANJAY (UP) - PANKI (UP) Total			00:00 00:00	00:00 00:00	00:00 00:00	00:00 00:00			744.00	13.701	10193.54	139661.7463	139661.75	100.00		
2	NR320004	220kv AgrajPG-Bharatpur(Raj.) 220kv AgrajPG-Bharatpur(Raj.) 220kv AgrajPG-Bharatpur(Raj.) Total	18-03-21 10:07 28-03-21 22:11	18-03-21 13:03 28-03-21 23:18	00:00 00:00 00:00	00:00 01:07 00:00	00:00 00:00 02:56	00:00 00:00 02:56	OSPD OSMU	S/D taken by Bharatpur(RVNL) for maintenance work at their Bharatpur S/S end Tripped only from Bharatpur (RVNL) end due to DC fail at their end. Line was remain charged from Aara end.	744.00 744.00 744.00	55.858 55.858 55.858	41558.35 41558.35 41558.35					
3	NR320003	220kv AgrajPG-Sikandra(UP) 220kv AgrajPG-Sikandra(UP) 220kv AgrajPG-Sikandra(UP) Total	20-03-21 11:13	20-03-21 18:46	00:00 00:00 00:00	00:00 01:07 00:00	00:00 00:00 07:13	00:00 00:00 07:13	OSPD	S/D taken by UPPTCL for line maintenance work.	742.88 744.00	55.858 55.858	41495.98 41558.35	2317882.296	2317882.30	100.00		
4	NR122006	220KV AUR-SIKANDARA-I 220KV AUR-SIKANDARA-I 220KV AUR-SIKANDARA-I Total			00:00 00:00 00:00	00:00 00:00 00:00	00:00 00:00 00:00	00:00 00:00 00:00			744.00 744.00	55.858 182.176	41558.35 135538.94	2321366.428	2321366.43	100.00		
5	NR122007	220KV AUR-SIKANDARA-II 220KV AUR-SIKANDARA-II 220KV AUR-SIKANDARA-II Total	12-03-21 10:30 13-03-21 05:52	12-03-21 19:48 13-03-21 07:22	00:00 00:00 00:00	00:00 01:30 00:00	00:00 00:00 09:18	00:00 00:00 09:18	LCSO	S/D taken for Retrofitment of Transfer bus isolator at Sikandra(UP) end under CERC Add. Cap. Scheme. Vids. CERC order no. Dtd. Tripped on B-N fault caused by flying conducting foreign material infringing electrical field of conductor. Sikandra (UP) end details: F.D.=30.30KM, F.C.=2.12KA, Amsya end details: F.C.=1.7KA	744.00 744.00	55.858 182.176	41558.35 135538.94	24691942.66	24691942.66	100.00		
6	NR122013	220KV DGANGA-PITHORAGRHI 220KV DGANGA-PITHORAGRHI 220KV DGANGA-PITHORAGRHI Total	07-03-21 03:55 17-03-21 11:14	07-03-21 06:47 17-03-21 14:37	00:00 00:00 00:00	00:00 01:30 00:00	00:00 00:00 17:02	00:00 00:00 17:02	OSMU OSPD	Line tripped only from Dhauligaon NHP end due to some problem at their end and Circuit Breaker was remain in closed position at Pihorath end. Line opened from NHP Dhauligaon end only for mock exercise of switching operation as per NPLDC instruction.	742.50 741.13	182.176 59.010	135265.68 43734.28	24642160.52	24642160.52	100.00		
7	NR122040	220KV FATEHPUR-KNP SOUTH 220KV FATEHPUR-KNP SOUTH 220KV FATEHPUR-KNP SOUTH Total	31-03-21 14:19	31-03-21 17:20	00:00 00:00 00:00	00:00 02:52 00:00	03:01 03:01 03:23	00:00 03:23 00:00	GOVC	Line tripped on over voltage protection operated at Dhauligaon NHP end and DT received at Pihorath/Dhauligaon end. Voltage= 241 KV	744.00 744.00	59.010 6.170	43556.26 4590.48	2570255.168	2570255.17	100.00		
8	NR122041	220KV FATEHPUR-NALBASTA 220KV FATEHPUR-NALBASTA 220KV FATEHPUR-NALBASTA Total	03-03-21 07:30 09-03-21 11:08	03-03-21 10:05 09-03-21 19:19	00:00 00:00 00:00	02:35 00:00 00:00	00:00 00:00 08:11	00:00 00:00 08:11	OSMU OSPD	Tripped only from Nambastar(UP) end on B-N fault. Fatehpur end details: MI-F.D.-5.5KM, Ib-12.70KA, Fault is under UPCL Jurisdiction. (Total line length:76 km; Powergrid Jurisdiction from Fatehpur- 2.2 km). S/D taken by UPPTCL for routine testing/maintenance work at their Nambastar(UP) end	741.42 744.00	6.170 10.400	4574.54 7337.60	28224.91694	28224.92	100.00		
9	NR122016	220KV KNP-MAINPURI 220KV KNP-MAINPURI 220KV KNP-MAINPURI Total			00:00 00:00 00:00	00:00 00:00 00:00	00:00 00:00 00:00	00:00 00:00 00:00			744.00 744.00	10.400 14.860	7337.60 11055.84	80471.04	80471.04	100.00		
10	NR122017	220KV KNP-NALBASTA 220KV KNP-NALBASTA 220KV KNP-NALBASTA Total			00:00 00:00 00:00	00:00 00:00 00:00	00:00 00:00 00:00	00:00 00:00 00:00			744.00 744.00	14.860 11055.84	164289.7824	164289.78	100.00			
11	NR122019	220KV KNP-PANKI-II 220KV KNP-PANKI-II 220KV KNP-PANKI-II 220KV KNP-PANKI-II Total	19-03-21 12:15	19-03-21 18:30	00:00 00:00 00:00 00:00	00:00 00:00 00:00 00:00	06:15 00:00 00:00 06:15	06:15 00:00 00:00 06:15	OSPD	S/D taken by UPPTCL for jumper tightening and conductor repair work at their panki thermal Station S/V end.	744.00 744.00	14.860 14.860	11055.84 11055.84	164289.7824	164289.78	100.00		
12	NR122020	220KV KNP-LNCHR-I 220KV KNP-LNCHR-I 220KV KNP-LNCHR-II 220KV KNP-LNCHR-II Total			00:00 00:00 00:00 00:00	00:00 00:00 00:00 00:00	00:00 00:00 00:00 00:00	00:00 00:00 00:00 00:00			744.00 744.00	14.860 143.553	11055.84 106803.43	164289.7824	164289.78	100.00		
13	NR122022	220KV KNP-LNCHR-III 220KV KNP-LNCHR-III 220KV KNP-LNCHR-III Total	12-03-21 12:18 12-03-21 17:07	12-03-21 17:07 13-03-21 01:41	00:00 00:00 00:00	04:49 08:34 04:49	00:00 00:00 00:00	00:00 00:00 00:00	OSMU OSFD	Tripped only from Uchahar NTPC end due to some protection protection problem at their end. S/D taken to attend V-phase snapped jumper at Lec No -400A.	744.00 739.18	143.553 144.630	106803.43 106908.09	15331953.07	15331953.07	100.00		
14	NR122024	220KV PITHORAGRHI-BRILLY(UP) 220KV PITHORAGRHI-BRILLY(UP) Total	07-03-21 03:55	07-03-21 05:56	00:00 00:00	02:01 02:01	00:00 00:00	00:00 00:00	OSMU	Line tripped only from BRILLY(UPPTCL) end due to some protection problem at UPPTCL end and CB was remain in closed position at Pihorath end.	741.98 741.98	177.880 177.880	131984.00 131984.00	15282920.27	15282920.27	98.94		
15	NR320004	220KV RABRILY-BACHHIRAWAN(UP) 220KV RABRILY-BACHHIRAWAN(UP) Total	12-03-21 17:19 28-03-21 11:36	12-03-21 19:50 28-03-21 16:18	00:00 00:00	00:00 00:00	00:00 00:00	02:31 04:42	OSFD OSFD	E/S/D taken by UPPTCL for attending hot spot on R-phase A bus isolator clamp at Bachhrawan(UPPTCL) end. E/S/D enabled by UPPTCL to attend hot spot in B-phase LSI at their Bachhrawan (UPPTCL) end	744.00	1.190	885.36					
16	NR122032	220KV SITARGANJ-BILY(UP) 220KV SITARGANJ-BILY(UP) Total			00:00 00:00	00:00 00:00	00:00 00:00	00:00 00:00			744.00 744.00	1.190 105.720	885.36 78655.68	1053.5784	1053.58	100.00		
17	NR122033	220KV TNKPR-BILY(UP) 220KV TNKPR-BILY(UP) 220KV TNKPR-BILY(UP) Total	08-03-21 11:59 15-03-21 10:14	08-03-21 13:40 15-03-21 12:43	00:00 00:00	01:41 02:29	00:00 00:00	00:00 00:00	OSMU	Tripped due to R-Y ph fault caused by flying kite thread intermingled with conductor, Bareilly(UP) end details: F.D.=20.31km, I.F.C.=1.09KA, Icc=2.28KA	742.32	106.000	78685.57	8315478.49	8315478.49	100.00		
		220KV TNKPR-BILY(UP)	24-03-21 14:24	24-03-21 19:21	00:00	00:00	00:00	04:57	OSFD	Line tripped only from Tanakpur NHP end and remain charged from CB Ganj (UPPTCL) end due to some protection problem at Tanakpur NHP end.								
		220KV TNKPR-BILY(UP)	31-03-21 14:01	31-03-21 18:40	00:00	00:00	04:39	04:57	GOVC	E/S/D taken by UPPTCL to attend hot spot in R-ph line isolator drooper jumper clamp at Bareilly(UP) end.								
		220KV TNKPR-BILY(UP) Total			00:00	04:10	04:39	04:57			735.18	106.000	77929.43	8260519.933	8260519.93	100.00		

Sr.No.	Unique ID of transmission Element	ELEMENT NAME	OUTAGE DATE TIME	RESTORATION DATE TIME	DURATION OF OUTAGE ATTRIBUTABLE TO				Classification/ Category Code	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	Total Duration Available for Consideration	SIL	Ckt. Kms.	Weightage Factor	H*(G*(Z@)/Z)	% Availability as certified by certifying agency						
					POWER @ (T)	GRID # (U)	OTHERS # (V)	System constraints Natural calamity & I C # (W)										Deemed Available * (D) Hrs:Min	Z	(E)	(F)	G-E x F	H
					#REF!	#REF!	#REF!	#REF!										#REF!	Hrs	E	F	G	H
3	NR1CT60	315MVA ICT-I SOHAWAL Total 315MVA ICT-II SOHAWAL			00:00 00:00	00:00 00:00	00:00 00:00	00:00 00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
4	NR3CT01	315MVA ICT-I SOHAWAL Total 315MVA ICT-2 AGRA			00:00 00:00	00:00 00:00	00:00 00:00	00:00 00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
5	NR1CT14	315MVA ICT-2 AGRA Total 315MVA ICT-I GORAKHPUR			00:00 00:00	00:00 00:00	00:00 00:00	00:00 00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
6	NR1CT15	315MVA ICT-I GORAKHPUR Total 315MVA ICT-II GORAKHPUR			00:00 00:00	00:00 00:00	00:00 00:00	00:00 00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
7	NR1CT27	315MVA ICT-II MAINPURI Total 315MVA ICT-I ALLAHABAD			00:00 00:00	00:00 00:00	00:00 00:00	00:00 00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
8	NR1CT01	315MVA ICT-II ALLAHABAD SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
9	NR1CT02	315MVA ICT-II ALLAHABAD SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
10	NR1CT67	315MVA ICT-III ALLAHABAD SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
11	NR1CT48	315MVA ICT-I FATEHPUR SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
12	NR1CT49	315MVA ICT-II FATEHPUR SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
13	NR1CT19	315MVA ICT-I KANPUR SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
14	NR1CT20	315MVA ICT-II KANPUR SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
15	NR1CT23	500 MVA ICT-I LUCKNOW SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	500.0000		500.0000	500.00	100.00							
16	NR1CT53	500MVA ICT-II LUCKNOW SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	500.0000		500.0000	500.00	100.00							
17	NR1CT26	315MVA ICT-I MAINPURI SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	315.0000		315.0000	315.00	100.00							
18	NR3CT02	500MVA ICT-III MAINPURI SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	500.0000		500.0000	500.00	100.00							
19	NR1CT65	500MVA ICT-I SHAHDHNPUR SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	500.0000		500.0000	500.00	100.00							
20	NR1CT66	500MVA ICT-II SHAHDHNPUR SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	500.0000		500.0000	500.00	100.00							
21	NR3CT07	315MVA ICT-III GORAKHPUR SUB TOTAL	20-03-21 08:39	20-03-21 23:46	15:07	00:00	00:00	00:00	OSFT	Emergency S/D taken to attend hot spot in 20789C isolator & B Ph of 207 CT at Gorkhpur	NRPC	744.00	315.0000		315.0000	315.00							
220/132 KV ICT'S																							
1	NR3CT04	200MVA ICT-II RAIBAREILLY Total			00:00	00:00	00:00	00:00		NRPC	744.00	200.0000		200.0000	200.00	100.00							
2	NR1CT39	200MVA ICT-III RAIBAREILLY Total			00:00	00:00	00:00	00:00		NRPC	744.00	100.0000		100.0000	100.00	100.00							
3	NR1CT43	220/132KV ICT-I PITHORAGRH SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	100.0000		100.0000	100.00	100.00							
4	NR1CT44	220/132KV ICT-II PITHORAGRH SUB TOTAL	17-03-21 05:00	17-03-21 14:32	09:32	00:00	00:00	00:00	OSFT	Emergency Hand tripped due to sudden observation of N2 (Nitrogen Gas) leakage in ICT-II at Pithoragarh.	NRPC	744.00	100.0000		100.0000	100.00							
5	NR1CT47	100 MVA ICT-I RAIBAREILLY SUB TOTAL	30-03-21 12:01	30-03-21 14:25	02:24	00:00	00:00	00:00	OSFT	E/S/D taken for replacement of Butterfly valve due to Oil leakage in ICT-II at Pithoragarh.	NRPC	744.00	100.0000		100.0000	98.40							
6	NR1CT40	100 MVA ICT-I RAIBAREILLY SUB TOTAL			00:00	00:00	00:00	00:00	GGDC	Hand tripped to facilitate charging of Dead Sitaganj due to tripping of radially cooected line 230kV Sitaganj- Ch GuntU.Pline.	NRPC	744.00	100.0000		100.0000	100.00							
7	NR1CT41	100 MVA ICT-I RAIBAREILLY SUB TOTAL			00:00	00:00	00:00	00:00	GGDC	Hand tripped to facilitate charging of Dead Sitaganj due to tripping of radially cooected line 230kV Sitaganj- Ch GuntU.Pline.	NRPC	744.00	100.0000		100.0000	100.00							
8	NR3CT06	100MVA ICT III at SITARGANJ SUB TOTAL			00:00	00:00	00:00	00:00	GGDC	Hand tripped to facilitate charging of Dead Sitaganj due to tripping of radially cooected line 230kV Sitaganj- Ch GuntU.Pline.	NRPC	744.00	100.0000		100.0000	100.00							
Total of ICTs					46:41	00:00	00:00	00:00			NRPC	744.00	100.0000	100.0000	100.00	99.88							
Bus & Switch Line Reactor																							
1	NR1BRT39	125MVAR B Reactor-I GORAKHPUR			00:00	00:00	00:00	00:00		NRPC	744.00	125.0000		125.0000	125.00	100.00							
2	NR1BRT26	125MVAR B Reactor-II AGRA			00:00	00:00	00:00	00:00		NRPC	744.00	125.0000		125.0000	125.00	100.00							
3	NR1BRT36	240MVAR B Reactor-I AGRA-765			00:00	00:00	00:00	00:00		NRPC	744.00	240.0000		240.0000	240.00	100.00							
4	NR1BRT35	240MVAR B Reactor-II AGRA-765 Total			00:00	00:00	00:00	00:00		NRPC	744.00	240.0000		240.0000	240.00	100.00							
5	NR1BRT28	240MVAR B Reactor-IV LUCKNOW-765	05-03-21 09:29	05-03-21 13:49	00:00	00:00	00:00	04:20	SVRD	Hand tripped on Voltage regulation as per NLRDC instruction. Lucknow= 75kV	NRPC	744.00	240.0000		240.0000	100.00							
6	NR1BRT23	330MVAR B Reactor-III FTHPR-765			00:00	00:00	00:00	00:00		NRPC	744.00	330.0000		330.0000	330.00	100.00							

Sr.No.	Unique ID of Transmission Element	ELEMENT NAME	OUTAGE DATE TIME	RESTORATION DATE TIME	DURATION OF OUTAGE ATTRIBUTABLE TO				Classification Category Code	Detailed Reason(s) for Outage	Outage Causing Agency and Reference Document	Total Duration Available for Consideration	SIL	Clt. Kms.	Weightage Factor	H-(G*(Z@)/Z)	% Availability as certified by certifying agency						
					POWER	GRID	OTHERS	System constraints Natural calamity & I C										Deemed Available	Z	E	F	G-E x F	H
					Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min										Hrs:Min	Hrs	(E)	(F)	(G x F)	(H)
7	NR1BRT13	130MVAR B Reactor-III FTHPR-765 Total 93MVAR B Reactor VINDH ARI-1W 90MVAR B Reactor VINDH ARI-1W Total			00:00	00:00	00:00	00:00		NRPC	744.00	330.000		330.000	330.00	100.00							
8	NR1BRT25	125MVAR B Reactor-I AGRA SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
9	NR1BRT01	80MVAR B Reactor ALLAHABAD SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	80.000		80.000	80.00	100.00							
10	NR1BRT33	125MVAR B Reactor-II ALLAHABAD SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
11	NR1BRT02	80MVAR B Reactor-I BALLA SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	80.000		80.000	80.00	100.00							
12	NR1BRT17	125MVAR B Reactor-II BALLA SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
13	NR1BRT27	125MVAR B Reactor-III BALLA SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
14	NR1BRT20	125MVAR B Reactor-IV BALLA SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
15	NR1BRT32	240MVAR B Reactor-I BALLA-765 240MVAR B Reactor-I BALLA-765 SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	240.000		240.000	240.00	100.00							
16	NR1BRT22	240MVAR B Reactor-II BALLA-765 SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	240.000		240.000	240.00	100.00							
17	NR1BRT03	80MVAR B Reactor BAREILLY 80MVAR B Reactor BAREILLY 80MVAR B Reactor BAREILLY SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	80.000		80.000	80.00	100.00							
18	NR1BRT44	255MVAR B Reactor BAREILLY 255MVAR B Reactor BAREILLY SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	100.000		100.000	100.00	100.00							
19	NR1BRT50	240MVAR B Reactor-I BAREILLY-765 240MVAR B Reactor-I BAREILLY-765 240MVAR B Reactor-I BAREILLY-765 240MVAR B Reactor-I BAREILLY-766 240MVAR B Reactor-I BAREILLY-765 SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	240.000		240.000	240.00	100.00							
20	NR1BRT18	125MVAR B Reactor-I FATEHPUR SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
21	NR1BRT19	125MVAR B Reactor-II FATEHPUR SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
22	NR1BRT46	125MVAR B Reactor-II GORAKHPUR SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
23	NR1BRT10	80MVAR B Reactor LUCKNOW SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	80.000		80.000	80.00	100.00							
24	NR1BRT16	125MVAR B Reactor-II LUCKNOW SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
25	NR1BRT21	125MVAR B Reactor LUCKNOW-765 SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
26	NR1BRT38	125MVAR B Reactor-I MAINPURI SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
27	NR1BRT49	125MVAR B Reactor-I SHAHDHNPUR SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
28	NR1BRT14	93MVAR B Reactor VINDH ARE-1N SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	93.000		93.000	93.00	100.00							
29	NR1BRT42	125MVAR B Reactor-I VINDH SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
30	NR1BRT43	125MVAR B Reactor-II VINDH SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	125.000		125.000	125.00	100.00							
31	NR3BRT06	330MVAR B Reactor-I VARANASI SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	330.000		330.000	330.00	100.00							
32	NR1BRT56	330MVAR B Reactor-II VARANASI SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	330.000		330.000	330.00	100.00							
33	NR1SRT01	AGRA 50MVAR S/R BHIWADI-CKT-I SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	50.000		50.000	50.00	100.00							
34	NR1SRT20	AGRA 50MVAR S/R FATEHPUR CKT-II SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	50.000		50.000	50.00	100.00							
35	NR1SRT02	ALLIHD 50MVAR S/R MNPR CCT-I SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	50.000		50.000	50.00	100.00							
36	NR1SRT03	ALLIHD 50MVAR S/R MNPR CCT-II SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	50.000		50.000	50.00	100.00							
37	NR1SRT18	BALLA 240MVAR S/R GAYA LINE SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	240.000		240.000	240.00	100.00							
38	NR1SRT16	BALLA 240MVAR S/R LUCKNOW CKT-I SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	240.000		240.000	240.00	100.00							
39	NR1SRT04	BAREILLY 50MVAR S/R MND CKT-I SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	50.000		50.000	50.00	100.00							
40	NR1SRT05	BAREILLY 50MVAR S/R MND CKT-II SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	50.000		50.000	50.00	100.00							
41	NR1SRT17	FATEHPUR 330MVAR S/R AGRA LINE FATEHPUR 330MVAR S/R AGRA LINE SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	330.000		330.000	330.00	100.00							
42	NR1SRT07	GORAKH 50MVAR S/R LKO CKT-I SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	50.000		50.000	50.00	100.00							
43	NR1SRT08	GORAKH 50MVAR S/R LKO CKT-II SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	50.000		50.000	50.00	100.00							
44	NR1SRT11	GORAKH 63MVAR S/R LKO-III LINE SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	63.000		63.000	63.00	100.00							
45	NR1SRT12	GORAKH 63MVAR S/R LKO-IV LINE SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	63.000		63.000	63.00	100.00							
46	NR1SRT24	GORAKH 80MVAR S/R BARH-I LINE SUB TOTAL			00:00	00:00	00:00	00:00		NRPC	744.00	80.000		80.000	80.00	100.00							

