

Standard of Performance data for the month of Dec-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-1 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT AGRA	SVRD	23-12-2024	08:56:00	23-12-2024	13:24:00	0.19	0.00	0.00	0.00	4.47		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -752 KV
BSR	240MVAR,BUS REACTOR-1 AT AGRA	SVRD	22-12-2024	08:53:00	22-12-2024	14:00:00	0.21	0.00	0.00	0.00	5.12		* 240MVAR B/Reactor-I AGRA-765* 22-12-24 08:53* 22-12-24 14:00 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -752 KV
BSR	240MVAR,BUS REACTOR-1 AT AGRA	SVRD	21-12-2024	08:59:00	21-12-2024	22:32:00	0.57	0.00	0.00	0.00	13.55		* 240MVAR B/Reactor-I AGRA-765* 21-12-24 08:59* 21-12-24 22:32 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -756 KV
BSR	240MVAR,BUS REACTOR-1 AT AGRA	LVRD	15-12-2024	09:21:00	15-12-2024	13:45:00	0.18	0.00	0.00	0.00	4.40		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -761 KV
							1.15	0.00	0.00	0.00	27.54	100.00	
BSR	125MVAR,BUS REACTOR-2 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
BSR	125MVAR,BUS REACTOR-2 AT ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	02-12-2024	09:28:00	02-12-2024	14:06:00	0.19	0.00	0.00	0.00	4.63		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	01-12-2024	09:44:00	01-12-2024	13:20:00	0.15	0.00	0.00	0.00	3.60		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	11-12-2024	09:25:00	11-12-2024	12:47:00	0.14	0.00	0.00	0.00	3.37		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh-758KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	16-12-2024	09:00:00	16-12-2024	13:19:00	0.18	0.00	0.00	0.00	4.32		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh -760 KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	17-12-2024	09:21:00	17-12-2024	13:14:00	0.16	0.00	0.00	0.00	3.88		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh -760 KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	10-12-2024	09:35:00	10-12-2024	13:31:00	0.16	0.00	0.00	0.00	3.93		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	18-12-2024	09:16:00	18-12-2024	15:47:00	0.27	0.00	0.00	0.00	6.52		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh -760 KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	05-12-2024	09:56:00	05-12-2024	12:50:00	0.12	0.00	0.00	0.00	2.90		* 330MVAR B/Reactor-I ALIGARH* 05-12-24 09:56* 05-12-24 12:50* SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh-749KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	06-12-2024	09:33:00	06-12-2024	17:17:00	0.32	0.00	0.00	0.00	7.73		* 330MVAR B/Reactor-I ALIGARH* 06-12-24 09:33* 06-12-24 17:17 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh-752KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	04-12-2024	08:49:00	04-12-2024	12:38:00	0.16	0.00	0.00	0.00	3.82		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh-745KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	03-12-2024	08:49:00	03-12-2024	13:07:00	0.18	0.00	0.00	0.00	4.30		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh-745KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	26-12-2024	08:57:00	26-12-2024	13:08:00	0.17	0.00	0.00	0.00	4.18		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh-752KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	14-12-2024	08:55:00	14-12-2024	12:32:00	0.15	0.00	0.00	0.00	3.62		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh -760 KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	25-12-2024	09:35:00	25-12-2024	16:14:00	0.28	0.00	0.00	0.00	6.65		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	09-12-2024	09:39:00	09-12-2024	13:27:00	0.16	0.00	0.00	0.00	3.80		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	15-12-2024	10:02:00	15-12-2024	13:09:00	0.13	0.00	0.00	0.00	3.12		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh -760 KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	13-12-2024	09:26:00	13-12-2024	13:22:00	0.16	0.00	0.00	0.00	3.93		* 330MVAR B/Reactor-I ALIGARH 13-12-24 09:26 13-12-24 13:22 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh -760 KV
							3.08	0.00	0.00	0.00	74.30	100.00	
BSR	330MVAR,BUS REACTOR-2 AT ALIGARH	SVRD	02-12-2024	09:16:00	02-12-2024	14:08:00	0.20	0.00	0.00	0.00	4.87		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	330MVAR,BUS REACTOR-2 AT ALIGARH	SVRD	13-12-2024	09:44:00	13-12-2024	13:16:00	0.15	0.00	0.00	0.00	3.53		
BSR	330MVAR,BUS REACTOR-2 AT ALIGARH	SVRD	09-12-2024	09:40:00	09-12-2024	13:43:00	0.17	0.00	0.00	0.00	4.05		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
BSR	330MVAR,BUS REACTOR-2 AT ALIGARH	SVRD	03-12-2024	08:57:00	03-12-2024	13:06:00	0.17	0.00	0.00	0.00	4.15		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh-753KV
							0.69	0.00	0.00	0.00	16.60	100.00	
BSR	80MVAR,BUS REACTOR-1 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT BALLIA	SVRD	02-12-2024	09:18:00	03-12-2024	23:07:00	1.58	0.00	0.00	0.00	37.82		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	240MVAR,BUS REACTOR-1 AT BALLIA	SVRD	01-12-2024	09:43:00	01-12-2024	21:35:00	0.49	0.00	0.00	0.00	11.87		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT BALLIA	SVRD	11-12-2024	08:25:00	18-12-2024	22:05:00	7.57	0.00	0.00	0.00	181.67		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballia-748KV
BSR	240MVAR,BUS REACTOR-1 AT BALLIA	SVRD	09-12-2024	09:27:00	10-12-2024	22:55:00	1.56	0.00	0.00	0.00	37.47		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT BALLIA	SVRD	23-12-2024	09:30:00	23-12-2024	21:25:00	0.50	0.00	0.00	0.00	11.92		* Hand tripped on Voltage regulation as per NRLDC instruction. BALLIA -753 KV
BSR	240MVAR,BUS REACTOR-1 AT BALLIA	SVRD	04-12-2024	11:03:00	08-12-2024	15:09:00	4.17	0.00	0.00	0.00	100.10		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballia-748KV
BSR	240MVAR,BUS REACTOR-1 AT BALLIA	SVRD	30-12-2024	09:30:00	30-12-2024	13:05:00	0.15	0.00	0.00	0.00	3.58		* 240MVAR B/Reactor-I LUCKNOW-765 30-12-24 09:01 30-12-24 12:31* 240MVAR B/Reactor-I BAREILLY-765 30-12-24 09:02 30-12-24 12:22* 330MVAR B/Reactor-I FTHPR-765 30-12-24 09:38 30-12-24 13:39* 240MVAR B/Reactor-I BALIA-765 30-12-24 09:30 30-12-24 13:05* 240MVAR B/Reactor-II BALIA-765 30-12-24 09:32 30-12-24 22:57* 240MVAR B/Reactor-I KANPUR(GIS) 30-12-24 09:40 30-12-24 12:22
BSR	240MVAR,BUS REACTOR-1 AT BALLIA	SVRD	26-12-2024	09:19:00	27-12-2024	23:34:00	1.59	0.00	0.00	0.00	38.25		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballia-752KV
							17.61	0.00	0.00	0.00	422.68	100.00	
							0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT BALLIA	SVRD	03-12-2024	07:37:00	03-12-2024	22:31:00	0.62	0.00	0.00	0.00	14.90		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballia-748KV
BSR	240MVAR,BUS REACTOR-2 AT BALLIA	SVRD	23-12-2024	09:31:00	23-12-2024	21:26:00	0.50	0.00	0.00	0.00	11.92		* Hand tripped on Voltage regulation as per NRLDC instruction. BALLIA -753 KV
BSR	240MVAR,BUS REACTOR-2 AT BALLIA	SVRD	18-12-2024	09:24:00	20-12-2024	21:24:00	2.50	0.00	0.00	0.00	60.00		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballia-750KV
BSR	240MVAR,BUS REACTOR-2 AT BALLIA	SVRD	30-12-2024	09:32:00	30-12-2024	22:57:00	0.56	0.00	0.00	0.00	13.42		* 240MVAR B/Reactor-I LUCKNOW-765 30-12-24 09:01 30-12-24 12:31* 240MVAR B/Reactor-I BAREILLY-765 30-12-24 09:02 30-12-24 12:22* 330MVAR B/Reactor-I FTHPR-765 30-12-24 09:38 30-12-24 13:39* 240MVAR B/Reactor-I BALIA-765 30-12-24 09:30 30-12-24 13:05* 240MVAR B/Reactor-II BALIA-765 30-12-24 09:32 30-12-24 22:57* 240MVAR B/Reactor-I KANPUR(GIS) 30-12-24 09:40 30-12-24 12:22
BSR	240MVAR,BUS REACTOR-2 AT BALLIA	SVRD	21-12-2024	09:08:00	21-12-2024	14:00:00	0.20	0.00	0.00	0.00	4.87		* 240MVAR B/Reactor-II BALIA-765* 21-12-24 09:08* 21-12-24 14:00 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Ballia-756KV
BSR	240MVAR,BUS REACTOR-2 AT BALLIA	SVRD	22-12-2024	10:12:00	22-12-2024	16:15:00	0.25	0.00	0.00	0.00	6.05		* 240MVAR B/Reactor-II BALIA-765* 22-12-24 10:12* 22-12-24 16:15 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. BALLIA -753 KV
BSR	240MVAR,BUS REACTOR-2 AT BALLIA	SVRD	17-12-2024	10:15:00	17-12-2024	22:27:00	0.51	0.00	0.00	0.00	12.20		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballia-750KV
							5.14	0.00	0.00	0.00	123.36	100.00	
BSR	125MVAR,BUS REACTOR-3 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-4 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Dec-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	16-12-2024	08:57:00	16-12-2024	13:02:00	0.17	0.00	0.00	0.00	4.08		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly -762 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	13-12-2024	09:40:00	13-12-2024	13:19:00	0.15	0.00	0.00	0.00	3.65		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly -762 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	23-12-2024	08:58:00	23-12-2024	13:09:00	0.17	0.00	0.00	0.00	4.18		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly -758 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	10-12-2024	09:28:00	10-12-2024	13:13:00	0.16	0.00	0.00	0.00	3.75		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	09-12-2024	09:36:00	09-12-2024	13:23:00	0.16	0.00	0.00	0.00	3.78		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	21-12-2024	09:06:36	21-12-2024	13:14:00	0.17	0.00	0.00	0.00	4.12		* 240MVAR B/Reactor-I BAREILLY-765* 21-12-24 09:06* 21-12-24 13:14 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly 765-758 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	20-12-2024	09:29:00	20-12-2024	16:11:00	0.28	0.00	0.00	0.00	6.70		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly 765 -755 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	31-12-2024	09:24:00	31-12-2024	13:27:00	0.17	0.00	0.00	0.00	4.05		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly -753 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	14-12-2024	09:38:00	14-12-2024	12:53:00	0.14	0.00	0.00	0.00	3.25		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly -762 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	30-12-2024	09:02:00	30-12-2024	12:22:00	0.14	0.00	0.00	0.00	3.33		* 240MVAR B/Reactor-I LUCKNOW-765 30-12-24 09:01 30-12-24 12:31* 240MVAR B/Reactor-I BAREILLY-765 30-12-24 09:02 30-12-24 12:22* 330MVAR B/Reactor-I FTHPR-765 30-12-24 09:38 30-12-24 13:39* 240MVAR B/Reactor-I BALIA-765 30-12-24 09:30 30-12-24 13:05* 240MVAR B/Reactor-II BALIA-765 30-12-24 09:32 30-12-24 22:57* 240MVAR B/Reactor-I KANPUR(GIS) 30-12-24 09:40 30-12-24 12:22
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	03-12-2024	08:47:00	03-12-2024	13:18:00	0.19	0.00	0.00	0.00	4.52		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly 2- 755 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	06-12-2024	09:29:00	06-12-2024	15:58:00	0.27	0.00	0.00	0.00	6.48		* 240MVAR B/Reactor-I BAREILLY-765* 06-12-24 09:29* 06-12-24 15:58 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly-758 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	17-12-2024	09:25:00	17-12-2024	13:14:00	0.16	0.00	0.00	0.00	3.82		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly -762 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	15-12-2024	09:19:00	15-12-2024	12:12:00	0.12	0.00	0.00	0.00	2.88		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly -762 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	08-12-2024	08:55:00	08-12-2024	13:37:00	0.20	0.00	0.00	0.00	4.70		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly-758 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	22-12-2024	09:24:00	22-12-2024	13:07:00	0.16	0.00	0.00	0.00	3.72		* 240MVAR B/Reactor-I BAREILLY-765* 22-12-24 09:24* 22-12-24 13:07 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly 765-751 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	07-12-2024	09:26:00	07-12-2024	13:21:00	0.16	0.00	0.00	0.00	3.92		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly-758 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	18-12-2024	09:22:00	18-12-2024	13:21:00	0.17	0.00	0.00	0.00	3.98		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly -762 KV
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	11-12-2024	09:29:00	11-12-2024	13:03:00	0.15	0.00	0.00	0.00	3.57		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly-758 KV
							3.29	0.00	0.00	0.00	78.48	100.00	
BSR	80MVAR,BUS REACTOR-1 AT BAREILLY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	100MVAR,BUS REACTOR-2 AT BAREILLY	SVRD	02-12-2024	10:23:00	02-12-2024	21:52:00	0.48	0.00	0.00	0.00	11.48		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	100MVAR,BUS REACTOR-2 AT BAREILLY	SVRD	03-12-2024	09:14:00	03-12-2024	22:58:00	0.57	0.00	0.00	0.00	13.73		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly400-392 KV
							1.05	0.00	0.00	0.00	25.21	100.00	
BSR	125MVAR,BUS REACTOR-1 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-1 AT FATEHPUR	SVRD	22-12-2024	10:02:00	22-12-2024	16:23:00	0.27	0.00	0.00	0.00	6.35		* 330MVAR B/Reactor-I FTHPR-765 22-12-24 10:02 22-12-24 16:23 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. FTP -752 KV
BSR	330MVAR,BUS REACTOR-1 AT FATEHPUR	SVRD	23-12-2024	11:06:00	23-12-2024	19:35:00	0.35	0.00	0.00	0.00	8.48		* Hand tripped on Voltage regulation as per NRLDC instruction. Fatehpur-752KV
BSR	330MVAR,BUS REACTOR-1 AT FATEHPUR	SVRD	29-12-2024	09:39:00	29-12-2024	13:27:00	0.16	0.00	0.00	0.00	3.80		* 330MVAR B/Reactor-I FTHPR-765 29-12-24 09:39 29-12-24 13:10 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. FTP -789 KV
BSR	330MVAR,BUS REACTOR-1 AT FATEHPUR	SVRD	30-12-2024	09:38:00	30-12-2024	13:39:00	0.17	0.00	0.00	0.00	4.02		* 240MVAR B/Reactor-I LUCKNOW-765 30-12-24 09:01 30-12-24 12:31* 240MVAR B/Reactor-I BAREILLY-765 30-12-24 09:02 30-12-24 12:22* 330MVAR B/Reactor-I FTHPR-765 30-12-24 09:38 30-12-24 13:39* 240MVAR B/Reactor-I BALIA-765 30-12-24 09:30 30-12-24 13:05* 240MVAR B/Reactor-II BALIA-765 30-12-24 09:32 30-12-24 22:57* 240MVAR B/Reactor-I KANPUR(GIS) 30-12-24 09:40 30-12-24 12:22
							0.95	0.00	0.00	0.00	22.65	100.00	
BSR	125MVAR,BUS REACTOR-2 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	25MVAR,BUS REACTOR-1 AT JAULIJI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT KANPUR(GIS)	SVRD	22-12-2024	09:18:00	22-12-2024	15:51:00	0.27	0.00	0.00	0.00	6.55		* 125MVAR B/Reactor-III KANPUR(GIS) 22-12-24 09:18 22-12-24 15:51 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur GIS-400 KV
BSR	125MVAR,BUS REACTOR-1 AT KANPUR(GIS)	SVRD	26-12-2024	09:58:00	26-12-2024	19:34:00	0.40	0.00	0.00	0.00	9.60		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur-395KV
							0.67	0.00	0.00	0.00	16.15	100.00	
BSR	240MVAR,BUS REACTOR-1 AT KANPUR(GIS)	SVRD	29-12-2024	10:05:00	29-12-2024	13:10:00	0.13	0.00	0.00	0.00	3.08		* 240MVAR B/Reactor-I KANPUR(GIS) 29-12-24 10:05 29-12-24 13:27 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. KNP -790 KV
BSR	240MVAR,BUS REACTOR-1 AT KANPUR(GIS)	SVRD	30-12-2024	09:40:00	30-12-2024	12:22:00	0.11	0.00	0.00	0.00	2.70		* 240MVAR B/Reactor-I LUCKNOW-765 30-12-24 09:01 30-12-24 12:31* 240MVAR B/Reactor-I BAREILLY-765 30-12-24 09:02 30-12-24 12:22* 330MVAR B/Reactor-I FTHPR-765 30-12-24 09:38 30-12-24 13:39* 240MVAR B/Reactor-I BALIA-765 30-12-24 09:30 30-12-24 13:05* 240MVAR B/Reactor-II BALIA-765 30-12-24 09:32 30-12-24 22:57* 240MVAR B/Reactor-I KANPUR(GIS) 30-12-24 09:40 30-12-24 12:22
							0.24	0.00	0.00	0.00	5.78	100.00	
BSR	240MVAR,BUS REACTOR-2 AT KANPUR(GIS)	SVRD	23-12-2024	09:41:00	24-12-2024	00:01:00	0.60	0.00	0.00	0.00	14.33		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur GIS-751KV
BSR	240MVAR,BUS REACTOR-2 AT KANPUR(GIS)	SVRD	22-12-2024	09:16:00	22-12-2024	16:01:00	0.28	0.00	0.00	0.00	6.75		* 240MVAR B/Reactor-II KANPUR(GIS) 22-12-24 09:16 22-12-24 16:01 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur GIS-751KV
							0.88	0.00	0.00	0.00	21.08	100.00	
BSR	125MVAR,BUS REACTOR-1 AT KANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT LUCKNOW			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT LUCKNOW			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT LUCKNOW 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	21-12-2024	09:07:00	21-12-2024	16:11:00	0.29	0.00	0.00	0.00	7.07		* 240MVAR B/Reactor-I LUCKNOW-765* 21-12-24 09:07* 21-12-24 16:11 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -757 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	08-12-2024	09:10:00	08-12-2024	13:42:00	0.19	0.00	0.00	0.00	4.53		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-758KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	18-12-2024	09:00:00	18-12-2024	13:23:00	0.18	0.00	0.00	0.00	4.38		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -758 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	02-12-2024	09:22:00	02-12-2024	21:52:00	0.52	0.00	0.00	0.00	12.50		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	01-12-2024	09:09:00	01-12-2024	13:14:00	0.17	0.00	0.00	0.00	4.08		* H/T FOR V/R AS PER NRLDC INSTRUCTION.

Standard of Performance data for the month of Dec-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	30-12-2024	09:01:00	30-12-2024	12:31:00	0.15	0.00	0.00	0.00	3.50		* 240MVAR B/Reactor-I LUCKNOW-765 30-12-24 09:01 30-12-24 12:31* 240MVAR B/Reactor-I BAREILLY-765 30-12-24 09:02 30-12-24 12:22* 330MVAR B/Reactor-I FTHPR-765 30-12-24 09:38 30-12-24 13:39* 240MVAR B/Reactor-I BALIA-765 30-12-24 09:30 30-12-24 13:05* 240MVAR B/Reactor-II BALIA-765 30-12-24 09:32 30-12-24 22:57* 240MVAR B/Reactor-I KANPUR(GIS) 30-12-24 09:40 30-12-24 12:22
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	LVRD	14-12-2024	08:53:00	14-12-2024	12:50:00	0.17	0.00	0.00	0.00	3.95		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -758 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	31-12-2024	09:25:00	31-12-2024	13:03:00	0.15	0.00	0.00	0.00	3.63		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -750 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	26-12-2024	08:59:00	26-12-2024	13:23:00	0.18	0.00	0.00	0.00	4.40		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-752KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	03-12-2024	08:47:00	03-12-2024	13:30:00	0.20	0.00	0.00	0.00	4.72		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-753KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	05-12-2024	09:41:00	05-12-2024	12:44:00	0.13	0.00	0.00	0.00	3.05		* 240MVAR B/Reactor-I LUCKNOW-765* 05-12-24 09:41* 05-12-24 12:44* SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-758KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	04-12-2024	08:52:00	04-12-2024	13:30:00	0.19	0.00	0.00	0.00	4.63		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-753KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	06-12-2024	08:32:00	06-12-2024	13:42:00	0.22	0.00	0.00	0.00	5.17		* 240MVAR B/Reactor-I LUCKNOW-765* 06-12-24 08:32* 06-12-24 13:42* SVRD* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-758KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	07-12-2024	09:17:00	07-12-2024	13:41:00	0.18	0.00	0.00	0.00	4.40		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-758KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	19-12-2024	09:00:00	19-12-2024	22:14:00	0.55	0.00	0.00	0.00	13.23		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -758 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	22-12-2024	08:50:00	22-12-2024	16:34:00	0.32	0.00	0.00	0.00	7.73		* 240MVAR B/Reactor-I LUCKNOW-765 22-12-24 08:50 22-12-24 16:34 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -755 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	20-12-2024	09:26:00	20-12-2024	21:58:00	0.52	0.00	0.00	0.00	12.53		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -758 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	16-12-2024	08:52:00	16-12-2024	13:04:00	0.18	0.00	0.00	0.00	4.20		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -758 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	09-12-2024	08:45:00	09-12-2024	13:32:00	0.20	0.00	0.00	0.00	4.78		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	13-12-2024	08:10:00	13-12-2024	21:40:00	0.56	0.00	0.00	0.00	13.50		* 240MVAR B/Reactor-I LUCKNOW-765* 13-12-24 08:10 13-12-24 21:40 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -758 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	17-12-2024	09:28:00	17-12-2024	13:17:00	0.16	0.00	0.00	0.00	3.82		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -758 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	23-12-2024	08:56:00	23-12-2024	13:33:00	0.19	0.00	0.00	0.00	4.62		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -755 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	11-12-2024	08:28:00	11-12-2024	13:18:00	0.20	0.00	0.00	0.00	4.83		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-758KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	15-12-2024	08:56:00	15-12-2024	13:09:00	0.18	0.00	0.00	0.00	4.22		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -758 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	10-12-2024	09:32:00	10-12-2024	22:43:00	0.55	0.00	0.00	0.00	13.18		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
							6.53	0.00	0.00	0.00	156.65	100.00	
BSR	125MVAR,BUS REACTOR-1 AT MAINPURI	SVRD	17-12-2024	10:23:00	17-12-2024	16:44:00	0.27	0.00	0.00	0.00	6.35		* Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri -398 KV
BSR	125MVAR,BUS REACTOR-1 AT MAINPURI	SVRD	15-12-2024	09:22:00	15-12-2024	13:50:00	0.19	0.00	0.00	0.00	4.47		* Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri -398 KV
BSR	125MVAR,BUS REACTOR-1 AT MAINPURI	SVRD	05-12-2024	09:31:00	05-12-2024	21:01:00	0.48	0.00	0.00	0.00	11.50		* 125MVAR B/Reactor-1 MAINPURI* 05-12-24 09:31* 05-12-24 21:01* SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri - 418 KV
BSR	125MVAR,BUS REACTOR-1 AT MAINPURI	SVRD	06-12-2024	09:05:00	06-12-2024	21:28:00	0.52	0.00	0.00	0.00	12.38		* 125MVAR B/Reactor-1 MAINPURI* 06-12-24 09:05* 06-12-24 21:28* SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri - 400 KV
BSR	125MVAR,BUS REACTOR-1 AT MAINPURI	SVRD	03-12-2024	09:01:00	03-12-2024	22:43:00	0.57	0.00	0.00	0.00	13.70		* Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri - 396KV
BSR	125MVAR,BUS REACTOR-1 AT MAINPURI	SVRD	02-12-2024	10:32:00	02-12-2024	21:56:00	0.48	0.00	0.00	0.00	11.40		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	125MVAR,BUS REACTOR-1 AT MAINPURI	SVRD	14-12-2024	09:05:00	14-12-2024	17:29:00	0.35	0.00	0.00	0.00	8.40		* Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri -398 KV
BSR	125MVAR,BUS REACTOR-1 AT MAINPURI	SVRD	13-12-2024	09:57:00	13-12-2024	15:31:00	0.23	0.00	0.00	0.00	5.57		
BSR	125MVAR,BUS REACTOR-1 AT MAINPURI	SVRD	07-12-2024	09:21:00	07-12-2024	21:14:00	0.50	0.00	0.00	0.00	11.88		* Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri -400 KV
BSR	125MVAR,BUS REACTOR-1 AT MAINPURI	SVRD	16-12-2024	08:59:00	16-12-2024	13:33:00	0.19	0.00	0.00	0.00	4.57		* Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri -398 KV
							3.78	0.00	0.00	0.00	90.22	100.00	
BSR	330MVAR,BUS REACTOR-1 AT ORAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-2 AT ORAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	25MVAR,BUS REACTOR-1 AT PITHORAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT SHAHJAHANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR,BUS REACTOR-1 AT SOHAWAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-2 AT SOHAWAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	93MVAR,BUS REACTOR-2 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	93MVAR,BUS REACTOR-1 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-4 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-1 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-2 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	Electrode Line (AGRA HVDC)-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	Electrode Line (AGRA HVDC)-CKT2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132 KV MAU-BALIA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV AGRA-BHARATPUR(RRVPNL)	LEFT	24-12-2024	22:18:00	24-12-2024	23:08:00	0.04	0.83	0.00	0.00	0.00		* Tripped on Y-N fault, Agra relay details:M1-FD-52.3km,FC-3.532KA; M2-FD-52.38 Km, FC-3.742 kA. Fault is in Agra jurisdiction.
CKT	220kV AGRA-BHARATPUR(RRVPNL)	OMSU	25-12-2024	01:08:00	25-12-2024	11:21:00	0.43	0.00	10.22	0.00	0.00		* Tripped on Y-N fault. Agra relay details:M2-FD-56.40 Km, FC-3.453 kA. Fault is in RRVPNL jurisdiction.
							0.47	0.83	10.22	0.00	0.00	99.89	
CKT	220KV-AGRA-KIRAWALI(UP)-ACL-CKT1	OSPD	13-12-2024	11:13:00	13-12-2024	16:19:00	0.21	0.00	0.00	0.00	5.10		* 220KV AGRA(PG)-KIRAWALI(UP)-1* 13-12-24 11:13* 13-12-24 16:19* OSPD Taken under S/d by UP for PLCC work.
							0.21	0.00	0.00	0.00	5.10	100.00	
CKT	220kV ALLAHABAD-JHUSI(UPPTCL)	OSPD	28-12-2024	11:48:00	28-12-2024	18:54:00	0.30	0.00	0.00	0.00	7.10		* Shutdown by UPPTCL for replacement of damaged Y Phase Jumper form gantry CT
CKT	220kV ALLAHABAD-JHUSI(UPPTCL)	OSPD	22-12-2024	11:24:00	22-12-2024	15:21:00	0.17	0.00	0.00	0.00	3.95		* 220KV ALLD-JHUSI(UP)* 22-12-24 11:24* 22-12-24 15:21* OSPD Taken under S/d by UP to facilitate the S/d of 220 KV Main bus at Jhuns.
							0.47	0.00	0.00	0.00	11.05	100.00	
CKT	220kV ALLAHABAD-REWA ROAD(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

CKT	220kV ALLAHABAD-REWA ROAD(UPPTCL)-2				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
								0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV-AURAIYA(NT)-SAIFAI(UP)-ACL-CKT1	OMSU	10-12-2024	12:00:00	10-12-2024	17:00:00	0.21	0.00	5.00	0.00	0.00	0.00		* Line tripped on B-N fault.Safai end details-M1-FD-62.KM,FC-2.16KAMP.NTPC Auraiya end details FD= 71m. Fault in NTPC switchyard.
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV AURAIYA(NTPC)-SIKANDRA(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV FATEHPUR-FATEHPUR(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV FATEHPUR-FATEHPUR(UPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV FATEHPUR-KANPUR SOUTH(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV FATEHPUR-NAUBASTA(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV JAULJIVI-PITHORAGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV JAULJIVI-PITHORAGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV-JAUNPUR(UP)-PHULPUR(UP)-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV-KANPUR-KIDWAI NAGAR-ACL-C1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV KANPUR-NAUBASTA(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV KANPUR-RANIYA(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	220kV MAINPURI(UPPTCL)-KANPUR	OSPD	14-12-2024	08:15:00	14-12-2024	18:50:00	0.44	0.00	0.00	0.00	10.58			* for stringing work of 765KV MAINPURI-UNNAO LINE by UP.
CKT	220kV MAINPURI(UPPTCL)-KANPUR	LART	28-12-2024	14:18:00	28-12-2024	14:18:00	0.00	0.00	0.00	0.00	0.00			* 220kV Kanpur-Mainpuri(UP) AR successfully from both ends at 14:18hrs due to B-N fault.M1-FD- 116.9 km,FC- 1.56kA,M2-FD- 117.0 km,FC-1.52KA.Fault is in UPPTCL jurisdiction.
							0.44	0.00	0.00	0.00	10.58	100.00		
CKT	220kV RAEBAREILY-BACHHRAWAN(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RAIBAREILLY-CG CITY(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RANIYA(UPPTCL)-PANKI(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV-SIKANDRA(UP)-KIRAWALI(UP)-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV-SIKANDRA(UP)-SAIFAI(UP)-ACL-CKT1	LART	30-12-2024	04:08:00	30-12-2024	04:08:00	0.00	0.00	0.00	0.00	0.00			* 220KV SIKANDRA(UP)-SAIFAI(UP)-1* 30-12-24 04:08 30-12-24 04:08 LART A/R successful on B-N fault.Sikandra end relay details-M1-FD-73.2 km,FC-1.8 KA,M2-76.73 km= ,FC-1.6 KA. Fault under Agra jurisdiction.
CKT	220kV-SIKANDRA(UP)-SAIFAI(UP)-ACL-CKT1	LART	27-12-2024	22:50:00	27-12-2024	22:50:00	0.00	0.00	0.00	0.00	0.00			* A/R successful on R-N fault.Sikandra end relay details-M1-FD-78.4KM= ,FC-NA,M2-FD-77.27KM,FC-2.311KAMP.
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	220kV SITARGANJ-BAREILLY(UPPTCL)	OMSU	22-12-2024	08:51:00	22-12-2024	09:55:00	0.04	0.00	1.07	0.00	0.00			* 220KV SITARGANJ-BLY(UP)* 22-12-24 08:51* 22-12-24 09:55* LPPT Line tripped on R-Y fault at 08:51 hrs. Sitarganj end relay details M1 FD-98.2 Km FC- 1.8 KA M2 FD- 99.3KM FC - 1.36 KA Fault in in Bareilly TLM jurisdiction* 22.04.2025 03:15:01 INDIA (60041608)* Kite thread between Loc No-306-307.
CKT	220kV SITARGANJ-BAREILLY(UPPTCL)	OSPD	22-12-2024	11:54:00	22-12-2024	19:14:00	0.31	0.00	0.00	0.00	7.33			* 220KV SITARGANJ-BLY(UP) 22-12-24 11:54 22-12-24 19:14 OSPD Taken under S/d by UP for safety purpose to replace R-ph conductor of overhead line 220 KV Bareilly-CB ganj.
CKT	220kV SITARGANJ-BAREILLY(UPPTCL)	OMSU	29-12-2024	14:01:00	29-12-2024	14:48:00	0.03	0.00	0.78	0.00	0.00			* 220KV SITARGANJ-BLY(UP) 29-12-24 14:01 29-12-24 14:48 LPPT Tripped on R-Y ph fault. Sitarganj end relay details-M1-FD-99.27 km,FC-1.60 KA,M2-100 km,FC-1.82 KA. AFAS details FD-99.076 km,FC-1.666 KA.Fault under Bareilly jurisdiction. * 22.04.2025 03:16:57 INDIA (60041608)* kite found between Location number -306-307
							0.38	0.00	1.85	0.00	7.33	100.00		
CKT	220kV SITARGANJ-TANAKPUR(NHPC)	OSFD	20-12-2024	10:34:00	20-12-2024	12:41:00	0.09	0.00	0.00	0.00	2.12			* Emergency shutdown taken by NHPC for replacement of pressure switch at Tanakpur.
CKT	220kV SITARGANJ-TANAKPUR(NHPC)	OMSU	29-12-2024	15:56:00	29-12-2024	16:54:00	0.04	0.00	0.97	0.00	0.00			* 220KV TNKPR-SITARGANJ* 29-12-24 15:56* 29-12-24 16:54* OMSU Tripped on Y-B fault.(Zone-3 fault). Sitarganj end relay details-M1-NA. M2- 291.5 km,FC-1.14 KA. Fault in Tanakpur jurisdiction.
							0.13	0.00	0.97	0.00	2.12	100.00		
CKT	220kV TANAKPUR(NHPC)-BAREILLY(UPPTCL)	OSPD	22-12-2024	12:10:00	22-12-2024	19:04:00	0.29	0.00	0.00	0.00	6.90			* 220KV TNKPR-BLY(UP)* 22-12-24 12:10* 22-12-24 19:04 OSPD Taken under S/d by UP for safety purpose to replace R-ph conductor of overhead line 220 KV Bareilly-CB ganj.
CKT	220kV TANAKPUR(NHPC)-BAREILLY(UPPTCL)	OMSU	29-12-2024	15:56:00	29-12-2024	18:10:00	0.09	0.00	2.23	0.00	0.00			* 220KV TNKPR-BLY(UP) 29-12-24 15:56 29-12-24 18:10 OMSU Tripped on Y-B fault. CB Ganj end relay details-M1-0.665 KM Zone 4 fault. Fault in UP jurisdiction.
							0.38	0.00	2.23	0.00	6.90	100.00		
CKT	220kV UNCHAHAR(NTPC)-KANPUR-1	LCSD	29-12-2024	10:28:00	31-12-2024	23:59:59	2.56	0.00	0.00	0.00	61.53			* 220KV KNP-UNCHR-I 29-12-24 10:28 **** LCSD S/D taken for diversion work of 220 KV Kanpur-Unchahar-1<*>2 line infringing with bypass road at Unchahar.
							2.56	0.00	0.00	0.00	61.53	100.00		
CKT	220kV UNCHAHAR(NTPC)-KANPUR-2	LCSD	29-12-2024	10:29:00	31-12-2024	23:59:59	2.56	0.00	0.00	0.00	61.52			* 220KV KNP-UNCHR-II 29-12-24 10:29 **** LCSD S/D taken for diversion work of 220 KV Kanpur-Unchahar-1<*>2 line infringing with bypass road at Unchahar.
							2.56	0.00	0.00	0.00	61.52	100.00		
CKT	220kV UNCHAHAR(NTPC)-KANPUR-3	LCSD	01-12-2024	00:00:01	03-12-2024	15:55:00	2.66	0.00	0.00	0.00	63.92			* 220KV KNP-UNCHR-III 19-11-24 08:59 **** LCSD For Diversion work of 220KV Unchahar Kanpur circuit 4 for NHAI Raebareilly Prayagraj bypass road crossing under Raebareilly.
CKT	220kV UNCHAHAR(NTPC)-KANPUR-3	OMSU	03-12-2024	17:22:00	06-12-2024	11:58:00	2.78	0.00	66.60	0.00	0.00			* Line tripped due to Y-N fault in Zone-2. Kanpur end relay details M1-FD-165.2 KM, FC-1.186 KA, M2-FD- 160.9 KM, FC-1.21. Fault under NTPC jurisdiction.
							5.44	0.00	66.60	0.00	63.92	100.00		
CKT	220kV UNCHAHAR(NTPC)-KANPUR-4	LCSD	01-12-2024	00:00:01	03-12-2024	15:56:00	2.66	0.00	0.00	0.00	63.93			* 220KV KNP-UNCHR-IV 19-11-24 09:00* **** LCSD* For Diversion work of 220KV Unchahar Kanpur circuit 4 for NHAI Raebareilly Prayagraj bypass road crossing under Raebareilly.
CKT	220kV UNCHAHAR(NTPC)-KANPUR-4	OSFD	03-12-2024	17:57:00	03-12-2024	18:47:00	0.04	0.00	0.00	0.00	0.83			* Line taken emergency shutdown from NTPC end only. Line remain charged from Kanpur end.
							2.70	0.00	0.00	0.00	64.76	100.00		
CKT	220kV UNCHAHAR(NTPC)-RAIBAREILLY-1	OSPD	17-12-2024	11:06:00	26-12-2024	15:24:00	9.18	0.00	0.00	0.00	220.30			* S/D taken by UPPTCL for height raising work for NHAI work
							9.18	0.00	0.00	0.00	220.30	100.00		
CKT	220kV UNCHAHAR(NTPC)-RAIBAREILLY-2	OSPD	17-12-2024	11:07:00	26-12-2024	15:26:00	9.18	0.00	0.00	0.00	220.32			* S/D taken by UPPTCL for height raising work for NHAI work
							9.18	0.00	0.00	0.00	220.32	100.00		
CKT	220kV UNCHAHAR(NTPC)-RAIBAREILLY-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		

Standard of Performance data for the month of Dec-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

CKT	400kV AGRA(UPPTCL)-FATEHABD(UPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV AGRA-AGRA(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV AGRA-BALLABGARH	LVRD	03-12-2024	01:42:00	03-12-2024	07:38:00	0.25	0.00	0.00	0.00	5.93			* H/T FOR V/R AS PER NRLDC INSTRUCTION
CKT	400kV AGRA-BALLABGARH	LVRD	28-12-2024	00:07:00	28-12-2024	17:20:00	0.72	0.00	0.00	0.00	17.22			* H/T FOR V/R AS PER NRLDC INSTRUCTION.
							0.97	0.00	0.00	0.00	23.15	100.00		
CKT	400kV AGRA-BASSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	400kV AGRA-BHIWADI-1	LVRD	05-12-2024	18:37:00	06-12-2024	06:11:00	0.48	0.00	0.00	0.00	11.57			* 400KV AGRA-BHIWADI-I* 05-12-24 18:37* 06-12-24 06:11* LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -419 KV
CKT	400kV AGRA-BHIWADI-1	LVRD	20-12-2024	21:30:00	21-12-2024	06:31:00	0.38	0.00	0.00	0.00	9.02			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-1	LVRD	18-12-2024	20:28:00	19-12-2024	06:02:00	0.40	0.00	0.00	0.00	9.57			* Hand tripped on Voltage regulation as per NRLDC instruction
CKT	400kV AGRA-BHIWADI-1	LVRD	01-12-2024	21:00:00	02-12-2024	06:36:00	0.40	0.00	0.00	0.00	9.60			* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV AGRA-BHIWADI-1	LVRD	16-12-2024	22:08:00	17-12-2024	06:21:00	0.34	0.00	0.00	0.00	8.22			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -417 KV
CKT	400kV AGRA-BHIWADI-1	LVRD	14-12-2024	21:22:00	15-12-2024	07:09:00	0.41	0.00	0.00	0.00	9.78			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-1	LVRD	11-12-2024	20:17:00	12-12-2024	06:40:00	0.43	0.00	0.00	0.00	10.38			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-1	LVRD	07-12-2024	21:37:00	08-12-2024	07:50:00	0.43	0.00	0.00	0.00	10.22			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-1	LVRD	09-12-2024	21:55:00	10-12-2024	06:41:00	0.37	0.00	0.00	0.00	8.77			* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV AGRA-BHIWADI-1	LVRD	03-12-2024	19:43:00	04-12-2024	06:39:00	0.46	0.00	0.00	0.00	10.93			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-1	LVRD	06-12-2024	21:05:00	07-12-2024	06:42:00	0.40	0.00	0.00	0.00	9.62			* 400KV AGRA-BHIWADI-I* 06-12-24 21:05* 07-12-24 06:42 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
							4.50	0.00	0.00	0.00	107.68	100.00		
CKT	400kV AGRA-BHIWADI-2	LVRD	28-12-2024	23:23:00	29-12-2024	06:30:00	0.30	0.00	0.00	0.00	7.12			* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV AGRA-BHIWADI-2	LVRD	24-12-2024	21:17:00	25-12-2024	06:56:00	0.40	0.00	0.00	0.00	9.65			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -414 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	10-12-2024	20:26:00	11-12-2024	06:29:00	0.42	0.00	0.00	0.00	10.05			* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV AGRA-BHIWADI-2	LVRD	08-12-2024	21:03:00	09-12-2024	06:26:00	0.39	0.00	0.00	0.00	9.38			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	22-12-2024	21:25:00	23-12-2024	07:02:00	0.40	0.00	0.00	0.00	9.62			* 400KV AGRA-BHIWADI-II* 22-12-24 21:25* **** LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -415 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	26-12-2024	21:05:00	27-12-2024	09:23:00	0.51	0.00	0.00	0.00	12.30			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -416 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	31-12-2024	20:23:00	31-12-2024	23:59:59	0.15	0.00	0.00	0.00	3.62			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -416 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	29-12-2024	20:24:00	30-12-2024	07:03:00	0.44	0.00	0.00	0.00	10.65			* 400KV AGRA-BHIWADI-II* 29-12-24 20:24* 30-12-24 07:03 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -416 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	28-12-2024	23:29:00	29-12-2024	06:30:00	0.29	0.00	0.00	0.00	7.02			* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV AGRA-BHIWADI-2	LVRD	30-12-2024	20:28:00	31-12-2024	07:45:00	0.47	0.00	0.00	0.00	11.28			* 400KV AGRA-BHIWADI-II 30-12-24 20:28 **** LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -416 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	27-12-2024	19:41:00	28-12-2024	08:13:00	0.52	0.00	0.00	0.00	12.53			* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV AGRA-BHIWADI-2	LVRD	02-12-2024	20:57:00	03-12-2024	06:38:00	0.40	0.00	0.00	0.00	9.68			* H/T FOR V/R AS PER NRLDC INSTRUCTION
CKT	400kV AGRA-BHIWADI-2	LVRD	04-12-2024	20:15:00	05-12-2024	06:26:00	0.42	0.00	0.00	0.00	10.18			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	15-12-2024	20:34:00	16-12-2024	07:03:00	0.44	0.00	0.00	0.00	10.48			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	13-12-2024	21:25:00	14-12-2024	06:26:00	0.38	0.00	0.00	0.00	9.02			* 400KV AGRA-BHIWADI-II 13-12-24 21:25 14-12-24 06:26 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	21-12-2024	20:57:00	22-12-2024	05:49:00	0.37	0.00	0.00	0.00	8.87			* 400KV AGRA-BHIWADI-II* 21-12-24 20:57* 22-12-24 05:49* LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -418 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	17-12-2024	22:22:00	18-12-2024	06:09:00	0.32	0.00	0.00	0.00	7.78			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -417 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	23-12-2024	21:06:00	24-12-2024	06:04:00	0.37	0.00	0.00	0.00	8.97			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -417 KV
CKT	400kV AGRA-BHIWADI-2	LART	16-12-2024	22:10:00	16-12-2024	22:10:00	0.00	0.00	0.00	0.00	0.00			* "A/R operated successfully from both end due to R-N fault.Agra end relay details:" M1: FD-46.9 KM,FC-7.74 KA; M2:FD-47.46 KM, FC-7.59 KA,Bhiwadi end relay details:M1: 144.7 KM, 2.62 KA,M2: FD-NA, FC- 2.64 KA. Fault under Agra TL Jurisdiction."
CKT	400kV AGRA-BHIWADI-2	LVRD	25-12-2024	20:48:00	26-12-2024	06:21:00	0.40	0.00	0.00	0.00	9.55			* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV AGRA-BHIWADI-2	LVRD	12-12-2024	20:28:00	13-12-2024	06:50:00	0.43	0.00	0.00	0.00	10.37			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	19-12-2024	21:26:00	20-12-2024	06:56:00	0.40	0.00	0.00	0.00	9.50			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	01-12-2024	00:00:01	01-12-2024	07:08:00	0.30	0.00	0.00	0.00	7.13			* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
							8.52	0.00	0.00	0.00	204.75	100.00		
CKT	400kV AGRA-FATEHABAD(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	400kV ALLAHABAD-FATEHPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	400kV ALLAHABAD-FATEHPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	400kV ALLAHABAD-FATEHPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	400kV ALLAHABAD-KANPUR GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	400kV ALLAHABAD-KANPUR GIS-2	OSFT	24-12-2024	13:03:00	24-12-2024	15:08:00	0.09	2.08	0.00	0.00	0.00			* E/S/D taken to attend hotspot at B-ph BPI terminal connector at KanpurGIS.
							0.09	2.08	0.00	0.00	0.00	99.72		
CKT	400kV ALLAHABAD-KANPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	400kV ALLAHABAD-MEJA(NTPC)-1	OSPD	19-12-2024	09:53:00	19-12-2024	18:58:00	0.38	0.00	0.00	0.00	9.08			* Shutdown taken by Meja for maintenance and testing of CB, Isolator, relays etc.
CKT	400kV ALLAHABAD-MEJA(NTPC)-1	OSPD	18-12-2024	10:10:00	18-12-2024	19:12:00	0.38	0.00	0.00	0.00	9.03			* Shutdown taken by Meja for maintenance and testing of CB, Isolator, relays etc
							0.76	0.00	0.00	0.00	18.11	100.00		
CKT	400kV ALLAHABAD-MEJA(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	400kV AURAIYA(NTPC)-AGRA-1	LVRD	29-12-2024	00:01:00	29-12-2024	06:44:00	0.28	0.00	0.00	0.00	6.72			* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV AURAIYA(NTPC)-AGRA-1	LVRD	29-12-2024	23:07:00	30-12-2024	08:23:00	0.39	0.00	0.00	0.00	9.27			* 312303 400KV AGRA-AURAIYA-I 29-12-24 23:07 **** LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -415 KV
							0.67	0.00	0.00	0.00	15.99	100.00		
CKT	400kV AURAIYA(NTPC)-AGRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	400kV AURAIYA(NTPC)-KANPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	400kV AURAIYA(NTPC)-KANPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00			
							0.00	0.00	0.00	0.00	0.00	100.00		
CKT	400kV BALIA-MAU(UPPTCL)-1	OSPD	09-12-2024	10:06:00	09-12-2024	17:51:00	0.32	0.00	0.00	0.00	7.75			* S/D taken for CT tan delta testing <[>&<]> other maintenance work by UPPTCL
							0.32	0.00	0.00	0.00	7.75	100.00		

Standard of Performance data for the month of Dec-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

CKT	400kV BALIA-RASRA(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV BALIA-SOHAHAL-1	OMSU	29-12-2024	15:16:00	29-12-2024	15:37:00	0.02	0.00	0.35	0.00	0.00		* 400KV BALIA-SOHAHAL-I* 29-12-24 15:16* 29-12-24 15:35 LPPT Tripped on R-B ph fault. Ballia end relay details-M1-FD-199.7 km,FC-2.448 KA,M2 FD-194.1 km,FC-2.35 KA. Sohawal end relay details-M1-FD-30.2 km,FC-9.9 KA,M2 FD-31.45 km,FC-10.02 KA. Fault under Sohawal jurisdiction.* 22.04.2025 03:44:17 INDIA (60041608)** Kite threat at Loc No-531
CKT	400kV BALIA-SOHAHAL-1	OSFT	06-12-2024	10:58:00	06-12-2024	16:30:00	0.23	5.53	0.00	0.00	0.00		* 400KV BALIA-SOHAHAL-I* 06-12-24 10:58* 06-12-24 16:30* OSFT Taken under E/S/D to attend hot spot on R-ph jumper at loc 06
CKT	400kV BALIA-SOHAHAL-2	OSPT	02-12-2024	09:49:00	02-12-2024	19:53:00	0.25	5.53	0.35	0.00	0.00	99.26	
							0.42	10.07	0.00	0.00	0.00		* S/D taken for jumper rectification work by Sohawal.
CKT	400kV GORAKHPUR-BASTI(UPPTCL)-1	OSPD	10-12-2024	12:44:00	10-12-2024	19:09:00	0.27	0.00	0.00	0.00	6.42		* S/D taken for routine testing and other maintenance work by UPPTCL.
CKT	400kV GORAKHPUR-BASTI(UPPTCL)-1	OMSU	12-12-2024	12:02:00	12-12-2024	14:49:00	0.12	0.00	2.78	0.00	0.00		* Line tripped due to DC received at Gorakhpur end <(>&<)-> DT sent by UP Basti. Bus bar protection operated at Basti end.
							0.39	0.00	2.78	0.00	6.42	100.00	
CKT	400KV-GORAKHPUR-BASTI AC CKT 2 LINE	OSPD	12-12-2024	10:37:00	12-12-2024	22:19:00	0.49	0.00	0.00	0.00	11.70		* For checking wiring of LBB at 400 KV substation Basti by UPPTCL.
CKT	400KV-GORAKHPUR-BASTI AC CKT 2 LINE	OSPD	11-12-2024	16:12:00	11-12-2024	22:15:00	0.25	0.00	0.00	0.00	6.05		* S/D taken for routine testing and other maintenance work by UPPTCL.
							0.74	0.00	0.00	0.00	17.75	100.00	
CKT	400KV-BASTI-LUCKNOW-ACL-CKT1	OSPD	07-12-2024	11:04:00	08-12-2024	00:37:00	0.57	0.00	0.00	0.00	13.55		* S/D taken by UPPTCL for routine testing <(>&<)-> mentinacne work
CKT	400KV-BASTI-LUCKNOW-ACL-CKT1	OMSU	12-12-2024	12:02:00	12-12-2024	14:15:00	0.09	0.00	2.22	0.00	0.00		* Line tripped due to DC received at Lucknow end <(>&<)-> DT sent by UP Basti. Bus bar protection operated at Basti end.
CKT	400KV-BASTI-LUCKNOW-ACL-CKT1	OSFD	08-12-2024	15:57:00	08-12-2024	18:16:00	0.10	0.00	0.00	0.00	2.32		* E/S/D taken by UPPTCL for taking Line Reactor into service after replacement of faulty PRV at their end
							0.76	0.00	2.22	0.00	15.87	100.00	
CKT	400KV-BASTI-LUCKNOW-ACL-CKT2	OSPD	12-12-2024	10:30:00	12-12-2024	22:02:00	0.48	0.00	0.00	0.00	11.53		* For checking wiring of LBB at 400 KV substation Basti by UPPTCL.
CKT	400KV-BASTI-LUCKNOW-ACL-CKT2	OSPD	13-12-2024	11:48:00	13-12-2024	22:21:00	0.44	0.00	0.00	0.00	10.55		* 400KV LUCKNOW-BASTI(UP)-II* 13-12-24 11:48* 13-12-24 22:21* OSPD For checking wiring of LBB at 400 KV substation Basti by UPPTCL.
							0.92	0.00	0.00	0.00	22.08	100.00	
CKT	400kV BAREILY(UPPTCL)-BAREILY-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV BAREILY(UPPTCL)-BAREILY-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAREILY765-KASHIPUR(PTCUL)-1	LVRD	12-12-2024	00:03:00	12-12-2024	06:16:00	0.26	0.00	0.00	0.00	6.22		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly-420 KV
CKT	400kV BAREILY765-KASHIPUR(PTCUL)-1	LVRD	16-12-2024	23:52:00	17-12-2024	06:23:00	0.27	0.00	0.00	0.00	6.52		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly -416 KV
CKT	400kV BAREILY765-KASHIPUR(PTCUL)-1	OSPD	05-12-2024	12:44:00	05-12-2024	14:38:00	0.08	0.00	0.00	0.00	1.90		* 400KV BARLY(765)-KASHIPUR-I* 05-12-24 12:44* 05-12-24 14:38* OSPD Taken under S/d for installation of MFT at Kashipur under ADRS project
CKT	400kV BAREILY765-KASHIPUR(PTCUL)-1	LVRD	09-12-2024	01:32:00	09-12-2024	08:40:00	0.30	0.00	0.00	0.00	7.13		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly -420 KV
CKT	400kV BAREILY765-KASHIPUR(PTCUL)-1	LVRD	10-12-2024	23:39:00	11-12-2024	05:59:00	0.26	0.00	0.00	0.00	6.33		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV BAREILY765-KASHIPUR(PTCUL)-1	LVRD	10-12-2024	02:39:00	10-12-2024	06:17:00	0.15	0.00	0.00	0.00	3.63		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
							1.32	0.00	0.00	0.00	31.73	100.00	
CKT	400kV BAREILY765-KASHIPUR(PTCUL)-2	OSPD	06-12-2024	11:33:00	06-12-2024	13:26:00	0.08	0.00	0.00	0.00	1.88		* 400KV BARLY(765)-KASHIPUR-II* 06-12-24 11:33* 06-12-24 13:26 OSPD Taken under S/d for installation of MFT at Kashipur under ADRS project
							0.08	0.00	0.00	0.00	1.88	100.00	
CKT	400kV BAREILY-BAREILY 765KV-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAREILY-BAREILY 765KV-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAREILLY-MORADABAD(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BAREILLY-RAMPUR-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV JAULJIVI-DHAULIGANGA-1	OSPT	06-12-2024	11:40:00	06-12-2024	16:44:00	0.21	5.07	0.00	0.00	0.00		* 220KV DHAULIGANGA-JAULJIVI -1* 06-12-24 11:40* 06-12-24 16:44* OSPT Taken under S/d for line bay AMP work.
							0.21	5.07	0.00	0.00	0.00	99.32	
CKT	220kV JAULJIVI-DHAULIGANGA-2	OSPT	07-12-2024	10:55:00	07-12-2024	16:08:00	0.22	5.22	0.00	0.00	0.00		* S/D taken for Line Bay AMP work and compliance of regional SIR audit point.
							0.22	5.22	0.00	0.00	0.00	99.30	
CKT	400kV FATEHPUR-MAINPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV FATEHPUR-MAINPURI-2	LNCC	28-12-2024	02:17:00	28-12-2024	12:29:00	0.43	0.00	0.00	10.20	0.00		* Tripped on R-N fault.Fatehpur end detail- M-1 FD-243.4kms , F/C- 2.53 KA,Fault is in mainpuri jurisdiction* 22.04.2025 03:55:39 INDIA (60041608)* insulator decapping -863 due to Heavy dense fog.MHA Disaster Manaagement division heavy fog warning advisory No- 40-4/2017-DM-1(A) dated 29.12.24
							0.43	0.00	0.00	10.20	0.00	100.00	
CKT	400KV-FATEHPUR-PANKI-ACL-C1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-FATEHPUR-PANKI-ACL-C2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GORAKHPUR-GORAKHPUR(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GORAKHPUR-GORAKHPUR(UPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JEHTA(UPPTCL)-UNNAO(UPPTCL)-1	LVRD	18-12-2024	10:02:00	18-12-2024	17:56:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped on Voltage regulation as per NRLDC instruction
							0.33	0.00	0.00	0.00	7.90	100.00	
CKT	400kV JEHTA(UPPTCL)-UNNAO(UPPTCL)-2	OSPD	19-12-2024	10:03:00	19-12-2024	18:28:00	0.35	0.00	0.00	0.00	8.42		* S/D taken by UPPTCL for annual routine testing work.
							0.35	0.00	0.00	0.00	8.42	100.00	
CKT	400kV JAULJIVI-BAREILLY-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JAULJIVI-BAREILLY-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KANPUR-AGRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KANPUR-BALLABHGARH-1	LVRD	03-12-2024	00:14:00	03-12-2024	07:46:00	0.31	0.00	0.00	0.00	7.53		* H/T FOR V/R AS PER NRLDC INSTRUCTION
CKT	400kV KANPUR-BALLABHGARH-1	LVRD	02-12-2024	00:08:00	02-12-2024	06:23:00	0.26	0.00	0.00	0.00	6.25		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV KANPUR-BALLABHGARH-1	LVRD	01-12-2024	00:29:00	01-12-2024	08:02:00	0.32	0.00	0.00	0.00	7.55		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur -418 KV
CKT	400kV KANPUR-BALLABHGARH-1	OSFT	24-12-2024	14:22:00	24-12-2024	22:23:00	0.33	8.02	0.00	0.00	0.00		* E/S/D taken to attend hotspot in line isolator Y-ph at Ballabgharh end(NR-1).
CKT	400kV KANPUR-BALLABHGARH-1	LVRD	09-12-2024	01:34:00	09-12-2024	06:32:00	0.21	0.00	0.00	0.00	4.97		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur -418 KV
CKT	400kV KANPUR-BALLABHGARH-1	LVRD	07-12-2024	00:20:00	07-12-2024	06:45:00	0.27	0.00	0.00	0.00	6.42		* 400KV KNP-BLBGARH-I* 07-12-24 00:20* 07-12-24 06:45* LVRD Hand tripped on Voltage regulation as per NRLDC instruction. KNP -412 KV
CKT	400kV KANPUR-BALLABHGARH-1	LVRD	04-12-2024	00:24:00	04-12-2024	05:59:00	0.23	0.00	0.00	0.00	5.58		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur-418 KV

Standard of Performance data for the month of Dec-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

CKT	400kV KANPUR-BALLABHGARH-1	LVRD	27-12-2024	23:10:00	28-12-2024	08:01:00	0.37	0.00	0.00	0.00	8.85		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV KANPUR-BALLABHGARH-1	LVRD	29-12-2024	00:31:00	29-12-2024	07:09:00	0.28	0.00	0.00	0.00	6.63		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV KANPUR-BALLABHGARH-1	LVRD	27-12-2024	02:29:00	27-12-2024	09:17:00	0.28	0.00	0.00	0.00	6.80		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur -418 KV
CKT	400kV KANPUR-BALLABHGARH-1	LVRD	09-12-2024	21:57:00	10-12-2024	06:35:00	0.36	0.00	0.00	0.00	8.63		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV KANPUR-BALLABHGARH-1	LVRD	23-12-2024	02:10:00	23-12-2024	07:45:00	0.23	0.00	0.00	0.00	5.58		* 400KV KNP-BLBGARH-I 23-12-24 02:10 **** LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Knp-412 KV
CKT	400kV KANPUR-BALLABHGARH-1	LVRD	10-12-2024	23:32:00	11-12-2024	06:22:00	0.29	0.00	0.00	0.00	6.83		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
							3.74	8.02	0.00	0.00	81.62	98.92	
CKT	400kV KANPUR-BALLABHGARH-2	LVRD	11-12-2024	23:52:00	12-12-2024	06:10:00	0.26	0.00	0.00	0.00	6.30		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur-418 KV
CKT	400kV KANPUR-BALLABHGARH-2	LVRD	12-12-2024	23:58:00	13-12-2024	06:55:00	0.29	0.00	0.00	0.00	6.95		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur-418 KV
CKT	400kV KANPUR-BALLABHGARH-2	LVRD	15-12-2024	23:45:00	16-12-2024	07:42:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur -416 KV
							0.88	0.00	0.00	0.00	21.20	100.00	
CKT	400kV KANPUR-BALLABHGARH-3	LVRD	31-12-2024	23:04:00	31-12-2024	23:59:59	0.04	0.00	0.00	0.00	0.93		* Hand tripped on Voltage regulation as per NRLDC instruction. KNP -415 KV
CKT	400kV KANPUR-BALLABHGARH-3	LVRD	31-12-2024	01:35:00	31-12-2024	07:42:00	0.26	0.00	0.00	0.00	6.12		* 400KV KNP-BLBGARH-III 31-12-24 01:35 **** LVRD Hand tripped on Voltage regulation as per NRLDC instruction. KNP -415 KV
CKT	400kV KANPUR-BALLABHGARH-3	LVRD	29-12-2024	23:02:00	30-12-2024	06:29:00	0.31	0.00	0.00	0.00	7.45		* 400KV KNP-BLBGARH-III* 29-12-24 23:02* 30-12-24 06:29 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. KNP -415 KV
							0.61	0.00	0.00	0.00	14.50	100.00	
CKT	400kV KANPUR-KANPUR GIS-1	OSFT	23-12-2024	13:26:00	23-12-2024	18:33:00	0.21	5.12	0.00	0.00	0.00		* E/S/D taken for rectification of broken jumper at loc no. 56 under Kanpur TLM
CKT	400kV KANPUR-KANPUR GIS-1	LEFT	23-12-2024	03:21:00	23-12-2024	03:55:00	0.02	0.57	0.00	0.00	0.00		* 400KV KANPUR-KANPUR(GIS)-I* 23-12-24 03:21* 23-12-24 03:55 LEFT Line Auto reclosed successfully at 400 kv Kanpur end and tripped only from Kanpur GIS end on R-N fault . AFAS detail at Kanpur 400KV end- FD-21.3 KM F.C-4.5 KA. Kanpur GIS end Relay details- M1-F.D-1.0 KM FC-21.6 ka M2 -1.0 KM FC-21.1 KA. Fault in Kanpur jurisdiction.
							0.23	5.69	0.00	0.00	0.00	99.24	
CKT	400kV KANPUR-KANPUR GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LUCKNOW-JEHTA(UPPTCL)-1	OSPD	16-12-2024	11:05:00	16-12-2024	18:13:00	0.30	0.00	0.00	0.00	7.13		* S/d taken by UPPTCL for annual routine testing work.
							0.30	0.00	0.00	0.00	7.13	100.00	
CKT	400kV LUCKNOW-JEHTA(UPPTCL)-2	OSPD	17-12-2024	10:20:00	17-12-2024	17:47:00	0.31	0.00	0.00	0.00	7.45		* S/D taken by UPPTCL for annual routine testing work.
							0.31	0.00	0.00	0.00	7.45	100.00	
CKT	400kV LUCKNOW-LUCKNOW 765-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LUCKNOW-LUCKNOW 765-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LUCKNOW-LUCKNOW(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LUCKNOW-SHAHJAHANPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LUCKNOW-SHAHJAHANPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LUCKNOW-SULTANPUR(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LUCKNOW 765-KANPUR GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LUCKNOW 765-KANPUR GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LUCKNOW(UPPTCL)-BAREILLY-1	OSFT	27-12-2024	14:45:00	27-12-2024	17:06:00	0.10	2.35	0.00	0.00	0.00		* E/S/D taken to remove bird bite between loc no.262-263 by Shajahnpur TLM.
							0.10	2.35	0.00	0.00	0.00	99.68	
CKT	400kV MAINPURI-BALLABHGARH-1	LVRD	27-12-2024	23:11:00	28-12-2024	08:02:00	0.37	0.00	0.00	0.00	8.85		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	400kV MAINPURI-BALLABHGARH-1	LVRD	09-12-2024	02:14:00	09-12-2024	06:30:00	0.18	0.00	0.00	0.00	4.27		* Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri -416 KV
							0.55	0.00	0.00	0.00	13.12	100.00	
CKT	400kV MAINPURI-BALLABHGARH-2	LVRD	31-12-2024	01:20:00	31-12-2024	07:16:00	0.25	0.00	0.00	0.00	5.93		* 400KV BLBGRH-MAINPURI-II 31-12-24 01:20 **** LVRD Hand tripped on Voltage regulation as per NRLDC instruction. MNP -418 KV
CKT	400kV MAINPURI-BALLABHGARH-2	LVRD	07-12-2024	00:33:00	07-12-2024	06:32:00	0.25	0.00	0.00	0.00	5.98		* 400KV BLBGRH-MAINPURI-II* 07-12-24 00:33* 07-12-24 06:32 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. MNP -410 KV
CKT	400kV MAINPURI-BALLABHGARH-2	LVRD	15-12-2024	00:02:00	15-12-2024	07:01:00	0.29	0.00	0.00	0.00	6.98		* Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri -416 KV
CKT	400kV MAINPURI-BALLABHGARH-2	LVRD	19-12-2024	00:16:00	19-12-2024	06:11:00	0.25	0.00	0.00	0.00	5.92		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballabhagarh-418 KV
CKT	400kV MAINPURI-BALLABHGARH-2	LVRD	15-12-2024	23:46:00	16-12-2024	07:12:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri-418 KV
							1.35	0.00	0.00	0.00	32.24	100.00	
CKT	400KV-MAU-RASRA-ACL-CKT1	OSPD	08-12-2024	09:51:00	08-12-2024	16:42:00	0.29	0.00	0.00	0.00	6.85		* S/D taken by UPPTCL for CT tan delta testing and other maintenance work.
							0.29	0.00	0.00	0.00	6.85	100.00	
CKT	400kV ORAI-ORAI(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ORAI-ORAI(UPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RIHAND(NTPC)-ALLAHABAD-1	LART	08-12-2024	11:03:00	08-12-2024	11:03:00	0.00	0.00	0.00	0.00	0.00		* Auto-reclosed successfully on B-N fault. Allahabad Relay details: M1-FD-133.7 KM, FC-2.75 ka; M2-FD-134.9 KM, FC-2.787 KA, Zone-1 fault. Single end AFAS detail: M1-NA, M2-FD-137.08 KM, FC-2.8 ka, FA- 81.74 degree. Rihand Relay details: FD-146.6 KM, FC-2.37 ka. Fault is in Mirzapur TL jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RIHAND(NTPC)-ALLAHABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SAHAJAHANPUR-BAREILLY-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SAHAJAHANPUR-BAREILLY-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SINGRAULI(NTPC)-ALLAHABAD-1	OMSU	13-12-2024	17:02:00	13-12-2024	18:15:00	0.05	0.00	1.22	0.00	0.00		* 400KV SING-ALLD-I* 13-12-24 17:02* 13-12-24 18:15* LEFT Line tripped on R-Y fault. Allahabad end details-M1- 221 KM , FC-1.910 KA M2- 220 KM , FC-1.913 KA, Singrauli end details-M1- 7.22 KM, FC-17.68 KA . M-2 - 8.1 KM Fault under Shaktinagar jurisdiction.* 22.04.2025 04:03:48 INDIA (60041608)* kite with thread found* between Loc 34-35 on Middle Conductor (Y-Ph)
CKT	400kV SINGRAULI(NTPC)-ALLAHABAD-1	OSFD	13-12-2024	18:33:00	14-12-2024	00:05:00	0.23	0.00	0.00	0.00	5.53		* 400KV SING-ALLD-I* 13-12-24 18:33* 14-12-24 00:05* OSFD* Emergency hand tripped at Singrauli (NT) end to attend hot spot observed at dropper clamp of CT R-ph.
							0.28	0.00	1.22	0.00	5.53	100.00	
CKT	400kV SINGRAULI(NTPC)-ALLAHABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SINGRAULI(NTPC)-ALLAHABAD-3	LART	06-12-2024	14:02:00	06-12-2024	14:02:00	0.00	0.00	0.00	0.00	0.00		* 400KV SINGRAULI-ALLAHABAD -III 06-12-24 14:02 06-12-24 14:02 LART Autoreclose successfully on B-N fault. Allahabd end details M-1 FD-79.36 KM, FC-4.00 KA, M-2 FD-77.03 KM FC-4.05 KA Singrauli end details M-1 FD-114.4 KM, FC-2.48 KA ,M-2 FD-114.1 KM FC-2.485 KA. Fault in Mirzapur TLM Jurisdiction.

Standard of Performance data for the month of Dec-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

CKT	400kV SINGRAULI(NTPC)-ANPARA(NTPC)-1	LPRD	01-12-2024	00:00:01	31-12-2024	23:59:59	0.00	0.00	0.00	0.00	0.00	100.00	
							31.00	0.00	0.00	0.00	744.00		* Line manually opened from Anpara end only to restrict short circuit level in Singrauli-Anpara complex.
CKT	400kV SINGRAULI(NTPC)-FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV SINGRAULI(NTPC)-LUCKNOW(UPPTCL)-1	OSPD	21-12-2024	12:31:00	31-12-2024	23:59:59	10.48	0.00	0.00	0.00	251.48		* 400KV SING-LKO(UP)-I* 21-12-24 12:31* **** OSPD shutdown for diversion of line due to infringement of under construction Prayagraj inner ring road of NHAI.
							10.48	0.00	0.00	0.00	251.48	100.00	
CKT	400kV SINGRAULI(NTPC)-RIHAND(NTPC)-1	OSFD	10-12-2024	16:10:00	10-12-2024	17:10:00	0.04	0.00	0.00	0.00	1.00		* E/S/D taken by NTPC singrauli for BCU database uplodng.
							0.04	0.00	0.00	0.00	1.00	100.00	
CKT	400kV SINGRAULI(NTPC)-RIHAND(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV SINGRAULI(NTPC)-VINDHYACHAL-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV SINGRAULI(NTPC)-VINDHYACHAL-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOHAWAL-LUCKNOW-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV SOHAWAL-LUCKNOW-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VARANASI-ALLAHABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV-SAHUPURI-VARANASI-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-SAHUPURI-VARANASI-ACL-CKT2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VARANASI -SARNATH(UPPTCL)-1	LART	24-12-2024	11:14:00	24-12-2024	11:14:00	0.00	0.00	0.00	0.00	0.00		* Auto-reclosed successfully from both end on B-N fault. Varanasi Relay details: M1-FD-70.66 KM, FC-5.499 kA; M2-FD-84.48 KM, FC-5.417 kA. Sarnath Relay details: M1-26.8 KM, FC-5.537 kA, M2-FD-32.7 KM, FC-7.529 kA. AFAS-NA. Fault is in Varanasi jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VARANASI -SARNATH(UPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV AGRA-ALIGARH	GOVC	13-12-2024	13:06:00	13-12-2024	13:51:00	0.03	0.00	0.00	0.75	0.00		* 765KV AGRA-ALIGARH* 13-12-24 13:06* 13-12-24 13:51 GOVC Line tripped on overvoltage protection stage-1 at Aligarh end. DT received at Agra end.
CKT	765kV AGRA-ALIGARH	OSFT	15-12-2024	11:35:00	15-12-2024	21:15:00	0.40	9.67	0.00	0.00	0.00		* E/S/D taken under by Aligarh to attend SF6 leakage in line bay compartment.
CKT	765kV AGRA-ALIGARH	GOVC	03-12-2024	13:02:00	03-12-2024	13:56:00	0.04	0.00	0.00	0.90	0.00		* Line tripped due to over voltage satge-1 operated at Aligarh end.
CKT	765kV AGRA-ALIGARH	GOVC	04-12-2024	13:08:00	04-12-2024	15:04:00	0.08	0.00	0.00	1.93	0.00		* Line tripped due to over voltage stage-1 operated at Aligarh end.
							0.55	9.67	0.00	3.58	0.00	98.69	
CKT	765kV ALIGARH-GREATER NOIDA(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV ALIGARH-JHATIKARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BALIA-LUCKNOW			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BALIA-VARANASI	LART	13-12-2024	15:53:00	13-12-2024	15:53:00	0.00	0.00	0.00	0.00	0.00		* 765KV VARANASI-BALIA* 13-12-24 15:53* 13-12-24 15:53 LART Line Auto reclosed successfully on R-N fault. Ballia end details-M1- 24.5KM , Ir-9.3KA M2- 25 KM , Ir-9.3 KA, Varanasi end details-M1- 125 KM , Ir-5.115 KA M2- 125 KM , Ir-5.205 KA. AFAS Ballia single end-M1-FD-21.04 KM,FC-9.7 KA,FA-80.31degree, M2-FD-21.77 KM,FC-9.6 KA,FA-79.69 degree TWFL-NA. Fault is in Azamgarh Jurisdiction.
CKT	765kV BALIA-VARANASI	LART	05-12-2024	16:53:00	05-12-2024	16:53:00	0.00	0.00	0.00	0.00	0.00		* 765KV VARANASI-BALIA 05-12-24 16:53 05-12-24 16:53 LART Autoreclose successfully on R-N fault. Varanasi end details M-1 FD-124.6 KM, FC-5.127 KA ,M-2 FD-124.8 KM FC-5.143 KA Ballia end details M-1 FD-24.76 KM, FC-9.251 KA ,M-2 FD-25.3 KM FC-9.314 KA. As per Ballia details Fault in Ballia TLM Jurisdiction.As per Varanasi end details Fault in Azamagrh TLM Jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV FATEHPUR-AGRA-1	LVRD	01-12-2024	00:00:01	01-12-2024	07:54:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -780 KV
CKT	765kV FATEHPUR-AGRA-1	LVRD	17-12-2024	22:04:00	18-12-2024	06:36:00	0.36	0.00	0.00	0.00	8.53		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -788 KV
CKT	765kV FATEHPUR-AGRA-1	LVRD	21-12-2024	22:37:00	22-12-2024	05:54:00	0.30	0.00	0.00	0.00	7.28		* 765KV AGRA-FATEHPUR-I* 21-12-24 22:37* 22-12-24 05:54 LVRD Hand tripped on Voltage regulation as per NRLDC Instruction. Agra-785 KV
CKT	765kV FATEHPUR-AGRA-1	LVRD	25-12-2024	21:39:00	26-12-2024	06:31:00	0.37	0.00	0.00	0.00	8.87		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	765kV FATEHPUR-AGRA-1	LVRD	19-12-2024	23:25:00	20-12-2024	07:49:00	0.35	0.00	0.00	0.00	8.40		* Hand tripped on Voltage regulation as per NRLDC Instruction. Agra-795 KV
CKT	765kV FATEHPUR-AGRA-1	LNCC	29-12-2024	07:13:00	29-12-2024	19:13:00	0.50	0.00	0.00	12.00	0.00		* 765KV AGRA-FATEHPUR-I* 29-12-24 07:13* 29-12-24 19:13* LEFT Line tripped due to insulator decapped at Loc no 35. Fatehpur end details- FD-11.6 KM. FC-5.78 KA.* 22.04.2025 04:17:39 INDIA (60041608)* insulator decapping at Loc No-35 due to heavy dense fog .MHA Disaster Management division heavy fog warning advisory No- 40-4/2017-DM-1(A) dated 29.12.24
CKT	765kV FATEHPUR-AGRA-1	LVRD	22-12-2024	21:38:00	23-12-2024	06:58:00	0.39	0.00	0.00	0.00	9.33		* 765KV AGRA-FATEHPUR-I* 22-12-24 21:38 **** LVRD Hand tripped on Voltage regulation as per NRLDC Instruction. Agra-783 KV
CKT	765kV FATEHPUR-AGRA-1	LVRD	10-12-2024	23:23:00	11-12-2024	05:40:00	0.26	0.00	0.00	0.00	6.28		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	765kV FATEHPUR-AGRA-1	LVRD	15-12-2024	20:51:00	16-12-2024	06:17:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -786 KV
CKT	765kV FATEHPUR-AGRA-1	LVRD	23-12-2024	23:45:00	24-12-2024	07:09:00	0.31	0.00	0.00	0.00	7.40		* Hand tripped on Voltage regulation as per NRLDC Instruction. Agra -780 KV
CKT	765kV FATEHPUR-AGRA-1	LVRD	13-12-2024	21:49:00	14-12-2024	06:00:00	0.34	0.00	0.00	0.00	8.18		* 765KV AGRA-FATEHPUR-I 13-12-24 21:49 14-12-24 06:00 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -792 KV
CKT	765kV FATEHPUR-AGRA-1	LVRD	27-12-2024	20:48:00	28-12-2024	07:28:00	0.44	0.00	0.00	0.00	10.67		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	765kV FATEHPUR-AGRA-1	LVRD	08-12-2024	20:47:00	09-12-2024	08:17:00	0.48	0.00	0.00	0.00	11.50		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -790 KV
CKT	765kV FATEHPUR-AGRA-1	LVRD	07-12-2024	00:23:00	07-12-2024	06:26:00	0.25	0.00	0.00	0.00	6.05		* 765KV AGRA-FATEHPUR-I* 07-12-24 00:23* 07-12-24 06:26* LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -790 KV
CKT	765kV FATEHPUR-AGRA-1	LVRD	04-12-2024	21:27:00	05-12-2024	06:35:00	0.38	0.00	0.00	0.00	9.13		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -795 KV
CKT	765kV FATEHPUR-AGRA-1	LVRD	02-12-2024	21:40:00	03-12-2024	06:03:00	0.35	0.00	0.00	0.00	8.38		* H/T FOR V/R AS PER NRLDC INSTRUCTION
CKT	765kV FATEHPUR-AGRA-1	LVRD	28-12-2024	23:09:00	29-12-2024	07:13:00	0.34	0.00	0.00	0.00	8.07		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	765kV FATEHPUR-AGRA-1	LVRD	30-12-2024	23:00:00	31-12-2024	07:51:00	0.37	0.00	0.00	0.00	8.85		* 765KV AGRA-FATEHPUR-I 30-12-24 23:00 **** LVRD Hand tripped on Voltage regulation as per NRLDC instruction. FTP -789 KV
							6.51	0.00	0.00	12.00	144.25	100.00	
CKT	765kV FATEHPUR-AGRA-2	LVRD	06-12-2024	01:09:00	06-12-2024	06:14:00	0.21	0.00	0.00	0.00	5.08		* 765KV AGRA-FATEHPUR-I* 06-12-24 01:09* 06-12-24 06:14* LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -795 KV
CKT	765kV FATEHPUR-AGRA-2	LVRD	03-12-2024	23:12:00	04-12-2024	06:27:00	0.30	0.00	0.00	0.00	7.25		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -795 KV
CKT	765kV FATEHPUR-AGRA-2	OSFT	30-12-2024	11:40:00	30-12-2024	19:00:00	0.31	7.33	0.00	0.00	0.00		* 312313 765KV AGRA-FATEHPUR-II 30-12-24 11:40 30-12-24 19:00 OSFT Taken under E/S/D to attend hot spot in line isolator at Agra end.= 65KV AGRA-FATEHPUR-II 30-12-24 11:40 30-12-24 19:00 OSFT Taken under E/S/D to attend hot spot in line isolator at Agra end.
CKT	765kV FATEHPUR-AGRA-2	LART	29-12-2024	05:54:00	29-12-2024	05:54:00	0.00	0.00	0.00	0.00	0.00		* Auto reclosed successfully on B-N fault.TWFL Agra - 95.09km.TWFL fatehpur- 239.37 km.Afas single end fatehpur- 202.148 kms , 3.16 KA.* Fault in Auraiya jurisdiction

Standard of Performance data for the month of Dec-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

CKT	765kV FATEHPUR-AGRA-2	LART	28-12-2024	02:05:00	28-12-2024	02:05:00	0.00	0.00	0.00	0.00	0.00		* Auto reclosed successfully on B-N fault.TWFL reading from Agra- 95.04 kms.M-1 - 89.4 kms, 7.42 KA.M-2- 90kms, 7.24 KA .Fatehpur-M-1- 222.7 kms, 2.81 kA.M-2- 223.5 kms, 2.917 Ka.TWFL- 239.53 Kms.Fault in auraiya jurisdiction
CKT	765kV FATEHPUR-AGRA-2	LVRD	29-12-2024	22:09:00	30-12-2024	07:02:00	0.37	0.00	0.00	0.00	8.88		* 765KV AGRA-FATEHPUR-II* 29-12-24 22:09* 30-12-24 07:02 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -789 KV
CKT	765kV FATEHPUR-AGRA-2	LVRD	31-12-2024	22:36:00	31-12-2024	23:59:59	0.06	0.00	0.00	0.00	1.40		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -780 KV
CKT	765kV FATEHPUR-AGRA-2	LVRD	26-12-2024	21:54:00	27-12-2024	07:51:00	0.42	0.00	0.00	0.00	9.95		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -789 KV
CKT	765kV FATEHPUR-AGRA-2	LVRD	13-12-2024	00:19:00	13-12-2024	06:38:00	0.26	0.00	0.00	0.00	6.32		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -794 KV
CKT	765kV FATEHPUR-AGRA-2	LVRD	09-12-2024	21:20:00	10-12-2024	06:20:00	0.38	0.00	0.00	0.00	9.00		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
CKT	765kV FATEHPUR-AGRA-2	LVRD	14-12-2024	21:30:00	15-12-2024	07:26:00	0.41	0.00	0.00	0.00	9.93		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -790 KV
CKT	765kV FATEHPUR-AGRA-2	LVRD	16-12-2024	22:02:00	17-12-2024	06:05:00	0.34	0.00	0.00	0.00	8.05		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -788 KV
CKT	765kV FATEHPUR-AGRA-2	LVRD	24-12-2024	22:43:00	25-12-2024	07:10:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -785 KV
CKT	765kV FATEHPUR-AGRA-2	LVRD	21-12-2024	00:45:00	21-12-2024	06:52:00	0.26	0.00	0.00	0.00	6.12		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra-795 KV
CKT	765kV FATEHPUR-AGRA-2	LVRD	18-12-2024	22:15:00	19-12-2024	06:45:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped on Voltage regulation as per NRLDC instruction
CKT	765kV FATEHPUR-AGRA-2	LVRD	07-12-2024	22:33:00	08-12-2024	06:08:00	0.32	0.00	0.00	0.00	7.58		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -790 KV
CKT	765kV FATEHPUR-AGRA-2	LVRD	11-12-2024	21:22:00	12-12-2024	06:45:00	0.39	0.00	0.00	0.00	9.38		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -790 KV
CKT	765kV FATEHPUR-AGRA-2	OSFT	23-12-2024	11:13:00	23-12-2024	19:39:00	0.35	8.43	0.00	0.00	0.00		* E/S/D taken to attend hotspot in line isolator at Agra end.
CKT	765kV FATEHPUR-AGRA-2	LVRD	01-12-2024	22:02:00	02-12-2024	06:35:00	0.36	0.00	0.00	0.00	8.55		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
						5.44	15.76	0.00	0.00	0.00	114.44	97.88	
CKT	765kV KANPUR-ALIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV LUCKNOW-BAREILY	OSPT	09-12-2024	10:04:00	09-12-2024	18:44:00	0.36	8.67	0.00	0.00	0.00		* S/D for attending Shutdown nature defect
CKT	765kV LUCKNOW-BAREILY	OSFT	11-12-2024	13:46:00	11-12-2024	14:44:00	0.04	0.97	0.00	0.00	0.00		* Line emergency hand tripped due to 708CB Y phase stuck at Lucknow.
						0.40	9.64	0.00	0.00	0.00	0.00	98.71	
CKT	765kV ORAI-ALIGARH-1	LVRD	09-12-2024	01:52:00	09-12-2024	07:36:00	0.24	0.00	0.00	0.00	5.73		* Hand tripped on Voltage regulation as per NRLDC instruction. Orai -802 KV
CKT	765kV ORAI-ALIGARH-1	LVRD	04-12-2024	02:34:00	04-12-2024	07:23:00	0.20	0.00	0.00	0.00	4.82		* Hand tripped on Voltage regulation as per NRLDC instruction. Orai -806 KV
CKT	765kV ORAI-ALIGARH-1	LVRD	27-12-2024	23:47:00	28-12-2024	08:04:00	0.35	0.00	0.00	0.00	8.28		* H/T FOR V/R AS PER NRLDC INSTRUCTION.
						0.79	0.00	0.00	0.00	0.00	18.83	100.00	
CKT	765kV ORAI-ALIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV VARANASI-FATEHPUR	LART	17-12-2024	19:59:00	17-12-2024	19:59:00	0.00	0.00	0.00	0.00	0.00		* A/R operated successfully from both end due to Y-N fault.Varanasi end relay details M1: FD-188.9Km, FD-4.035KA, M2: FD-189.1Km, FD-3.99KA. TWFL-NA.Fatehpur end relay details:M1: 19.32 KM, 10.02 KA,M2: FD-19.4 KM, FC-9.38 KA. TWFL-NA.Fault under Fatehpur jurisdiction.
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV VARANASI-KANPUR GIS-1	OSFT	08-12-2024	11:38:00	08-12-2024	16:01:00	0.18	4.38	0.00	0.00	0.00		* E/S/D taken for rectification of broken conductor of Jumper by Varanasi TLM.
						0.18	4.38	0.00	0.00	0.00	0.00	99.41	
CKT	765kV VARANASI-KANPUR GIS-2	OSFT	10-12-2024	14:09:00	10-12-2024	19:30:00	0.22	5.35	0.00	0.00	0.00		* E/S/D taken for replacement of damaged CLR insulator at loc no.846.
						0.22	5.35	0.00	0.00	0.00	0.00	99.28	
CKT	BALIA HVDC-AGZRH-DCNEUTRAL-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	RIHAND HVDC-CHAPKI-DCNEUTRAL-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,LR OF BHIWADI-1 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,LR OF FATEHPUR-2 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF FATEHPUR-2 AT ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF FATEHPUR-1 AT ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF KANPUR AT ALIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SOHAWAL-2 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SOHAWAL-1 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF LUCKNOW-1 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF GAYA-1 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF MEERUT-1 AT BAREILLY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF MEERUT-2 AT BAREILLY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AGRA-1 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF LUCKNOW-2 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF LUCKNOW-1 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,LR OF BASTI-1 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,LR OF BASTI-2 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF MOTIHARI-1 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF MOTIHARI-2 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	21MVAR LINE REACTOR SPARE AT JAULJIVI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR SWLR OF BAREILLY-1 AT JAULJIVI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR SWLR OF BAREILLY-2 AT JAULJIVI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Dec-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

								0.00	0.00	0.00	0.00	0.00	100.00		
LNR	330MVAR,SWLR OF ALIGARH AT KANPUR 765			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	100.00		
								0.00	0.00	0.00	0.00	0.00	100.00		
LNR	63MVAR,SWLR OF BASTI-2 AT LUCKNOW			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	100.00		
								0.00	0.00	0.00	0.00	0.00	100.00		
LNR	63MVAR,SWLR OF BASTI-1 AT LUCKNOW			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	100.00		
								0.00	0.00	0.00	0.00	0.00	100.00		
LNR	240MVAR,SWLR OF BALLIA-1 AT LUCKNOW 765			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	100.00		
								0.00	0.00	0.00	0.00	0.00	100.00		
LNR	240MVAR,SWLR OF BAREILY-1 AT LUCKNOW 765			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	100.00		
								0.00	0.00	0.00	0.00	0.00	100.00		
LNR	50MVAR,SWLR OF BALIA-1 AT SOHAWAL			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	100.00		
								0.00	0.00	0.00	0.00	0.00	100.00		
LNR	50MVAR,SWLR OF BALIA-2 AT SOHAWAL			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	100.00		
								0.00	0.00	0.00	0.00	0.00	100.00		
LNR	240MVAR,SWLR OF KANPUR-1 AT VARANASI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	100.00		
								0.00	0.00	0.00	0.00	0.00	100.00		
LNR	240MVAR,SWLR OF KANPUR-2 AT VARANASI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	100.00		
								0.00	0.00	0.00	0.00	0.00	100.00		
STATCOM	-300/+300 MVAR STATCOM AT LUCKNOW 765			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	100.00		
								0.00	0.00	0.00	0.00	0.00	100.00		
VALVE_HALL	800KV AGRA-BISWANATHCHARIALI POLE-1	LART	24-12-2024	15:02:00	24-12-2024	15:02:00	0.00	0.00	0.00	0.00	0.00	0.00			* DC transient fault occurred. FD from Agra-1363.9 km, FD from BNC-410.7 km, Tower No. 1078/A-3(81/0). Fault is in ER-2 jurisdiction.
VALVE_HALL	800KV AGRA-BISWANATHCHARIALI POLE-1	LPRD	02-12-2024	17:24:00	02-12-2024	18:31:00	0.05	0.00	0.00	0.00	0.00	1.12			* H/T FOR P/R AS PER NRLDC INSTRUCTION
VALVE_HALL	800KV AGRA-BISWANATHCHARIALI POLE-1	OSPD	21-12-2024	08:16:00	21-12-2024	20:26:00	0.51	0.00	0.00	0.00	0.00	12.17			* 800KV HVDC AGRA-BNC POLE-I* 21-12-24 08:16* 21-12-24 20:26 OSPD For stringing work of 765kV S/C (Quad) Mainpuri - Bara Ckt-1 transmission Line(Req by UP)
VALVE_HALL	800KV AGRA-BISWANATHCHARIALI POLE-1	OMSU	24-12-2024	17:54:00	24-12-2024	19:35:00	0.07	0.00	1.68	0.00	0.00	0.00			* E/S/D taken by ER-2 for removal of kite and kite thread from jumper at tower no. 1074.
VALVE_HALL	800KV AGRA-BISWANATHCHARIALI POLE-1	OSPD	20-12-2024	08:17:00	20-12-2024	20:52:00	0.52	0.00	0.00	0.00	0.00	12.58			* For stringing work of 765kV S/C (Quad) Mainpuri - Bara Ckt-1 transmission Line(Req by UP)
							1.15	0.00	1.68	0.00	0.00	25.87	100.00		
VALVE_HALL	800KV AGRA-BISWANATHCHARIALI POLE-2	LPRD	02-12-2024	17:24:00	02-12-2024	18:34:00	0.05	0.00	0.00	0.00	0.00	1.17			* H/T FOR P/R AS PER NRLDC INSTRUCTION
VALVE_HALL	800KV AGRA-BISWANATHCHARIALI POLE-2	OSPD	21-12-2024	08:17:00	21-12-2024	20:28:00	0.51	0.00	0.00	0.00	0.00	12.18			* 800KV HVDC AGRA-BNC POLE-II 21-12-24 08:17 21-12-24 20:28 OSPD For stringing work of 765kV S/C (Quad)

Standard of Performance data for the month of Dec-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

XMER	315MVA,400/220kV ICT-1 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-2 AT AGRA	GOFC	14-12-2024	03:52:00	14-12-2024	05:23:00	0.06	0.00	0.00	1.52	0.00	100.00	* 315MVA ICT-II AGRA* 14-12-24 03:52* 14-12-24 05:23* GOFC* Tripped on MV overexcitation (V/f protection operated) at Agra .
							0.06	0.00	0.00	1.52	0.00		
XMER	315MVA,400/220kV ICT-1 AT ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT ALLAHABAD	OSPT	06-12-2024	09:44:00	06-12-2024	21:25:00	0.49	11.68	0.00	0.00	0.00		* 315MVA ICT-II ALLAHABAD* 06-12-24 09:44* 06-12-24 21:25* OSPT Taken under S/d for ICT Main Bays(406 and 202) LBB retrofitting works.
							0.49	11.68	0.00	0.00	0.00	98.43	
XMER	315MVA,400/220kV ICT-3 AT ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT ALIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT ALIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BAREILLY 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BAREILLY 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	105MVA,400/220kV ICT-SPARE AT JAULJIVI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT JAULJIVI	OSPT	09-12-2024	11:20:00	09-12-2024	22:36:00	0.47	11.27	0.00	0.00	0.00		* S/D TAKEN For AMP work.
							0.47	11.27	0.00	0.00	0.00	98.49	
XMER	315MVA,400/220kV ICT-2 AT JAULJIVI	OSPT	11-12-2024	09:49:00	11-12-2024	22:19:00	0.52	12.50	0.00	0.00	0.00		* For AMP work.
							0.52	12.50	0.00	0.00	0.00	98.32	
XMER	1500MVA,765/400kV ICT-1 AT KANPUR GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT KANPUR GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT LUCKNOW			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT LUCKNOW			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT LUCKNOW 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT LUCKNOW 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MAINPURI	OSPT	23-12-2024	10:14:00	23-12-2024	19:52:00	0.40	9.63	0.00	0.00	0.00		* S/D taken for AMP work.
							0.40	9.63	0.00	0.00	0.00	98.71	
XMER	315MVA,400/220kV ICT-2 AT MAINPURI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MAINPURI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1000MVA,765/400kV ICT-1 AT ORAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1000MVA,765/400kV ICT-2 AT ORAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	100MVA,220/132kV ICT-2 AT PITHORAGARH	OSPT	20-12-2024	09:14:00	20-12-2024	17:54:00	0.36	8.67	0.00	0.00	0.00		* For AMP Work.
							0.36	8.67	0.00	0.00	0.00	98.84	
XMER	100MVA,220/132kV ICT-1 AT PITHORAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	100MVA,220/132kV ICT-1 AT RAIBAREILLY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	200MVA,220/132kV ICT-2 AT RAIBAREILLY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	200MVA,220/132kV ICT-3 AT RAIBAREILLY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SHAHJAHANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Dec-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

XMER	500MVA,400/220kV ICT-2 AT SHAHJAHANPUR	OSPT	21-12-2024	09:02:00	21-12-2024	17:05:00	0.00	0.00	0.00	0.00	0.00	100.00	* 500MVA ICT-II SHAHJHNPR* 21-12-24 09:02* 21-12-24 17:05* OSPT For AMP Work.
							0.34	8.05	0.00	0.00	0.00	98.92	
XMER	100MVA,220/132kV ICT-1 AT SITARGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	100MVA,220/132kV ICT-2 AT SITARGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	100MVA,220/132kV ICT-3 AT SITARGANJ	OSPT	02-12-2024	10:03:00	02-12-2024	21:35:00	0.48	11.53	0.00	0.00	0.00		* S/D taken for AMP work.
							0.48	11.53	0.00	0.00	0.00	98.45	
XMER	315MVA,400/220kV ICT-1 AT SOHAWAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SOHAWAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOHAWAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	