

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-1 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT AGRA	SVRD	12-11-2024	09:40:00	12-11-2024	14:06:00	0.19	0.00	0.00	0.00	4.43		* 240MVAR B/Reactor-I AGRA-765 12-11-24 09:40 12-11-24 14:06 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -755 KV
BSR	240MVAR,BUS REACTOR-1 AT AGRA	SVRD	23-11-2024	09:47:00	23-11-2024	13:28:00	0.15	0.00	0.00	0.00	3.68		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	240MVAR,BUS REACTOR-1 AT AGRA	SVRD	29-11-2024	08:34:00	29-11-2024	16:01:00	0.31	0.00	0.00	0.00	7.45		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra-755 KV
							0.65	0.00	0.00	0.00	15.56	100.00	
BSR	125MVAR,BUS REACTOR-2 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	08-11-2024	09:50:00	08-11-2024	19:47:00	0.42	0.00	0.00	0.00	9.95		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	21-11-2024	09:18:00	21-11-2024	13:17:00	0.17	0.00	0.00	0.00	3.98		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh -762KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	23-11-2024	09:36:00	23-11-2024	13:15:00	0.15	0.00	0.00	0.00	3.65		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	25-11-2024	08:32:00	25-11-2024	13:36:00	0.21	0.00	0.00	0.00	5.07		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh-753 KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	29-11-2024	09:17:00	29-11-2024	13:44:00	0.19	0.00	0.00	0.00	4.45		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh -755KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	26-11-2024	09:03:00	26-11-2024	20:04:00	0.46	0.00	0.00	0.00	11.02		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh-753 KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	30-11-2024	09:39:00	30-11-2024	13:39:00	0.17	0.00	0.00	0.00	4.00		* Hand tripped on Voltage regulation as per NRLDC instruction. Aligarh-753KV
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	06-11-2024	09:35:00	06-11-2024	19:30:00	0.41	0.00	0.00	0.00	9.92		* Hand tripped on Voltage regulation as per NRLDC instruction.
BSR	330MVAR,BUS REACTOR-1 AT ALIGARH	SVRD	12-11-2024	09:40:00	14-11-2024	01:13:00	1.65	0.00	0.00	0.00	39.55		* HT ON VR
							3.83	0.00	0.00	0.00	91.59	100.00	
BSR	330MVAR,BUS REACTOR-2 AT ALIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT BALLIA	SVRD	01-11-2024	00:00:01	15-11-2024	01:59:00	14.08	0.00	0.00	0.00	337.98		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballia -750 KV
BSR	240MVAR,BUS REACTOR-1 AT BALLIA	SVRD	25-11-2024	09:31:00	26-11-2024	00:59:00	0.64	0.00	0.00	0.00	15.47		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballia -754 KV
BSR	240MVAR,BUS REACTOR-1 AT BALLIA	SVRD	30-11-2024	09:37:00	30-11-2024	22:55:00	0.55	0.00	0.00	0.00	13.30		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballia-748KV
							15.27	0.00	0.00	0.00	366.75	100.00	
BSR	125MVAR,BUS REACTOR-2 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT BALLIA	SVRD	23-11-2024	09:26:00	23-11-2024	22:27:00	0.54	0.00	0.00	0.00	13.02		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	240MVAR,BUS REACTOR-2 AT BALLIA	SVRD	24-11-2024	10:44:00	25-11-2024	00:38:00	0.58	0.00	0.00	0.00	13.90		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	240MVAR,BUS REACTOR-2 AT BALLIA	SVRD	26-11-2024	07:47:00	28-11-2024	00:18:00	1.69	0.00	0.00	0.00	40.52		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballia -754 KV
							2.81	0.00	0.00	0.00	67.44	100.00	
BSR	125MVAR,BUS REACTOR-3 AT BALLIA	SVRD	01-11-2024	00:00:01	27-11-2024	22:22:00	26.93	0.00	0.00	0.00	646.37		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballia -392KV
							26.93	0.00	0.00	0.00	646.37	100.00	
BSR	125MVAR,BUS REACTOR-4 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT BAREILLY 765	SVRD	29-11-2024	08:34:00	29-11-2024	20:05:00	0.48	0.00	0.00	0.00	11.52		* Hand tripped on Voltage regulation as per NRLDC instruction. Bareilly -750KV
							0.48	0.00	0.00	0.00	11.52	100.00	
BSR	80MVAR,BUS REACTOR-1 AT BAREILLY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	100MVAR,BUS REACTOR-2 AT BAREILLY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-1 AT FATEHPUR	SVRD	12-11-2024	09:48:00	12-11-2024	13:52:00	0.17	0.00	0.00	0.00	4.07		* 311045 330MVAR B/Reactor-I FTHPR-765 12-11-24 09:48 12-11-24 13:52 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Fatehpur -760 KV
							0.17	0.00	0.00	0.00	4.07	100.00	
BSR	125MVAR,BUS REACTOR-2 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	25MVAR,BUS REACTOR-1 AT JAULJI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT KANPUR(GIS)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT KANPUR(GIS)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT KANPUR(GIS)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT KANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT LUCKNOW			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT LUCKNOW			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT LUCKNOW 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	15-11-2024	09:42:00	15-11-2024	19:40:00	0.42	0.00	0.00	0.00	9.97		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	21-11-2024	09:12:00	21-11-2024	14:35:00	0.22	0.00	0.00	0.00	5.38		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow -760KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	23-11-2024	09:29:00	23-11-2024	13:18:00	0.16	0.00	0.00	0.00	3.82		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	16-11-2024	09:24:00	17-11-2024	02:24:00	0.71	0.00	0.00	0.00	17.00		* H/T FOR V/R AS PER NRLDC INSTRUCTION
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	27-11-2024	09:29:00	27-11-2024	22:02:00	0.52	0.00	0.00	0.00	12.55		* 240MVAR B/Reactor-I LUCKNOW-765* 27-11-24 09:29* 27-11-24 22:02 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-780 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	26-11-2024	09:03:00	26-11-2024	13:44:00	0.20	0.00	0.00	0.00	4.68		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-755 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	25-11-2024	09:30:00	26-11-2024	01:15:00	0.66	0.00	0.00	0.00	15.75		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-755 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	22-11-2024	09:19:00	22-11-2024	15:38:00	0.26	0.00	0.00	0.00	6.32		* Hand tripped on voltage regulation as per NRLDC instruction
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	30-11-2024	08:52:00	30-11-2024	15:41:00	0.28	0.00	0.00	0.00	6.82		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-748KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	28-11-2024	09:45:00	28-11-2024	15:18:00	0.23	0.00	0.00	0.00	5.55		* 240MVAR B/Reactor-I LUCKNOW-765* 28-11-24 09:45* 28-11-24 15:18 SVRD Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-780 KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	29-11-2024	09:23:00	29-11-2024	13:50:00	0.19	0.00	0.00	0.00	4.45		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow-756KV
BSR	240MVAR,BUS REACTOR-1 AT LUCKNOW 765	SVRD	10-11-2024	09:53:00	10-11-2024	22:01:00	0.51	0.00	0.00	0.00	12.13		* Hand tripped on Voltage regulation as per NRLDC instruction. Lucknow765 -755 KV
							4.36	0.00	0.00	0.00	104.42	100.00	
BSR	125MVAR,BUS REACTOR-1 AT MAINPURI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-1 AT ORAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-2 AT ORAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	25MVAR,BUS REACTOR-1 AT PITHORAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT SHAHJAHANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR,BUS REACTOR-1 AT SOHAWAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-2 AT SOHAWAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	93MVAR,BUS REACTOR-2 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	93MVAR,BUS REACTOR-1 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-4 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-1 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-2 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	Electrode Line (AGRA HVDC)-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	Electrode Line (AGRA HVDC)-CKT2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	132 KV MAU-BALIA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV AGRA-BHARATPUR(RRVNPL)	OSFT	22-11-2024	13:56:00	22-11-2024	18:42:00	0.20	4.77	0.00	0.00	0.00		* E/S/D taken for rectification of broken pilot insulator at Loc No. 106.
							0.20	4.77	0.00	0.00	0.00	99.34	
CKT	220KV-AGRA-KIRAWALI(UP)-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV ALLAHABAD-JHUSI(UPPTCL)	LCSD	21-11-2024	11:22:00	27-11-2024	17:25:00	6.25	0.00	0.00	0.00	150.05		* S/d taken for Nhai diversion work
							6.25	0.00	0.00	0.00	150.05	100.00	
CKT	220kV ALLAHABAD-REWA ROAD(UPPTCL)-1	OSPT	19-11-2024	12:02:00	19-11-2024	19:21:00	0.31	7.32	0.00	0.00	0.00		* 220KV ALLD-REWA RD-I 19-11-24 12:02 19-11-24 19:21 OSPT For LBB retrofitment works at Prayagraj SS.
							0.31	7.32	0.00	0.00	0.00	98.98	
CKT	220kV ALLAHABAD-REWA ROAD(UPPTCL)-2	OSPT	23-11-2024	10:37:00	23-11-2024	18:45:00	0.34	8.13	0.00	0.00	0.00		* S/D taken for LBB retrofitment works at Allahabad substation.
							0.34	8.13	0.00	0.00	0.00	98.87	
CKT	220KV-AURAIYA(NT)-SAIFAI(UP)-ACL-CKT1	LEFT	16-11-2024	15:19:00	16-11-2024	16:47:00	0.06	1.47	0.00	0.00	0.00		* Tripped on B-N fault. Saifai end details M1:- FC=2.31 KA Distance 44.5 KM ; M2:- FC=2.32 KA* Distance=49.49 KM. Fault under Auraiya jurisdiction.
							0.06	1.47	0.00	0.00	0.00	99.80	
CKT	220kV AURAIYA(NTPC)-SIKANDRA(UPPTCL)-1	OSPT	26-11-2024	09:35:00	26-11-2024	19:10:00	0.40	9.58	0.00	0.00	0.00		* S/D for rectification of S/D nature defects.
CKT	220kV AURAIYA(NTPC)-SIKANDRA(UPPTCL)-1	OSFD	04-11-2024	15:00:00	04-11-2024	17:49:00	0.12	0.00	0.00	0.00	2.82		* 220KV AUR-SIKANDARA-I 04-11-24 15:00 04-11-24 17:49 OSFD E/S/D taken by UPPLC for attending red hotspot in R PHASE CT at Sikandara end.
							0.52	9.58	0.00	0.00	2.82	98.67	
CKT	220kV FATEHPUR-FATEHPUR(UPPTCL)-1	OSPD	30-11-2024	11:13:00	30-11-2024	16:23:00	0.22	0.00	0.00	0.00	5.17		* S/D taken by UPPTCL for Routine testing/maintenance work .
							0.22	0.00	0.00	0.00	5.17	100.00	
CKT	220kV FATEHPUR-FATEHPUR(UPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV FATEHPUR-KANPUR SOUTH(UPPTCL)	OSFD	06-11-2024	12:27:00	06-11-2024	17:00:00	0.19	0.00	0.00	0.00	4.55		* E/S/D taken by UPPTCL for attending TC-2 unhealthy alarm.
							0.19	0.00	0.00	0.00	4.55	100.00	
CKT	220kV FATEHPUR-NAUBASTA(UPPTCL)	OSPD	28-11-2024	09:58:00	28-11-2024	17:04:00	0.30	0.00	0.00	0.00	7.10		* 220KV FATEHPUR-NAUBASTA* 28-11-24 09:58* 28-11-24 17:04 OSPD Taken under S/d by UP for insulator cleaning
CKT	220kV FATEHPUR-NAUBASTA(UPPTCL)	OSPD	19-11-2024	10:42:00	19-11-2024	17:55:00	0.30	0.00	0.00	0.00	7.22		* 220KV FATEHPUR-NAUBASTA* 19-11-24 10:42 19-11-24 17:55* OSPD Taken under S/D by UP for cleaning of disc insulator
							0.60	0.00	0.00	0.00	14.32	100.00	
CKT	220kV JAULJIVI-PITHORAGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV JAULJIVI-PITHORAGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-JAUNPUR(UP)-PHULPUR(UP)-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-KANPUR-KIDWAI NAGAR-ACL-C1	OSPD	16-11-2024	10:25:00	16-11-2024	20:17:00	0.41	0.00	0.00	0.00	9.87		* S/D taken by UPPTCL for rectification of SF6 Gas leakage problem from breaker GIS module.
							0.41	0.00	0.00	0.00	9.87	100.00	
CKT	220kV KANPUR-NAUBASTA(UPPTCL)	OSPD	29-11-2024	12:01:00	29-11-2024	18:19:00	0.26	0.00	0.00	0.00	6.30		* S/D taken by UPPTCL for routine testing/maintenance work

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

CKT	220kV KANPUR-NAUBASTA(UPPTCL)	OMSU	20-11-2024	02:42:00	20-11-2024	04:09:00	0.06	0.00	1.45	0.00	0.00		* 220KV KNP-NAUBASTA 20-11-24 02:42' 20-11-24 04:09 OMSU* Line autoreclosed successfully opertaed on Y-N fault from Kanpur(PG) end but tripped from Naubasta (up) end. Fault details at Kanpur end-M1-F.D.-13.23 KM,F.C.-7.68 KA,M2- F.D.-12.62 KM,F.C.-7.99 KA.Naubasta end Details-F.D.-06.096 KM,F.C.-5.46 KA. Fault is in Kanpur Jurisdiction.Total Line Lenth-19.32 KM, Powergrid Jurisdiction-14.861 KM.
							0.32	0.00	1.45	0.00	6.30	100.00	
CKT	220kV KANPUR-RANIYA(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV MAINPURI(UPPTCL)-KANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RAEBAREILY-BACHHRAWAN(UPPTCL)	OSFD	09-11-2024	11:40:00	09-11-2024	15:34:00	0.16	0.00	0.00	0.00	3.90		* E/S/D taken by UPPTCL for attending hot spot in B- Phase line isolator.
							0.16	0.00	0.00	0.00	3.90	100.00	
CKT	220kV RAIBAREILLY-CG CITY(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV RANIYA(UPPTCL)-PANKI(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-SIKANDRA(UP)-KIRAWALI(UP)-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV-SIKANDRA(UP)-SAIFA(UP)-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SITARGANJ-BAREILLY(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SITARGANJ-TANAKPUR(NHPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV TANAKPUR(NHPC)-BAREILY(UPPTCL)	OSFT	27-11-2024	11:54:00	27-11-2024	17:34:00	0.24	5.67	0.00	0.00	0.00		* 220KV TNKPR-BLY(UP) 27-11-24 11:54 27-11-24 17:34 OSFT Taken under E/S/D by Bareilly TL group to attend sparking observed at loc no 249
							0.24	5.67	0.00	0.00	0.00	99.21	
CKT	220kV UNCHAHAR(NTPC)-KANPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV UNCHAHAR(NTPC)-KANPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV UNCHAHAR(NTPC)-KANPUR-3	LCSD	19-11-2024	08:59:00	30-11-2024	23:59:59	11.63	0.00	0.00	0.00	279.02		* 220KV KNP-UNCHR-III 19-11-24 08:59 **** LCSD For Diversion work of 220KV Unchahar Kanpur circuit 4 for NHAI Raebareilly Prayagraj bypass road crossing under Raebareilly.
							11.63	0.00	0.00	0.00	279.02	100.00	
CKT	220kV UNCHAHAR(NTPC)-KANPUR-4	LCSD	19-11-2024	09:00:00	30-11-2024	23:59:59	11.63	0.00	0.00	0.00	279.00		* 220KV KNP-UNCHR-IV 19-11-24 09:00* **** LCSD* For Diversion work of 220KV Unchahar Kanpur circuit 4 for NHAI Raebareilly Prayagraj bypass road crossing under Raebareilly.
							11.63	0.00	0.00	0.00	279.00	100.00	
CKT	220kV UNCHAHAR(NTPC)-RAIBAREILLY-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV UNCHAHAR(NTPC)-RAIBAREILLY-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV UNCHAHAR(NTPC)-RAIBAREILLY-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AGRA(UPPTCL)-FATEHABD(UPPTCL)-2	OSPD	23-11-2024	10:45:00	23-11-2024	18:30:00	0.32	0.00	0.00	0.00	7.75		* S/D taken for replacement of defective polymer insulator by UPPTCL.
							0.32	0.00	0.00	0.00	7.75	100.00	
CKT	400kV AGRA-AGRA(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AGRA-BALLABGARH	LART	04-11-2024	10:59:00	04-11-2024	10:59:00	0.00	0.00	0.00	0.00	0.00		* 400KV AGRA-BLBGRH* 04-11-24 10:59* 04-11-24 10:59 LART Line A/R successfully on Y-N fault. AFAS details from Ballabgarh end: FD-126.076 Km, FC-3.522 kA, FA- 84.098 degree;Ballabgarh end relay details:M1: FD-124.768 km, FC-3.596kA, Zone-1; M2: FD-126.072 km, FC-3.522 kA. Agra end Relay details: M1: FD-50.2 km, FC-8.9 kA, Zone-1; M2: FD-50.54 km, FC-8.7 kA. Fault is in Agra TLM jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AGRA-BASSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AGRA-BHIWADI-1	LVRD	01-11-2024	00:00:01	01-11-2024	09:47:00	0.41	0.00	0.00	0.00	9.78		* H/T FOR V/R AS PER NRLDC INSTRUCTION
CKT	400kV AGRA-BHIWADI-1	LVRD	25-11-2024	21:14:00	26-11-2024	07:53:00	0.44	0.00	0.00	0.00	10.65		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -418 KV
CKT	400kV AGRA-BHIWADI-1	LVRD	27-11-2024	19:20:00	28-11-2024	06:41:00	0.47	0.00	0.00	0.00	11.35		* 400KV AGRA-BHIWADI-I 27-11-24 19:20 28-11-24 06:41 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -419 KV
CKT	400kV AGRA-BHIWADI-1	LVRD	29-11-2024	23:46:00	30-11-2024	06:26:00	0.28	0.00	0.00	0.00	6.67		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-1	LVRD	16-11-2024	21:38:00	17-11-2024	08:05:00	0.44	0.00	0.00	0.00	10.45		* H/T FOR V/R AS PER NRLDC INSTRUCTION
CKT	400kV AGRA-BHIWADI-1	LART	13-11-2024	08:45:00	13-11-2024	08:45:00	0.00	0.00	0.00	0.00	0.00		* Auto reclosed operated successfully on B-N fault.Agra end relay details: M1-FD-209Km, FC-2.02 kA; Bhiwadi end relay details: M1-FD-3.349 Km, FC-25.2 kA, M2- FD-3.26 Km, FC-26.46 kA. Fault is in NR-1 jurisdiction.
CKT	400kV AGRA-BHIWADI-1	LVRD	03-11-2024	21:27:00	04-11-2024	06:14:00	0.37	0.00	0.00	0.00	8.78		* 400KV AGRA-BHIWADI-I* 03-11-24 21:27* 04-11-24 06:14* LVRD* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420KV
CKT	400kV AGRA-BHIWADI-1	LVRD	19-11-2024	21:52:00	20-11-2024	06:48:00	0.37	0.00	0.00	0.00	8.93		* 400KV AGRA-BHIWADI-I* 19-11-24 21:52* 20-11-24 06:48* LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-1	LVRD	14-11-2024	20:46:00	15-11-2024	08:15:00	0.48	0.00	0.00	0.00	11.48		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -424KV
CKT	400kV AGRA-BHIWADI-1	LVRD	23-11-2024	22:16:00	24-11-2024	08:12:00	0.41	0.00	0.00	0.00	9.93		* H/T FOR V/R AS PER NRLDC INSTRUCTION
CKT	400kV AGRA-BHIWADI-1	LVRD	10-11-2024	20:00:00	11-11-2024	06:25:00	0.43	0.00	0.00	0.00	10.42		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -422KV
CKT	400kV AGRA-BHIWADI-1	LVRD	05-11-2024	21:24:00	06-11-2024	06:40:00	0.39	0.00	0.00	0.00	9.27		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -421KV
CKT	400kV AGRA-BHIWADI-1	LVRD	12-11-2024	20:26:00	13-11-2024	08:39:00	0.51	0.00	0.00	0.00	12.22		* 400KV AGRA-BHIWADI-I 12-11-24 20:26 **** LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -423KV
CKT	400kV AGRA-BHIWADI-1	LVRD	07-11-2024	21:05:00	08-11-2024	07:53:00	0.45	0.00	0.00	0.00	10.80		* H/T FOR V/R AS PER NRLDC INSTRUCTION
							5.45	0.00	0.00	0.00	130.73	100.00	
CKT	400kV AGRA-BHIWADI-2	LVRD	13-11-2024	21:31:00	14-11-2024	07:35:00	0.42	0.00	0.00	0.00	10.07		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -424KV
CKT	400kV AGRA-BHIWADI-2	LVRD	06-11-2024	21:28:00	07-11-2024	07:56:00	0.44	0.00	0.00	0.00	10.47		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -421KV
CKT	400kV AGRA-BHIWADI-2	LVRD	09-11-2024	19:46:00	10-11-2024	08:56:00	0.55	0.00	0.00	0.00	13.17		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -422KV
CKT	400kV AGRA-BHIWADI-2	LVRD	26-11-2024	19:58:00	27-11-2024	05:49:00	0.41	0.00	0.00	0.00	9.85		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -418 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	30-11-2024	21:20:00	30-11-2024	23:59:59	0.11	0.00	0.00	0.00	2.67		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	28-11-2024	20:46:00	29-11-2024	06:18:00	0.40	0.00	0.00	0.00	9.53		* 400KV AGRA-BHIWADI-II* 28-11-24 20:46* 29-11-24 06:18* LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -419 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	18-11-2024	22:36:00	19-11-2024	06:34:00	0.33	0.00	0.00	0.00	7.97		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -424KV
CKT	400kV AGRA-BHIWADI-2	LVRD	16-11-2024	02:34:00	16-11-2024	09:09:00	0.27	0.00	0.00	0.00	6.58		* H/T FOR V/R AS PER NRLDC INSTRUCTION
CKT	400kV AGRA-BHIWADI-2	LVRD	17-11-2024	22:07:00	18-11-2024	08:51:00	0.45	0.00	0.00	0.00	10.73		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -424KV
CKT	400kV AGRA-BHIWADI-2	LVRD	22-11-2024	23:41:00	23-11-2024	07:45:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -416 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	24-11-2024	19:38:00	25-11-2024	08:37:00	0.54	0.00	0.00	0.00	12.98		* H/T FOR V/R AS PER NRLDC INSTRUCTION

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

CKT	400kV AGRA-BHIWADI-2	LVRD	20-11-2024	19:52:00	21-11-2024	06:08:00	0.43	0.00	0.00	0.00	10.27		* 400KV AGRA-BHIWADI-II 20-11-24 19:52 21-11-24 06:08 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	21-11-2024	20:29:00	22-11-2024	06:07:00	0.40	0.00	0.00	0.00	9.63		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420 KV
CKT	400kV AGRA-BHIWADI-2	LVRD	01-11-2024	22:01:00	02-11-2024	09:23:00	0.47	0.00	0.00	0.00	11.37		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -420KV
CKT	400kV AGRA-BHIWADI-2	LVRD	04-11-2024	21:35:00	05-11-2024	06:43:00	0.38	0.00	0.00	0.00	9.13		* 400KV AGRA-BHIWADI-II 04-11-24 21:35 05-11-24 06:43 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -421KV
CKT	400kV AGRA-BHIWADI-2	LVRD	11-11-2024	21:19:00	12-11-2024	05:52:00	0.36	0.00	0.00	0.00	8.55		* 400KV AGRA-BHIWADI-II* 11-11-24 21:19* 12-11-24 05:52* LVRD* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -423KV
							6.30	0.00	0.00	0.00	151.04	100.00	
CKT	400kV AGRA-FATEHABAD(UPPTCL)-1	OMSU	11-11-2024	12:32:00	11-11-2024	15:15:00	0.11	0.00	0.00	0.00	0.00		* 400KV AGRA-FATEHABD(UP)-I* 11-11-24 12:32* 11-11-24 15:15 OMSU Tripped due to DT received at Agra end. DT send by Fatehabad (UP)
CKT	400kV AGRA-FATEHABAD(UPPTCL)-1	OSPD	21-11-2024	10:26:00	21-11-2024	18:23:00	0.33	0.00	0.00	0.00	7.95		* S/d taken by UPPTCL for Defective Polymer Replacement Work
							0.44	0.00	2.72	0.00	7.95	100.00	
CKT	400kV ALLAHABAD-FATEHPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALLAHABAD-FATEHPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALLAHABAD-FATEHPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALLAHABAD-KANPUR GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALLAHABAD-KANPUR GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALLAHABAD-KANPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALLAHABAD-MEJA(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALLAHABAD-MEJA(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AURAIYA(NTPC)-AGRA-1	LEFT	20-11-2024	13:08:00	21-11-2024	03:25:00	0.60	14.28	0.00	0.00	0.00		* 400KV AGRA-AURAIYA-I* 20-11-24 13:08* 21-11-24 03:25* LEFT Tripped due to B-N fault.Agra end details-M1-FD-148.9 KM,FC-3.04 KA= ..
CKT	400kV AURAIYA(NTPC)-AGRA-1	OSPT	23-11-2024	09:09:00	23-11-2024	20:16:00	0.46	11.12	0.00	0.00	0.00		Fault under Auraiya TLM jurisdiction. Insulator found decapped at loc no 03.(Decapped Insulator has been replaced).
							1.06	25.40	0.00	0.00	0.00	96.47	* S/D taken for Rectification of S/D nature defects
CKT	400kV AURAIYA(NTPC)-AGRA-2	OSPT	29-11-2024	09:07:00	29-11-2024	20:37:00	0.48	11.50	0.00	0.00	0.00		* S/D taken for rectification of S/d nature defects.
							0.48	11.50	0.00	0.00	0.00	98.40	
CKT	400kV AURAIYA(NTPC)-KANPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AURAIYA(NTPC)-KANPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BALIA-MAU(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BALIA-RASRA(UPPTCL)-1	OSPT	30-11-2024	10:37:00	30-11-2024	19:24:00	0.37	8.78	0.00	0.00	0.00		* S/D taken for AMP work.
							0.37	8.78	0.00	0.00	0.00	98.78	
CKT	400kV BALIA-SOHAWAL-1	OSFT	15-11-2024	12:05:00	15-11-2024	15:24:00	0.14	3.32	0.00	0.00	0.00		* E/S/D taken to attend hot spot in Y phase line isolator at Ballia S/s.
							0.14	3.32	0.00	0.00	0.00	99.54	
CKT	400kV BALIA-SOHAWAL-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV GORAKHPUR-BASTI(UPPTCL)-1	OSPD	18-11-2024	10:02:00	18-11-2024	18:04:00	0.34	0.00	0.00	0.00	8.03		* For AMP work by UPPTCL.
CKT	400KV GORAKHPUR-BASTI(UPPTCL)-1	OSPD	17-11-2024	10:38:00	17-11-2024	19:41:00	0.38	0.00	0.00	0.00	9.05		* For AMP work by UPPTCL.
CKT	400KV GORAKHPUR-BASTI(UPPTCL)-1	OSPD	19-11-2024	10:25:00	19-11-2024	19:01:00	0.36	0.00	0.00	0.00	8.60		* 400KV GKP-BASTI(UP)-I* 19-11-24 10:25* 19-11-24 19:01* OSPD For jumper tightening work by UPPTCL.
							1.08	0.00	0.00	0.00	25.68	100.00	
CKT	400KV-GORAKHPUR-BASTI AC CKT 2 LINE	OSPD	22-11-2024	10:49:00	22-11-2024	18:29:00	0.32	0.00	0.00	0.00	7.67		* S/d taken by UPPTCL for jumper tightening work
CKT	400KV-GORAKHPUR-BASTI AC CKT 2 LINE	OSPD	20-11-2024	10:52:00	20-11-2024	18:56:00	0.34	0.00	0.00	0.00	8.07		* 400KV GKP-BASTI(UP)-II 20-11-24 10:52 20-11-24 18:56 OSPD For jumper tightening work by UPPTCL.
CKT	400KV-GORAKHPUR-BASTI AC CKT 2 LINE	OSPD	21-11-2024	10:30:00	21-11-2024	18:58:00	0.35	0.00	0.00	0.00	8.47		* S/d taken by UPPTCL for jumper tightening work
							1.01	0.00	0.00	0.00	24.21	100.00	
CKT	400KV-BASTI-LUCKNOW-ACL-CKT1	OSPD	25-11-2024	10:54:00	25-11-2024	18:51:00	0.33	0.00	0.00	0.00	7.95		* S/D taken by UPPTCL for jumper tightening work
CKT	400KV-BASTI-LUCKNOW-ACL-CKT1	OSPD	24-11-2024	10:51:00	24-11-2024	18:32:00	0.32	0.00	0.00	0.00	7.68		* S/D taken by UPPTCL for jumper tightning
CKT	400KV-BASTI-LUCKNOW-ACL-CKT1	OSPD	23-11-2024	10:55:00	23-11-2024	20:05:00	0.38	0.00	0.00	0.00	9.17		* S/d taken by UPPTCL for jumper tightening work
							1.03	0.00	0.00	0.00	24.80	100.00	
CKT	400KV-BASTI-LUCKNOW-ACL-CKT2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAREILY(UPPTCL)-BAREILY-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAREILY(UPPTCL)-BAREILY-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAREILLY765-KASHIPUR(PTCUL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAREILLY765-KASHIPUR(PTCUL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAREILY-BAREILY 765kV-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAREILY-BAREILY 765kV-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BAREILLY-MORADABAD(UPPTCL)-1	LART	12-11-2024	09:03:00	12-11-2024	09:03:00	0.00	0.00	0.00	0.00	0.00		* 400KV BAREILLY-MBAD-I 12-11-24 09:03 12-11-24 09:03 LART Auto reclose successfully on Y-N fault.Bareilly end details-M1-FD-80.3 KM, FC-3.957 KA= .M2-FD- 80.7 KM, FC-3.89 KA, AFAS Bareilly end-M1-FD-82.471 KM,FC-4.115 KA,FA-80.689 degree.Moradabad end details-F.D.-5.438 Km, F.C.-12.06 Ka. Fault under Bareilly jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-BAREILLY-RAMPUR-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV JAULJIVI-DHAULGANGA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV JAULJIVI-DHAULGANGA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV FATEHPUR-MAINPURI-1	OSPD	14-11-2024	08:34:00	14-11-2024	19:58:00	0.48	0.00	0.00	0.00	11.40		* S/D taken by UPPTCL for stringing purpose of 765 kV S/C Mainpuri-Bara T/L Ckt-1 between Location no 45/0-46/0 (1B).

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

CKT	400kV FATEHPUR-MAINPURI-2	OSPD	14-11-2024	08:35:00	14-11-2024	19:03:00	0.48	0.00	0.00	0.00	11.40	100.00	* S/D taken by UPPTCL for stringing purpose of 765 kV S/C Mainpuri-Bara T/L Ckt-1 between Location no 45/0-46/0 (1B).
							0.44	0.00	0.00	0.00	10.47		
CKT	400KV-FATEHPUR-PANKI-ACL-C1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-FATEHPUR-PANKI-ACL-C2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv GORAKHPUR-GORAKHPUR(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv GORAKHPUR-GORAKHPUR(UPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv JEHTA(UPPTCL)-UNNAO(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv JEHTA(UPPTCL)-UNNAO(UPPTCL)-2	OMSU	17-11-2024	14:56:00	17-11-2024	19:50:00	0.20	0.00	4.90	0.00	0.00		* "Line tripped from Jehta end only due to D/T received from Unnao end during shifting of transfer Bus Side Isolator from Bus1 to Bus 2 at Unnao end. Later on line taken under E/S/D by UPPTCL Unnao at 16:03 Hrs.* "
							0.20	0.00	4.90	0.00	0.00	100.00	
CKT	400kvv JAULJIVI-BAREILLY-1	OSFT	08-11-2024	09:39:00	09-11-2024	02:10:00	0.69	16.52	0.00	0.00	0.00		* E/S/D taken for attending hot spot (133 Degree C) observed in R Phase wave trap dropper at Jauljivi end.
							0.69	16.52	0.00	0.00	0.00	97.71	
CKT	400kvv JAULJIVI-BAREILLY-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv KANPUR-AGRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv KANPUR-BALLABHGARH-1	OMST	06-11-2024	17:04:00	06-11-2024	19:38:00	0.11	2.57	0.00	0.00	0.00		* Tripped due to DT received from Ballabgharh end.
CKT	400kvv KANPUR-BALLABHGARH-1	LVRD	29-11-2024	00:08:00	29-11-2024	06:36:00	0.27	0.00	0.00	0.00	6.47		* 400KV KNP-BLBGARH-I* 29-11-24 00:08* 29-11-24 06:36 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. KNP -415 KV
CKT	400kvv KANPUR-BALLABHGARH-1	LVRD	29-11-2024	23:44:00	30-11-2024	06:12:00	0.27	0.00	0.00	0.00	6.47		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur -416 KV
CKT	400kvv KANPUR-BALLABHGARH-1	LVRD	26-11-2024	01:32:00	26-11-2024	07:31:00	0.25	0.00	0.00	0.00	5.98		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur -418 KV
CKT	400kvv KANPUR-BALLABHGARH-1	LVRD	19-11-2024	01:35:00	19-11-2024	06:43:00	0.21	0.00	0.00	0.00	5.13		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur-420KV
CKT	400kvv KANPUR-BALLABHGARH-1	LVRD	25-11-2024	00:16:00	25-11-2024	08:10:00	0.33	0.00	0.00	0.00	7.90		* HIT FOR V/R AS PER NRLDC INSTRUCTION
CKT	400kvv KANPUR-BALLABHGARH-1	LVRD	14-11-2024	00:11:00	14-11-2024	09:25:00	0.39	0.00	0.00	0.00	9.23		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur -416KV
CKT	400kvv KANPUR-BALLABHGARH-1	LVRD	21-11-2024	23:51:00	22-11-2024	06:11:00	0.26	0.00	0.00	0.00	6.33		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur -415 KV
							2.09	2.57	0.00	0.00	47.51	99.64	
CKT	400kvv KANPUR-BALLABHGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv KANPUR-BALLABHGARH-3	LVRD	18-11-2024	02:13:00	18-11-2024	07:18:00	0.21	0.00	0.00	0.00	5.08		* Hand tripped on Voltage regulation as per NRLDC instruction. Ballabgharh-426KV
CKT	400kvv KANPUR-BALLABHGARH-3	OSFT	18-11-2024	12:20:00	18-11-2024	16:59:00	0.19	4.65	0.00	0.00	0.00		* Line taken under emergency S/D by Kanpur group to attend the damaged IPS Tube connector of B-phase.
CKT	400kvv KANPUR-BALLABHGARH-3	LVRD	06-11-2024	01:38:00	06-11-2024	06:53:00	0.22	0.00	0.00	0.00	5.25		* Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur -417KV
CKT	400kvv KANPUR-BALLABHGARH-3	LVRD	20-11-2024	22:20:00	21-11-2024	06:35:00	0.34	0.00	0.00	0.00	8.25		* 400KV KNP-BLBGARH-III 20-11-24 22:20 **** LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Kanpur -413 KV
							0.96	4.65	0.00	0.00	16.58	99.35	
CKT	400kvv KANPUR-KANPUR GIS-1	OSFT	30-11-2024	11:36:00	30-11-2024	13:33:00	0.08	1.95	0.00	0.00	0.00		* E/S/D taken to attend hotspot in 42789A isolator Y-ph connector (towards LSI) at Kanpur400.
							0.08	1.95	0.00	0.00	0.00	99.73	
CKT	400kvv KANPUR-KANPUR GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv LUCKNOW-JEHTA(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv LUCKNOW-JEHTA(UPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv LUCKNOW-LUCKNOW 765-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv LUCKNOW-LUCKNOW 765-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv LUCKNOW-LUCKNOW(UPPTCL)	OSPD	18-11-2024	10:23:00	18-11-2024	23:04:00	0.53	0.00	0.00	0.00	12.68		* S/D taken by UPPTCL for Upgradation of Busbar Protection Panel work at 400KV SS Sarojini Nagar.
							0.53	0.00	0.00	0.00	12.68	100.00	
CKT	400kvv LUCKNOW-SHAHAJAHANPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv LUCKNOW-SHAHAJAHANPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv LUCKNOW-SULTANPUR(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv LUCKNOW 765-KANPUR GIS-1	OSFT	16-11-2024	09:49:00	16-11-2024	14:58:00	0.22	5.15	0.00	0.00	0.00		* E/S/D taken for reconnection of opened conductor dropper of 411 Tie Bay Y phase of 89B isolator at Lucknow end.
							0.22	5.15	0.00	0.00	0.00	99.28	
CKT	400kvv LUCKNOW 765-KANPUR GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv LUCKNOW(UPPTCL)-BAREILLY-1	LART	08-11-2024	12:18:00	08-11-2024	12:18:00	0.00	0.00	0.00	0.00	0.00		* A/R operated on R-N fault. Relay details at Bareilly end-M1-F.D.-52.1 KM, F.C.-6.47 KA, M2-F.D.-50.2 KM, F.C.-6.77 KA. AFAS (Bareilly) FD-52.213KM, FC-6.93KA, Fault angle -71.49 degree. Fault is in Bareilly TLM Jurisdiction.
CKT	400kvv LUCKNOW(UPPTCL)-BAREILLY-1	OSPD	19-11-2024	09:10:00	19-11-2024	20:16:00	0.46	0.00	0.00	0.00	11.10		* 400KV BAREILLY-LKO(UP) 19-11-24 09:10 19-11-24 20:16 OSPD S/D taken by UPPTCL for Upgradation of busbar protection panel work at 400KV Lucknow(UP).
							0.46	0.00	0.00	0.00	11.10	100.00	
CKT	400kvv MAINPURI-BALLABHGARH-1	LVRD	22-11-2024	01:36:00	22-11-2024	06:13:00	0.19	0.00	0.00	0.00	4.62		* Hand tripped on Voltage regulation as per NRLDC instruction. Mainpuri -414 KV
							0.19	0.00	0.00	0.00	4.62	100.00	
CKT	400kvv MAINPURI-BALLABHGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-MAU-RASRA-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv ORAI-ORAI(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv ORAI-ORAI(UPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv RIHAND(NTPC)-ALLAHABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv RIHAND(NTPC)-ALLAHABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kvv SAHAJAHANPUR-BAREILLY-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

CKT	400kV SAHAJAHANPUR-BAREILLY-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV SINGRAULI(NTPC)-ALLAHABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV SINGRAULI(NTPC)-ALLAHABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV SINGRAULI(NTPC)-ALLAHABAD-3	OSPD	14-11-2024	10:12:00	15-11-2024	19:48:00	1.40	0.00	0.00	0.00	33.60	100.00	* S/D taken by NTPC for TBC SAS integration work.
							1.40	0.00	0.00	0.00	33.60		
CKT	400kV SINGRAULI(NTPC)-ANPARA(NTPC)-1	LPRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00	100.00	* Line manually opened from Anpara end only to restrict short circuit level in Singrauli-Anpara complex.
							30.00	0.00	0.00	0.00	720.00		
CKT	400kV SINGRAULI(NTPC)-FATEHPUR	OSFD	16-11-2024	12:14:00	16-11-2024	13:18:00	0.04	0.00	0.00	0.00	1.07	100.00	* E/S/D taken by NTPC Singrauli to replace BCU data.
							0.04	0.00	0.00	0.00	1.07		
CKT	400kV SINGRAULI(NTPC)-LUCKNOW(UPPTCL)-1	OSPD	21-11-2024	10:22:00	21-11-2024	22:28:00	0.50	0.00	0.00	0.00	12.10	100.00	* S/d taken by UPPTCL for upgradation of Bus-Bar protection panel
							0.50	0.00	0.00	0.00	12.10		
CKT	400kV SINGRAULI(NTPC)-RIHAND(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV SINGRAULI(NTPC)-RIHAND(NTPC)-2	OSPD	20-11-2024	11:27:00	20-11-2024	13:01:00	0.07	0.00	0.00	0.00	1.57	100.00	* 400KV SING-RIHAND-II 20-11-24 11:27 20-11-24 13:01 OSPD S/D taken by NTPC for BCU data update.
							0.07	0.00	0.00	0.00	1.57		
CKT	400kV SINGRAULI(NTPC)-VINDHYACHAL-1	OSFD	16-11-2024	17:08:00	16-11-2024	18:38:00	0.06	0.00	0.00	0.00	1.50	100.00	* E/S/D taken by NTPC Singrauli for Oil Leakage database Uploading in Bay Control Unit.
CKT	400kV SINGRAULI(NTPC)-VINDHYACHAL-1	LCSD	22-11-2024	09:09:00	24-11-2024	22:35:00	2.56	0.00	0.00	0.00	61.43	100.00	* for Replacement of 03 nos. Line CT at Singrauli end under Add Cap 2019-24
							2.62	0.00	0.00	0.00	62.93		
CKT	400kV SINGRAULI(NTPC)-VINDHYACHAL-2	OSPD	20-11-2024	16:18:00	20-11-2024	18:09:00	0.08	0.00	0.00	0.00	1.85	100.00	* 400KV SING-VINDH-II 20-11-24 16:18 20-11-24 18:09 OSPD S/D taken by NTPC for BCU data update
							0.08	0.00	0.00	0.00	1.85		
CKT	400kV SOHAWAL-LUCKNOW-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV SOHAWAL-LUCKNOW-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV VARANASI-ALLAHABAD-1	OSPT	05-11-2024	09:12:00	05-11-2024	18:06:00	0.37	8.90	0.00	0.00	0.00	98.76	* S/D taken for Insulator cleaning at various locations in polluted area.
							0.37	8.90	0.00	0.00	0.00		
CKT	400KV-SAHUPURI-VARANASI-ACL-CKT1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV-SAHUPURI-VARANASI-ACL-CKT2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV VARANASI -SARNATH(UPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400kV VARANASI -SARNATH(UPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	765kV AGRA-ALIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	765kV ALIGARH-GREATER NOIDA(UPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	765kV ALIGARH-JHATIKARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	765kV BALIA-LUCKNOW	OSPT	24-11-2024	08:19:00	24-11-2024	19:07:00	0.45	10.80	0.00	0.00	0.00	96.91	* S/D taken for AMP work and Insulator cleaning at various locations in polluted area
CKT	765kV BALIA-LUCKNOW	OSPT	23-11-2024	08:18:00	23-11-2024	19:43:00	0.48	11.42	0.00	0.00	0.00		* S/D taken for AMP work and Insulator cleaning at various locations in polluted area
							0.93	22.22	0.00	0.00	0.00		
CKT	765kV BALIA-VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	765kV FATEHPUR-AGRA-1	LVRD	03-11-2024	21:23:00	04-11-2024	06:56:00	0.40	0.00	0.00	0.00	9.55		* 311007* 765KV AGRA-FATEHPUR-I 03-11-24 21:23 04-11-24 06:56 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -788KV
							0.27	0.00	0.00	0.00	6.38		
CKT	765kV FATEHPUR-AGRA-1	LVRD	29-11-2024	00:16:00	29-11-2024	06:39:00	0.27	0.00	0.00	0.00	6.38		* 765KV AGRA-FATEHPUR-I 29-11-24 00:16 29-11-24 06:39 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -785 KV
							0.12	0.00	0.00	0.00	2.92		
CKT	765kV FATEHPUR-AGRA-1	LVRD	14-11-2024	02:34:00	14-11-2024	05:29:00	0.12	0.00	0.00	0.00	2.92		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -785KV
							0.43	0.00	0.00	0.00	10.28		
CKT	765kV FATEHPUR-AGRA-1	LVRD	14-11-2024	21:25:00	15-11-2024	07:42:00	0.43	0.00	0.00	0.00	10.28		* Hand tripped on Voltage regulation as per NRLDC instruction.Agra -784KV
							0.54	0.00	0.00	0.00	12.90		
CKT	765kV FATEHPUR-AGRA-1	OSPD	25-11-2024	09:07:00	25-11-2024	22:01:00	0.54	0.00	0.00	0.00	12.90		* S/D taken by UPPTCL for stringing work of 765 KV Bara-Mainpuri-1.
							0.29	0.00	0.00	0.00	6.95		
CKT	765kV FATEHPUR-AGRA-1	LVRD	21-11-2024	23:21:00	22-11-2024	06:18:00	0.29	0.00	0.00	0.00	6.95		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -785 KV
							0.22	0.00	0.00	0.00	5.37		
CKT	765kV FATEHPUR-AGRA-1	LVRD	23-11-2024	01:38:00	23-11-2024	07:00:00	0.22	0.00	0.00	0.00	5.37		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -780 KV
							0.56	13.33	0.00	0.00	0.00		
CKT	765kV FATEHPUR-AGRA-1	LEFT	20-11-2024	05:49:00	20-11-2024	19:09:00	0.56	13.33	0.00	0.00	0.00		* 765KV AGRA-FATEHPUR-I 20-11-24 05:49 **** LEFT Tripped due to Y-N fault.Agra end details-M1-FD=293.3KM,FC=2.81 KA,M2-FD=294.5 KM, FC=2.57 KA, Agra TWFL distance=304.96 KM, Fatehpur end-M1-FD=27.9 KM,FC=10.88 KA, M2-FD=27.4 KM,FC=9.997 KA, Fatehpur TWFL distance -29.2 KM AFAS, Fatehpur end-M1-FD=25.915 KM,FC=10.314 KA,FA=84.83 degree, M2-FD=25.788 KM,FC=10.291 KA,FA=86.08 degree. Fault under Fatehpur jurisdiction.
							0.85	0.00	0.00	0.00	20.32		
CKT	765kV FATEHPUR-AGRA-1	LVRD	01-11-2024	13:12:00	02-11-2024	09:31:00	0.85	0.00	0.00	0.00	20.32		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -790KV
							0.20	0.00	0.00	0.00	4.77		
CKT	765kV FATEHPUR-AGRA-1	LVRD	27-11-2024	00:55:00	27-11-2024	05:41:00	0.20	0.00	0.00	0.00	4.77		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -792 KV
							0.80	0.00	0.00	0.00	19.20		
CKT	765kV FATEHPUR-AGRA-1	LVRD	17-11-2024	14:10:00	18-11-2024	09:22:00	0.80	0.00	0.00	0.00	19.20		* Hand tripped on Voltage regulation as per NRLDC instruction.Agra -790KV
							0.00	0.00	0.00	0.00	0.02		
CKT	765kV FATEHPUR-AGRA-1	LVRD	30-11-2024	23:59:00	30-11-2024	23:59:59	0.00	0.00	0.00	0.00	0.02		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -780 KV
							4.68	13.33	0.00	0.00	98.66	98.15	
CKT	765kV FATEHPUR-AGRA-2	LVRD	16-11-2024	02:48:00	16-11-2024	07:18:00	0.19	0.00	0.00	0.00	4.50		* H/T FOR V/R AS PER NRLDC INSTRUCTION
							0.27	0.00	0.00	0.00	6.43		
CKT	765kV FATEHPUR-AGRA-2	LVRD	01-11-2024	03:39:00	01-11-2024	10:05:00	0.27	0.00	0.00	0.00	6.43		* H/T FOR V/R AS PER NRLDC INSTRUCTION
							0.00	0.00	0.00	0.00	0.00		
CKT	765kV FATEHPUR-AGRA-2	LART	14-11-2024	04:42:00	14-11-2024	04:42:00	0.00	0.00	0.00	0.00	0.00		* A/R operated successfully from both end due to B-N fault, Agra end details:-M1-FD=89.5km,FC=7.46KA,M2-FD=89km,FC=7.22KA,Fatehpur end details:-M1-FD=222.2km,FC=2.88KA,M2-FD=223.4km,FC=2.87KA, TWFL=239.53km from Fatehpur and 95.15 km from Agra. Fault in Auriya jurisdiction
							0.55	0.00	13.25	0.00	0.00		
CKT	765kV FATEHPUR-AGRA-2	OMSU	14-11-2024	04:53:00	14-11-2024	18:08:00	0.55	0.00	13.25	0.00	0.00		* Tripped due to B-N fault, Agra end details:-M1-FD=77.7km,FC=8.554KA=, M2-FD=77.4km,FC=7.65KA,Fatehpur end details:-M1-FD=235.2km,FC=2.77KA=, M2-FD=233.5km,FC=2.76KA, TWFL=252.21km from Fatehpur and 82.46km from Agra. As per Agra relay and TWFL details Fault in Agra ju= risdiction and as per Fatehpur relay details Fault in Auriya Jurisdiction.* 22.04.2025 04:38:19 INDIA (60041608)* Heavy Bird Excreta deposit on Loc No-673.
							0.27	0.00	0.00	0.00	6.38		
CKT	765kV FATEHPUR-AGRA-2	LVRD	21-11-2024	00:13:00	21-11-2024	06:36:00	0.27	0.00	0.00	0.00	6.38		* 765KV AGRA-FATEHPUR-II 21-11-24 00:13 21-11-24 06:36 LVRD Hand tripped on Voltage regulation as per NRLDC instruction. Agra -790 KV
							0.00	0.00	0.00	0.00	0.00		
CKT	765kV FATEHPUR-AGRA-2	LART	14-11-2024	04:38:00	14-11-2024	04:38:00	0.00	0.00	0.00	0.00	0.00		* A/R operated successfully from both end due to B-N fault, Agra end details:-M1-FD=89km,FC=7.5KA,M2-FD=88.7km,FC=7.24KA,Fatehpur end details:-M1-FD=222.5km,FC=2.87KA,M2-FD=223.7km,FC=2.87KA, TWFL=239.92km from Fatehpur and 94.72 km from Agra. Fault in Auriya jurisdiction.
							0.18	0.00	0.00	0.00	4.27		
CKT	765kV FATEHPUR-AGRA-2	LVRD	19-11-2024	02:11:00	19-11-2024	06:27:00	0.18	0.00	0.00	0.00	4.27		* Hand tripped on Voltage regulation as per NRLDC instruction.Agra -790KV
							0.79	0.00	0.00	0.00	19.00		
CKT	765kV FATEHPUR-AGRA-2	LVRD	24-11-2024	13:45:00	25-11-2024	08:45:00	0.79	0.00	0.00	0.00	19.00		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -788 KV
							0.28	0.00	0.00	0.00	6.00		
CKT	765kV FATEHPUR-AGRA-2	LVRD	26-11-2024	01:08:00	26-11-2024	07:50:00	0.28	0.00	0.00	0.00	6.00		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -792 KV
							0.25	0.00	0.00	0.00	5.92		
CKT	765kV FATEHPUR-AGRA-2	LVRD	30-11-2024	00:22:00	30-11-2024	06:17:00	0.25	0.00	0.00	0.00	5.92		* Hand tripped on Voltage regulation as per NRLDC instruction. Agra -780 KV

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

LNR	240MVAR,SWLR OF KANPUR-1 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF KANPUR-2 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT LUCKNOW 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV AGRA-BISWANATHCHARIALI POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV AGRA-BISWANATHCHARIALI POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV AGRA-ALIPURDUAR POLE-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV AGRA-ALIPURDUAR POLE-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-1	OSPT	21-11-2024	08:20:00	21-11-2024	21:05:00	0.53	12.75	0.00	0.00	0.00		* For HVDC system <(>&<)> associated AC system AMP, RTV coating of BPI/Smoothing Reactor, SF6 leakage from converter transformer bushing.
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-1	OSPT	19-11-2024	08:30:00	19-11-2024	23:14:00	0.61	14.73	0.00	0.00	0.00		* 500KV HVDC BALIA-BHWD POLE-I* 19-11-24 08:30* 19-11-24 23:14 OSPT For HVDC system <(>&<)> associated AC system AMP, RTV coating of BPI/Smoothing Reactor, SF6 leakage from converter transformer bushing
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-1	LART	15-11-2024	02:38:00	15-11-2024	02:38:00	0.00	0.00	0.00	0.00	0.00		* 500KV HVDC BALIA-BHWD POLE-I 15-11-24 02:28 15-11-24 02:28 LART DC transient fault occurred ,FD=547.891km from Ballia,FD=241.899km from Bhiwadi, Tower no-1497, Fault in Mainpuri jurisdiction.
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-1	LART	13-11-2024	06:20:00	13-11-2024	06:20:00	0.00	0.00	0.00	0.00	0.00		* 500KV HVDC BALIA-BHWD POLE-I 13-11-24 06:20 13-11-24 06:20 LART DC transient occurred. FD from Ballia- 156.328 KM, FD from Bhiwadi- 633.462 KM Tower No-424, Fault in Azamgarh jurisdiction
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-1	LART	04-11-2024	20:07:00	04-11-2024	20:07:00	0.00	0.00	0.00	0.00	0.00		* 500KV HVDC BALIA-BHWD POLE-I* 04-11-24 20:07* 04-11-24 20:07 LART DC transient fault occurred as per details: Ballia end : FD- 384.57 km; Bhiwadi end: FD- 405.213 km; Tower no. 1056. Fault is in Kanpur TLM jurisdiction.
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-1	OMST	17-11-2024	18:26:00	17-11-2024	19:15:00	0.03	0.82	0.00	0.00	0.00		* Pole-1 tripped during HVDC Ballia Bhiwadi Pole-2 shutdown TDM bus fault rectification work. Fault was identified in valve hall neutral side CT opto converter at Balia end.
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-1	OSPT	20-11-2024	08:22:00	20-11-2024	22:37:00	0.59	14.25	0.00	0.00	0.00		* 500KV HVDC BALIA-BHWD POLE-1 20-11-24 08:22 20-11-24 22:37 OSPT For HVDC system <(>&<)> associated AC system AMP, RTV coating of B= PI/Smoothing Reactor, SF6 leakage from converter transformer bushing.
							1.76	42.55	0.00	0.00	0.00	94.09	
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	OSFT	30-11-2024	15:16:00	30-11-2024	17:37:00	0.10	2.35	0.00	0.00	0.00		* E/S/D taken to attend heavy water leakage in the valve cooling pump-1 at Ballia end.
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	LART	28-11-2024	23:48:00	28-11-2024	23:48:00	0.00	0.00	0.00	0.00	0.00		* DC transient fault occurred. FD- 163.414 Km from Balia end. FD- 626.376 Km from Bhiwadi end. Tower No. 444. Fault is in Azamgarh jurisdiction.
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	LART	28-11-2024	18:18:00	28-11-2024	18:18:00	0.00	0.00	0.00	0.00	0.00		* 500KV HVDC BALIA-BHWD POLE-II 28-11-24 18:18 28-11-24 18:18 LART DC transient occurred. FD from Ballia-163.384 KM FD from Bhiwadi- 626.406 KM Tower no 444, Fault in Azamgarh TLM jurisdiction
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	LART	14-11-2024	06:23:00	14-11-2024	06:23:00	0.00	0.00	0.00	0.00	0.00		* DC transient fault occurred, FD from Ballia end= 396.63 Km, FD from Bhiwadi end =393.16 Km; Tower No. 1089. Fault is in Kanpur TLM ju= urisdiction.
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	OSPT	18-11-2024	08:22:00	18-11-2024	21:38:00	0.55	13.27	0.00	0.00	0.00		* For HVDC system <(>&<)> associated AC system AMP, RTV coating of BPI/Smoothing Reactor, SF6 leakage from converter transformer bushing
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	LART	15-11-2024	23:48:00	15-11-2024	23:48:00	0.00	0.00	0.00	0.00	0.00		* DC Line transient fault : Distance from Ballia -186.171 KM and from Bhiwadi - 603.619 KM.* Tower No - 508. Fault under Azamgarh TLM jurisdiction.
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	OSPT	17-11-2024	08:21:00	17-11-2024	21:14:00	0.54	12.88	0.00	0.00	0.00		* For AMP work of HVDC system , RTV coating of BPI / attending SF6 leakage from converter transformer.
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	OSPT	19-11-2024	07:59:00	20-11-2024	00:59:00	0.71	17.00	0.00	0.00	0.00		* 500KV HVDC BALIA-BHWD POLE-II 19-11-24 07:59 20-11-24 00:59 OSPT For HVDC system <(>&<)> associated AC system AMP, RTV coating of BPI/Smoothing Reactor, SF6 leakage from converter transformer bushing
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	LART	12-11-2024	21:13:00	12-11-2024	21:13:00	0.00	0.00	0.00	0.00	0.00		* 500KV HVDC BALIA-BHWD POLE-II* 12-11-24 21:13* 12-11-24 21:13 LART* DC transient occurred. FD from Ballia- 590.382 KM, FD from Bhiwadi- 197.408 KM Tower No- 1617 Fault in NR- jurisdiction
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	LART	21-11-2024	19:13:00	21-11-2024	19:13:00	0.00	0.00	0.00	0.00	0.00		* DC transient fault occurred, FD=500.302km from Balia, FD=289.488km from Bhiwadi. Tower no-1367. Fault under Mainpuri jurisdiction
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	LART	23-11-2024	21:22:00	23-11-2024	21:22:00	0.00	0.00	0.00	0.00	0.00		* DC line Transient fault at Fault Distance:Fom Ballia 163.384KM <(>&<)>From Bhiwadi 626.00KM. Tower No. - 444.
VALVE_HALL	500kV HVDC BALIA-BHIWADI POLE-2	LART	14-11-2024	06:17:00	14-11-2024	06:17:00	0.00	0.00	0.00	0.00	0.00		* DC transient fault occurred, FD from Ballia end= 396.68 Km, FD from Bhiwadi end=393.16 Km; Tower No. 1089. Fault is in Kanpur TLM ju= rsisdiction.
							1.90	45.50	0.00	0.00	0.00	93.68	
VALVE_HALL	500kV HVDC RIHAND-DADRI POLE-1	OSPT	09-11-2024	09:09:00	11-11-2024	00:18:00	1.63	39.15	0.00	0.00	0.00		* S/D for AMP of HVDC Rihand-Dadri Poles,retrofitment of poles MV switch gear,modification in valve cooling system,insulator cleaning in Transmission line.
VALVE_HALL	500kV HVDC RIHAND-DADRI POLE-1	LART	17-11-2024	10:18:00	17-11-2024	10:18:00	0.00	0.00	0.00	0.00	0.00		* "DC transient fault occurred. Distance from Dadri end 450.4 kms <(>&<)> from Rihand end - 364.6km. Fault under Fatehpur jurisdiction.
VALVE_HALL	500kV HVDC RIHAND-DADRI POLE-1	LART	14-11-2024	05:32:00	14-11-2024	05:32:00	0.00	0.00	0.00	0.00	0.00		* DC transient fault occurred, FD- 390.7 Km from Rihand end ,FD-424.3 Km from Dadri end ; Fault is in Fatehpur TLM jurisdiction.
							1.63	39.15	0.00	0.00	0.00	94.56	
VALVE_HALL	500kV HVDC RIHAND-DADRI POLE-2	LART	08-11-2024	19:59:00	08-11-2024	19:59:00	0.00	0.00	0.00	0.00	0.00		* DC transient fault; Distance from Dadri end 306.4 kms <(>&<)> from Rihand end - 508.6km.* Fault in Auraiya TLM jurisdiction.
VALVE_HALL	500kV HVDC RIHAND-DADRI POLE-2	LART	03-11-2024	03:14:00	03-11-2024	03:14:00	0.00	0.00	0.00	0.00	0.00		* DC transient fault occurred. Distance from Dadri end 109.6 km <(>&<)> from Rihand end - 705.4km. Fault under NR-1 jurisdiction.
VALVE_HALL	500kV HVDC RIHAND-DADRI POLE-2	LART	30-11-2024	02:46:00	30-11-2024	02:46:00	0.00	0.00	0.00	0.00	0.00		* DC transient fault occurred, FD from Rihand end=746.3 km, FD from Dadri end=68.7 kms. Fault in NR-1 jurisdiction.
VALVE_HALL	500kV HVDC RIHAND-DADRI POLE-2	OSPT	10-11-2024	08:31:00	12-11-2024	21:31:00	2.54	61.00	0.00	0.00	0.00		* S/D for AMP of HVDC Rihand-Dadri Poles,retrofitment of poles MV switch gear,modification in valve cooling system,insulator cleaning in Transmission line.
							2.54	61.00	0.00	0.00	0.00	91.53	
VALVE_HALL	250MW,VINDHYACHAL HVDC 8TB POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	250MW,VINDHYACHAL HVDC 8TB POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT AGRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT ALLAHABAD	OSPT	27-11-2024	10:51:00	27-11-2024	20:27:00	0.40	9.60	0.00	0.00	0.00		* 315MVA ICT-I ALLAHABAD 27-11-24 10:51 27-11-24 20:27 OSPT Taken under S/d for main bay LBB retrofitment work.
							0.40	9.60	0.00	0.00	0.00	98.67	
XMER	315MVA,400/220kV ICT-2 AT ALLAHABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT ALLAHABAD	OSPT	16-11-2024	09:37:00	18-11-2024	05:40:00	1.84	44.05	0.00	0.00	0.00		* S/D taken for AMP Work.
							1.84	44.05	0.00	0.00	0.00	93.88	
XMER	1500MVA,765/400kV ICT-1 AT ALIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT ALIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

XMER	1500MVA,765/400kV ICT-2 AT BALLIA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	1500MVA,765/400kV ICT-1 AT BAREILLY 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	1500MVA,765/400kV ICT-2 AT BAREILLY 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-1 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	1500MVA,765/400kV ICT-1 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-2 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	1500MVA,765/400kV ICT-2 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	500MVA,400/220kV ICT-3 AT FATEHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-1 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-2 AT GORAKHPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-3 AT GORAKHPUR	OSFT	28-11-2024	13:13:00	28-11-2024	18:35:00	0.22	5.37	0.00	0.00	0.00		* 315MVA ICT-III GORAKHPUR 28-11-24 13:13 28-11-24 18:35 OSFT Taken under E/S/D to attend spark in 207 89L R-ph isolator
							0.22	5.37	0.00	0.00	0.00	99.25	
XMER	105MVA,400/220kV ICT-SPARE AT JAULJIVI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-1 AT JAULJIVI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-2 AT JAULJIVI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	1500MVA,765/400kV ICT-1 AT KANPUR GIS	OSFT	13-11-2024	11:44:00	13-11-2024	15:11:00	0.14	3.45	0.00	0.00	0.00		* E/S/D taken to attend oil leakage in R-ph.
							0.14	3.45	0.00	0.00	0.00	99.52	
XMER	1500MVA,765/400kV ICT-2 AT KANPUR GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-1 AT KANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-2 AT KANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	500MVA,400/220kV ICT-1 AT LUCKNOW			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	500MVA,400/220kV ICT-2 AT LUCKNOW			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	1500MVA,765/400kV ICT-1 AT LUCKNOW 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	1500MVA,765/400kV ICT-2 AT LUCKNOW 765			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-1 AT MAINPURI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-2 AT MAINPURI	OSPT	22-11-2024	12:47:00	22-11-2024	15:56:00	0.13	3.15	0.00	0.00	0.00		* S/D taken for Tan Delta measurement of bushing and replacement of HV WTI Sensor.
							0.13	3.15	0.00	0.00	0.00	99.56	
XMER	500MVA,400/220kV ICT-3 AT MAINPURI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
XMER	1000MVA,765/400kV ICT-1 AT ORAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	1000MVA,765/400kV ICT-2 AT ORAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	100MVA,220/132kV ICT-2 AT PITHORAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	100MVA,220/132kV ICT-1 AT PITHORAGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	100MVA,220/132kV ICT-1 AT RAIBAREILLY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	200MVA,220/132kV ICT-2 AT RAIBAREILLY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	200MVA,220/132kV ICT-3 AT RAIBAREILLY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-1 AT SHAHJAHANPUR	OSPT	27-11-2024	08:31:00	27-11-2024	16:05:00	0.32	7.57	0.00	0.00	0.00		* 500MVA ICT-I SHAHJHNPR* 27-11-24 08:31* 27-11-24 16:05* OSPT Taken under S/d for AMP work and protection testing
							0.32	7.57	0.00	0.00	0.00	98.95	
XMER	500MVA,400/220kV ICT-2 AT SHAHJAHANPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	100MVA,220/132kV ICT-1 AT SITARGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	100MVA,220/132kV ICT-2 AT SITARGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	100MVA,220/132kV ICT-3 AT SITARGANJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-1 AT SOHAWAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-2 AT SOHAWAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	500MVA,400/220kV ICT-3 AT SOHAWAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
XMER	1500MVA,765/400kV ICT-1 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., NORTHERN REGION-III

XMER	1500MVA,765/400kV ICT-2 AT VARANASI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	