

Standard of Performance data for the month of FEB-2021

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION - I

Sl No:	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVar/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available						
1	SR1L01	KURNOOL(NEW) - NELLOREPS - I	302.303	SR-I	--	16/02/21	13:22	16/02/21	16:49				3.45						Emergency S/D availed to remove struck rollers which got struck during OPGW works vide code:SR-2441,NL-1542	SRPC, SRPC/SE-IPGTA/2014/10274/291, Dtd. 27.11.14	99.49	
						Sub Total -->							3.45	0.00	0.00	0.00						
2	SR1L02	KURNOOL(NEW) - NELLOREPS - II	302.303	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
3	SR1L03	KURNOOL(NEW) - TIRUVALUM - I	355.01	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
4	SR1L04	KURNOOL(NEW) - TIRUVALUM - II	355.01	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
5	SR1L05	RAICHUR(NEW) - KURNOOL(NEW) - I	120.482	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
6	SR1L06	RAICHUR(NEW) - KURNOOL(NEW) - II	118.423	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
7	SR1L07	RAICHUR(NEW) - SHOLAPUR - I	207.754	SR-I	--	17/02/21	13:36	17/02/21	20:34				6.97						Emergency S/D availed by WR for Line CVT rectification works vide code:SR-2635,NL-1637,WR-2232		98.96	
						Sub Total -->							6.97	0.00	0.00	0.00						
8	SR1L08	ALMATHY - THIRUVALAM I	40.969		--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
9	SR1L09	ALMATHY - THIRUVALAM II	40.969		--	--	--	--	--	--	--	--										100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
10	SR1L10	ALMATHY - VALLUR - I	36.348	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00	N/A	N/A	N/A			
11	SR1L11	ALMATHY - VALLUR - II	36.348	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
12	SR1L12	GAJWEL - HYDERABAD	62.496	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00	N/A	N/A	N/A			
13	SR1L13	GOOTY - NELAMANGALA	256.130	SR-I	--	21/02/21	12:08	21/02/21	14:10				2.03			0.00			H/T on Emergency vide SR-3280 for removal of damaged pilot rope at Location No 695 in SR-II portion. SD availed by SR-II		99.70	

Sl No:	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available						
						28/02/21	14:16	28/02/21	17:07										Line tripped on Y-N fault. Fault details GTY end:FD: M1 261.78km/1.5kA, M2 244.11km/1.95kA, AFAS FD: M1 240.16km/1.6kA, M2 239.925km/1.97kA. Neelamangala end:FD: 20.82KM, FC:10.7KA). A/R successful and line tripped due to persisting fault. Agree-Fire			
						Sub Total -->							2.03	0.00	2.85	0.00						
14	SR1L14	GOOTY - RAICHUR(NEW) - I	128.700	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
15	SR1L15	GOOTY - RAICHUR(NEW) - II	128.700	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
16	SR1L16	GOOTY - PAVAGADA 1	208.621	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
17	SR1L17	GOOTY - PAVAGADA 2	208.621	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
18	SR1L18	HYDERABAD - KURNOOL	226.500	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
19	SR1L19	HYDERABAD - NSAGAR	155.264	SR-I	--	16/02/21	11:36	16/02/21	11:36				0.00						A/R Successful on Y-N fault at 11:36Hrs/16.02.2021.Fault details.NSR end:M1-89.88KM,2.97KA,M2-94.5KM,2.918KA, HYD end:M1-80.8KM,3.429KA.		100.00	
						17/02/21	12:52	17/02/21	13:26				0.00		0.57				Tripped on Y-N Fault. FL=90KM from HYD. Agri-Fire			
						Sub Total -->							0.00	0.00	0.57	0.00						
20	SR1L20	JEYPORE - GAJUWAKA - I	220.000	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
21	SR1L21	JEYPORE - GAJUWAKA - II	220.000	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
22	SR1L22	KADAPA - NPKUNTA	9.512	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
23	SR1L23	KHAMMAM - NSAGAR I	144.577	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
24	SR1L24	KHAMMAM - VIJAYAWADA	114.775	SR-I	--	25/02/21	07:55	25/02/21	07:55				0.00						A/R Successful on B-N fault. Fault details: VJA end:56.547km,5.851ka,KMM end:62.389KM,5.047KA		99.54	
						26/02/21	11:28	26/02/21	14:35				3.12						H/T on emergency for replacement of CVT due to B ph voltage drift vide SR 3917			
						Sub Total -->							3.12	0.00	0.00	0.00						
25	SR1L25	KURNOOL(PG) - GOOTY	112.609	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
26	SR1L26	KURNOOL(AP) - GOOTY	84.190	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
27	SR1L27	KURNOOL - KURNOOL(NEW) - I	9.880	SR-I	--																95.32	
						Sub Total -->							31.13	0.00	6.83	0.00						

Sl No:	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available						
28	SR1L28	KURNOOL - KURNOOL(NEW) - II	9.880	SR-I	--																100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
29	SR1L29	MAHBOOBNAGAR - RAICHUR	73.680	SR-I	--	04/02/21	06:43	04/02/21	07:28												Tripped at RTPS end only. Mal-operation of KPCL's Protection at RTPS for fault in adjacent 400kV N'Sagar - Mahaboobnagar Line.	100.00
						Sub Total -->							0.00	0.75	0.00	0.00						
30	SR1L30	MALKARAM - HYDERABAD	27.870	SR-I	--	09/02/21	09:36	09/02/21	19:16												H/T for AMP works vide code SR-1256	98.56
						16/02/21		10:32		16/02/21		17:56								S/D availed by TSTransco for maintenance works vide code:SR-2421		
						Sub Total -->							9.67	0.00	0.00	7.40						
31	SR1L31	NELLOREPS - GOOTY - I	289.004	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
32	SR1L32	NELLOREPS - GOOTY - II	289.004	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
33	SR1L33	NELLOREPS - MEPL	3.830	SR-I	--	04/02/21	13:53	04/02/21	19:50												Vide SR-506,H/T on request of MEPL for replacement of CVT at MEPL Yard due to oil leak	100.00
						23/02/21		02:56		23/02/21		06:55								Tripped on Over Voltage protection operation at MEPL end DT receipt at NPS end.		
						Sub Total -->							0.00	0.00	0.00	9.93						
34	SR1L34	NELLOREPS - SEPL	3.830	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
35	SR1L35	NELLOREPS - NCC - I	33.580	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
36	SR1L36	NELLOREPS - NCC - II	32.730	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
37	SR1L37	NELLOREPS - NELLORE - I	3.650	SR-I	--	20/02/21	08:41	21/02/21	17:24												H/T Vide SR-3146 for Reactor dismantling and shifting works. Line Differential relay retrofit works	100.00
						Sub Total -->							0.00	0.00	0.00	32.72						
38	SR1L38	NELLOREPS - NELLORE - II	3.650	SR-I	--	17/02/21	09:55	18/02/21	21:38												H/T for Reactor dismantling works at Nellore SS vide code:SR-2603	100.00
						Sub Total -->							0.00	0.00	0.00	35.72						
39	SR1L39	NELLORE - SIRIPERUMBUDUR I	189.000	SR-I	--	25/02/21	09:28	01/03/21	00:00												H/T for erection of reactor works vide code:3763	100.00
						Sub Total -->							0.00	0.00	0.00	86.53						
40	SR1L40	NELLORE - SIRIPERUMBUDUR II	189.000	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
41	SR1L41	NELLORE - TIRUVALUM - I	172.964	SR-I	--	20/02/21	08:41	20/02/21	08:44												H/T vide SR-3153 for facilitating Shutdown of NLR-NPS-I	100.00
						21/02/21		17:20		21/02/21		17:24								H/T for facilitating line charging of NPS-NLR-1 line vide SR/3300		
						Sub Total -->							0.00	0.00	0.00	0.12						
42	SR1L42	NELLORE - TIRUVALUM - II	172.964	SR-I	--																	100.00
						Sub Total -->							0.00	0.00	0.00	0.00						
43	SR1L43	NELLOREPS - TPCIL - I	32.730	SR-I	--	24/02/21	10:20	24/02/21	23:50												S/D availed by M/s TPCIL for maintenance works vide code:SR-3646	100.00

Sl No:	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVar/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency			
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available									
						Sub Total -->																			
						25/02/21	09:47	25/02/21	22:16						12.48				Emergency S/D availed by M/s TPCIL vide code:SR-3770						
44	SR1L44	NELLOREPS - TPCIL - II	32.730	SR-I	--	23/02/21	09:10	23/02/21	19:44						10.57				S/D availed by M/s TPCIL vide SR-3494		100.00				
						Sub Total -->																			
45	SR1L45	NSAGAR - KADAPA - I	277.325	SR-I	--										0.00							100.00			
						Sub Total -->																			
46	SR1L46	NSAGAR - KADAPA - II	278.664	SR-I	--										0.00							100.00			
						Sub Total -->																			
47	SR1L47	NSAGAR - KURNOOL(NEW)	264.954	SR-I	--										0.00							100.00			
						Sub Total -->																			
48	SR1L48	NSAGAR - MAHBOOBNAGAR	184.350	SR-I	--	04/02/21	06:42	04/02/21	06:42						0.00							100.00			
						Sub Total -->																			
49	SR1L49	NPKUNTA - KOLAR	9.512	SR-I	--																	100.00			
						Sub Total -->																			
50	SR1L50	RAICHUR - MUNIRABAD	172.440	SR-I	--	14/02/21	08:29	14/02/21	18:54						10.42							98.45			
						Sub Total -->																			
51	SR1L51	RAICHUR(NEW) - RAICHUR - I	22.219	SR-I	--										0.00							100.00			
						Sub Total -->																			
52	SR1L52	RAICHUR(NEW) - RAICHUR - II	22.219	SR-I	--										0.00							100.00			
						Sub Total -->																			
53	SR1L53	RAMAGUNDAM - CHANDRAPUR - I	177.600	SR-I	--										0.00							100.00			
						Sub Total -->																			
54	SR1L54	RAMAGUNDAM - CHANDRAPUR - II	177.600	SR-I	--										0.00							100.00			
						Sub Total -->																			
55	SR1L55	RAMAGUNDAM - GAJWEL	124.765	SR-I	--										0.00							100.00			
						Sub Total -->																			
56	SR1L56	RAMAGUNDAM - HYDERABAD - III	201.236	SR-I	--										0.00							100.00			
						Sub Total -->																			
57	SR1L57	RAMAGUNDAM - HYDERABAD - IV	201.236	SR-I	--	03/02/21	01:23	03/02/21	02:31						1.13							99.83			
						Sub Total -->																			
58	SR1L58	RAMAGUNDAM - MALKARAM	166.212	SR-I	--										0.00							100.00			
						Sub Total -->																			
59	SR1L59	RAMAGUNDAM - NSAGAR - I	267.200	SR-I	--	17/02/21	21:55	01/03/21	00:00						266.08							100.00			
						Sub Total -->																			
60	SR1L60	RAMAGUNDAM - NSAGAR - II	267.200	SR-I	--	10/02/21	22:35	11/02/21	11:02						12.45							100.00			
						14/02/21	22:11	15/02/21	07:44						9.55							100.00			
						Sub Total -->																			

Sl No.	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency	
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available							
61	SR1L61	RAMAGUNDAM - WARANGAL	98.803	SR-I	--																100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
62	SR1L62	SIMHADRI - GAJUWAKA - I	13.233	SR-I	--	02/02/21	08:40	06/02/21	20:33										H/T on request of M/S NTPC vide SR-156.S/D availed by M/S NTPC.		100.00		
Sub Total -->													0.00	0.00	0.00	107.88							
63	SR1L63	SIMHADRI - GAJUWAKA - II	13.272	SR-I	--																100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
64	SR1L64	VEMAGIRI - SIMHADRI - I	193.326	SR-I	--																100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
65	SR1L65	VEMAGIRI - SIMHADRI - II	193.326	SR-I	--																100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
66	SR1L66	VIJAYAWADA - GAJUWAKA	316.899	SR-I	--																100.00		
Sub Total -->													0.00	0.00	0.00	0.00	--	--	--				
67	SR1L67	VIJAYAWADA - NELLORE - I	340.000	SR-I	--																100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
68	SR1L68	VIJAYAWADA - NELLORE - II	340.000	SR-I	--																100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
69	SR1L69	VIJAYAWADA-NELLORE(AP)	330.393	SR-I	--	19/02/21	09:43	19/02/21	18:02										S/d availed by M/S APTRANSCO vide code SR-2998		100.00		
Sub Total -->													0.00	0.00	0.00	8.32							
70	SR1L70	VIJAYAWADA - VEMAGIRI - III	195.210	SR-I	--																100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
71	SR1L71	VIJAYAWADA - VEMAGIRI - IV	195.210	SR-I	--																100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
72	SR1L72	VTPS-NELLORE(AP)	330.870	SR-I	--																100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
73	SR1L73	WARANGAL - KHAMMAM	117.087	SR-I	--	01/02/21	00:00	02/02/21	07:44										Line kept under voltage regulation vide SR-3285 after AMP works.		100.00		
Sub Total -->													0.00	0.00	0.00	31.73							
74	SR1L74	VEMAGIRI(PG) - GAJUWAKA	165.454	SR-I																	100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
75	SR1L75	VIJAYAWADA - VEMAGIRI(PG)	187.8	SR-I																	100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
76	SR1L76	MAHESHWARAM-KURNOOL AP	174.996	SR-I																	100.00		
Sub Total -->													0.00	0.00	0.00	0.00							
77	SR1L77	NIZAMABAD-DICHPALLY 1	4.428	SR-I																	100.00		
Sub Total -->													0.00	0.00	0.00	0.00							

Sl No.	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency		
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available								
78	SR1L78	NIZAMABAD-DICHPALLY 2	4.428	SR-1																	100.00			
						Sub Total -->							0.00	0.00	0.00	0.00								
79	SR1L79	NIZAMABAD-MAHESHWARAM 1	243.059	SR-1		02/02/21	20:06	03/02/21	07:14												H/T under voltage regulation vide SR-255,NL-211. Voltages:Trip-NZB:807KV/798KV,MHW-782KV Close-NZB-758/776KV,MHW-745/765KV	100.00		
						07/02/21	18:09	08/02/21	06:07													H/T under voltage regulation vide code:SR-1021,NL-721 NZB:805/790KV,MHW:800/729KV.		
						10/02/21	19:36	11/02/21	06:43													H/T under voltage regulation vide SR-1556/NL-1058 Bus Voltages : Trip: NZB-805/796kV MHW-798/781 Close: NZB: 770KV/774KV , MHW: 756KV/774KV		
						16/02/21	18:08	17/02/21	05:17													H/T under voltage regulation vide code SR-2501,NL-1569 (NZM end:800KV/790KV;MHW end: 79KV/784KV)		
						18/02/21	18:35	19/02/21	06:37													H/T under voltage regulation Vide SR-2888/NL-1775. Trip Voltages : NZB-805/787kV MHW-797/771kV Close voltages: NZB-765/780KV MHW-749/769KV		
						23/02/21	18:21	24/02/21	06:11													H/T under voltage regulation vide code:SR-3569,NL-2152 NZB:791/777KV MHW:785/773KV		
						26/02/21	19:04	27/02/21	06:08													H/T under voltage regulation vide SR-3968/NL-2410 Bus Voltages: Trip NZB-806/789kV MHW-796/773kV		
						Sub Total -->							0.00	0.00	0.00	80.30								
80	SR1L80	NIZAMABAD-MAHESHWARAM 2	243.059	SR-1		01/02/21	00:00	01/02/21	06:27												H/T under voltage Regulation vide SR-3664 NL-3159 Voltage : NZB-810/806/793KV,MHW-804/798/779KV	100.00		
						01/02/21	19:22	02/02/21	06:40													H/T under voltage regulation vide code SR-117,NL-94; MHW end: 780KV/766KV; NZMB end:792KV/779KV		
						03/02/21	19:57	04/02/21	06:31													H/T under voltage regulation Vide SR-412/NL-320 Bus Voltages : NZB-797/790kV MHW-787/777		
						04/02/21	20:16	05/02/21	06:27													H/T on voltage regulation vide SR-569 NL-420 NZB end:807/804/798 kV MHW end:802/794/781 kV		
						05/02/21	19:19	06/02/21	06:54													H/T under voltage regulation vide SR-755, NL-539 (NZB: 806/801/791kV, MHW: 799/792/782kV)		
						06/02/21	18:42	07/02/21	07:04													H/T under voltage regulation vide code:SR-917,NL-627 NZB:800/782KV,MHW:792/771KV		
						08/02/21	18:32	09/02/21	06:13													H/T under voltage regulation vide SR-1170 NL-819 Voltage : NZB-803/803/792KV, MHW-797/792/781KV		
						09/02/21	19:11	10/02/21	06:41													H/T under voltage regulation vide SR-1367 NL-935 Voltage : NZB-805/805/794, MHW-802/796/784KV		
						11/02/21	18:38	12/02/21	05:35													H/T Under Voltage regulation vide SR-1700/ NL-1112 Bus Voltages : Open: MHW-795/774kV NZB-803/792kV Close: NZB-772/787kV MHW-764/783kV		
						12/02/21	19:30	13/02/21	05:42													H/T under voltage regulation vide SR-1906,NL-1217.Voltages:NZB:803KV/793KV&MHW:798KV/777KV		
						13/02/21	20:12	14/02/21	05:47													H/T vide under voltage regulation vide SR-2069 NL1302 NZB:803/803/797kV MHW:799/796/779kV		
						14/02/21	16:58	15/02/21	06:43													H/T under voltage regulation vide code:SR-2140,NL-1360 NZB:773/759KV MHW:773/758KV		
						15/02/21	18:11	16/02/21	06:16													H/T under voltage regulation vide code:SR-2307,NL-1461 NZB:803/790KV MHW:802/790KV		
						17/02/21	18:43	18/02/21	05:54													H/T under voltage Regulation vide SR-2695 NL-1960 Voltage : NZB-802/798/788KV,MHW-795/788/773 kV		
						19/02/21	18:14	20/02/21	05:49													H/T under voltage regulation vide SR-3068/NL-1866 Bus Voltages NZB:806/791 MHW:800/781KV Close voltages:NZB-784/795KV,MHW-775/793KV		
						20/02/21	18:49	21/02/21	06:28														H/T under Voltage Regulation vide SR-3223-NL-1940 open:NZB:799/795/786kV open MHW:793/789/779kV close: NZB:771KV/781KV; close MHW:765KV/775KV	
						21/02/21	17:55	22/02/21	06:24														H/T under voltage regulation vide SR-3305, NL-2001 (NZB:802/798/787kV; MHW:797/791/782kV).Taken into service vide SR-3332,NL-2024.Volatges-NZB:760KV/772KV;MHW:751KV/769KV.	
						22/02/21	17:52	23/02/21	07:16														H/T under voltage regulation vide code:SR-3436,NL-2070 NZB:786/774KV MHW:787/771KV Closing:(NZB:750/755kV; MHW:736/744kV)	
						24/02/21	19:05	25/02/21	06:10														H/T under voltage Regulation vide SR-3705, NL-2236 Voltage : NZB-804/792KV,MHW-796/777KV	
						25/02/21	19:58	26/02/21	06:03														H/T under voltage Regulation vide SR-3843 NL-2329 Voltage : NZB-808/798KV, MHW-801/781KV	
						27/02/21	20:32	28/02/21	06:38														H/T under voltage regulation vide SR-4129/NL-2503. Close: NZB-812/799KV MHW-804/783KV Open: NZB-752/768KV MHW-748/762KV	

Sl No.	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available						
						28/02/21	18:29	01/03/21	00:00										H/T under Voltage regulation vide SR-4204 NKL-2549 MHW end:802/795/784 Nzb:808/803/797kV			
						Sub Total -->							0.00	0.00	0.00	239.28						
81	SR1L81	NIZAMABAD-WARDHA 1	291.2	SR-I																	100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
82	SR1L82	NIZAMABAD-WARDHA 2	291.2	SR-I		13/02/21	07:49	13/02/21	20:13										H/T for construction of Wardha-Nizamabad-2 line Dimond formation works (win400kV Parti-Bhadrawati line) vide WR-1678, NLDC-1245, SR-1927		100.00	
						14/02/21	08:09	14/02/21	19:26										H/T for construction of Wardha-Nizamabad-2 line Dimond formation works (win400kV Parti-Bhadrawati line) vide SR-2090,WR-1788 NL-1325			
						Sub Total -->							0.00	0.00	0.00	0.00						
83	SR1L83	VIJAYAWADA-VEMAGIRI PG 1	187.8	SR-I																	100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
84	SR1L84	VIJAYAWADA-VEMAGIRI PG 2	187.8	SR-I																	100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
85	SR1L85	VIJAYAWADA-VEMAGIRI PG 3	187.8	SR-I																	100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
86	SR1L86	KADAPA- CHITTOOR	147.14	SR-I																	100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
87	SR1L87	VEMAGIRI PG - SIMHADRI-I	180.98	SR-I																	100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
88	SR1L88	VEMAGIRI PG - SIMHADRI-II	180.98	SR-I																	100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
89	SR1L89	VEMAGIRI PG - VEMAGIRI AP - I	38.41	SR-I		17/02/21	10:50	17/02/21	15:37										S/D availed by APTrasco for maintenance works vide code:sr-2616		100.00	
						Sub Total -->							0.00	0.00	0.00	4.78						
90	SR1L90	VEMAGIRI PG - VEMAGIRI AP - II	38.41	SR-I		19/02/21	10:19	19/02/21	14:27										H/T on request of M/S APTRANSCO vide SR-3007.S/D availed by M/S APTRANSCO.		100.00	
						Sub Total -->							0.00	0.00	0.00	4.13						
91	SR1L91	400KV KADAPA - NP KUNTA - II	68.69	SR-I																	100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
92	SR1L92	400KV KADAPA - NP KUNTA - III	68.69	SR-I																	100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						
93	SR1L93	765KV KADAPA-THIRUVALAM 1		SR-I		02/02/21	23:06	04/02/21	07:45										H/T under voltage regulation vide code:SR-264,NL-222 809/800KV		100.00	

Sl No:	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available						
			245.7																			
						Sub Total -->							0.00	0.00	0.00	32.65						
94	SR1L94	765KV KADAPA-THIRUVALAM 2		SR-1		01/02/21	00:00	02/02/21	10:00												98.32	
						04/02/21	07:59	04/02/21	19:18				11.32									
						05/02/21	23:01	06/02/21	07:35													
						06/02/21	23:09	09/02/21	07:58													
						09/02/21	20:43	10/02/21	07:56													
						11/02/21	22:08	12/02/21	10:08													
						12/02/21	21:27	13/02/21	08:47													
						13/02/21	20:43	15/02/21	08:19													
						15/02/21	18:04	16/02/21	07:31													
						16/02/21	18:05	17/02/21	06:52													
						19/02/21	22:59	20/02/21	09:58													
						21/02/21	15:45	22/02/21	06:54													
						Sub Total -->							11.32	0.00	0.00	221.90						
95	SR1L95	765KV KADAPA-KURNOOL 1		SR-1		15/02/21	18:02	15/02/21	18:07												99.70	
						15/02/21	18:07	16/02/21	07:19													
						19/02/21	22:34	19/02/21	22:34				0.00									
						19/02/21	22:39	20/02/21	14:55													
						20/02/21	14:55	21/02/21	07:53													
						21/02/21	17:19	21/02/21	19:16				1.95									
						21/02/21	19:16	22/02/21	07:09													
						Sub Total -->							1.95	0.00	16.35	42.05						
96	SR1L96	765KV KADAPA-KURNOOL 2		SR-1																	100.00	
						Sub Total -->							0.00	0.00	0.00	0.00						

Sl No:	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVAcr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency		
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available								
102	SR1T27	VIJAYAWADA ICT II	315	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
103	SR1T28	WARANGAL ICT I	315	SR-I	--	--	--	--	--	--	--										100.00			
													0.00	0.00	0.00	0.00								
105	SR1T29	WARANGAL ICT II	315	SR-I	--	--	--	--	--	--	--										100.00			
													0.00	0.00	0.00	0.00								
106	SR1T30	VEMAGIRI ICT I	1500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
107	SR1T31	VEMAGIRI ICT II	1500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
108	SR1T32	NIZAMABAD ICT I	1500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
109	SR1T33	NIZAMABAD ICT II	1500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
110	SR1T34	MAHESHWARAM ICT I	1500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
111	SR1T35	MAHESHWARAM ICT II	1500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
112	SR1T36	HYDERABAD ICT IV	500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
113	SR1T37	GOOTY ICT III	500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
114	SR1T38	KHAMMAM ICT III	500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
115	SR1T39	WARANGAL ICT III	500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
116	SR1T40	SRIKAKULAM 765/400KV ICT I	500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
117	SR1T41	SRIKAKULAM 765/400KV ICT II	500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
118	SR1T42	VIJAYAWADA ICT III	500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
119	SR1T43	KADAPA ICT III	500	SR-I	--																100.00			
													0.00	0.00	0.00	0.00								
119	SR1R01	KURNOOL(NEW) BUS REACTOR	240	SR-I	--	01/02/21	11:05	01/02/21	17:46												100.00			
													6.68											
													9.03											
													11.95											
													11.57											
													9.45											
													48.68											
120	SR1R02	NELLOREPS BUS REACTOR	240	SR-I	--	04/02/21	10:25	04/02/21	20:56												100.00			
													10.52											
													14.23											
													9.00											
													7.90											
													10.45											
													11.92											
													8.95											

Sl No.	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available						
													0.00	0.00	0.00	0.00						
136	SR1R18	765 KV SRIKAKULAM-VEMAGIRI 1 LR	240	SR-I	--																100.00	
													0.00	0.00	0.00	0.00						
137	SR1R19	330MVAR BUS REACTOR at SKLM	330	SR-I	--																100.00	
													0.00	0.00	0.00	0.00						
138	SR1R20	VEMAGIRI 240MVAR BUS REACTOR-I	240	SR-I	--																100.00	
													0.00	0.00	0.00	0.00						
139	SR1R21	VEMAGIRI 240MVAR BUS REACTOR-II	240	SR-I	--																100.00	
													0.00	0.00	0.00	0.00						
140	SR1R22	VEMAGIRI 80MVAR BUS REACTOR	80	SR-I	--																100.00	
													0.00	0.00	0.00	0.00						
141	SR1R23	MAHESHWARAM BUS REACTOR 1	240	SR-I	--	05/02/21	08:22	05/02/21	18:00							9.63				H/T under voltage regulation vide SR-624,NL-454.Voltage:751KV/761KV		100.00
						08/02/21	07:31	08/02/21	17:29							9.97				H/T under voltage regulation vide code SR-1065,NL-753 Voltage : Open-751/759KV, Close-790/781KV		
						12/02/21	07:38	12/02/21	18:19							10.68				H/T under voltage regulation vide SR-1759/NL-1163 Bus Voltages:744/754KV		
						13/02/21	09:07	13/02/21	17:34							8.45				H/T under voltage regulation vide Sr-1964, NL-1260. Voltages : 756/767KV Closing: (787/777kV)		
						14/02/21	09:25	14/02/21	19:51							10.43				H/T under voltage regulation vide SR-2104, NL-1328		
						15/02/21	07:44	15/02/21	20:36							12.87				H/T under voltage regulation vide SR-2198, NL-1408		
						16/02/21	07:29	16/02/21	19:59							12.50				H/T under voltage regulation vide code:SR-2362,NL-1508 745/754KV		
						17/02/21	06:54	17/02/21	18:06							11.20				H/T under voltage regulation vide SR-2555 NL-1607 Voltage:803/792 KV		
						18/02/21	07:57	18/02/21	17:41							9.73				H/T under voltage regulation vide code SR-2764,NL-1702 trip Voltage (742KV/753KV) Closed Vide SR-2865/NL-1752 Voltages (806/795 kV)		
						19/02/21	07:58	19/02/21	17:13							9.25				H/T under voltage regulation vide SR-2962 NL-1825 Trip Voltage:745/756KV Vide SR-3055,NL-1858 taken into service Close Voltages:794/786kV		
						23/02/21	07:27	23/02/21	18:15							10.80				H/T under voltage regulation vidr SE-3479 NL-2108 753/762 kV Close:790/794KV		
						24/02/21	07:20	24/02/21	18:11							10.85				H/T under voltage regulation vide code:SR-3603,NL-2185 Voltage : Open-746/754KV, Close-797/789KV		
						25/02/21	07:03	25/02/21	18:14							11.18				H/T under Voltage regulation vide SR-3734 NL-2264 Bus voltage: Open-752/761kV, Close-793/785KV		
						26/02/21	07:17	26/02/21	18:16							10.98				H/T under voltage Regulation vide SR-3872 NL-2352 Voltage: Open-746/755KV BR-I taken into service vide SR-3954/NL-2404 Voltage: Close- 809/802kV		
						27/02/21	07:22	27/02/21	17:39							10.28				H/T under voltage Regulation vide SR-3996 NL-2437 Voltage : Open-748/755KV Taken into service vide SR-4090/NL-2484 Bus Voltages : Close - 783/773KV		
						28/02/21	08:33	28/02/21	17:27							8.90				H/T under voltage regulation vide SR-4159, NL-2525, RT02/1560. Voltages 751/760KV.		
													0.00	0.00	0.00	167.72						
142	SR1R24	POLE-2 EAST REACTOR	125	SR-I	--	01/02/21	00:00	01/03/21	00:00							672.00				H/T for voltage regulation vide code SR 757, continued from last month		100.00
													0.00	0.00	0.00	672.00						
143	SR1R25	VIJAYWADA BUS REACTOR 4	125	SR-I	--	10/02/21	09:36	10/02/21	18:01							8.42				H/T for AMP works vide SR-1459		98.75
													8.42	0.00	0.00	0.00						
144	SR1R26	NAGARJUNA SAGAR BUS REACTOR II	125	SR-I	--																100.00	

Sl No.	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available						
						Sub Total -->							0.00	0.00	0.00	0.00						
145	SR1R27	WARDHA 1 LR AT NIZAMABAD	240	SR-I	..																	100.00
						Sub Total -->																
146	SR1R28	WARDHA 2 LR AT NIZAMABAD	240	SR-I	..																	100.00
						Sub Total -->																
147	SR1R29	SOLAPUR - RAICHUR -I LR	240	SR-I	..																	100.00
						Sub Total -->																
148	SR1R30	ANGUL - SRIKAKULAM - I LR	240	SR-I	..																	100.00
						Sub Total -->																
149	SR1R31	ANGUL - SRIKAKULAM - II LR	240	SR-I	..																	100.00
						Sub Total -->																
150	SR1R32	WARDHA - NIZAMABAD - I L/R	240	SR-I	..																	100.00
						Sub Total -->																
151	SR1R33	WARDHA - NIZAMABAD - II L/R	240	SR-I	..																	100.00
						Sub Total -->																
152	SR1R34	HYDERABAD - GAJWEL LR	50	SR-I	..																	100.00
						Sub Total -->																
153	SR1R35	NELLORE - THIRUVALAM - I LR	50	SR-I	..																	100.00
						Sub Total -->																
154	SR1R36	NELLORE - THIRUVALAM - II LR	50	SR-I	..																	100.00
						Sub Total -->																
155	SR1R37	GOOTY - KURNOOL LR	50	SR-I	..																	100.00
						Sub Total -->																
156	SR1R38	GOOTY BUS REACTOR 2	125	SR-I	..																	100.00
						Sub Total -->																
157	SR1R39	NELLORE BUS REACTOR 2	125	SR-I	..	17/02/21	09:55	01/03/21	00:00												H/T for Reactor dismantling works vide code:SR-2606	100.00
						Sub Total -->																
158	SR1R40	NIZAMABAD 765KV BUS REACTOR 1	240	SR-I	..																	100.00
						Sub Total -->																
159	SR1R40	KADAPA BUS REACTOR -2	125	SR-I	..	05/02/21	10:11	05/02/21	18:07												H/T under voltage regulation vide SR-658,NL-479.Voltage:761KV/770KV	100.00
						Sub Total -->																
159	SR1R41	NPS-GOOTY-1 L/R	63	SR-I	..																	100.00

Sl No:	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available						
													0.00	0.00	0.00	0.00						
160	SR1R42	NPS-GOOTY-2 L/R	63	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						
161	SR1R43	SRIKAKULAM-ANGUL 1 L/R	240	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						
162	SR1R44	SRIKAKULAM-ANGUL 2 L/R	240	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						
163	SR1R45	VEMAGIRI-SRIKAKULAM1 L/R	240	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						
164	SR1R46	VEMAGIRI-SRIKAKULAM2 L/R	240	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						
165	SR1R47	VIJAYWADA BUS REACTOR 3	125	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						
166	SR1R48	NIZAMABAD-WARDHA -I L/R	240	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						
167	SR1R49	NIZAMABAD-WARDHA -II L/R	240	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						
168	SR1R50	MAHESHWARAM BUS REACTOR -II	240	SR-I	..	09/02/21	07:24	09/02/21	17:45													100.00
						17/02/21	07:43	17/02/21	18:08													
						18/02/21	07:57	18/02/21	17:58													
						22/02/21	07:30	22/02/21	18:24													
						26/02/21	08:29	26/02/21	18:17													
													0.00	0.00	0.00	51.48						
169	SR1R51	NELLORE PS BUS REACTOR -II	240	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						
169	SR1R51	MAHESHWARAM-NIZAMABAD-I L/R	240	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						
170	SR1R52	MAHESHWARAM-NIZAMABAD-II L/R	240	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						
171	SR1R38	NIZAMABAD-MAHESHWARAM I L/R	240	SR-I	..																	100.00
													0.00	0.00	0.00	0.00						

Sl No:	Unique ID of transmission Element	Element Name	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Details of Outage		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Restoration Time as per Regulation 5(b) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency		
						Date	Time	Date	Time	No. of towers damaged	no. of insulator failed		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available								
172	SR1R53	NIZAMABAD-MAHESHWARAM II L/R	240	SR-I	--																	100.00		
Sub Total -->													0.00	0.00	0.00	0.00								
173	SR1R54	JEYPORE LR-1 AT GAJUWAKA	80	SR-I	--																	100.00		
Sub Total -->													0.00	0.00	0.00	0.00								
174	SR1R55	JEYPORE LR-2 AT GAJUWAKA	80	SR-I	--																	100.00		
Sub Total -->													0.00	0.00	0.00	0.00								
175	SR1B1	GAJUWAKA BACK TO BACK POLE - I	500	SR-I	--																	100.00		
Sub Total -->													0.00	0.00	0.00	0.00								
176	SR1B2	GAJUWAKA BACK TO BACK POLE - II	500	SR-I	--																	100.00		
Sub Total -->													0.00	0.00	0.00	0.00								
177	SR1B3	TALCHER - KOLAR HVDC POLE - I	1000	SR-I	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	100.00		
Sub Total -->													0.00	0.00	0.00	0.00								
178	SR1B4	TALCHER - KOLAR HVDC POLE - II	1000	SR-I	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	100.00		
Sub Total -->													0.00	0.00	0.00	0.00								
179	SR1S1	STATCOM AT NPKUNTA	100	SR-I	--																	100.00		
Sub Total -->													0.00	0.00	0.00	0.00								
180	SR1S1	STATCOM AT HYDERABAD	200	SR-I	--	03/02/21	01:15	01/03/21	00:00	622.75												7.33		
Sub Total -->													622.75	0.00	0.00	0.00								