



SRTS - I :: SECUNDERABAD
Operation Services

INTER OFFICE MEMO

From: Chief Manager (OS)
Secunderabad.

To: DGM (OS)
SRLDC, Bangalore

Ref:SR-I:OS: : :2014

Date: 16/10/14

Subject: SOP data of SRTS-1 for the month of September 2014.

Please find attached the SOP data of Non Switchable Line Reactors & FSCs of SRTS-I for the month of September 2014.

This is for kind information and further needful action please.

Regards

SDCS RAO

EXCLUSIVE OUTAGE OF STATIC VAR COMPENSATOR/SERIESE COMPENSATOR/

31

SEPTEMBER-2014

Sl.No	ELEMENT NAME	Capacity	TRIP DATE/TIME	REST DATE/TIME	OUTAGE DURATION			Availability	Reason
					POWERG RID SR-1	OTHERS	SYSTEM CONSTRAINT / NATURAL CALAMITY / MILITANCY		
							DEEMED AVAILAB LE		
1	GTY LR at NSR	50.00						100.00%	
2	GWK I LR at VJA	63.00						100.00%	
3	GWL LR at HYD	50.00						100.00%	
4	JEV I LR at GWK	80.00						100.00%	
5	JEV II LR at GWK	80.00						100.00%	
6	MBN LR at NSR	63.00						100.00%	
7	MLK LR at HYD	50.00						100.00%	
8	NLR I LR at VJA	50.00						100.00%	
9	NLR II LR at VJA	50.00						100.00%	
10	NSR I LR at CDP	50.00						100.00%	
11	NSR II LR at CDP	50.00						100.00%	
12	NSR LR at GTY	50.00						100.00%	
13	POLE II ER at GWK	80.00						100.00%	
14	POLE II SR at GWK	80.00						100.00%	
15	RGR LR at MBD	63.00						100.00%	
16	RDM I LR at NSR	50.00						100.00%	
17	RDM II LR at NSR	50.00						100.00%	
18	SMH I LR at GWK	63.00						100.00%	
19	SMH II LR at GWK	63.00						100.00%	
20	VJA I LR at GWK	63.00						100.00%	
21	VJA II LR at NLR	50.00						100.00%	
22	VJA III LR at NLR	50.00						100.00%	
23	VMG III LR at VJA	63.00						100.00%	
24	VMG IV LR at VJA	63.00						100.00%	
25	WGL LR at KMM	50.00						100.00%	
26	NSR I FSC at CDP	201.75						100.00%	
27	NSR II FSC at CDP	201.75						100.00%	
28	FSC-1 at GTY	181.5						100.00%	
29									
	FSC-2 at GTY	181.5	20.09.14 09:00	20.09.14 17:12	8.2			98.90%	FSC-II was taken out from service vide cccc code CP09/668, SRLDC code 527 for Gooty- Nelamangala line S/D works & 2252 Bay AMP works carried out on line equipment. 1 No Capacitor in Y Ph & 1 No Capacitor in B Ph are replaced in FSC -II. FSC -II was taken in to service vide cpc code CP09/679.
30	TVLM1 LR at NLR	50.00						100.00%	
31	TVLM2 LR at NLR	50.00						100.00%	
					8.20	0.00	0.00	0.00	

(Handwritten signature)