

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	11-01-2023	09:28:00	11-01-2023	16:19:00	0.29	0.00	0.00	0.00	6.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1854(394 - 394Kv)
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	10-01-2023	08:53:00	10-01-2023	16:07:00	0.30	0.00	0.00	0.00	7.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1635(408 - 408Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	05-01-2023	09:46:00	05-01-2023	20:26:00	0.44	0.00	0.00	0.00	10.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/733 (393-396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	03-01-2023	11:02:00	03-01-2023	17:44:00	0.28	0.00	0.00	0.00	6.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/367(396 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	09-01-2023	08:15:00	09-01-2023	16:49:00	0.36	0.00	0.00	0.00	8.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1412(399-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	30-01-2023	09:17:00	30-01-2023	16:18:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4952 (393-393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	23-01-2023	09:52:00	23-01-2023	18:03:00	0.34	0.00	0.00	0.00	8.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3842 (395 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	29-01-2023	09:55:00	29-01-2023	16:27:00	0.27	0.00	0.00	0.00	6.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4785(396-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	20-01-2023	08:03:00	20-01-2023	16:24:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3310 (400-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	25-01-2023	08:41:00	25-01-2023	18:02:00	0.39	0.00	0.00	0.00	9.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4160(406-408 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	19-01-2023	08:05:00	19-01-2023	16:26:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3110(400 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	24-01-2023	08:15:00	24-01-2023	17:23:00	0.38	0.00	0.00	0.00	9.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3974(406 406- Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	14-01-2023	09:23:00	14-01-2023	16:47:00	0.31	0.00	0.00	0.00	7.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2393 (398 -399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	27-01-2023	08:31:00	27-01-2023	16:33:00	0.34	0.00	0.00	0.00	8.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4427(403 - 404Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	21-01-2023	09:18:00	21-01-2023	17:46:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3529 (395-396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	28-01-2023	09:18:00	28-01-2023	21:00:00	0.49	0.00	0.00	0.00	11.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4601(395 - 397 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	18-01-2023	08:40:00	18-01-2023	16:49:00	0.34	0.00	0.00	0.00	8.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2918(405-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	26-01-2023	09:20:00	26-01-2023	16:27:00	0.30	0.00	0.00	0.00	7.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4326(399 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	31-01-2023	09:31:00	31-01-2023	16:28:00	0.29	0.00	0.00	0.00	6.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/5109 (395 395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	07-01-2023	10:00:00	07-01-2023	16:31:00	0.27	0.00	0.00	0.00	6.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1128 (396-396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	02-01-2023	08:56:00	02-01-2023	16:14:00	0.30	0.00	0.00	0.00	7.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/169(403 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	04-01-2023	09:15:00	04-01-2023	20:44:00	0.48	0.00	0.00	0.00	11.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/546 (395-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	12-01-2023	08:59:00	12-01-2023	16:06:00	0.30	0.00	0.00	0.00	7.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2031 (404-405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	01-01-2023	10:44:00	01-01-2023	16:11:00	0.23	0.00	0.00	0.00	5.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 1/07(397-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	13-01-2023	08:28:00	13-01-2023	23:54:00	0.64	0.00	0.00	0.00	15.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2212(404-406 Kv)
							8.68	0.00	0.00	0.00	208.05	100.00	
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	25-01-2023	10:47:00	26-01-2023	18:27:00	1.32	0.00	0.00	0.00	31.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4203(396-399 Kv).
							1.32	0.00	0.00	0.00	31.67	100.00	
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	04-01-2023	10:45:00	04-01-2023	20:00:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/570(393 -395 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	11-01-2023	10:47:00	11-01-2023	17:18:00	0.27	0.00	0.00	0.00	6.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1875(396 - 401Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	10-01-2023	08:46:00	10-01-2023	16:37:00	0.33	0.00	0.00	0.00	7.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1629(406 -406 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	02-01-2023	11:19:00	02-01-2023	16:30:00	0.22	0.00	0.00	0.00	5.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/197(392 - 394Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	06-01-2023	09:17:00	06-01-2023	16:40:00	0.31	0.00	0.00	0.00	7.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/912(395-397 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	14-01-2023	10:15:00	14-01-2023	17:18:00	0.29	0.00	0.00	0.00	7.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2420 (394 -397 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	13-01-2023	08:32:00	13-01-2023	20:58:00	0.52	0.00	0.00	0.00	12.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2213(408-411 Kv)
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	25-01-2023	11:59:00	25-01-2023	20:43:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4210(396-401 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	16-01-2023	10:31:00	16-01-2023	16:34:00	0.25	0.00	0.00	0.00	6.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2644(393-396 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	24-01-2023	09:06:00	24-01-2023	21:07:00	0.50	0.00	0.00	0.00	12.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3972(403 - 403 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	30-01-2023	09:21:00	30-01-2023	16:43:00	0.31	0.00	0.00	0.00	7.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/ 9556 (393 - 394 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	29-01-2023	08:25:00	29-01-2023	21:03:00	0.53	0.00	0.00	0.00	12.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4772(408-412 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	19-01-2023	08:23:00	19-01-2023	14:52:00	0.27	0.00	0.00	0.00	6.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3113(401 - 405Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	18-01-2023	11:43:00	18-01-2023	17:09:00	0.23	0.00	0.00	0.00	5.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2973(396-398 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	27-01-2023	10:49:00	27-01-2023	19:08:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4475(395 - 399Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	15-01-2023	11:44:00	15-01-2023	17:43:00	0.25	0.00	0.00	0.00	5.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/ 2538 (389 - 392 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	23-01-2023	09:20:00	23-01-2023	18:09:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3817 (398-402 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	08-01-2023	09:58:00	08-01-2023	17:18:00	0.31	0.00	0.00	0.00	7.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1313(388-392 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	05-01-2023	08:48:00	05-01-2023	20:37:00	0.49	0.00	0.00	0.00	11.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/704 (410 -413 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	07-01-2023	09:38:00	07-01-2023	22:18:00	0.53	0.00	0.00	0.00	12.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1119 (391-395 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	03-01-2023	08:45:00	03-01-2023	18:03:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/334(408 - 411Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	12-01-2023	10:32:00	12-01-2023	16:01:00	0.23	0.00	0.00	0.00	5.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2051 (393-396 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	09-01-2023	09:38:00	09-01-2023	16:45:00	0.30	0.00	0.00	0.00	7.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1449(393-396 Kv).
							8.00	0.00	0.00	0.00	191.21	100.00	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	28-01-2023	08:19:00	28-01-2023	21:11:00	0.54	0.00	0.00	0.00	12.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4580(400 - 403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	11-01-2023	09:26:00	11-01-2023	17:16:00	0.33	0.00	0.00	0.00	7.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1839(397 - 403Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	01-01-2023	10:34:00	01-01-2023	16:29:00	0.25	0.00	0.00	0.00	5.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 1/09(389-406 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	07-01-2023	09:39:00	07-01-2023	16:54:00	0.30	0.00	0.00	0.00	7.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1120 (395 -400 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	02-01-2023	09:15:00	02-01-2023	16:32:00	0.30	0.00	0.00	0.00	7.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/176(394 - 398Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	05-01-2023	11:07:00	05-01-2023	20:34:00	0.39	0.00	0.00	0.00	9.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/755 (393-398Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	08-01-2023	09:59:00	08-01-2023	17:21:00	0.31	0.00	0.00	0.00	7.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1312(392-398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	12-01-2023	09:22:00	12-01-2023	16:03:00	0.28	0.00	0.00	0.00	6.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/ 2032 (402-408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	10-01-2023	08:49:00	10-01-2023	16:44:00	0.33	0.00	0.00	0.00	7.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1630(406 - 411Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	03-01-2023	08:47:00	03-01-2023	18:06:00	0.39	0.00	0.00	0.00	9.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/333(411 - 417Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	09-01-2023	08:17:00	09-01-2023	16:47:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1418(398-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	06-01-2023	09:19:00	06-01-2023	16:37:00	0.30	0.00	0.00	0.00	7.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/913(398-403 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	31-01-2023	09:39:00	31-01-2023	16:37:00	0.29	0.00	0.00	0.00	6.97	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/5112 (396 -400 Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	16-01-2023	08:27:00	16-01-2023	16:35:00	0.34	0.00	0.00	0.00	8.13	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2625(405-409 Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	24-01-2023	08:09:00	24-01-2023	17:20:00	0.38	0.00	0.00	0.00	9.18	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3973(402 - 406 Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	23-01-2023	09:18:00	23-01-2023	18:37:00	0.39	0.00	0.00	0.00	9.32	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3820 (402 -404 Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	19-01-2023	09:23:00	19-01-2023	14:55:00	0.23	0.00	0.00	0.00	5.53	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3123(396 - 402Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	25-01-2023	08:37:00	25-01-2023	16:47:00	0.34	0.00	0.00	0.00	8.17	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4163(405-408 Kv).Enter text	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	20-01-2023	08:24:00	20-01-2023	20:46:00	0.52	0.00	0.00	0.00	12.37	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3314 (404-407 Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	26-01-2023	08:56:00	26-01-2023	16:44:00	0.33	0.00	0.00	0.00	7.80	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4318(402 - 406Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	18-01-2023	08:46:00	18-01-2023	17:15:00	0.35	0.00	0.00	0.00	8.48	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2916(405-409 Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	27-01-2023	08:35:00	27-01-2023	17:07:00	0.36	0.00	0.00	0.00	8.53	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4429(403 - 408Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	29-01-2023	10:03:00	29-01-2023	19:52:00	0.41	0.00	0.00	0.00	9.82	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4796(400-405 Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	15-01-2023	10:20:00	15-01-2023	16:28:00	0.26	0.00	0.00	0.00	6.13	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2533(393-398 Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	17-01-2023	09:12:00	17-01-2023	17:21:00	0.34	0.00	0.00	0.00	8.15	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2757 (400 - 404 Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	30-01-2023	09:23:00	30-01-2023	16:52:00	0.31	0.00	0.00	0.00	7.48	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/ 4957 (395 -394 Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	13-01-2023	09:16:00	13-01-2023	17:31:00	0.34	0.00	0.00	0.00	8.25	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2230 (401-407 Kv).	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	04-01-2023	10:34:00	04-01-2023	20:02:00	0.39	0.00	0.00	0.00	9.47	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/568(389-394 Kv).	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	14-01-2023	09:07:00	14-01-2023	17:19:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2391 (389 -396 Kv).
							9.99	0.00	0.00	0.00	239.67	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	14-01-2023	10:02:00	14-01-2023	17:51:00	0.33	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2421 (398 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	13-01-2023	09:32:00	13-01-2023	18:41:00	0.38	0.00	0.00	0.00	9.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2227 (396 -397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	10-01-2023	10:03:00	10-01-2023	16:17:00	0.26	0.00	0.00	0.00	6.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1663(392-392 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	09-01-2023	11:08:00	09-01-2023	17:14:00	0.25	0.00	0.00	0.00	6.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1475(390-391 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	20-01-2023	09:45:00	20-01-2023	16:56:00	0.30	0.00	0.00	0.00	7.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3326 (392-393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	25-01-2023	12:06:00	25-01-2023	16:23:00	0.18	0.00	0.00	0.00	4.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4213(395 -398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	28-01-2023	11:24:00	28-01-2023	16:38:00	0.22	0.00	0.00	0.00	5.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4645(392 - 392 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	30-01-2023	09:29:00	30-01-2023	16:56:00	0.31	0.00	0.00	0.00	7.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4953 (399 - 399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	12-01-2023	09:08:00	12-01-2023	16:29:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2034 (402-403 Kv).
							2.54	0.00	0.00	0.00	60.79	100.00	
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	10-01-2023	10:48:00	10-01-2023	17:19:00	0.27	0.00	0.00	0.00	6.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1664(392 - 392Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	04-01-2023	10:33:00	04-01-2023	16:52:00	0.26	0.00	0.00	0.00	6.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/569(394 -394 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	30-01-2023	09:31:00	30-01-2023	16:55:00	0.31	0.00	0.00	0.00	7.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/ 4954 (399 -399 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	24-01-2023	09:49:00	24-01-2023	21:00:00	0.47	0.00	0.00	0.00	11.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4003 (396 - 396 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	29-01-2023	11:35:00	29-01-2023	21:22:00	0.41	0.00	0.00	0.00	9.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4812(396-400 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	25-01-2023	10:41:00	25-01-2023	16:36:00	0.25	0.00	0.00	0.00	5.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4201(388-390 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	27-01-2023	09:32:00	27-01-2023	16:39:00	0.30	0.00	0.00	0.00	7.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4443(397 - 398Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	28-01-2023	09:31:00	28-01-2023	16:39:00	0.30	0.00	0.00	0.00	7.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4599(396 - 397 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	09-01-2023	11:00:00	09-01-2023	17:56:00	0.29	0.00	0.00	0.00	6.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1476(391-393 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	12-01-2023	09:06:00	12-01-2023	17:25:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2033 (402-402 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	11-01-2023	09:50:00	11-01-2023	17:28:00	0.32	0.00	0.00	0.00	7.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1860(395 - 395Kv).
							3.53	0.00	0.00	0.00	84.25	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	31-01-2023	09:41:00	31-01-2023	21:41:00	0.50	0.00	0.00	0.00	12.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/5117 (393-393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	09-01-2023	08:16:00	09-01-2023	16:46:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1416(395-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	20-01-2023	08:05:00	20-01-2023	20:43:00	0.53	0.00	0.00	0.00	12.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3311 (392-393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	17-01-2023	09:15:00	17-01-2023	17:51:00	0.36	0.00	0.00	0.00	8.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2763 (397 - 397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	23-01-2023	09:09:00	24-01-2023	21:02:00	1.50	0.00	0.00	0.00	35.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3816 (393 393- Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	26-01-2023	09:53:00	26-01-2023	17:44:00	0.33	0.00	0.00	0.00	7.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4339(394 - 394Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	19-01-2023	09:35:00	19-01-2023	17:26:00	0.33	0.00	0.00	0.00	7.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3135(398 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	22-01-2023	08:34:00	22-01-2023	20:23:00	0.49	0.00	0.00	0.00	11.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3664 (402 - 402 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	21-01-2023	09:30:00	21-01-2023	17:03:00	0.32	0.00	0.00	0.00	7.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3541 (396-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	10-01-2023	11:12:00	10-01-2023	19:08:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1675(391 - 393Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	11-01-2023	09:26:00	14-01-2023	00:10:00	2.61	0.00	0.00	0.00	62.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1841(387 - 387Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	05-01-2023	08:39:00	07-01-2023	22:00:00	2.56	0.00	0.00	0.00	61.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/706 (394-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	14-01-2023	09:58:00	14-01-2023	17:02:00	0.29	0.00	0.00	0.00	7.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2422 (396 - 396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	27-01-2023	08:36:00	27-01-2023	19:04:00	0.44	0.00	0.00	0.00	10.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4432(397 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	30-01-2023	07:58:00	30-01-2023	23:59:00	0.67	0.00	0.00	0.00	16.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4920 (401 - 402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	29-01-2023	08:22:00	29-01-2023	20:53:00	0.52	0.00	0.00	0.00	12.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4770(399 -402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	15-01-2023	08:54:00	15-01-2023	20:15:00	0.47	0.00	0.00	0.00	11.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2521(405-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	28-01-2023	10:08:00	28-01-2023	18:12:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4621(390 - 390 Kv).
							12.94	0.00	0.00	0.00	310.19	100.00	
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	05-01-2023	08:43:00	07-01-2023	22:10:00	2.56	0.00	0.00	0.00	61.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/707 (398-40 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	11-01-2023	09:28:00	14-01-2023	00:29:00	2.63	0.00	0.00	0.00	63.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1842(387 - 392Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	20-01-2023	08:08:00	21-01-2023	17:11:00	1.38	0.00	0.00	0.00	33.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3312 (393-396 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	14-01-2023	09:13:00	14-01-2023	17:09:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2395 (388 -391 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	25-01-2023	10:44:00	25-01-2023	20:23:00	0.40	0.00	0.00	0.00	9.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4202(387-392 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	28-01-2023	10:09:00	28-01-2023	18:38:00	0.35	0.00	0.00	0.00	8.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4622(390 - 395 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	23-01-2023	09:12:00	24-01-2023	21:03:00	1.49	0.00	0.00	0.00	35.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3821 (390-391 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	22-01-2023	08:37:00	22-01-2023	20:24:00	0.49	0.00	0.00	0.00	11.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3665 (402 - 404 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	19-01-2023	09:29:00	19-01-2023	17:31:00	0.34	0.00	0.00	0.00	8.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3128(394 - 396Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	29-01-2023	08:23:00	29-01-2023	21:06:00	0.53	0.00	0.00	0.00	12.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4771(402 -406 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	17-01-2023	09:10:00	17-01-2023	17:17:00	0.34	0.00	0.00	0.00	8.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2762 (393 - 397 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	31-01-2023	09:45:00	31-01-2023	23:59:59	0.59	0.00	0.00	0.00	14.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/5116 (390-393 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	30-01-2023	07:59:00	31-01-2023	00:19:00	0.68	0.00	0.00	0.00	16.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4921 (402 - 403 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	16-01-2023	09:44:00	16-01-2023	16:32:00	0.28	0.00	0.00	0.00	6.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2638(391-394 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	27-01-2023	08:37:00	27-01-2023	19:18:00	0.45	0.00	0.00	0.00	10.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4433(399 - 403Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	10-01-2023	11:14:00	10-01-2023	19:06:00	0.33	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1674(393 - 397Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	09-01-2023	08:16:00	09-01-2023	17:00:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1417(392 -395 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	15-01-2023	08:58:00	15-01-2023	20:23:00	0.48	0.00	0.00	0.00	11.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2522(406-407 Kv).
							14.01	0.00	0.00	0.00	336.16	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	17-01-2023	09:00:00	17-01-2023	17:12:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2758 (403 - 405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	03-01-2023	08:40:00	03-01-2023	16:41:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/336(405 - 407Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	09-01-2023	08:16:00	09-01-2023	17:02:00	0.37	0.00	0.00	0.00	8.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1410(401-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	12-01-2023	08:32:00	12-01-2023	15:56:00	0.31	0.00	0.00	0.00	7.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2024 (409-410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	11-01-2023	09:26:00	11-01-2023	16:17:00	0.29	0.00	0.00	0.00	6.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1840(394 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	06-01-2023	09:18:00	06-01-2023	16:50:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/908(398-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	10-01-2023	08:42:00	10-01-2023	16:08:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1639(412 - 410Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	02-01-2023	08:58:00	02-01-2023	16:15:00	0.30	0.00	0.00	0.00	7.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/167(399 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	01-01-2023	10:33:00	01-01-2023	16:10:00	0.23	0.00	0.00	0.00	5.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 1/05(397 -399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	04-01-2023	09:13:00	04-01-2023	19:50:00	0.44	0.00	0.00	0.00	10.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/544 (397-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	05-01-2023	08:37:00	05-01-2023	17:40:00	0.38	0.00	0.00	0.00	9.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/687(740 - 750Kv).* 05.01.2023
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	13-01-2023	08:21:00	13-01-2023	16:51:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2209(406-408 Kv)
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	20-01-2023	08:02:00	20-01-2023	16:23:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3308 (402-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	24-01-2023	08:16:00	24-01-2023	17:15:00	0.37	0.00	0.00	0.00	8.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3978(409 - 410 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	14-01-2023	09:17:00	14-01-2023	17:33:00	0.34	0.00	0.00	0.00	8.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2398 (398 - 400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	07-01-2023	09:53:00	07-01-2023	16:28:00	0.27	0.00	0.00	0.00	6.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1126 (397-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	23-01-2023	09:40:00	23-01-2023	17:58:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3838 (399 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	18-01-2023	08:37:00	18-01-2023	16:42:00	0.34	0.00	0.00	0.00	8.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2919(404-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	25-01-2023	08:50:00	25-01-2023	16:13:00	0.31	0.00	0.00	0.00	7.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4166(408-410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	19-01-2023	08:01:00	19-01-2023	16:27:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3109(403 - 404Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	29-01-2023	10:01:00	29-01-2023	16:05:00	0.25	0.00	0.00	0.00	6.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4783(404-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	28-01-2023	09:19:00	28-01-2023	16:23:00	0.29	0.00	0.00	0.00	7.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4602(405 - 407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	22-01-2023	09:45:00	22-01-2023	15:39:00	0.25	0.00	0.00	0.00	5.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3683 (398 - 400 KV).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	31-01-2023	09:30:00	31-01-2023	16:35:00	0.30	0.00	0.00	0.00	7.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/5107 (399 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	27-01-2023	08:30:00	27-01-2023	16:39:00	0.34	0.00	0.00	0.00	8.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4431(406 - 408Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	30-01-2023	07:57:00	30-01-2023	16:49:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4917 (406 - 408 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	21-01-2023	09:16:00	21-01-2023	17:47:00	0.36	0.00	0.00	0.00	8.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3533 (399-402 Kv).*
							8.80	0.00	0.00	0.00	211.30	100.00	
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	27-01-2023	09:36:00	27-01-2023	16:36:00	0.29	0.00	0.00	0.00	7.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4448(396 - 396Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	17-01-2023	09:26:00	17-01-2023	18:40:00	0.39	0.00	0.00	0.00	9.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2761 (393 - 396 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	16-01-2023	08:24:00	16-01-2023	20:18:00	0.50	0.00	0.00	0.00	11.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2621(399-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	19-01-2023	09:23:00	19-01-2023	16:30:00	0.30	0.00	0.00	0.00	7.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3121(393 - 397Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	31-01-2023	09:36:00	31-01-2023	21:33:00	0.50	0.00	0.00	0.00	11.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5113 (393 -393 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	24-01-2023	10:10:00	24-01-2023	21:00:00	0.45	0.00	0.00	0.00	10.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4000 (393 - 396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	30-01-2023	08:00:00	30-01-2023	16:53:00	0.37	0.00	0.00	0.00	8.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4919 (400 - 402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	22-01-2023	09:48:00	22-01-2023	20:25:00	0.44	0.00	0.00	0.00	10.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3681 (393 - 393 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	05-01-2023	08:55:00	05-01-2023	20:39:00	0.49	0.00	0.00	0.00	11.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/703 (399-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	10-01-2023	09:04:00	10-01-2023	16:09:00	0.30	0.00	0.00	0.00	7.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1637(399 - 400Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	13-01-2023	09:17:00	14-01-2023	00:07:00	0.62	0.00	0.00	0.00	14.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2224 (395-398 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	14-01-2023	09:58:00	14-01-2023	16:55:00	0.29	0.00	0.00	0.00	6.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/ 2417 (392 - 394 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	03-01-2023	09:00:00	03-01-2023	20:00:00	0.46	0.00	0.00	0.00	11.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/341(401 - 401Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	04-01-2023	09:34:00	04-01-2023	22:20:00	0.53	0.00	0.00	0.00	12.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/548 (392-394 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	06-01-2023	09:26:00	06-01-2023	16:32:00	0.30	0.00	0.00	0.00	7.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/925 (393 -396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	09-01-2023	09:49:00	09-01-2023	16:56:00	0.30	0.00	0.00	0.00	7.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1451(392-395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	11-01-2023	10:58:00	11-01-2023	17:00:00	0.25	0.00	0.00	0.00	6.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1879(393 - 396Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	20-01-2023	09:22:00	20-01-2023	20:47:00	0.48	0.00	0.00	0.00	11.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/ 3317(393-393 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	21-01-2023	09:27:00	21-01-2023	17:48:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3532 (395-397 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	15-01-2023	10:08:00	15-01-2023	16:12:00	0.25	0.00	0.00	0.00	6.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2531(396-397 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	28-01-2023	09:25:00	28-01-2023	16:29:00	0.29	0.00	0.00	0.00	7.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4603(395 - 398 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	25-01-2023	10:46:00	25-01-2023	18:15:00	0.31	0.00	0.00	0.00	7.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4200(391-394 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	18-01-2023	10:31:00	18-01-2023	18:25:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2958(391-394 Kv).
							8.79	0.00	0.00	0.00	210.43	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	14-01-2023	10:08:00	14-01-2023	17:01:00	0.29	0.00	0.00	0.00	6.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2418 (395 -397 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	28-01-2023	11:30:00	29-01-2023	19:23:00	1.33	0.00	0.00	0.00	31.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4641(398 - 401 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	27-01-2023	07:03:00	27-01-2023	16:47:00	0.41	0.00	0.00	0.00	9.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4412(403-405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	17-01-2023	10:29:00	17-01-2023	18:44:00	0.34	0.00	0.00	0.00	8.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2776 (394 - 396 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	19-01-2023	09:31:00	19-01-2023	16:40:00	0.30	0.00	0.00	0.00	7.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3121(397 - 399Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	18-01-2023	09:34:00	18-01-2023	18:34:00	0.38	0.00	0.00	0.00	9.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2937(390-391 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	20-01-2023	09:30:00	20-01-2023	20:52:00	0.47	0.00	0.00	0.00	11.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3325 (393-395 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	15-01-2023	10:03:00	15-01-2023	17:44:00	0.32	0.00	0.00	0.00	7.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2530(394-397 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	04-01-2023	09:41:00	04-01-2023	22:24:00	0.53	0.00	0.00	0.00	12.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/549 (394-398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	07-01-2023	09:59:00	07-01-2023	17:38:00	0.32	0.00	0.00	0.00	7.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1132 (392-394 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	09-01-2023	09:43:00	09-01-2023	17:06:00	0.31	0.00	0.00	0.00	7.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1447(389-391 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	16-01-2023	08:18:00	16-01-2023	20:22:00	0.50	0.00	0.00	0.00	12.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2620(399-399 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	25-01-2023	08:43:00	25-01-2023	18:23:00	0.40	0.00	0.00	0.00	9.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4165(399-401 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	30-01-2023	09:40:00	30-01-2023	16:45:00	0.30	0.00	0.00	0.00	7.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4950 (398 - 398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	22-01-2023	09:56:00	22-01-2023	20:33:00	0.44	0.00	0.00	0.00	10.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3682 (396 - 398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	02-01-2023	10:01:00	03-01-2023	20:03:00	1.42	0.00	0.00	0.00	34.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/191(390 - 393Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	10-01-2023	09:18:00	10-01-2023	16:12:00	0.29	0.00	0.00	0.00	6.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1638(400 - 400Kv).
							8.35	0.00	0.00	0.00	200.06	100.00	
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	10-01-2023	08:51:00	10-01-2023	18:17:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1631(408 - 408Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	02-01-2023	11:27:00	02-01-2023	16:24:00	0.21	0.00	0.00	0.00	4.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/198(388 - 390Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	28-01-2023	08:22:00	28-01-2023	16:34:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4578(397 - 398 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	20-01-2023	09:41:00	20-01-2023	16:27:00	0.28	0.00	0.00	0.00	6.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3322 (388-390 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	18-01-2023	11:47:00	18-01-2023	16:58:00	0.22	0.00	0.00	0.00	5.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2974(390-392 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	25-01-2023	08:39:00	25-01-2023	16:31:00	0.33	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4164(407 -407 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	19-01-2023	10:34:00	19-01-2023	16:38:00	0.25	0.00	0.00	0.00	6.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3148(391 - 391Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	30-01-2023	09:34:00	30-01-2023	16:25:00	0.29	0.00	0.00	0.00	6.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/ 4955 (398-398 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	24-01-2023	09:57:00	24-01-2023	17:17:00	0.31	0.00	0.00	0.00	7.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4001 (403 - 403 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	15-01-2023	11:50:00	15-01-2023	16:16:00	0.19	0.00	0.00	0.00	4.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2540 (393-396 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	16-01-2023	10:31:00	16-01-2023	16:21:00	0.24	0.00	0.00	0.00	5.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2645(392-392 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	03-01-2023	09:00:00	03-01-2023	18:47:00	0.41	0.00	0.00	0.00	9.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/335(410 - 410Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	11-01-2023	09:39:00	11-01-2023	17:17:00	0.32	0.00	0.00	0.00	7.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1857(396 - 396Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	08-01-2023	09:59:00	08-01-2023	17:26:00	0.31	0.00	0.00	0.00	7.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1314(395-399 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	09-01-2023	08:20:00	09-01-2023	16:51:00	0.36	0.00	0.00	0.00	8.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1419(404-407 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	13-01-2023	12:23:00	13-01-2023	16:48:00	0.18	0.00	0.00	0.00	4.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2255 (385-389 Kv).
							4.63	0.00	0.00	0.00	110.71	100.00	
BSR	125MVAR, BUS REACTOR-1 AT NAGAPATTINAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	15-01-2023	11:49:00	15-01-2023	16:22:00	0.19	0.00	0.00	0.00	4.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2541 (393 - 396 kV).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	19-01-2023	10:58:00	19-01-2023	17:35:00	0.28	0.00	0.00	0.00	6.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3157(394 - 396Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	21-01-2023	09:34:00	21-01-2023	17:05:00	0.31	0.00	0.00	0.00	7.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3533 (399-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	28-01-2023	11:21:00	28-01-2023	18:42:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4644(389 - 391 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	20-01-2023	11:54:00	20-01-2023	16:36:00	0.20	0.00	0.00	0.00	4.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3365 (392-397 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	10-01-2023	11:26:00	10-01-2023	18:44:00	0.30	0.00	0.00	0.00	7.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1677(399 - 402Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	09-01-2023	10:58:00	09-01-2023	20:39:00	0.40	0.00	0.00	0.00	9.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1477(394-396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	03-01-2023	11:50:00	03-01-2023	20:36:00	0.37	0.00	0.00	0.00	8.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/377(395 - 399Kv).
							2.36	0.00	0.00	0.00	56.49	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	10-01-2023	10:34:00	10-01-2023	16:20:00	0.24	0.00	0.00	0.00	5.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1665(393 - 395Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	11-01-2023	09:21:00	11-01-2023	16:13:00	0.29	0.00	0.00	0.00	6.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1834(395 - 395Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	12-01-2023	08:35:00	12-01-2023	16:21:00	0.32	0.00	0.00	0.00	7.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2022 (411-412 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	04-01-2023	09:39:00	04-01-2023	16:51:00	0.30	0.00	0.00	0.00	7.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/550 (398-403 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	14-01-2023	09:27:00	14-01-2023	17:27:00	0.33	0.00	0.00	0.00	8.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2405 (403 - 405 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	17-01-2023	10:15:00	17-01-2023	17:15:00	0.29	0.00	0.00	0.00	7.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2774 (393 - 395 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	28-01-2023	09:13:00	28-01-2023	16:35:00	0.31	0.00	0.00	0.00	7.37	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4593(396 - 398 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	21-01-2023	09:33:00	21-01-2023	17:09:00	0.32	0.00	0.00	0.00	7.60	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3531 (403-406 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	30-01-2023	09:26:00	30-01-2023	16:47:00	0.31	0.00	0.00	0.00	7.35	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4943 (399 - 402 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	20-01-2023	09:32:00	20-01-2023	17:01:00	0.31	0.00	0.00	0.00	7.48	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3324 (396-398 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	19-01-2023	09:30:00	19-01-2023	16:40:00	0.30	0.00	0.00	0.00	7.17	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3124(400 - 403Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	22-01-2023	09:50:00	22-01-2023	15:50:00	0.25	0.00	0.00	0.00	6.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1041/3684 (399 - 402 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	25-01-2023	10:45:00	25-01-2023	16:25:00	0.24	0.00	0.00	0.00	5.67	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4198(397-399 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	18-01-2023	10:24:00	18-01-2023	16:55:00	0.27	0.00	0.00	0.00	6.52	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2956(395-397 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	31-01-2023	10:51:00	31-01-2023	16:31:00	0.24	0.00	0.00	0.00	5.67	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5153 (396 -398 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	29-01-2023	10:05:00	29-01-2023	16:14:00	0.26	0.00	0.00	0.00	6.15	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4788(401 -403 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	27-01-2023	09:29:00	27-01-2023	16:42:00	0.30	0.00	0.00	0.00	7.22	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4441(398 - 401Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	24-01-2023	10:06:00	24-01-2023	17:34:00	0.31	0.00	0.00	0.00	7.47	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4002 (406 - 406 Kv)	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	09-01-2023	10:54:00	09-01-2023	17:20:00	0.27	0.00	0.00	0.00	6.43	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1473(390-390 Kv).	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	06-01-2023	09:28:00	06-01-2023	17:11:00	0.32	0.00	0.00	0.00	7.72	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/910(402-405 Kv).	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	05-01-2023	08:46:00	05-01-2023	17:48:00	0.38	0.00	0.00	0.00	9.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/702 (410-413 Kv)
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	03-01-2023	10:54:00	03-01-2023	16:46:00	0.24	0.00	0.00	0.00	5.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/365(396 - 398Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	13-01-2023	09:14:00	13-01-2023	18:11:00	0.37	0.00	0.00	0.00	8.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2225 (400-401 Kv).
							6.77	0.00	0.00	0.00	162.28	100.00	
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	19-01-2023	09:33:00	19-01-2023	16:47:00	0.30	0.00	0.00	0.00	7.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3125(403 - 403Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	20-01-2023	09:34:00	20-01-2023	17:05:00	0.31	0.00	0.00	0.00	7.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3334 (398-399 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	17-01-2023	10:17:00	17-01-2023	17:23:00	0.30	0.00	0.00	0.00	7.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2775 (395 - 396 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	31-01-2023	10:52:00	31-01-2023	16:27:00	0.23	0.00	0.00	0.00	5.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/5154 (398 -400 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	25-01-2023	12:02:00	25-01-2023	16:29:00	0.19	0.00	0.00	0.00	4.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4212(399 -402 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	28-01-2023	09:14:00	28-01-2023	16:35:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4594(398 - 401 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	18-01-2023	10:26:00	18-01-2023	16:56:00	0.27	0.00	0.00	0.00	6.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2957(397-400 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	30-01-2023	09:28:00	30-01-2023	16:42:00	0.30	0.00	0.00	0.00	7.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4946 (402 - 404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	14-01-2023	09:31:00	14-01-2023	17:28:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2406 (405 - 405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	12-01-2023	08:38:00	12-01-2023	16:18:00	0.32	0.00	0.00	0.00	7.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2023 (412-414 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	11-01-2023	09:22:00	11-01-2023	16:24:00	0.29	0.00	0.00	0.00	7.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1836(395 - 398Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	09-01-2023	10:55:00	09-01-2023	17:24:00	0.27	0.00	0.00	0.00	6.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1474(390-393 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	10-01-2023	10:35:00	10-01-2023	16:14:00	0.24	0.00	0.00	0.00	5.65	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1666(395 - 397Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4789(403 -406 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/376(394 - 397Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2226 (401-403 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/732 (399-401Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/552 (403-403 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1133 (401-404 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4442(401 - 403Kv).	
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	29-01-2023	10:07:00	29-01-2023	16:16:00	0.26	0.00	0.00	0.00	6.15		
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	03-01-2023	11:49:00	03-01-2023	16:53:00	0.21	0.00	0.00	0.00	5.07		
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	13-01-2023	09:16:00	13-01-2023	18:04:00	0.37	0.00	0.00	0.00	8.80		
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	05-01-2023	09:43:00	05-01-2023	17:51:00	0.34	0.00	0.00	0.00	8.13		
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	04-01-2023	09:41:00	04-01-2023	16:55:00	0.30	0.00	0.00	0.00	7.23		
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	07-01-2023	10:03:00	07-01-2023	17:49:00	0.32	0.00	0.00	0.00	7.77		
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	27-01-2023	09:30:00	27-01-2023	16:46:00	0.30	0.00	0.00	0.00	7.27		
							5.76	0.00	0.00	0.00	138.16	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	13-01-2023	08:32:00	14-01-2023	00:44:00	0.68	0.00	0.00	0.00	16.20	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2210(405-406 Kv) * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/705 (402 -403 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2423 (398 - 398 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	05-01-2023	08:48:00	05-01-2023	20:36:00	0.49	0.00	0.00	0.00	11.80		
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	14-01-2023	10:05:00	14-01-2023	17:54:00	0.33	0.00	0.00	0.00	7.82		
							1.50	0.00	0.00	0.00	35.82	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	26-01-2023	09:17:00	26-01-2023	16:41:00	0.31	0.00	0.00	0.00	7.40	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4324(398 - 401Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1127 (395 -395 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/5108 (394 -394 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	07-01-2023	09:57:00	07-01-2023	16:45:00	0.28	0.00	0.00	0.00	6.80		
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	31-01-2023	09:37:00	31-01-2023	16:50:00	0.30	0.00	0.00	0.00	7.22		

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	18-01-2023	08:38:00	18-01-2023	16:50:00	0.34	0.00	0.00	0.00	8.20	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2917(402-404 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	14-01-2023	09:20:00	14-01-2023	17:48:00	0.35	0.00	0.00	0.00	8.47	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 012397 /(398 - 399 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	30-01-2023	07:52:00	30-01-2023	16:23:00	0.36	0.00	0.00	0.00	8.52	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4918 (404 - 405 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	27-01-2023	08:36:00	27-01-2023	19:10:00	0.44	0.00	0.00	0.00	10.57	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4428(405 - 407Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	23-01-2023	09:50:00	23-01-2023	18:15:00	0.35	0.00	0.00	0.00	8.42	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3843 (395-395 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	21-01-2023	09:21:00	21-01-2023	17:57:00	0.36	0.00	0.00	0.00	8.60	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3530 (397-399 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	25-01-2023	08:35:00	25-01-2023	18:10:00	0.40	0.00	0.00	0.00	9.58	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4158(405 - 405 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	29-01-2023	10:02:00	29-01-2023	16:48:00	0.28	0.00	0.00	0.00	6.77	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4784(399-402 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	19-01-2023	08:03:00	19-01-2023	17:56:00	0.41	0.00	0.00	0.00	9.88	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3108(400 - 400Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	24-01-2023	08:18:00	24-01-2023	17:28:00	0.38	0.00	0.00	0.00	9.17	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3975(406 - 406 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	17-01-2023	09:04:00	17-01-2023	17:25:00	0.35	0.00	0.00	0.00	8.35	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2753 (398 - 401 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	22-01-2023	10:02:00	22-01-2023	20:46:00	0.45	0.00	0.00	0.00	10.73	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3685 (399 - 399 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	20-01-2023	08:09:00	20-01-2023	20:58:00	0.53	0.00	0.00	0.00	12.82	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3309 (401-402 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	28-01-2023	09:20:00	28-01-2023	16:37:00	0.30	0.00	0.00	0.00	7.28	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4600(397 - 399 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	06-01-2023	09:20:00	06-01-2023	16:46:00	0.31	0.00	0.00	0.00	7.43	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/909(390-392 Kv).	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	12-01-2023	08:58:00	12-01-2023	16:26:00	0.31	0.00	0.00	0.00	7.47	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2030 (404-405 Kv).	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	10-01-2023	09:11:00	10-01-2023	19:43:00	0.44	0.00	0.00	0.00	10.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1636(402 - 404Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	11-01-2023	08:54:00	11-01-2023	16:30:00	0.32	0.00	0.00	0.00	7.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1827(400 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	04-01-2023	09:12:00	04-01-2023	20:58:00	0.49	0.00	0.00	0.00	11.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/545 (395-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	09-01-2023	08:20:00	09-01-2023	17:37:00	0.39	0.00	0.00	0.00	9.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1411(400-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	13-01-2023	08:24:00	13-01-2023	18:42:00	0.43	0.00	0.00	0.00	10.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2208(405-406 Kv)
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	05-01-2023	08:44:00	05-01-2023	20:44:00	0.50	0.00	0.00	0.00	12.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/701 (404 -406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	03-01-2023	10:56:00	03-01-2023	17:51:00	0.29	0.00	0.00	0.00	6.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/366(393 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	02-01-2023	09:42:00	02-01-2023	16:22:00	0.28	0.00	0.00	0.00	6.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/166(399 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	01-01-2023	10:45:00	01-01-2023	16:34:00	0.24	0.00	0.00	0.00	5.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 1/06(399 -401 Kv).
							10.19	0.00	0.00	0.00	244.57	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SRIPERUMBUDUR	SVRD	20-01-2023	09:29:00	26-01-2023	19:02:00	6.40	0.00	0.00	0.00	153.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3331 (391-392 Kv).
							6.40	0.00	0.00	0.00	153.55	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TIRUNELVELLI	SVRD	27-01-2023	10:42:00	27-01-2023	17:21:00	0.28	0.00	0.00	0.00	6.65		
							0.28	0.00	0.00	0.00	6.65	100.00	
BSR	63MVAR, BUS REACTOR-2 AT TIRUNELVELLI	SVRD	27-01-2023	11:06:00	27-01-2023	17:43:00	0.28	0.00	0.00	0.00	6.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4477(405 - 405Kv).
							0.28	0.00	0.00	0.00	6.62	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT TRIVANDRUM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	12-01-2023	10:35:00	12-01-2023	16:09:00	0.23	0.00	0.00	0.00	5.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/ 2052 (400 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	14-01-2023	09:24:00	14-01-2023	14:52:00	0.23	0.00	0.00	0.00	5.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2404 (402 - 404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	30-01-2023	09:24:00	30-01-2023	16:12:00	0.28	0.00	0.00	0.00	6.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4948 (398-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	20-01-2023	11:57:00	20-01-2023	16:49:00	0.20	0.00	0.00	0.00	4.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3367 (401-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	11-01-2023	09:44:00	11-01-2023	16:12:00	0.27	0.00	0.00	0.00	6.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1856(403 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	29-01-2023	10:15:00	29-01-2023	16:41:00	0.27	0.00	0.00	0.00	6.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4790(406-407 Kv).
							1.48	0.00	0.00	0.00	35.61	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	12-01-2023	10:46:00	12-01-2023	16:14:00	0.23	0.00	0.00	0.00	5.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/ 2055 (400 -400 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	11-01-2023	09:46:00	11-01-2023	16:01:00	0.26	0.00	0.00	0.00	6.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1858(403 - 406Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	19-01-2023	11:00:00	19-01-2023	16:37:00	0.23	0.00	0.00	0.00	5.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3158(402 - 406Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	29-01-2023	10:17:00	29-01-2023	16:30:00	0.26	0.00	0.00	0.00	6.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4791(407-409 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	28-01-2023	11:47:00	28-01-2023	16:32:00	0.20	0.00	0.00	0.00	4.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4649(402 - 403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	30-01-2023	09:25:00	30-01-2023	16:17:00	0.29	0.00	0.00	0.00	6.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4949 (400-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	20-01-2023	09:52:00	20-01-2023	16:29:00	0.28	0.00	0.00	0.00	6.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3327 (402-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	10-01-2023	11:00:00	10-01-2023	16:27:00	0.23	0.00	0.00	0.00	5.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1669(393 - 397Kv).
							1.98	0.00	0.00	0.00	47.25	100.00	
BSR	63MVAR, BUS REACTOR AT TUTICORIN PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	PUGALUR-1 _LINE_REACTOR_ 63MVAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	09-01-2023	08:43:00	09-01-2023	23:40:00	0.62	0.00	0.00	0.00	14.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1428/1513(745-757 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	04-01-2023	09:49:00	04-01-2023	19:54:00	0.42	0.00	0.00	0.00	10.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/559/606 (745-757 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	05-01-2023	07:09:00	06-01-2023	20:37:00	1.56	0.00	0.00	0.00	37.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/687(740 - 750Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	13-01-2023	09:39:00	13-01-2023	20:38:00	0.46	0.00	0.00	0.00	10.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2233/2288 (747-757Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	17-01-2023	12:27:00	17-01-2023	18:44:00	0.26	0.00	0.00	0.00	6.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2790 (735 - 751 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	18-01-2023	10:19:00	19-01-2023	17:42:00	1.31	0.00	0.00	0.00	31.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2955(745-756 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	14-01-2023	10:04:00	14-01-2023	18:18:00	0.34	0.00	0.00	0.00	8.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2424 (754 - 760 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	28-01-2023	09:31:00	29-01-2023	20:58:00	1.48	0.00	0.00	0.00	35.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4610(745 - 760 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	20-01-2023	09:15:00	21-01-2023	20:44:00	1.48	0.00	0.00	0.00	35.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3321/3575 (741 -751 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	27-01-2023	08:22:00	27-01-2023	16:31:00	0.34	0.00	0.00	0.00	8.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4422(754 - 767Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	12-01-2023	11:01:00	12-01-2023	16:50:00	0.24	0.00	0.00	0.00	5.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2057/2133 (750-766 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	02-01-2023	08:54:00	03-01-2023	15:26:00	1.27	0.00	0.00	0.00	30.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/168(744 - 752Kv).
							9.78	0.00	0.00	0.00	234.80	100.00	
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	14-01-2023	10:08:00	14-01-2023	18:22:00	0.34	0.00	0.00	0.00	8.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2509 (762 - 771 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	06-01-2023	07:32:00	07-01-2023	22:15:00	1.61	0.00	0.00	0.00	38.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/894 (745 - 754) Kv.
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	13-01-2023	09:43:00	13-01-2023	21:26:00	0.49	0.00	0.00	0.00	11.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2234/2289 (757-766Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	18-01-2023	09:34:00	19-01-2023	17:46:00	1.34	0.00	0.00	0.00	32.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2935(732-745 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	20-01-2023	08:01:00	21-01-2023	20:47:00	1.53	0.00	0.00	0.00	36.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3308 (733-745 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	10-01-2023	09:23:00	10-01-2023	20:20:00	0.46	0.00	0.00	0.00	10.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1644(765 - 776Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	04-01-2023	08:32:00	04-01-2023	20:47:00	0.51	0.00	0.00	0.00	12.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/534/586 (740-752 Kv).
							6.28	0.00	0.00	0.00	150.84	100.00	
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	20-01-2023	09:37:00	20-01-2023	16:26:00	0.28	0.00	0.00	0.00	6.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3323 (394-395 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	21-01-2023	09:20:00	21-01-2023	17:48:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3528(396-398 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	27-01-2023	09:31:00	27-01-2023	16:52:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4444(397 - 397Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	31-01-2023	09:30:00	31-01-2023	16:32:00	0.29	0.00	0.00	0.00	7.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5111 (395 -396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	12-01-2023	09:21:00	12-01-2023	17:17:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2036 (401-403 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	09-01-2023	08:18:00	09-01-2023	16:58:00	0.36	0.00	0.00	0.00	8.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1414(401-403 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	15-01-2023	10:21:00	15-01-2023	16:08:00	0.24	0.00	0.00	0.00	5.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2535(399-401 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	26-01-2023	09:22:00	26-01-2023	16:26:00	0.29	0.00	0.00	0.00	7.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4329(401 - 403Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	30-01-2023	09:10:00	30-01-2023	16:19:00	0.30	0.00	0.00	0.00	7.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4944 (391-392 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	17-01-2023	09:09:00	17-01-2023	17:17:00	0.34	0.00	0.00	0.00	8.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2755 (398 - 398 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	14-01-2023	09:20:00	14-01-2023	16:51:00	0.31	0.00	0.00	0.00	7.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2396 (397 - 397 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	24-01-2023	08:19:00	24-01-2023	17:25:00	0.38	0.00	0.00	0.00	9.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3977(407 - 409 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	23-01-2023	09:50:00	23-01-2023	18:17:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3845 (395 - 396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	18-01-2023	08:42:00	18-01-2023	18:27:00	0.41	0.00	0.00	0.00	9.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2921(405-406 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	29-01-2023	09:51:00	29-01-2023	16:09:00	0.26	0.00	0.00	0.00	6.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4786(395-396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	25-01-2023	08:46:00	25-01-2023	16:21:00	0.32	0.00	0.00	0.00	7.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4162(407 - 410 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	02-01-2023	09:23:00	02-01-2023	16:17:00	0.29	0.00	0.00	0.00	6.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/173(397 - 399Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	07-01-2023	10:02:00	07-01-2023	16:51:00	0.28	0.00	0.00	0.00	6.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1130 (398-398 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	10-01-2023	09:14:00	10-01-2023	18:13:00	0.37	0.00	0.00	0.00	8.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1633(400 - 401Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	11-01-2023	09:30:00	11-01-2023	16:22:00	0.29	0.00	0.00	0.00	6.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1838(390 - 393Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	06-01-2023	11:17:00	06-01-2023	17:30:00	0.26	0.00	0.00	0.00	6.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/921(393 -393 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	04-01-2023	09:35:00	04-01-2023	16:54:00	0.31	0.00	0.00	0.00	7.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/557 (395-397 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	03-01-2023	11:13:00	03-01-2023	17:43:00	0.27	0.00	0.00	0.00	6.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/369(395 - 395Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	13-01-2023	09:19:00	13-01-2023	20:42:00	0.47	0.00	0.00	0.00	11.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2228 (397-397 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	19-01-2023	09:20:00	19-01-2023	17:30:00	0.34	0.00	0.00	0.00	8.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3126(394 - 397Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	28-01-2023	09:10:00	28-01-2023	20:56:00	0.49	0.00	0.00	0.00	11.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4596(391 - 393 Kv).
							8.49	0.00	0.00	0.00	204.03	100.00	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	13-01-2023	09:23:00	13-01-2023	20:48:00	0.48	0.00	0.00	0.00	11.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2229 (397-400 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	29-01-2023	09:58:00	29-01-2023	20:50:00	0.45	0.00	0.00	0.00	10.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4787(398-401 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	15-01-2023	10:17:00	15-01-2023	16:12:00	0.25	0.00	0.00	0.00	5.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2534(398-399 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	27-01-2023	09:38:00	27-01-2023	16:48:00	0.30	0.00	0.00	0.00	7.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4445(397 - 396Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	25-01-2023	11:57:00	25-01-2023	16:29:00	0.19	0.00	0.00	0.00	4.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4211(395-398 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	20-01-2023	11:51:00	20-01-2023	16:29:00	0.19	0.00	0.00	0.00	4.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3366 (393-395 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	24-01-2023	09:02:00	24-01-2023	17:38:00	0.36	0.00	0.00	0.00	8.60	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3976(405- 405 Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	23-01-2023	09:52:00	23-01-2023	18:02:00	0.34	0.00	0.00	0.00	8.17	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3844 (395 - 397 Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	28-01-2023	09:15:00	28-01-2023	20:58:00	0.49	0.00	0.00	0.00	11.72	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4597(395 - 398 Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	21-01-2023	09:16:00	21-01-2023	20:42:00	0.48	0.00	0.00	0.00	11.43	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3527(396-396 Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	12-01-2023	09:25:00	12-01-2023	20:35:00	0.47	0.00	0.00	0.00	11.17	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2037 (403-403 Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	11-01-2023	10:50:00	11-01-2023	16:27:00	0.23	0.00	0.00	0.00	5.62	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1876(392 - 394Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	14-01-2023	09:59:00	14-01-2023	16:52:00	0.29	0.00	0.00	0.00	6.88	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2419 (399 - 399 Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	18-01-2023	11:40:00	18-01-2023	18:40:00	0.29	0.00	0.00	0.00	7.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2975(391-393 Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	10-01-2023	09:19:00	10-01-2023	18:18:00	0.37	0.00	0.00	0.00	8.98	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1634(400 - 403Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	09-01-2023	08:23:00	09-01-2023	17:03:00	0.36	0.00	0.00	0.00	8.67	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1415(406-408 Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	02-01-2023	09:27:00	02-01-2023	16:20:00	0.29	0.00	0.00	0.00	6.88	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/174(399 - 399Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	07-01-2023	10:03:00	07-01-2023	16:55:00	0.29	0.00	0.00	0.00	6.87	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1134 (398-400 Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	30-01-2023	09:15:00	30-01-2023	16:31:00	0.30	0.00	0.00	0.00	7.27	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4945 (393 -394 Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	31-01-2023	10:54:00	31-01-2023	16:35:00	0.24	0.00	0.00	0.00	5.68	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/5156 (393 -396 Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	19-01-2023	09:25:00	19-01-2023	17:34:00	0.34	0.00	0.00	0.00	8.15	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3127(397 - 399Kv).	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	17-01-2023	09:29:00	17-01-2023	17:21:00	0.33	0.00	0.00	0.00	7.87	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2756 (397 - 397 Kv).	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
							7.33	0.00	0.00	0.00	175.50	100.00	
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	26-01-2023	09:18:00	26-01-2023	16:22:00	0.29	0.00	0.00	0.00	7.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4327(398 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	17-01-2023	09:06:00	17-01-2023	17:13:00	0.34	0.00	0.00	0.00	8.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2754 (396 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	31-01-2023	09:24:00	31-01-2023	16:29:00	0.30	0.00	0.00	0.00	7.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/5110 (395 -395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	28-01-2023	08:18:00	28-01-2023	16:24:00	0.34	0.00	0.00	0.00	8.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4579(402 - 402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	19-01-2023	08:20:00	19-01-2023	17:26:00	0.38	0.00	0.00	0.00	9.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3114(402 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	25-01-2023	08:42:00	25-01-2023	16:13:00	0.31	0.00	0.00	0.00	7.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4161(406 -407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	20-01-2023	09:29:00	20-01-2023	16:23:00	0.29	0.00	0.00	0.00	6.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3318 (393-393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	18-01-2023	08:38:00	18-01-2023	16:41:00	0.34	0.00	0.00	0.00	8.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2920(402-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	14-01-2023	09:17:00	14-01-2023	16:51:00	0.32	0.00	0.00	0.00	7.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2394 (396 - 396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	15-01-2023	10:27:00	15-01-2023	15:50:00	0.22	0.00	0.00	0.00	5.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2536(401-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	03-01-2023	11:04:00	03-01-2023	17:39:00	0.27	0.00	0.00	0.00	6.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/368(397 - 397Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	10-01-2023	09:10:00	10-01-2023	18:09:00	0.37	0.00	0.00	0.00	8.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1632(399 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	13-01-2023	08:28:00	13-01-2023	20:37:00	0.51	0.00	0.00	0.00	12.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2211(404-406 Kv)
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	12-01-2023	09:08:00	12-01-2023	17:17:00	0.34	0.00	0.00	0.00	8.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2035 (399-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	09-01-2023	08:13:00	09-01-2023	16:52:00	0.36	0.00	0.00	0.00	8.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1413(399-401 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	04-01-2023	09:30:00	04-01-2023	16:52:00	0.31	0.00	0.00	0.00	7.37	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/555 (393-395 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/911(393-395 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1129 (396-398 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1837(390 - 390Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 1/08(396-399 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/734 (397-399 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/172(395 - 397Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/3686 (396 - 397 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4773(408-412 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4922 (406 - 408 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4430(404 - 406Kv).	
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	06-01-2023	09:21:00	06-01-2023	17:30:00	0.34	0.00	0.00	0.00	8.15		
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	07-01-2023	10:01:00	07-01-2023	16:42:00	0.28	0.00	0.00	0.00	6.68		
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	11-01-2023	09:23:00	11-01-2023	16:17:00	0.29	0.00	0.00	0.00	6.90		
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	01-01-2023	10:47:00	01-01-2023	16:13:00	0.23	0.00	0.00	0.00	5.43		
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	05-01-2023	09:48:00	05-01-2023	20:25:00	0.44	0.00	0.00	0.00	10.62		
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	02-01-2023	09:13:00	02-01-2023	16:14:00	0.29	0.00	0.00	0.00	7.02		
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	22-01-2023	09:47:00	22-01-2023	21:08:00	0.47	0.00	0.00	0.00	11.35		
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	29-01-2023	08:22:00	29-01-2023	16:06:00	0.32	0.00	0.00	0.00	7.73		
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	30-01-2023	07:54:00	30-01-2023	16:15:00	0.35	0.00	0.00	0.00	8.35		
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	27-01-2023	08:32:00	27-01-2023	16:44:00	0.34	0.00	0.00	0.00	8.20		
							8.64	0.00	0.00	0.00	207.20		100.00
CKT	230kv BHAVINI-ARANI(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kv BHAVINI-ARANI(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	230kV BHAVINI-KANCHIPURAM(TANTR ANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV BHAVINI-KANCHIPURAM(TANTR ANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230 KV-BHAVNI-SIRUSERI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230 KV-BHAVNI-SIRUSERI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV EDAPPON(KSEB)-EDAMON(KSEB)	OSPD	07-01-2023	09:36:00	07-01-2023	14:32:00	0.21	0.00	0.00	0.00	4.93	100.00	* Line Shut Down availed by KSEB for relay testing at Edappon end vide SRLDC Code No CR-01/1113.
CKT	230kV KARAİKAL(PED)-BAHOUR(PED)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KUNDRA(KSEB)-EDAMON(KSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAYAMKULAM(KSEB)-EDAPPON(KSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	220kV TIRUNELVELI-EDAMON(KSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV ALMATY-TIRUVALAM-1	OSPD	24-01-2023	09:31:00	24-01-2023	18:15:00	0.36	0.00	0.00	0.00	8.73	100.00	* Shut down availed by TANTRANSCO for AMP works vide SRLDC code no. CR-01/3991.
CKT	400 KV ALMATY-TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	8.73	100.00	
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(NTECL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(NTECL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHITTOOR(APTRANSCO)-SRIPERUMBUDUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GOOTY-SOMANAHALLI	OSPT	11-01-2023	09:01:00	11-01-2023	11:29:00	0.10	2.47	0.00	0.00	0.00	100.00	* Emergency Shut down availed for attending isolator hot spot at Gooty vide SRLDC code no. CR-01/1826
CKT	400kV GOOTY-SOMANAHALLI	OSPT	15-01-2023	12:03:00	15-01-2023	15:45:00	0.15	3.70	0.00	0.00	0.00	100.00	* Emergency Shut down availed by SR-1 for attending Hot Spot in Line isolator at Gooty end - vide SRLDC code no. CR-01/2542
CKT	400kV GOOTY-SOMANAHALLI	LEFT	15-01-2023	16:12:00	16-01-2023	05:44:00	0.56	13.53	0.00	0.00	0.00	100.00	* Tripped on R-N (Ph-earth) transient fault.* Somanahalli end details: M1/M2 FLR: 182.51/183.90 kM FC: 2.03/1.69 kA* Gooty end

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV KAIGA(NPCIL)-NARENDRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	16-01-2023	12:01:00	16-01-2023	16:39:00	0.19	0.00	0.00	0.00	4.63	100.00	* Shut down availed by KPTCL to facilitate R-Ph insulator replacement work at Loc No 173 of 400kV Kaiga-Guttur Line-2 vide SRLDC code
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	29-01-2023	11:39:00	29-01-2023	16:48:00	0.22	0.00	0.00	0.00	5.15	100.00	* Shutdown availed by KPTCL vide SRLDC code no. CR- 01/4811 to attend isolator alignment work at Guttur SS
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	13-01-2023	10:53:00	14-01-2023	07:55:00	0.88	0.00	0.00	0.00	21.03	100.00	* Shutdown availed by KPTCL for Line Maintenance work vide SRLDC code no. CR-01/2249.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	15-01-2023	05:10:00	16-01-2023	16:47:00	1.48	0.00	35.62	0.00	0.00	100.00	* Tripped on R ph to G Fault.Fault details:- Kaiga End: FLR:96.94 KM, FC:2.776 Kamps, Guttur End:M1/M2 FLR: 100.7/101.1 KM, FC:4.383/NR,
CKT	400kV KARAIKUDI-MADURAI	OSPT	03-01-2023	09:43:00	03-01-2023	17:09:00	0.31	7.43	0.00	0.00	0.00	100.00	* Shut down availed for AMP works vide SRLDC code no. CR-01/350
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-2	OSPD	18-01-2023	08:56:00	18-01-2023	19:16:00	0.43	0.00	0.00	0.00	10.33	100.00	* Shut down availed by NPCIL for carrying out line Insulators cleaning work vide SRLDC code no. CR- 01/2928
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-3	OSPD	11-01-2023	06:51:00	11-01-2023	18:39:00	0.49	0.00	0.00	0.00	11.80	100.00	* Shut down availed by NPCIL vide SRLDC code no. CR-01/459/1806

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV KOLAR-HOODY(KPTCL)-1			00:00:00		00:00:00	0.49	0.00	0.00	0.00	11.80	100.00	
CKT	400kV KOLAR-HOODY(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-HOSUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-HOSUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-MYLASANDRA (KPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-THIRUVALAM-1	LVRD	15-01-2023	20:33:00	16-01-2023	09:36:00	0.54	0.00	0.00	0.00	13.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2591 (426-425 Kv).
CKT	400kV KOLAR-THIRUVALAM-1	LVRD	01-01-2023	00:00:01	04-01-2023	11:41:00	3.49	0.00	0.00	0.00	83.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 12/4020(420-416 Kv).
CKT	400kV KOLAR-THIRUVALAM-1	LVRD	07-01-2023	22:06:00	09-01-2023	10:07:00	1.50	0.00	0.00	0.00	36.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1263 (411-408 Kv).
CKT	400kV KOLAR-THIRUVALAM-1	OSPT	04-01-2023	12:30:00	05-01-2023	02:14:00	0.57	13.73	0.00	0.00	0.00		* Shutdown is availed for AMP works vide SRLDC code CR-01/576.
CKT	400kV KOLAR-THIRUVALAM-1	LVRD	05-01-2023	02:14:00	05-01-2023	08:41:00	0.27	0.00	0.00	0.00	6.45		* Line kept open as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/661

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV KOLAR-THIRUVALAM-1	LVRD	17-01-2023	00:03:00	17-01-2023	06:06:00	0.25	0.00	0.00	0.00	6.05		* Line kept open as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2710 (419 - 417) KV
							6.62	13.73	0.00	0.00	145.25	98.15	
CKT	400kV KUDGI GIS-NARENDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDGI GIS-NARENDRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NP KUNTA-KOLAR	LVRD	02-01-2023	01:07:00	04-01-2023	08:07:00	2.29	0.00	0.00	0.00	55.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/120 (430-429Kv).
							2.29	0.00	0.00	0.00	55.00	100.00	
CKT	400kV MADURAI-PUGALUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-PUGALUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TIRUNELVELI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TIRUNELVELI-2	LART	10-01-2023	11:55:00	10-01-2023	11:55:00	0.00	0.00	0.00	0.00	0.00		* Line autoreclosed on Y-G fault.* Tirunelveli end details: M1: FLR: 100.9 KM, FC: 3.47 Kamps, M2: FLR: 95.1 KM, FC: 3.18 Kamps.* Madurai
CKT	400kV MADURAI-TIRUNELVELI-2	LART	04-01-2023	22:21:00	04-01-2023	22:21:00	0.00	0.00	0.00	0.00	0.00		* Line autoreclosed on R-G fault.* Madurai end details: M1: FLR: 90.6 KM, FC: 3.68 Kamps, M2: FLR: 89.93 KM, FC: 3.55 Kamps.*

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV MADURAI-TUTICORIN PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TUTICORIN PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMALPET-MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-KOZHIKODE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-KOZHIKODE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELLI TS2-NEYVELLI TS1 EXP			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELI TS2(NLC)-KARUR-1	OSPD	24-01-2023	15:17:00	24-01-2023	17:13:00	0.08	0.00	0.00	0.00	1.93		* Shut down availed by NPCIL for FTC of 406 CB of Unit-6 at NLCTSI vide SRLDC code no. CR-01/4031.* Line idel charged from Pugalur

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV NEYVELLI TS2 EXP(NLC) EXP-KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELI(NLC)-SALEM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGAPATTINAM- OSPD NEYVELI TS1(NLC) EXP		20-01-2023	09:35:00	20-01-2023	18:18:00	0.36	0.00	0.00	0.00	8.72	100.00	* Emergency Shutdown availed by NLC TS-I for attending CVT oil leak vide SRLDC code no. CR- 01/3335.
CKT	400kV NAGAPATTINAM-NEYVELI TS2(NLC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-KARUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-KALVINDAPATTU-1	OSPD	02-01-2023	09:09:00	02-01-2023	19:29:00	0.43	0.00	0.00	0.00	10.33		* Shut down availed for attending overhauling of isolators (Line isolator <-&<-> 02 nos bay isolators towards line) vide SRLDC code no. CR-
CKT	400kV NNTPS(NLC)-KALVINDAPATTU-1	OSPD	03-01-2023	09:02:00	03-01-2023	19:39:00	0.44	0.00	0.00	0.00	10.62		
CKT	400kV NNTPS(NLC)-KALVINDAPATTU-1	OSPD	04-01-2023	08:23:00	04-01-2023	18:14:00	0.41	0.00	0.00	0.00	9.85		
CKT	400kV NNTPS(NLC)-PUDUCHERRY-1	OSPT	10-01-2023	14:55:00	10-01-2023	17:00:00	0.09	2.08	0.00	0.00	0.00	100.00	* Emergency shut down availed for attending Sparking and hotspot in 40489B R-ph isolator (Line side Isolator) vide SRLDC code no. CR= -
CKT	400kV NARENDRA-GUTTUR(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.72	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-2	LVRD	26-01-2023	20:36:00	27-01-2023	07:25:00	0.45	0.00	0.00	0.00	10.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4387 (429- 427 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 12/4013 (427-425Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/482 (422 - 419 Kv).
CKT	400kV NARENDRA-GUTTUR(KPTCL)-2	LVRD	01-01-2023	00:00:01	02-01-2023	07:43:00	1.32	0.00	0.00	0.00	31.72		
CKT	400kV NARENDRA-GUTTUR(KPTCL)-2	LVRD	04-01-2023	00:38:00	04-01-2023	09:38:00	0.38	0.00	0.00	0.00	9.00		

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV PUGALUR-ARASUR-1			00:00:00		00:00:00	2.15	0.00	0.00	0.00	51.54	100.00	
CKT	400kV PUGALUR-ARASUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANS CO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANS CO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV PALAKKAD-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PALAKKAD-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUDUCHERRY-SVCHATRAM(TANTRA NSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV PAVAGADA-DEVANAHALLI(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV PAVAGADA-DEVANAHALLI(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-HIRIYUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	01-01-2023	00:00:01	02-01-2023	09:38:00	1.40	0.00	0.00	0.00	0.00	100.00	
							1.40	0.00	0.00	0.00	33.63	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 12/4019(423-421 Kv).
CKT	400kV PAVAGADA-TUMKUR-2	LVRD	02-01-2023	01:06:00	02-01-2023	09:20:00	0.34	0.00	0.00	0.00	8.23	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/116 (432-430Kv).
CKT	400kV PAVAGADA-TUMKUR-2	LVRD	07-01-2023	22:11:00	09-01-2023	10:02:00	1.49	0.00	0.00	0.00	35.85	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/1264 (418-416 Kv).
CKT	400kV PAVAGADA-TUMKUR-2	LVRD	12-01-2023	23:57:00	13-01-2023	08:38:00	0.36	0.00	0.00	0.00	8.68	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2165(428 - 425Kv).
CKT	400kV PAVAGADA-TUMKUR-2	LVRD	15-01-2023	20:35:00	17-01-2023	06:11:00	1.40	0.00	0.00	0.00	33.60	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/2589 (429 - 426 Kv).
							3.59	0.00	0.00	0.00	86.36	100.00	
CKT	400kV PAVAGADA-TUMKUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400KV SALEM-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SALEM-NNTPS(NLC)	OSPT	04-01-2023	14:38:00	04-01-2023	18:17:00	0.15	3.65	0.00	0.00	0.00		* Shut down availed for CLR Insulator replacement work vide SRLDC code no. CR-01/583.
							0.15	3.65	0.00	0.00	0.00	99.51	
CKT	400KV SALEM-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SALEM-UDUMALPET-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-SOMANHALLI-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SOMANAHALLI-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SOMANAHALLI-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SOMANAHALLI-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV SOMANAHALLI-HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-SOMANHALLI-MYLASANDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SVCHATRM(TANTRAN SCO)-SRIPERMBUDR-			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-KOCHI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-KOCHI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV THIRUNELVELI-KOCHI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV THIRUNELVELI-KOCHI-2	LART	20-01-2023	20:31:00	20-01-2023	20:31:00	0.00	0.00	0.00	0.00	0.00		* Line autoreclosed on Y-G fault.* Kochi end details: M1: FLR: 153.38 KM, FC: 1.92 KAmps, M2: FLR: 140 KM, FC: 1.94 KAmps.*
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TRIVANDRUM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TRIVANDRUM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TUTICORIN PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-UDUMALPET-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-KARAIKUDI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-MADURAI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV TRICHY-NAGAPATTANAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-NAGAPATTANAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-KALVINDAPATTU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-KALVINDAPATTU-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-SRIPERUMDUR-1	OSPT	04-01-2023	12:30:00	05-01-2023	02:14:00	0.57	13.73	0.00	0.00	0.00		* Shutdown is availed for AMP works vide SRLDC code CR-01/576.
CKT	400kV TIRUVALAM-SRIPERUMDUR-1	LVRD	17-01-2023	00:03:00	17-01-2023	06:06:00	0.25	0.00	0.00	0.00	6.05		* Line kept open as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2710 (419-417) KV
CKT	400kV TIRUVALAM-SRIPERUMDUR-1	LVRD	05-01-2023	02:14:00	05-01-2023	08:41:00	0.27	0.00	0.00	0.00	6.45		* Line kept open as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/661
CKT	400kV TIRUVALAM-SRIPERUMDUR-1	LVRD	01-01-2023	00:00:01	04-01-2023	11:41:00	3.49	0.00	0.00	0.00	83.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 12/4020(420-416 Kv).

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400KV TIRUVALAM-SRIPERUMDUR-1	LVRD	07-01-2023	22:06:00	09-01-2023	10:07:00	1.50	0.00	0.00	0.00	36.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1263 (411-408 Kv). * Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2591 (426-425 Kv).
CKT	400KV TIRUVALAM-SRIPERUMDUR-1	LVRD	15-01-2023	20:33:00	16-01-2023	09:36:00	0.54	0.00	0.00	0.00	13.05		
							6.62	13.73	0.00	0.00	145.25	98.15	
CKT	400KV TUTICORIN GIS - TUTICORIN PS- 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400KV TUTICORIN GIS - TUTICORIN PS- 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN GIS - TUTICORIN PS- 3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN GIS - TUTICORIN PS- 4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN PS-KUDAMKULAM(NPCIL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN PS-TUTICORIN JV(NTPL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN PS-TUTICORIN JV(NTPL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV UDMALPET-ARASUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDMALPET-ARASUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET-E.PALAYM(TANTRANS CO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET-E.PALAYM(TANTRANS CO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET - PALLAKAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET - PALLAKAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VALLUR(NTECL)-KALIVANTHAPATTU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VALLUR(NTECL)-KALIVANTHAPATTU-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV YELHANKA GIS-DEVANAHALLI(KPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV YELHANKA-NELAMANGALA(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV YELAHANKA GIS-TUMKUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV YELAHANKA GIS-TUMKUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DHARAMPURI-TUMKUR-1	OSPT	18-01-2023	11:20:00	18-01-2023	14:00:00	0.11	2.67	0.00	0.00	0.00	100.00	* Emergency shut down availed for attending suspected hotspot found in location 351 vide SRLDC code no. CR- 01/2971
CKT	400kV DHARAMPURI-TUMKUR-1	LART	12-01-2023	14:07:00	12-01-2023	14:07:00	0.00	0.00	0.00	0.00	0.00	100.00	* Auto reclosed successfully on Rph -G (Ph-earth) transient fault. TUMKUR END :- M1 = 133 KM/3.05 kA M2= 129 KM /2.54 kA
CKT	400KV KUDGI-KOLHAPUR GIS-1			00:00:00		00:00:00	0.11	2.67	0.00	0.00	0.00	99.64	
CKT	400KV KUDGI-KOLHAPUR GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400KV TUTICORIN PS-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN PS-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF VALLUR-1 AT KALIVANTPATTU	SVRD	23-01-2023	09:58:00	31-01-2023	23:59:59	8.59	0.00	0.00	0.00	206.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3851 (395 -396 Kv).
							8.59	0.00	0.00	0.00	206.03	100.00	
LNR	63MVAR,SWLR OF TIRUNALVELLI-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF TIRUNALVELLI-2 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF MYSORE-1 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF MYSORE-2 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF TRICHY AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	63MVAR,SWLR OF KARAIKUDI AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF HIRIYUR AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF PAVAGADA AT MYSORE	SVRD	13-01-2023	12:29:00	18-01-2023	18:21:00	5.24	0.00	0.00	0.00	125.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2257 (390-392 Kv).
							5.24	0.00	0.00	0.00	125.87	100.00	
LNR	50MVAR,SWLR OF NEYVELI-2 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NEYVELI-1 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF HOSUR-2 AT SALEM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KOLAR AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF CHITTOOR AT SRIPERUMBUDUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	50MVAR,SWLR OF SVCHATRAM AT SRIPERUMBDUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PALAKKAD-1 AT THRISSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PALAKKAD-2 AT THRISSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF UDUMALPT-1 AT TIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF UDUMALPT-2 AT TIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NAGAPATTINAM-1 AT TRICHY	SVRD	01-01-2023	00:00:01	18-01-2023	18:21:00	17.77	0.00	0.00	0.00	426.35	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 12/2602(389-389 Kv).
LNR	63MVAR,SWLR OF NAGAPATTINAM-2 AT TRICHY	SVRD	01-01-2023	00:00:01	18-01-2023	18:27:00	17.77	0.00	0.00	0.00	426.45	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 12/2603(389-392 Kv).
LNR	50MVAR,SWLR OF KADAPA-1 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	50MVAR,SWLR OF KADAPA-2 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NELLORE-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NELLORE-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SALEM-2 AT UDUMALPET	SVRD	19-01-2023	11:41:00	31-01-2023	23:59:59	12.51	0.00	0.00	0.00	300.32	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3168(396-396 Kv).*
LNR	63MVAR,SWLR OF TIRUNELVELI-2 AT UDUMALPT	SVRD	19-01-2023	11:35:00	31-01-2023	23:59:59	12.52	0.00	0.00	0.00	300.42	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3166(396-396 Kv).*
LNR	63MVAR,SWLR OF TIRUNELVELI-1 AT UDUMALPT	SVRD	19-01-2023	11:36:00	31-01-2023	23:59:59	12.52	0.00	0.00	0.00	300.40	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3167(396-396 Kv).
STATCOM	-200/+200 MVAR STATCOM AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-200/+200 MVAR STATCOM AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
SVC	Trichy STATCOM-MSR-1 (-125 MVAR)	OSPT	24-01-2023	09:07:00	25-01-2023	16:59:00	1.33	31.87	0.00	0.00	0.00		* Shut down availed for AMP works and spare change over vide SRLDC code no. CR-01/3990.
							1.33	31.87	0.00	0.00	0.00	95.72	
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	OSPT	10-01-2023	12:12:00	12-01-2023	20:17:00	2.34	56.08	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-01/1682.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	LART	08-01-2023	05:50:00	08-01-2023	05:50:00	0.00	0.00	0.00	0.00	0.00		* Pole-1 LFL and DC line fault recovery sequence operated and cleared fault in second attempt.* Fault detail from Kolar:- FL: 111.7 KM,
							2.34	56.08	0.00	0.00	0.00	92.46	
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	LART	31-01-2023	20:10:00	31-01-2023	20:10:00	0.00	0.00	0.00	0.00	0.00		* LFL and DC line fault recovery sequence operated and cleared in second attempt. Fault Distance 261.8 KM from Kolar end (Tower no.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	OSPT	13-01-2023	16:25:00	13-01-2023	18:49:00	0.10	2.40	0.00	0.00	0.00		* Emergency Shut down taken for attending IVT Bphase hotspot Vide SRLDC code CR-01/2285.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	LART	25-01-2023	05:46:00	25-01-2023	05:46:00	0.00	0.00	0.00	0.00	0.00		* Recovery Sequence operated and cleared in first attempt. Distance from Kolar 128.2 km, Tower No 3346. Fault location is in Cuddapah
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	OSPT	10-01-2023	11:55:00	12-01-2023	21:20:00	2.39	57.42	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-01/1683
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	OSPT	20-01-2023	19:19:00	20-01-2023	23:11:00	0.16	3.87	0.00	0.00	0.00		* Emergency Shut down availed by Talcher HVDC for attending valve cooling system issue vide SRLDC code no. CR-01/3449/3697.
							2.65	63.69	0.00	0.00	0.00	91.44	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-1	LART	06-01-2023	18:40:00	06-01-2023	18:40:00	0.00	0.00	0.00	0.00	0.00		* Pole-1 blocked on DC line fault cleared in First attempt.Fault details:- Fault distance 831.8 KM from Pugalur, Fault current 4.2 KA, Tower No:
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-1	OMST	23-01-2023	07:12:00	23-01-2023	09:02:00	0.08	1.83	0.00	0.00	0.00		* Pole 1 blocked at Raigarh end due to Pole 1 Neutral DC Bus Differential Protection operated . Standby protection system mal operated due to
							0.08	1.83	0.00	0.00	0.00	99.75	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-2	LART	06-01-2023	18:06:00	06-01-2023	18:06:00	0.00	0.00	0.00	0.00	0.00		* At 1806 hrs 800 kV Raigarh-Pugalur line 2 LFL operated and cleared in 1st attempt,* Fault readings from Pugalur* Tower location 2436,* FL
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
VALVE_HALL	800kV HVDC RAIGARH- PUGALUR POLE-3	OMST	23-01-2023	13:30:00	23-01-2023	15:35:00	0.09	2.08	0.00	0.00	0.00		* Tripped at pugalur end due to momentary disturbance in 220V DC system.
VALVE_HALL	800kV HVDC RAIGARH- PUGALUR POLE-3	LART	06-01-2023	18:40:00	06-01-2023	18:40:00	0.00	0.00	0.00	0.00	0.00		* At 1840 hrs 800 kV Raigarh-Pugalur line 1 LFL operated and cleared in 1st attempt,* Fault readings from Pugalur* Tower location 2436,* FL
							0.09	2.08	0.00	0.00	0.00	99.72	
VALVE_HALL	800kV HVDC RAIGARH- PUGALUR POLE-4	OMST	23-01-2023	13:30:00	23-01-2023	15:55:00	0.10	2.42	0.00	0.00	0.00		* Tripped at pugalur end due to momentary disturbance in 220V DC system.
VALVE_HALL	800kV HVDC RAIGARH- PUGALUR POLE-4	LART	06-01-2023	18:06:00	06-01-2023	18:06:00	0.00	0.00	0.00	0.00	0.00		* Pole-4 blocked on DC line fault cleared in First attempt.Fault details:- Fault distance 831.7 KM from Pugalur, Fault current 4.0 KA, Tower No:
							0.10	2.42	0.00	0.00	0.00	99.68	
VALVE_HALL	320kV HVDC PUGALUR- THRISSUR POLE-1	OSPT	17-01-2023	10:43:00	17-01-2023	13:06:00	0.10	2.38	0.00	0.00	0.00		* Shut down of VSC Pole 1 at Pugalur HVDC and Thrissur HVDC is availed for replacement of faulty trip logic card vide SRLDC code no. CR-
							0.10	2.38	0.00	0.00	0.00	99.68	
VALVE_HALL	320kV HVDC PUGALUR- THRISSUR POLE-2	OSPT	30-01-2023	09:29:00	31-01-2023	20:27:00	1.46	34.97	0.00	0.00	0.00		* VSC- POLE 2 - Shut down availed for AMP works vide SRLDC code no. CR-01/4927.
VALVE_HALL	320kV HVDC PUGALUR- THRISSUR POLE-2	OMST	13-01-2023	13:02:00	13-01-2023	16:05:00	0.13	3.05	0.00	0.00	0.00		* HVDC PUGALUR- THRISSUR - VSC LINK 2 got tripped at Pugalur end with indication "Trips by equipment Protection" optd.
							1.59	38.02	0.00	0.00	0.00	94.89	
XMER	315MVA,400/220kV ICT- 1 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT- 2 AT ARASUR	OSPT	23-01-2023	09:40:00	23-01-2023	18:23:00	0.36	8.72	0.00	0.00	0.00		* ICT 2 Shut down availed for AMP works vide SRLDC code no. CR-01/3847.
							0.36	8.72	0.00	0.00	0.00	98.83	
XMER	500MVA,400/220kV ICT- 3 AT ARASUR	OSPT	28-01-2023	09:40:00	28-01-2023	18:49:00	0.38	9.15	0.00	0.00	0.00		* ICT Shut down availed for AMP works vide SRLDC code no. CR-01/4615

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	500MVA,400/220kV ICT-1 AT BIDADI			00:00:00		00:00:00	0.38	9.15	0.00	0.00	0.00	98.77	
XMER	500MVA,400/220kV ICT-2 AT BIDADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HIRIYUR	SCSD	06-01-2023	09:06:00	06-01-2023	18:45:00	0.40	0.00	0.00	0.00	9.65		* Shut down availed for implementation and testing of modified logic of SPS vide SRLDC code no. CR-01/906
XMER	315MVA,400/220kV ICT-2 AT HIRIYUR			00:00:00		00:00:00	0.40	0.00	0.00	0.00	9.65	100.00	
XMER	500MVA,400/220kV ICT-3 AT HIRIYUR	SCSD	07-01-2023	09:34:00	07-01-2023	18:50:00	0.39	0.00	0.00	0.00	9.27		* Shut Down availed for Implementation and Testing of Modified logic of the SPS as per SLRDC instructions vide SRLDC Code No CR-
XMER	315MVA,400/220kV ICT-1 AT HOSUR			00:00:00		00:00:00	0.39	0.00	0.00	0.00	9.27	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-2 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARAUKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KARAUKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KARAUKUDI		23-01-2023	09:40:00	23-01-2023	20:01:00	0.43	10.35	0.00	0.00	0.00	100.00	* ICT 3 Shut down availed for AMP works vide SRLDC code no. CR-01/3846.

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-1 AT KOCHI			00:00:00		00:00:00	0.43	10.35	0.00	0.00	0.00	98.61	
XMER	315MVA,400/220kV ICT-2 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT KOLAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT KOLAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-2 AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT NARENDRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT NARENDRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARUR	SPRD	23-01-2023	08:40:00	23-01-2023	09:04:00	0.02	0.00	0.00	0.00	0.40		* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 01/3805, CR- 01/3809
XMER	315MVA,400/220kV ICT-1 AT KARUR	SPRD	23-01-2023	10:49:00	23-01-2023	11:59:00	0.05	0.00	0.00	0.00	1.17		* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 01/3861 (134, 0, 239 - > 0, 0, 279).
XMER	315MVA,400/220kV ICT-1 AT KARUR	SPRD	30-01-2023	08:52:00	30-01-2023	11:53:00	0.13	0.00	0.00	0.00	3.02		* ICT Hand tripped as per SRLDC instruction for Power Regulation in the system vide SRLDC code no. CR- 01/4938 . Loads before Tripping =
XMER	315MVA,400/220kV ICT-1 AT KARUR	SPRD	20-01-2023	17:57:00	20-01-2023	20:38:00	0.11	0.00	0.00	0.00	2.68		* Hand tripped as per SRLDC instruction for physical regulation in the system vide SRLDC code no. CR- 01/3430(Load Before Tripping ICT-
XMER	315MVA,400/220kV ICT-1 AT KARUR	SPRD	06-01-2023	08:38:00	06-01-2023	11:31:00	0.12	0.00	0.00	0.00	2.88		* ICT -1 Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 01/ 214.
							0.43	0.00	0.00	0.00	10.15	100.00	
XMER	315MVA,400/220kV ICT-2 AT KARUR	SPRD	20-01-2023	08:43:00	20-01-2023	09:50:00	0.05	0.00	0.00	0.00	1.12		* Hand tripped as per SRLDC instruction for POWER Regulation in the system vide SRLDC code no. CR- 01/3316

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	500MVA,400/220kV ICT-5 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-2 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	500MVA,400/220kV ICT-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	TuticorinGIS ICT3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUMKUR		08-01-2023	08:57:00	08-01-2023	14:40:00	0.24	5.72	0.00	0.00	0.00	100.00	* Shut down availed for AMP works vide SRLDC code no. CR-01/1303
XMER	500MVA,400/220kV ICT-3 AT TUMKUR			00:00:00		00:00:00	0.24	5.72	0.00	0.00	0.00	99.23	
XMER	1500MVA,765/400kV ICT-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System	OUTAGE ATTRIBU TABLE To Deemed	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-2 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
												30,056.63	