

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	03-02-2024	09:27:00	03-02-2024	20:27:00	0.46	0.00	0.00	0.00	11.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/487 (393-397Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	01-02-2024	07:14:00	02-02-2024	17:22:00	1.42	0.00	0.00	0.00	34.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/40(397 - 397Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	26-02-2024	08:04:00	26-02-2024	17:32:00	0.39	0.00	0.00	0.00	9.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4933 (405-406Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	24-02-2024	09:37:00	25-02-2024	15:44:00	1.26	0.00	0.00	0.00	30.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4636( 400-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	21-02-2024	08:30:00	21-02-2024	20:50:00	0.51	0.00	0.00	0.00	12.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3976 (400 - 400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	20-02-2024	08:25:00	20-02-2024	17:04:00	0.36	0.00	0.00	0.00	8.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3767 (397-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	19-02-2024	08:34:00	19-02-2024	19:17:00	0.45	0.00	0.00	0.00	10.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3589 (394-398Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	16-02-2024	08:18:00	16-02-2024	20:57:00	0.53	0.00	0.00	0.00	12.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3036( 393-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	12-02-2024	08:11:00	12-02-2024	17:17:00	0.38	0.00	0.00	0.00	9.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2217 (401 - 401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	27-02-2024	08:04:00	27-02-2024	17:28:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5114 (402-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	10-02-2024	07:59:00	10-02-2024	18:31:00	0.44	0.00	0.00	0.00	10.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1893 (406-408Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	23-02-2024	08:44:00	23-02-2024	20:56:00	0.51	0.00	0.00	0.00	12.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4398(393 - 395Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	08-02-2024	09:18:00	09-02-2024	18:12:00	1.37	0.00	0.00	0.00	32.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1464( 392-393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	05-02-2024	07:06:00	06-02-2024	17:06:00	1.42	0.00	0.00	0.00	34.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/785 (400-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	22-02-2024	08:24:00	22-02-2024	18:34:00	0.42	0.00	0.00	0.00	10.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4194(396 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	14-02-2024	09:43:00	15-02-2024	17:18:00	1.32	0.00	0.00	0.00	31.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2679(386 - 386Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	17-02-2024	07:46:00	18-02-2024	17:06:00	1.39	0.00	0.00	0.00	33.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3211( 400-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	07-02-2024	09:07:00	07-02-2024	17:17:00	0.34	0.00	0.00	0.00	8.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1242(391 - 393Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	13-02-2024	08:58:00	13-02-2024	16:52:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2469 (395 - 397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	29-02-2024	09:01:00	29-02-2024	17:50:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5522 (399 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	28-02-2024	08:45:00	28-02-2024	18:10:00	0.39	0.00	0.00	0.00	9.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5307 (399 - 400Kv).
							14.45	0.00	0.00	0.00	346.59	100.00	
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	07-02-2024	11:03:00	13-02-2024	17:22:00	6.26	0.00	0.00	0.00	150.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1287(394 - 397Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	15-02-2024	09:56:00	15-02-2024	20:40:00	0.45	0.00	0.00	0.00	10.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2881(393 - 396Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	23-02-2024	10:33:00	29-02-2024	23:59:59	6.56	0.00	0.00	0.00	157.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4443(393 - 396Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	16-02-2024	09:49:00	18-02-2024	20:33:00	2.45	0.00	0.00	0.00	58.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3082( 391-394 Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	20-02-2024	10:10:00	20-02-2024	17:15:00	0.30	0.00	0.00	0.00	7.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3798 (397-397 Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	01-02-2024	00:00:01	02-02-2024	22:02:00	1.92	0.00	0.00	0.00	46.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4783(392 - 396Kv).
							17.94	0.00	0.00	0.00	430.34	100.00	
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	12-02-2024	08:09:00	12-02-2024	17:29:00	0.39	0.00	0.00	0.00	9.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2211 (400 - 404 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	11-02-2024	07:57:00	11-02-2024	15:59:00	0.34	0.00	0.00	0.00	8.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2071 (408-412Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	06-02-2024	09:25:00	06-02-2024	17:09:00	0.32	0.00	0.00	0.00	7.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1023(400 - 403Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	08-02-2024	07:40:00	08-02-2024	17:25:00	0.41	0.00	0.00	0.00	9.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1462( 408-410 Kv).

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	10-02-2024	09:47:00	10-02-2024	18:44:00	0.37	0.00	0.00	0.00	8.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1928 (390-393Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	23-02-2024	10:04:00	23-02-2024	17:11:00	0.30	0.00	0.00	0.00	7.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4437(400 - 403Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	24-02-2024	08:58:00	24-02-2024	17:53:00	0.37	0.00	0.00	0.00	8.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4634( 393-398 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	14-02-2024	09:52:00	15-02-2024	17:31:00	1.32	0.00	0.00	0.00	31.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2677(389 - 392Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	22-02-2024	08:26:00	22-02-2024	18:25:00	0.42	0.00	0.00	0.00	9.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4191(398 - 402Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	16-02-2024	09:22:00	17-02-2024	17:39:00	1.35	0.00	0.00	0.00	32.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3070( 395-398 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	09-02-2024	08:51:00	09-02-2024	18:09:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1702( 400-401 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	29-02-2024	08:56:00	29-02-2024	18:10:00	0.39	0.00	0.00	0.00	9.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5520 (395 - 398Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	21-02-2024	08:24:00	21-02-2024	17:43:00	0.39	0.00	0.00	0.00	9.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3973 (399 - 402 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	19-02-2024	08:44:00	19-02-2024	19:30:00	0.45	0.00	0.00	0.00	10.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3592 (398-400Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	02-02-2024	07:57:00	02-02-2024	17:27:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/247(404 -408 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	01-02-2024	08:29:00	01-02-2024	17:36:00	0.38	0.00	0.00	0.00	9.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/62( 403-403 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	26-02-2024	08:04:00	26-02-2024	17:33:00	0.40	0.00	0.00	0.00	9.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4937 (406-406Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	05-02-2024	08:06:00	05-02-2024	18:37:00	0.44	0.00	0.00	0.00	10.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/810 (408-409 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	18-02-2024	09:25:00	18-02-2024	16:58:00	0.32	0.00	0.00	0.00	7.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3439 (397 -398 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	27-02-2024	08:11:00	28-02-2024	18:20:00	1.42	0.00	0.00	0.00	34.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5118 (404-407Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	07-02-2024	08:59:00	07-02-2024	17:08:00	0.34	0.00	0.00	0.00	8.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1237(397 - 397Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	13-02-2024	09:03:00	13-02-2024	17:18:00	0.34	0.00	0.00	0.00	8.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2463 (398 - 400 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	20-02-2024	08:25:00	20-02-2024	16:51:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3763 (400-403 Kv).
							<b>11.60</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>277.51</b>	<b>100.00</b>	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	26-02-2024	08:05:00	26-02-2024	17:35:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4938 (406-408Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	10-02-2024	09:48:00	10-02-2024	16:53:00	0.30	0.00	0.00	0.00	7.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1929 (394-397Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	05-02-2024	08:07:00	05-02-2024	18:42:00	0.44	0.00	0.00	0.00	10.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/811 (409-413 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	22-02-2024	08:27:00	23-02-2024	17:08:00	1.36	0.00	0.00	0.00	32.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4192(402 - 406Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	21-02-2024	08:25:00	21-02-2024	17:45:00	0.39	0.00	0.00	0.00	9.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3974 (402 - 406 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	01-02-2024	08:30:00	01-02-2024	20:17:00	0.49	0.00	0.00	0.00	11.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/63( 403-408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	27-02-2024	08:09:00	27-02-2024	17:25:00	0.39	0.00	0.00	0.00	9.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5119 (400-404Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	18-02-2024	09:27:00	18-02-2024	17:01:00	0.32	0.00	0.00	0.00	7.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3440 (400 -404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	24-02-2024	08:59:00	24-02-2024	17:57:00	0.37	0.00	0.00	0.00	8.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4635( 399-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	20-02-2024	08:23:00	20-02-2024	16:53:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3765 (397-400 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	12-02-2024	08:13:00	12-02-2024	17:32:00	0.39	0.00	0.00	0.00	9.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2212 (404 - 408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	03-02-2024	09:10:00	03-02-2024	17:38:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/476 (395-395Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	02-02-2024	07:58:00	02-02-2024	17:25:00	0.39	0.00	0.00	0.00	9.45		

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	04-02-2024	08:58:00	04-02-2024	17:10:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/683 (411 - 411Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	19-02-2024	08:48:00	19-02-2024	17:41:00	0.37	0.00	0.00	0.00	8.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3593 (400-403Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	09-02-2024	08:53:00	09-02-2024	18:08:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1703( 401-404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	17-02-2024	07:48:00	17-02-2024	16:41:00	0.37	0.00	0.00	0.00	8.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3212( 404-407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	16-02-2024	08:20:00	16-02-2024	18:46:00	0.44	0.00	0.00	0.00	10.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3039( 398-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	08-02-2024	07:41:00	08-02-2024	17:27:00	0.41	0.00	0.00	0.00	9.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1463( 410-413 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	06-02-2024	09:15:00	06-02-2024	17:14:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1017(395 - 401Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	13-02-2024	09:02:00	13-02-2024	17:20:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2464 (397 - 398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	15-02-2024	08:51:00	15-02-2024	17:34:00	0.36	0.00	0.00	0.00	8.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2853(402 - 406Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	07-02-2024	09:01:00	07-02-2024	17:03:00	0.34	0.00	0.00	0.00	8.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1238(397 - 401Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	28-02-2024	08:52:00	28-02-2024	17:07:00	0.34	0.00	0.00	0.00	8.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5313 (401 - 407Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	29-02-2024	08:57:00	29-02-2024	18:11:00	0.39	0.00	0.00	0.00	9.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5521 (398 - 403Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	25-02-2024	09:12:00	25-02-2024	15:49:00	0.28	0.00	0.00	0.00	6.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4812( 398-402 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	11-02-2024	07:58:00	11-02-2024	16:04:00	0.34	0.00	0.00	0.00	8.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2072 (414-417Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	14-02-2024	09:53:00	14-02-2024	17:25:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2678(392 - 397Kv).
							11.30	0.00	0.00	0.00	270.67	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	02-02-2024	07:52:00	03-02-2024	17:35:00	1.41	0.00	0.00	0.00	33.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/249 (402 - 407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	01-02-2024	09:15:00	01-02-2024	20:19:00	0.46	0.00	0.00	0.00	11.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/77( 391-391 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	13-02-2024	10:24:00	14-02-2024	17:30:00	1.30	0.00	0.00	0.00	31.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2501 (391 - 394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	22-02-2024	08:32:00	22-02-2024	18:00:00	0.39	0.00	0.00	0.00	9.47		* and tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4203(402 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	16-02-2024	09:24:00	16-02-2024	16:02:00	0.28	0.00	0.00	0.00	6.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3069( 393-393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	10-02-2024	09:50:00	10-02-2024	18:34:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1930 (395-398Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	27-02-2024	08:53:00	28-02-2024	18:32:00	1.40	0.00	0.00	0.00	33.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5128 (402-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	11-02-2024	10:44:00	11-02-2024	15:46:00	0.21	0.00	0.00	0.00	5.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2104 (390-392Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	09-02-2024	08:53:00	09-02-2024	18:14:00	0.39	0.00	0.00	0.00	9.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1704( 402-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	18-02-2024	09:21:00	18-02-2024	17:03:00	0.32	0.00	0.00	0.00	7.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3441( 398 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	17-02-2024	08:43:00	17-02-2024	16:42:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3235( 401-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	23-02-2024	08:47:00	23-02-2024	17:08:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4402(398 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	20-02-2024	09:34:00	21-02-2024	20:52:00	1.47	0.00	0.00	0.00	35.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3783 (392-395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	26-02-2024	08:56:00	26-02-2024	17:22:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4952 (404-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	07-02-2024	09:18:00	07-02-2024	16:49:00	0.31	0.00	0.00	0.00	7.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1247(395 - 395Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	29-02-2024	09:01:00	29-02-2024	18:15:00	0.39	0.00	0.00	0.00	9.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5528 (397 - 399Kv).
							9.72	0.00	0.00	0.00	233.26	100.00	

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	01-02-2024	09:18:00	01-02-2024	20:18:00	0.46	0.00	0.00	0.00	11.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/78( 391-397 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	03-02-2024	09:10:00	03-02-2024	17:36:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/477 (396-396Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	02-02-2024	07:54:00	02-02-2024	17:20:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/250 (407 - 411 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	28-02-2024	09:23:00	28-02-2024	17:00:00	0.32	0.00	0.00	0.00	7.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5339 (391 - 391Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	29-02-2024	09:03:00	29-02-2024	17:58:00	0.37	0.00	0.00	0.00	8.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5529 (399 - 399Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	25-02-2024	09:14:00	25-02-2024	15:47:00	0.27	0.00	0.00	0.00	6.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4811( 397-401 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	14-02-2024	10:00:00	14-02-2024	17:32:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2682(391 - 395Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	08-02-2024	09:13:00	08-02-2024	17:18:00	0.34	0.00	0.00	0.00	8.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1486( 394-394 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	23-02-2024	08:48:00	23-02-2024	17:09:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4412(398 - 398Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	07-02-2024	09:19:00	07-02-2024	16:51:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1248(395 - 395Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	10-02-2024	09:52:00	10-02-2024	16:49:00	0.29	0.00	0.00	0.00	6.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1931 (398-399Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	05-02-2024	10:28:00	06-02-2024	17:11:00	1.28	0.00	0.00	0.00	30.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/848(394-394Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	16-02-2024	08:28:00	16-02-2024	16:04:00	0.32	0.00	0.00	0.00	7.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3041( 401-401 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	15-02-2024	08:55:00	15-02-2024	17:11:00	0.34	0.00	0.00	0.00	8.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2859(402 - 402Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	21-02-2024	09:30:00	21-02-2024	20:53:00	0.47	0.00	0.00	0.00	11.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4003 (396 - 396 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	20-02-2024	09:37:00	20-02-2024	17:07:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3784 (395-397 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	22-02-2024	08:33:00	22-02-2024	18:02:00	0.40	0.00	0.00	0.00	9.48		* and tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4204(402 - 402Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	17-02-2024	08:44:00	17-02-2024	17:16:00	0.36	0.00	0.00	0.00	8.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3236( 402-405 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	09-02-2024	08:54:00	09-02-2024	17:38:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1705( 402-402 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	27-02-2024	08:58:00	27-02-2024	17:26:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5129 (404-408Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	26-02-2024	09:01:00	26-02-2024	17:24:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4953 (404-409Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	11-02-2024	10:44:00	11-02-2024	15:47:00	0.21	0.00	0.00	0.00	5.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2105 (392-395Kv).
							8.51	0.00	0.00	0.00	204.50	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4764(390 - 394Kv).
							29.00	0.00	0.00	0.00	696.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT KOCHI	SVRD	13-02-2024	09:14:00	17-02-2024	20:49:00	4.48	0.00	0.00	0.00	107.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2472 (401 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOCHI	SVRD	20-02-2024	09:58:00	20-02-2024	17:14:00	0.30	0.00	0.00	0.00	7.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3785 (408-411 Kv).
							4.78	0.00	0.00	0.00	114.85	100.00	
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	01-02-2024	07:10:00	03-02-2024	23:21:00	2.67	0.00	0.00	0.00	64.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/39(399 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	21-02-2024	08:23:00	21-02-2024	20:51:00	0.52	0.00	0.00	0.00	12.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3972 (397 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	22-02-2024	08:21:00	23-02-2024	20:55:00	1.52	0.00	0.00	0.00	36.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4190(399 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	18-02-2024	08:13:00	18-02-2024	18:12:00	0.42	0.00	0.00	0.00	9.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3417(406 - 408 Kv).

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	19-02-2024	09:27:00	19-02-2024	17:34:00	0.34	0.00	0.00	0.00	8.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3617 (396-398Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	12-02-2024	08:10:00	12-02-2024	17:25:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2215 (402 - 404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	04-02-2024	09:31:00	06-02-2024	17:04:00	2.32	0.00	0.00	0.00	55.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/698 (400 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	26-02-2024	08:07:00	26-02-2024	17:31:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4936 (399-401Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	13-02-2024	07:43:00	13-02-2024	16:47:00	0.38	0.00	0.00	0.00	9.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2443 (401 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	08-02-2024	07:35:00	09-02-2024	18:31:00	1.46	0.00	0.00	0.00	34.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1458( 405-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	27-02-2024	08:02:00	27-02-2024	20:59:00	0.54	0.00	0.00	0.00	12.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5112 (402-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	16-02-2024	08:16:00	16-02-2024	21:00:00	0.53	0.00	0.00	0.00	12.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3035( 397-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	10-02-2024	07:57:00	10-02-2024	18:23:00	0.44	0.00	0.00	0.00	10.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1891 (408-409Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	07-02-2024	09:06:00	07-02-2024	19:54:00	0.45	0.00	0.00	0.00	10.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1240(401 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	20-02-2024	07:04:00	20-02-2024	16:47:00	0.41	0.00	0.00	0.00	9.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3737 (401-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	29-02-2024	08:43:00	29-02-2024	23:59:59	0.64	0.00	0.00	0.00	15.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5527 (399 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	24-02-2024	08:57:00	24-02-2024	17:05:00	0.34	0.00	0.00	0.00	8.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4626( 399-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	17-02-2024	07:58:00	17-02-2024	17:39:00	0.40	0.00	0.00	0.00	9.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3210( 401-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	14-02-2024	09:42:00	15-02-2024	17:25:00	1.32	0.00	0.00	0.00	31.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2681(394 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	28-02-2024	08:17:00	28-02-2024	18:09:00	0.41	0.00	0.00	0.00	9.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5306 (402 - 404Kv).
							15.89	0.00	0.00	0.00	380.83	100.00	
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	20-02-2024	09:48:00	29-02-2024	23:59:59	9.59	0.00	0.00	0.00	230.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3787 (395-396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	15-02-2024	08:59:00	15-02-2024	20:22:00	0.47	0.00	0.00	0.00	11.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2858(401 - 401Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	12-02-2024	08:10:00	12-02-2024	18:05:00	0.41	0.00	0.00	0.00	9.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2209 (400 - 400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	16-02-2024	08:24:00	18-02-2024	20:29:00	2.50	0.00	0.00	0.00	60.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3042( 399-401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	01-02-2024	08:36:00	03-02-2024	20:36:00	2.50	0.00	0.00	0.00	60.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/59( 401-403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	04-02-2024	09:09:00	11-02-2024	20:26:00	7.47	0.00	0.00	0.00	179.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/685 (395 - 395Kv).
							22.94	0.00	0.00	0.00	550.86	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	15-02-2024	10:04:00	15-02-2024	20:27:00	0.43	0.00	0.00	0.00	10.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2882(398 - 401Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	01-02-2024	08:41:00	03-02-2024	20:44:00	2.50	0.00	0.00	0.00	60.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/60( 404-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	12-02-2024	08:16:00	14-02-2024	17:34:00	2.39	0.00	0.00	0.00	57.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2210 (400 - 403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	20-02-2024	10:01:00	29-02-2024	23:59:59	9.58	0.00	0.00	0.00	229.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3788 (396-398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	16-02-2024	09:20:00	18-02-2024	20:32:00	2.47	0.00	0.00	0.00	59.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3068( 402-402 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	06-02-2024	09:32:00	11-02-2024	20:29:00	5.46	0.00	0.00	0.00	130.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1025(397 - 397Kv).
							22.83	0.00	0.00	0.00	547.86	100.00	
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	19-02-2024	08:48:00	19-02-2024	17:36:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3594 (397-399Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	07-02-2024	09:03:00	07-02-2024	16:57:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1239(392 - 392Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	22-02-2024	08:24:00	22-02-2024	17:51:00	0.39	0.00	0.00	0.00	9.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4189(393 - 396Kv).

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	17-02-2024	08:54:00	17-02-2024	20:30:00	0.48	0.00	0.00	0.00	11.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3237( 401-404 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	03-02-2024	09:58:00	03-02-2024	20:33:00	0.44	0.00	0.00	0.00	10.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/491 (395-397Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	01-02-2024	09:14:00	01-02-2024	17:31:00	0.35	0.00	0.00	0.00	8.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/79( 395-395 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	04-02-2024	09:01:00	04-02-2024	16:58:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/686 (404 - 402Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	02-02-2024	07:56:00	03-02-2024	00:16:00	0.68	0.00	0.00	0.00	16.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/246 (404 - 406 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	23-02-2024	08:42:00	23-02-2024	17:14:00	0.36	0.00	0.00	0.00	8.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4397(395 - 395Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	10-02-2024	10:05:00	10-02-2024	17:22:00	0.30	0.00	0.00	0.00	7.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1927 (402-402Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	18-02-2024	09:31:00	18-02-2024	17:01:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3438 (400 - 401 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	14-02-2024	09:49:00	14-02-2024	17:18:00	0.31	0.00	0.00	0.00	7.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2675(385 - 385Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	26-02-2024	08:08:00	26-02-2024	17:37:00	0.40	0.00	0.00	0.00	9.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4939 (402-402Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	15-02-2024	08:53:00	15-02-2024	17:33:00	0.36	0.00	0.00	0.00	8.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2854(400 - 400Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	09-02-2024	08:56:00	09-02-2024	18:14:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1701( 400-403 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	08-02-2024	09:11:00	08-02-2024	17:12:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1483( 396-396 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	16-02-2024	08:21:00	16-02-2024	20:58:00	0.53	0.00	0.00	0.00	12.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3040( 398-398 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	13-02-2024	09:01:00	13-02-2024	16:58:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2465 (395 - 395 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	06-02-2024	09:13:00	06-02-2024	17:23:00	0.34	0.00	0.00	0.00	8.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1021(390 - 393Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	27-02-2024	08:09:00	27-02-2024	17:14:00	0.38	0.00	0.00	0.00	9.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5120 (400-400Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	05-02-2024	08:08:00	05-02-2024	18:01:00	0.41	0.00	0.00	0.00	9.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/812 (405-410 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	24-02-2024	08:59:00	24-02-2024	17:12:00	0.34	0.00	0.00	0.00	8.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4632( 392-394 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	12-02-2024	09:11:00	12-02-2024	17:33:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2232 (391 - 395 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	20-02-2024	08:27:00	20-02-2024	17:16:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3766 (398-400 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	21-02-2024	08:27:00	21-02-2024	17:52:00	0.39	0.00	0.00	0.00	9.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3975 (399 - 403 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	11-02-2024	08:01:00	11-02-2024	15:54:00	0.33	0.00	0.00	0.00	7.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2073 (412-415Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	29-02-2024	08:40:00	29-02-2024	18:09:00	0.40	0.00	0.00	0.00	9.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5519 (392 - 393Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	28-02-2024	08:49:00	28-02-2024	16:55:00	0.34	0.00	0.00	0.00	8.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5312 (398 - 399Kv).
							<b>10.64</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>255.14</b>	<b>100.00</b>	
BSR	125MVAR, BUS REACTOR-1 AT NAGAPATTINAM	SVRD	27-02-2024	09:15:00	29-02-2024	23:59:59	2.62	0.00	0.00	0.00	62.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5143 (402-402Kv).
							<b>2.62</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>62.75</b>	<b>100.00</b>	
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	05-02-2024	08:09:00	05-02-2024	18:20:00	0.42	0.00	0.00	0.00	10.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/813 (409-411 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	09-02-2024	08:55:00	09-02-2024	17:39:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1706( 402-406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	21-02-2024	08:29:00	21-02-2024	17:39:00	0.38	0.00	0.00	0.00	9.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3981 (405 - 410 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	23-02-2024	08:52:00	23-02-2024	16:42:00	0.33	0.00	0.00	0.00	7.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4404(403 - 407Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	24-02-2024	09:13:00	25-02-2024	15:56:00	1.28	0.00	0.00	0.00	30.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4644( 397-397 Kv).

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	12-02-2024	09:16:00	12-02-2024	17:43:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2234 (401 - 403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	11-02-2024	07:57:00	11-02-2024	15:56:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2070 (405-405Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	07-02-2024	09:16:00	07-02-2024	16:53:00	0.32	0.00	0.00	0.00	7.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1246(400 - 400Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	29-02-2024	09:26:00	29-02-2024	18:11:00	0.37	0.00	0.00	0.00	8.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5550 (399 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	15-02-2024	09:58:00	15-02-2024	17:37:00	0.32	0.00	0.00	0.00	7.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2883(400 - 402Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	02-02-2024	08:37:00	02-02-2024	17:31:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/262 (407 - 408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	03-02-2024	09:52:00	03-02-2024	17:46:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/492 (399-401Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	01-02-2024	08:31:00	01-02-2024	17:23:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/61( 404-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	26-02-2024	08:55:00	26-02-2024	17:49:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4959 (403-406Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	16-02-2024	08:20:00	16-02-2024	16:20:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3043( 401-404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	17-02-2024	07:50:00	17-02-2024	16:42:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3216( 405-409 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	08-02-2024	10:05:00	08-02-2024	19:44:00	0.40	0.00	0.00	0.00	9.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1510( 395-399 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	06-02-2024	09:18:00	06-02-2024	17:17:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1015(398 - 401Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	27-02-2024	08:50:00	27-02-2024	17:19:00	0.35	0.00	0.00	0.00	8.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5127 (404-408Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	10-02-2024	09:52:00	10-02-2024	18:28:00	0.36	0.00	0.00	0.00	8.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1932 (395-398Kv).
							8.04	0.00	0.00	0.00	193.23	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC	SVRD	01-02-2024	00:00:01	10-02-2024	00:18:00	9.01	0.00	0.00	0.00	216.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4459 (401 - 404 Kv).
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC	SVRD	12-02-2024	08:17:00	29-02-2024	23:59:59	17.66	0.00	0.00	0.00	423.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2224 (414 - 417 Kv).
							26.67	0.00	0.00	0.00	640.02	100.00	
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC	SVRD	12-02-2024	08:19:00	29-02-2024	23:59:59	17.65	0.00	0.00	0.00	423.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2225 (419 - 422 Kv).
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC	SVRD	01-02-2024	00:00:01	10-02-2024	00:21:00	9.02	0.00	0.00	0.00	216.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4460 (404 - 407 Kv).
							26.67	0.00	0.00	0.00	640.03	100.00	
BSR	63MVAR, BUS REACTOR-1 AT PALAKKAD	SVRD	03-02-2024	10:09:00	15-02-2024	20:44:00	12.44	0.00	0.00	0.00	298.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/505 (406-410Kv).
BSR	63MVAR, BUS REACTOR-1 AT PALAKKAD	SVRD	16-02-2024	11:31:00	17-02-2024	20:45:00	1.39	0.00	0.00	0.00	33.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3092( 410-412 Kv).
BSR	63MVAR, BUS REACTOR-1 AT PALAKKAD	SVRD	26-02-2024	08:51:00	29-02-2024	23:59:59	3.63	0.00	0.00	0.00	87.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4944 (415-416Kv).
							17.46	0.00	0.00	0.00	418.96	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR	SVRD	27-02-2024	09:14:00	29-02-2024	23:59:59	2.62	0.00	0.00	0.00	62.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5144 (403-406Kv).
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR	SVRD	01-02-2024	10:09:00	10-02-2024	00:32:00	8.60	0.00	0.00	0.00	206.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/95( 399-403 Kv).
							11.22	0.00	0.00	0.00	269.15	100.00	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	22-02-2024	08:26:00	22-02-2024	17:54:00	0.39	0.00	0.00	0.00	9.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4198(403 - 407Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	06-02-2024	09:13:00	06-02-2024	17:30:00	0.35	0.00	0.00	0.00	8.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1018(400 - 404Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	05-02-2024	07:13:00	05-02-2024	18:01:00	0.45	0.00	0.00	0.00	10.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/789 (412-414 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	12-02-2024	09:20:00	12-02-2024	17:47:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2230 (400 - 402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	07-02-2024	09:27:00	07-02-2024	16:55:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1249(400 - 402Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	18-02-2024	09:27:00	18-02-2024	16:52:00	0.31	0.00	0.00	0.00	7.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3442 (408 - 408 Kv).

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	27-02-2024	08:49:00	27-02-2024	17:01:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5125 (405-407Kv)
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	20-02-2024	08:26:00	20-02-2024	17:03:00	0.36	0.00	0.00	0.00	8.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3761 (405-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	17-02-2024	08:49:00	17-02-2024	16:48:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3231( 406-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	10-02-2024	09:49:00	10-02-2024	16:55:00	0.30	0.00	0.00	0.00	7.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1934 (402-404Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	23-02-2024	08:49:00	23-02-2024	16:57:00	0.34	0.00	0.00	0.00	8.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4408(405 - 407Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	26-02-2024	08:58:00	26-02-2024	17:16:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4954 (409-412Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	25-02-2024	09:15:00	25-02-2024	15:40:00	0.27	0.00	0.00	0.00	6.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4808( 406-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	11-02-2024	09:14:00	11-02-2024	15:50:00	0.28	0.00	0.00	0.00	6.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2091 (405-405Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	02-02-2024	08:39:00	02-02-2024	16:53:00	0.34	0.00	0.00	0.00	8.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/263 (410 - 411 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	01-02-2024	09:11:00	01-02-2024	17:17:00	0.34	0.00	0.00	0.00	8.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/73( 400-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	04-02-2024	08:55:00	04-02-2024	16:54:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/687 ( 409 - 411Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	03-02-2024	09:14:00	03-02-2024	20:40:00	0.48	0.00	0.00	0.00	11.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/478 (402-405Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	13-02-2024	08:57:00	13-02-2024	17:01:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2466 (405 - 407 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	09-02-2024	08:57:00	09-02-2024	16:58:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1707( 409-412 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	28-02-2024	09:23:00	28-02-2024	17:03:00	0.32	0.00	0.00	0.00	7.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5337 (399 - 401Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	29-02-2024	09:23:00	29-02-2024	17:53:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5546 (398 - 401Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	14-02-2024	10:03:00	14-02-2024	17:25:00	0.31	0.00	0.00	0.00	7.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2689(400 - 402Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	19-02-2024	08:51:00	19-02-2024	17:34:00	0.36	0.00	0.00	0.00	8.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3595 (404-408Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	08-02-2024	10:10:00	08-02-2024	17:23:00	0.30	0.00	0.00	0.00	7.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1511( 400-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	16-02-2024	08:18:00	16-02-2024	16:17:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3044( 401-403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	24-02-2024	09:15:00	24-02-2024	16:52:00	0.32	0.00	0.00	0.00	7.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4646( 398-400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	21-02-2024	08:35:00	21-02-2024	17:53:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3987 (408 - 410 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	15-02-2024	09:47:00	15-02-2024	17:16:00	0.31	0.00	0.00	0.00	7.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2876(398 - 398Kv).
							<b>9.88</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>236.93</b>	<b>100.00</b>	
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	28-02-2024	09:25:00	28-02-2024	17:04:00	0.32	0.00	0.00	0.00	7.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5338 (401 - 403Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	29-02-2024	09:25:00	29-02-2024	17:56:00	0.36	0.00	0.00	0.00	8.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5547 (401 - 401Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	23-02-2024	08:56:00	23-02-2024	17:03:00	0.34	0.00	0.00	0.00	8.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4409(407 - 409Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	10-02-2024	09:51:00	10-02-2024	16:58:00	0.30	0.00	0.00	0.00	7.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1935 (404-407Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	20-02-2024	09:44:00	20-02-2024	16:55:00	0.30	0.00	0.00	0.00	7.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3782 (402-405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	11-02-2024	09:16:00	11-02-2024	15:51:00	0.27	0.00	0.00	0.00	6.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2092 (405-406Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	22-02-2024	08:27:00	22-02-2024	17:53:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4199(407 - 410Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	18-02-2024	09:29:00	18-02-2024	16:55:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3443 (408 - 410 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	04-02-2024	08:58:00	04-02-2024	17:00:00	0.34	0.00	0.00	0.00	8.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/684 ( 411 - 413Kv).

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	03-02-2024	09:17:00	03-02-2024	20:45:00	0.48	0.00	0.00	0.00	11.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/479 (405-405Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	01-02-2024	09:11:00	01-02-2024	17:18:00	0.34	0.00	0.00	0.00	8.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/74( 402-402 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	02-02-2024	08:41:00	02-02-2024	16:58:00	0.35	0.00	0.00	0.00	8.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/264 (412 -414 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	26-02-2024	09:00:00	26-02-2024	17:18:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4955 (412-413Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	25-02-2024	09:16:00	25-02-2024	15:43:00	0.27	0.00	0.00	0.00	6.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4809( 408-409 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	07-02-2024	09:29:00	07-02-2024	16:58:00	0.31	0.00	0.00	0.00	7.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1250(402 - 402Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	13-02-2024	09:02:00	13-02-2024	17:09:00	0.34	0.00	0.00	0.00	8.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2467 (405 - 405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	09-02-2024	08:59:00	09-02-2024	17:01:00	0.34	0.00	0.00	0.00	8.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1708( 412-414 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	05-02-2024	07:20:00	05-02-2024	18:05:00	0.45	0.00	0.00	0.00	10.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/804 (412-414 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	16-02-2024	08:19:00	16-02-2024	16:25:00	0.34	0.00	0.00	0.00	8.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3045( 403-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	15-02-2024	09:48:00	15-02-2024	17:28:00	0.32	0.00	0.00	0.00	7.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2877(398 - 402Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	17-02-2024	08:50:00	17-02-2024	16:54:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3232( 408-409 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	06-02-2024	09:14:00	06-02-2024	17:26:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1020(404 - 406Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	27-02-2024	08:51:00	27-02-2024	17:10:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5126 (405-407Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	24-02-2024	09:17:00	24-02-2024	16:54:00	0.32	0.00	0.00	0.00	7.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4647( 400-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	19-02-2024	08:51:00	19-02-2024	17:39:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3596 (408-408Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	14-02-2024	11:24:00	14-02-2024	17:32:00	0.26	0.00	0.00	0.00	6.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2700(400 - 400Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	12-02-2024	09:22:00	12-02-2024	17:40:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2233 (402 - 405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	21-02-2024	08:36:00	21-02-2024	17:48:00	0.38	0.00	0.00	0.00	9.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3988 (410 - 410 Kv).
							9.53	0.00	0.00	0.00	227.47	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	01-02-2024	00:00:01	03-02-2024	23:33:00	2.98	0.00	0.00	0.00	71.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4782(391 - 393Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	24-02-2024	08:57:00	29-02-2024	23:59:59	5.63	0.00	0.00	0.00	135.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4629( 394-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	14-02-2024	10:01:00	15-02-2024	20:42:00	1.45	0.00	0.00	0.00	34.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2688(394 - 394Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	20-02-2024	08:23:00	20-02-2024	17:30:00	0.38	0.00	0.00	0.00	9.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3768 (394-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	07-02-2024	10:59:00	13-02-2024	17:25:00	6.27	0.00	0.00	0.00	150.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1286(393 - 393Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	21-02-2024	09:09:00	23-02-2024	21:12:00	2.50	0.00	0.00	0.00	60.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3996 (395 - 395 Kv).
							19.21	0.00	0.00	0.00	460.88	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	10-02-2024	08:09:00	10-02-2024	18:42:00	0.44	0.00	0.00	0.00	10.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1892 (403-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	22-02-2024	08:33:00	22-02-2024	18:52:00	0.43	0.00	0.00	0.00	10.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3738 (400-403 Kv).* 22.02.2024 12:27:40 INDIA (60011256)* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4197(399 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	01-02-2024	07:52:00	01-02-2024	16:44:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/50( 402-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	02-02-2024	08:03:00	02-02-2024	17:29:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/243 (404 - 404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	08-02-2024	09:22:00	08-02-2024	17:23:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1487( 392-394 Kv).

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	24-02-2024	08:56:00	25-02-2024	15:51:00	1.29	0.00	0.00	0.00	30.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4628( 392-392 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	06-02-2024	09:16:00	06-02-2024	17:44:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1019(393 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	05-02-2024	07:06:00	05-02-2024	17:59:00	0.45	0.00	0.00	0.00	10.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/786 (399-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	27-02-2024	08:14:00	28-02-2024	18:44:00	1.44	0.00	0.00	0.00	34.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5113 (400-400Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	12-02-2024	08:13:00	12-02-2024	17:50:00	0.40	0.00	0.00	0.00	9.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2216 (401 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	09-02-2024	08:51:00	09-02-2024	18:22:00	0.40	0.00	0.00	0.00	9.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1700( 400-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	07-02-2024	09:05:00	07-02-2024	17:15:00	0.34	0.00	0.00	0.00	8.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1241(391 - 391Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	23-02-2024	08:44:00	23-02-2024	21:19:00	0.52	0.00	0.00	0.00	12.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4399(392 - 392Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	14-02-2024	09:47:00	19-02-2024	19:20:00	5.40	0.00	0.00	0.00	129.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2674(386 - 386Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	21-02-2024	08:28:00	21-02-2024	17:47:00	0.39	0.00	0.00	0.00	9.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3977 (395 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	13-02-2024	09:15:00	13-02-2024	17:09:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2468 (393 - 395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	26-02-2024	08:09:00	26-02-2024	17:31:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4931 (401-401Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	20-02-2024	07:13:00	20-02-2024	17:28:00	0.43	0.00	0.00	0.00	10.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3738 (400-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	29-02-2024	08:57:00	29-02-2024	23:59:59	0.63	0.00	0.00	0.00	15.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5523 (396 - 396Kv).
							14.72	0.00	0.00	0.00	353.29	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SRIPERUMBUDUR	SVRD	01-02-2024	00:00:01	03-02-2024	23:31:00	2.98	0.00	0.00	0.00	71.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4784(394 - 394Kv).
BSR	63MVAR, BUS REACTOR-1 AT SRIPERUMBUDUR	SVRD	05-02-2024	09:01:00	29-02-2024	23:59:59	24.62	0.00	0.00	0.00	590.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/816 (397-397 Kv).
							27.60	0.00	0.00	0.00	662.50	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TIRUNELVELLI	SVRD	05-02-2024	11:31:00	22-02-2024	18:47:00	17.30	0.00	0.00	0.00	415.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/860 (406-408 Kv).
							17.30	0.00	0.00	0.00	415.27	100.00	
BSR	63MVAR, BUS REACTOR-2 AT TIRUNELVELLI	SVRD	05-02-2024	11:32:00	29-02-2024	23:59:59	24.52	0.00	0.00	0.00	588.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/861 (408-410 Kv).
							24.52	0.00	0.00	0.00	588.47	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TRIVANDRUM	SVRD	03-02-2024	09:32:00	29-02-2024	23:59:59	26.60	0.00	0.00	0.00	638.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/480 (405-411Kv).
							26.60	0.00	0.00	0.00	638.47	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	20-02-2024	08:28:00	20-02-2024	17:13:00	0.37	0.00	0.00	0.00	8.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3759 (407-409 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	08-02-2024	10:01:00	08-02-2024	17:32:00	0.31	0.00	0.00	0.00	7.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1508( 401-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	28-02-2024	10:24:00	28-02-2024	18:08:00	0.32	0.00	0.00	0.00	7.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5350 (401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	18-02-2024	09:23:00	18-02-2024	16:51:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3444 (405 - 407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	03-02-2024	09:47:00	03-02-2024	17:47:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/489 (398-400Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	01-02-2024	09:15:00	01-02-2024	16:58:00	0.32	0.00	0.00	0.00	7.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/75( 403-405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	02-02-2024	09:17:00	02-02-2024	17:06:00	0.33	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/269 (400 - 401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	26-02-2024	09:03:00	27-02-2024	17:14:00	1.34	0.00	0.00	0.00	32.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4956 (412-412Kv).

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	10-02-2024	09:49:00	10-02-2024	16:45:00	0.29	0.00	0.00	0.00	6.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1936 (401-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	17-02-2024	08:52:00	17-02-2024	17:41:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3233( 411-412 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	15-02-2024	09:50:00	15-02-2024	17:20:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2878(401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	21-02-2024	08:38:00	21-02-2024	17:54:00	0.39	0.00	0.00	0.00	9.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3989 (410 - 413 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	14-02-2024	09:56:00	14-02-2024	17:29:00	0.32	0.00	0.00	0.00	7.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2683(400 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	13-02-2024	09:05:00	13-02-2024	17:18:00	0.34	0.00	0.00	0.00	8.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2470 (401 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	16-02-2024	09:15:00	16-02-2024	16:03:00	0.28	0.00	0.00	0.00	6.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3066( 402-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	07-02-2024	11:05:00	07-02-2024	17:13:00	0.26	0.00	0.00	0.00	6.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1284(404 - 406Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	05-02-2024	07:10:00	05-02-2024	18:09:00	0.46	0.00	0.00	0.00	10.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/788 (409-410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	09-02-2024	08:58:00	09-02-2024	16:44:00	0.32	0.00	0.00	0.00	7.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1709( 412-414 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	23-02-2024	08:51:00	23-02-2024	16:40:00	0.33	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4406(408 - 408Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	29-02-2024	09:30:00	29-02-2024	18:05:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5548 (403 - 406Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	24-02-2024	09:16:00	24-02-2024	16:57:00	0.32	0.00	0.00	0.00	7.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4649( 400-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	22-02-2024	08:36:00	22-02-2024	18:07:00	0.40	0.00	0.00	0.00	9.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4201(411 - 411Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	06-02-2024	09:21:00	06-02-2024	17:18:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1024(405 - 405Kv).
							8.71	0.00	0.00	0.00	208.71	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	20-02-2024	08:30:00	20-02-2024	17:15:00	0.37	0.00	0.00	0.00	8.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3760 (409-411 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	16-02-2024	09:17:00	16-02-2024	16:13:00	0.29	0.00	0.00	0.00	6.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3067( 403-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	10-02-2024	09:50:00	10-02-2024	16:54:00	0.29	0.00	0.00	0.00	7.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1938 (403-407Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	23-02-2024	08:52:00	23-02-2024	16:49:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4407(408 - 410Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	13-02-2024	10:21:00	13-02-2024	17:22:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2496 (401 - 403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	03-02-2024	09:50:00	03-02-2024	17:49:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/490 (400-401Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	02-02-2024	09:19:00	02-02-2024	17:07:00	0.33	0.00	0.00	0.00	7.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/270 (402 - 404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	01-02-2024	09:16:00	01-02-2024	16:53:00	0.32	0.00	0.00	0.00	7.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/76( 405-405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	18-02-2024	09:22:00	18-02-2024	17:00:00	0.32	0.00	0.00	0.00	7.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3445 (405 - 405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	08-02-2024	10:10:00	08-02-2024	17:36:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1509( 404-406 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	15-02-2024	09:51:00	15-02-2024	17:19:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2880(401 - 404Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	14-02-2024	09:58:00	14-02-2024	17:28:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2684(400 - 402Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	09-02-2024	08:59:00	09-02-2024	16:46:00	0.32	0.00	0.00	0.00	7.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1710( 414-417 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	22-02-2024	08:37:00	22-02-2024	18:10:00	0.40	0.00	0.00	0.00	9.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4202(411 - 414Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	17-02-2024	08:53:00	17-02-2024	16:47:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3234( 412-413 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	07-02-2024	11:06:00	07-02-2024	17:15:00	0.26	0.00	0.00	0.00	6.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1285(406 - 408Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	12-02-2024	09:18:00	12-02-2024	17:24:00	0.34	0.00	0.00	0.00	8.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2235 (402 - 402 Kv).

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	27-02-2024	10:01:00	27-02-2024	17:21:00	0.31	0.00	0.00	0.00	7.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5150 (407-409Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	06-02-2024	09:21:00	06-02-2024	17:20:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1022(405 - 405Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	21-02-2024	08:42:00	21-02-2024	17:56:00	0.39	0.00	0.00	0.00	9.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3990 (413 - 416 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	24-02-2024	09:16:00	24-02-2024	17:02:00	0.32	0.00	0.00	0.00	7.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4650( 400-402 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	19-02-2024	08:54:00	19-02-2024	17:35:00	0.36	0.00	0.00	0.00	8.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3597 (408-410Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	25-02-2024	09:14:00	25-02-2024	15:52:00	0.28	0.00	0.00	0.00	6.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4810( 408-411 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	28-02-2024	10:35:00	28-02-2024	17:06:00	0.27	0.00	0.00	0.00	6.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5351 (401 - 404Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	29-02-2024	09:28:00	29-02-2024	18:06:00	0.36	0.00	0.00	0.00	8.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5549 (401 - 403Kv).
							8.07	0.00	0.00	0.00	193.40	100.00	
BSR	63MVAR, BUS REACTOR AT TUTICORIN PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	PUGALUR-1 _LINE_REACTOR_ 63MVAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	17-02-2024	09:41:00	18-02-2024	18:26:00	1.37	0.00	0.00	0.00	32.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3245/2111( 740-746 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	27-02-2024	09:56:00	29-02-2024	23:59:59	2.59	0.00	0.00	0.00	62.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5155 (756-764Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	22-02-2024	09:34:00	24-02-2024	19:34:00	2.42	0.00	0.00	0.00	58.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4219(749 - 457Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	20-02-2024	08:02:00	20-02-2024	18:48:00	0.45	0.00	0.00	0.00	10.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3758 (756-764 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	09-02-2024	07:14:00	09-02-2024	16:29:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1669/1029( 753-761 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	21-02-2024	09:34:00	21-02-2024	20:55:00	0.47	0.00	0.00	0.00	11.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4005 (751 - 759 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	01-02-2024	05:46:00	01-02-2024	14:10:00	0.35	0.00	0.00	0.00	8.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/09(759 - 770Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	03-02-2024	09:02:00	03-02-2024	19:34:00	0.44	0.00	0.00	0.00	10.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/468/304 (765-771Kv).
							8.48	0.00	0.00	0.00	203.12	100.00	
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	19-02-2024	08:56:00	19-02-2024	19:06:00	0.42	0.00	0.00	0.00	10.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3607/2395 (755-764Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	26-02-2024	08:56:00	26-02-2024	17:41:00	0.37	0.00	0.00	0.00	8.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4961 (767-775Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	09-02-2024	11:32:00	09-02-2024	18:25:00	0.29	0.00	0.00	0.00	6.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1746/1089( 765-774 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	12-02-2024	09:23:00	12-02-2024	20:17:00	0.45	0.00	0.00	0.00	10.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2251 (758 - 768 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	01-02-2024	07:11:00	03-02-2024	19:37:00	2.52	0.00	0.00	0.00	60.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/37(749 - 761Kv).
							4.05	0.00	0.00	0.00	97.13	100.00	
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	21-02-2024	08:37:00	21-02-2024	20:50:00	0.51	0.00	0.00	0.00	12.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3979 (404 - 404 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	17-02-2024	07:55:00	17-02-2024	17:45:00	0.41	0.00	0.00	0.00	9.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3214( 403-404 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	15-02-2024	08:55:00	15-02-2024	17:25:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2857(398 - 401Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	20-02-2024	07:11:00	20-02-2024	17:19:00	0.42	0.00	0.00	0.00	10.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3740 (403-405 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	13-02-2024	09:00:00	13-02-2024	16:58:00	0.33	0.00	0.00	0.00	7.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2460 (396 - 398 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	06-02-2024	09:36:00	06-02-2024	17:08:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1016(397 - 397Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	26-02-2024	08:12:00	26-02-2024	17:21:00	0.38	0.00	0.00	0.00	9.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4935 (403-405Kv).

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	02-02-2024	08:02:00	02-02-2024	17:58:00	0.41	0.00	0.00	0.00	9.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/246 (407 - 408 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	04-02-2024	09:32:00	04-02-2024	16:53:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/697 (395 - 398Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	01-02-2024	07:53:00	01-02-2024	17:16:00	0.39	0.00	0.00	0.00	9.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/52( 403-406 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	12-02-2024	08:18:00	12-02-2024	17:48:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2214 (406 - 408 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	16-02-2024	08:25:00	16-02-2024	20:59:00	0.52	0.00	0.00	0.00	12.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3038( 399-402 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	24-02-2024	09:04:00	24-02-2024	16:53:00	0.33	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4638( 396-396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	07-02-2024	09:12:00	07-02-2024	17:37:00	0.35	0.00	0.00	0.00	8.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1244(392 - 395Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	09-02-2024	09:02:00	09-02-2024	18:21:00	0.39	0.00	0.00	0.00	9.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1699( 401-401 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	22-02-2024	08:22:00	23-02-2024	20:58:00	1.53	0.00	0.00	0.00	36.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4188(394 - 395Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	19-02-2024	08:41:00	19-02-2024	17:35:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3591 (398-398Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	08-02-2024	09:20:00	08-02-2024	17:16:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1485( 395-395 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	05-02-2024	07:04:00	05-02-2024	18:22:00	0.47	0.00	0.00	0.00	11.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/783( 401-402 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	27-02-2024	08:05:00	27-02-2024	17:22:00	0.39	0.00	0.00	0.00	9.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5116 (403-403Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	18-02-2024	09:13:00	18-02-2024	16:57:00	0.32	0.00	0.00	0.00	7.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3437 (394 - 396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	10-02-2024	08:01:00	11-02-2024	15:55:00	1.33	0.00	0.00	0.00	31.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1895 (406-407Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	14-02-2024	09:52:00	14-02-2024	17:38:00	0.32	0.00	0.00	0.00	7.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2673(390 - 390Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	25-02-2024	09:15:00	25-02-2024	15:42:00	0.27	0.00	0.00	0.00	6.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4807( 402-402 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	28-02-2024	08:46:00	28-02-2024	17:16:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5310 (400 - 400Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	29-02-2024	09:12:00	29-02-2024	17:55:00	0.36	0.00	0.00	0.00	8.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5525 (392 - 392Kv).
							11.85	0.00	0.00	0.00	284.70	100.00	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	13-02-2024	09:05:00	13-02-2024	17:27:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2462 (397 - 397 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	27-02-2024	08:07:00	28-02-2024	00:08:00	0.67	0.00	0.00	0.00	16.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5117 (403-403Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	12-02-2024	09:12:00	12-02-2024	18:18:00	0.38	0.00	0.00	0.00	9.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2240 (394 - 396 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	07-02-2024	09:15:00	08-02-2024	17:20:00	1.34	0.00	0.00	0.00	32.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1245(395 - 395Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	17-02-2024	09:24:00	17-02-2024	17:50:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3244( 401-401 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	01-02-2024	07:56:00	04-02-2024	16:56:00	3.38	0.00	0.00	0.00	81.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/53( 406-406 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	28-02-2024	08:53:00	28-02-2024	18:13:00	0.39	0.00	0.00	0.00	9.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5311 (402 - 403Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	29-02-2024	09:16:00	29-02-2024	23:59:59	0.61	0.00	0.00	0.00	14.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5526 (392 - 392Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	14-02-2024	09:54:00	16-02-2024	21:05:00	2.47	0.00	0.00	0.00	59.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2680(390 - 394Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	23-02-2024	08:48:00	26-02-2024	17:24:00	3.36	0.00	0.00	0.00	80.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4401(397 - 400Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	19-02-2024	09:28:00	21-02-2024	20:53:00	2.48	0.00	0.00	0.00	59.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3617 (396-398Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	05-02-2024	07:07:00	06-02-2024	17:11:00	1.42	0.00	0.00	0.00	34.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/784 (402-404 Kv).
							17.20	0.00	0.00	0.00	412.33	100.00	

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	21-02-2024	08:33:00	21-02-2024	20:47:00	0.51	0.00	0.00	0.00	12.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3978 (401 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	06-02-2024	09:45:00	06-02-2024	17:48:00	0.34	0.00	0.00	0.00	8.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1014(395 - 395Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	24-02-2024	09:01:00	24-02-2024	16:51:00	0.33	0.00	0.00	0.00	7.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4637( 396-396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	23-02-2024	08:46:00	23-02-2024	20:54:00	0.51	0.00	0.00	0.00	12.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4400(395 - 397Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	18-02-2024	09:17:00	18-02-2024	16:47:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3436 (396 - 396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	14-02-2024	09:50:00	14-02-2024	17:36:00	0.32	0.00	0.00	0.00	7.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2672(388 - 390Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	07-02-2024	09:09:00	07-02-2024	17:18:00	0.34	0.00	0.00	0.00	8.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1243(392 - 392Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	25-02-2024	09:12:00	25-02-2024	15:38:00	0.27	0.00	0.00	0.00	6.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4806( 398-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	05-02-2024	07:02:00	05-02-2024	18:18:00	0.47	0.00	0.00	0.00	11.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/782( 400-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	08-02-2024	09:17:00	08-02-2024	17:13:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1484( 394-395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	15-02-2024	08:52:00	15-02-2024	17:19:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2859(402 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	19-02-2024	08:38:00	19-02-2024	17:30:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3590 (396-398Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	09-02-2024	09:00:00	09-02-2024	18:18:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1698( 400-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	10-02-2024	07:58:00	11-02-2024	15:51:00	1.33	0.00	0.00	0.00	31.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/1894 (406-406Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	12-02-2024	08:15:00	12-02-2024	17:46:00	0.40	0.00	0.00	0.00	9.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2213 (405 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	13-02-2024	08:54:00	13-02-2024	16:55:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2459 (396 - 396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	17-02-2024	07:51:00	17-02-2024	17:42:00	0.41	0.00	0.00	0.00	9.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3213( 403-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	16-02-2024	08:22:00	16-02-2024	18:41:00	0.43	0.00	0.00	0.00	10.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3037( 399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	27-02-2024	08:02:00	27-02-2024	17:18:00	0.39	0.00	0.00	0.00	9.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5115 (406-406Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	26-02-2024	08:09:00	26-02-2024	17:19:00	0.38	0.00	0.00	0.00	9.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4934 (402-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	01-02-2024	07:50:00	01-02-2024	17:11:00	0.39	0.00	0.00	0.00	9.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/51( 401-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	04-02-2024	09:29:00	04-02-2024	16:50:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/696 (395 - 395Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	02-02-2024	08:00:00	02-02-2024	17:21:00	0.39	0.00	0.00	0.00	9.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/244 (405 - 407Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	20-02-2024	07:08:00	20-02-2024	17:12:00	0.42	0.00	0.00	0.00	10.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3739 (400-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	22-02-2024	08:20:00	22-02-2024	17:55:00	0.40	0.00	0.00	0.00	9.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4185(393 - 394Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	29-02-2024	09:07:00	29-02-2024	17:51:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5524 (392 - 392Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	28-02-2024	08:43:00	28-02-2024	17:13:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5309 (400 - 400Kv).
							11.13	0.00	0.00	0.00	266.87	100.00	
CKT	230kV BHAVINI-ARANI(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV BHAVINI-ARANI(TANTRANSCO)-2	OMSU	09-02-2024	21:21:00	09-02-2024	21:21:00	0.00	0.00	0.00	0.00	0.00		* Auto reclosure successful on B-G fault. No fault readings recorded at both ends.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV BHAVINI-KANCHIPURAM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV BHAVINI-KANCHIPURAM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	



**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-TALAGUPPA(KPTCL)-1	LNCC	17-02-2024	15:04:00	17-02-2024	16:16:00	0.05	0.00	0.00	1.20	0.00		* Line tripped on Y phase to Ground fault, AR attempted but failed due to fault in reclaim time. Hassan End Details: M1: 31.3KM/5.42KA, M2: 30.7KM/6.2KA, Talaguppa End Details: M1: 272KM/12.06KA, M2: 265.4KM/0.906KA* As per Patrolling report Agriculture Fire found at span Loc 112-113.
CKT	400kV HASSAN-TALAGUPPA(KPTCL)-1	OMSU	22-02-2024	14:18:00	22-02-2024	14:56:00	0.03	0.00	0.63	0.00	0.00		* Line tripped at Talaguppa end only. Due to tripping of ICT-1 at 400KV Talaguppa, 400KV Talaguppa-Shantigrama Line was in service through Tie Bay only. Due to which 400KV Talaguppa-Shantigrama Line also tripped along with ICT-1 at Talaguppa end.
							0.08	0.00	0.63	1.20	0.00	100.00	
CKT	400kV HOSUR-SALEM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HOSUR-SALEM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-NARENDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-NARENDRA-2	LART	04-02-2024	02:58:00	04-02-2024	02:58:00	0.00	0.00	0.00	0.00	0.00		* Auto reclosed successfully on B-N (Ph-earth) transient fault,Z1 operation. Narendra end Details: FLR - M1/M2= 49.82/50.29 kms and FC - 4.781/4.719 kA ,Fault angle=79 degree. Kaiga end Details: FLR - M1/M2=49.5/48.89 kms and FC - NR/2.31 kA.* Fault comes under Narendra TLM Jurisdiction.
CKT	400kV KAIGA(NPCIL)-NARENDRA-2	OSPD	01-02-2024	00:00:01	01-02-2024	14:15:00	0.59	0.00	0.00	0.00	14.25		* Shut down availed by NPCIL to replace CB and line CT vide SRLDC code no. CR-01/3972.
							0.59	0.00	0.00	0.00	14.25	100.00	
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	10-02-2024	16:05:00	10-02-2024	19:42:00	0.15	0.00	0.00	0.00	3.62		* Shut down availed on emergency basis by KPTCL Kaiga for facilitating rectification of flashed over insulator at Loc. no. 227 of 400kV Kaiga-Guttur # 2
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	22-02-2024	10:07:00	22-02-2024	19:41:00	0.40	0.00	0.00	0.00	9.57		* Shut down availed by Kaiga for quarterly maintenance works vide SRLDC code no. CR-02/4231.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	11-02-2024	10:34:00	11-02-2024	14:52:00	0.18	0.00	0.00	0.00	4.30		* Shutdown taken by KPTCL for maintenance works vide SRLDC code: 02/2101
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	02-02-2024	10:09:00	02-02-2024	18:22:00	0.34	0.00	0.00	0.00	8.22		* Shut down availed by KPTCL for attending Insulator Decapping in Kaiga Guttur Ckt 2 vide SRLDC code no. CR-02/285.
							1.07	0.00	0.00	0.00	25.71	100.00	
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	10-02-2024	04:38:00	11-02-2024	15:09:00	1.44	0.00	34.52	0.00	0.00		* Line tripped on Y-G fault, KAIGA end details: M1: FLR: 62.26 KM, FC: 4.09KAmps. GUTTUR end details:M1: FLR: 140.5 KM, FC:2.9 Kamps. Fault is in KPTCL Jurisdiction.Y-PH Insulator Failure found in Loc.no.227.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OSPD	15-02-2024	10:53:00	15-02-2024	19:14:00	0.35	0.00	0.00	0.00	8.35		* Shut down availed by KPCTL for SF6 gas leakage in CB vide SRLDC code no. CR-02/2895
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	01-02-2024	04:34:00	02-02-2024	18:30:00	1.58	0.00	37.93	0.00	0.00		* Line tripped on R-G fault.* Kaiga end details: M1: NA, M2: FLR: 96.94 KM, FC: 2.647 Kamps.* Guttur end details:M1: FLR: NR, FC: 2.95 Kamps, M2: FLR: NR, FC: 2.95 Kamps.* Fault is in KPTCL Jurisdiction.* Charging attempt failed at 05:57 hrs on 01.02.2024 vide SRLDC code CR 02/01/07
							3.37	0.00	72.45	0.00	8.35	100.00	
CKT	400kV KARAIKUDI-MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-1	OSPD	07-02-2024	07:55:00	07-02-2024	20:14:00	0.51	0.00	0.00	0.00	12.32		* Shut down availed by KKNPP for maintenance works vide SRLDC code no. CR-02/1227
							0.51	0.00	0.00	0.00	12.32	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-2	OSPD	14-02-2024	07:47:00	14-02-2024	20:15:00	0.52	0.00	0.00	0.00	12.47		* Shut down availed by Kudankulam for maintenance works vide SRLDC code no. CR-02/2652
							0.52	0.00	0.00	0.00	12.47	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-KOCHI-KOTTAYAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-KOCHI-KOTTAYAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-HOODY(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-HOODY(KPTCL)-2	LMAC	24-02-2024	07:16:00	24-02-2024	08:02:00	0.03	0.00	0.00	0.77	0.00		* Line tripped on B-G fault at Hoody end only and Auto reclosed successful at Kolar end. Kolar end details: M1: FLR: 54.9 KM, FC: 6.07 Kamps, M2: FLR: 57.63 KM, FC: 6.043 Kamps. Hoody end details:M1: FLR: 15.47 KM, FC: 12.97 Kamps, M2: NR.* Fault is in KolarTLM Jurisdiction.* Emergency patrolling has been carried out by Kolar TLM and found drip pipe hanging on earth wire and top conductor(Bph) at location no 110.

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV KOLAR-HOODY(KPTCL)-2	LMAC	24-02-2024	11:07:00	24-02-2024	15:10:00	0.17	0.00	0.00	4.05	0.00		* Emergency Shut down availed for removing foreign material (Drip Pipe) which is hanging on earth wire and top conductor(Bph) at location no 110 vide SRLDC code no. CR-02/4666.
							0.20	0.00	0.00	4.82	0.00	100.00	
CKT	400kV KOLAR-HOSUR-1	LVRD	20-02-2024	10:09:00	20-02-2024	10:40:00	0.02	0.00	0.00	0.00	0.52		* Hand tripped as per SRLDC instruction (Mock exercise to study the volatge profile in the vicinity) vide code CR-02/3797
							0.02	0.00	0.00	0.00	0.52	100.00	
CKT	400kV KOLAR-HOSUR-2	LVRD	20-02-2024	10:17:00	20-02-2024	10:41:00	0.02	0.00	0.00	0.00	0.40		* Hand tripped as per SRLDC instruction (Mock exercise to study the volatge profile in the vicinity) vide code CR-02/3800
							0.02	0.00	0.00	0.00	0.40	100.00	
CKT	400kV KOLAR-MYLASANDRA (KPTCL)	LMAC	07-02-2024	17:19:00	07-02-2024	20:03:00	0.11	0.00	0.00	2.73	0.00		* Line tripped on B ph to G fault. Fault details:-Kolar End: M2 FLR:74.4 KM, FC:3.54 KA, Mylasandra End: M1/M2 FLR:6.36/6.2 KM, FC: 12.07/12.04 KA. tripped due agri fire found between the tower location 587-588.
							0.11	0.00	0.00	2.73	0.00	100.00	
CKT	400kV KOLAR-THIRUVALAM-1	LPRD	08-02-2024	12:37:00	08-02-2024	12:56:00	0.01	0.00	0.00	0.00	0.32		* Hand tripped as per SRLDC instruction for taking 400kV Kolar-Sriperumbudur Line into service vide SRLDC code no. CR- 02/1535.
							0.01	0.00	0.00	0.00	0.32	100.00	
CKT	400kV KUDGI GIS-NARENDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDGI GIS-NARENDRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NP KUNTA-KOLAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-PUGALUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-PUGALUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TIRUNELVELI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TIRUNELVELI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TUTICORIN PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TUTICORIN PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMALPET-MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-KOZHICODE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-KOZHICODE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELLI TS2-NEYVELLI TS1 EXP	OSPD	25-02-2024	10:04:00	25-02-2024	11:31:00	0.06	0.00	0.00	0.00	1.45		* Shut down availed by NLC TS-1 Expansion for Y phase CB pole to be replaced by new one vide SRLDC code no. CR-02/4818.
							0.06	0.00	0.00	0.00	1.45	100.00	
CKT	400kV NEYVELI TS2(NLC)-KARUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELLI TS2 EXP(NLC) EXP-KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELI(NLC)-SALEM-2	OMSU	13-02-2024	06:19:00	13-02-2024	07:26:00	0.05	0.00	1.12	0.00	0.00		* Line tripped on receipt of DT from Neyveli End, PD operated at Their End.
CKT	400kV NEYVELI(NLC)-SALEM-2	LART	13-02-2024	06:18:00	13-02-2024	06:18:00	0.00	0.00	0.00	0.00	0.00		* Line autoreclosed sucessful on R -G fault. Salem end details: M1: FLR: 3.59 KM, FC: 18 Kamps, M2: FLR: 3.6 KM, FC: 17.6 Kamps. Neyveli end details:M1: FLR: 165.7 KM, FC:1.09 Kamps, M2: FLR: 171 KM, FC: 0.509 Kamps* Fault is in salem Jurisdiction.
CKT	400kV NEYVELI(NLC)-SALEM-2	SCSD	16-02-2024	09:18:00	17-02-2024	20:04:00	1.45	0.00	0.00	0.00	34.77		* Shut down availed for Replacement of 390KV LAs with 336KV Las and retrofitting of Auto Reclose (>&<) LBB relay under under Add cap works at Salem vide SRLDC code no. CR-02/3063.
							1.50	0.00	1.12	0.00	34.77	100.00	
CKT	400kV NAGAPATTINAM-NEYVELI TS1(NLC) EXP			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGAPATTINAM-NEYVELI TS2(NLC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-2	OSPT	29-02-2024	11:17:00	29-02-2024	19:02:00	0.32	7.75	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-02/5568
							0.32	7.75	0.00	0.00	0.00	98.89	
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	LNCC	17-02-2024	15:21:00	17-02-2024	16:33:00	0.05	0.00	0.00	1.20	0.00		* Line tripped on Y phase to Ground fault. Hassan End Details: M1: 35.3KM/4.8KA, M2: 33.9KM/5.5KA, Nelamangala End Details: M1: 164.2K= M/208KA, M2: 156KM/2.08KA* As per Patrolling report Agriculture Fire found at span Loc 112-113
							0.05	0.00	0.00	1.20	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-1	OSPT	27-02-2024	14:43:00	27-02-2024	19:22:00	0.19	4.65	0.00	0.00	0.00		* Emergency shutdown availed by Somanahalli SS for replacement of 40289A Y phase burnt contacts and corona ring at Nelamangala SS vide code CR-02/5178.
							0.19	4.65	0.00	0.00	0.00	99.33	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-1	OSPD	08-02-2024	07:52:00	09-02-2024	23:10:00	1.64	0.00	0.00	0.00	39.30		* Shut down availed by TNEB for jumper connection works at loc no 221 <(>&<) 222 for Ariyalur TNEB SS vide SRLDC code no. CR-02/1439.
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-1	OSPD	23-02-2024	13:10:00	23-02-2024	14:35:00	0.06	0.00	0.00	0.00	1.42		* Shut down availed for SEM meter wiring correction works vide SRLDC code no. CR-02/4447.
							1.70	0.00	0.00	0.00	40.72	100.00	
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-2	OSPD	07-02-2024	08:01:00	09-02-2024	21:23:00	2.56	0.00	0.00	0.00	61.37		* Shut down availed by TNEB for jumoeer connection works at Ariyalur vide SRLDC code no. CR-02/1215
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-2	OSPD	26-02-2024	12:19:00	26-02-2024	13:37:00	0.05	0.00	0.00	0.00	1.30		* Line shutdown availed by Ariyalur SS to reverse polarity in SEM meter at Ariyalur end.
							2.61	0.00	0.00	0.00	62.67	100.00	
CKT	400kV NNTPS(NLC)-PUDUCHERRY-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-1	OSPT	06-02-2024	08:09:00	06-02-2024	19:15:00	0.46	11.10	0.00	0.00	0.00		* Shut down availed for AMP works <(>&<) attending shutdown natured defects vide SRLDC code no. CR-02/995
							0.46	11.10	0.00	0.00	0.00	98.41	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-2	OSPT	08-02-2024	08:23:00	08-02-2024	19:30:00	0.46	11.12	0.00	0.00	0.00		* Shut down availed forAMP Works and attending shutdown nature defects in the line vide SRLDC code no. CR-02/1476.
CKT	400kV NARENDRA-GUTTUR(KPTCL)-2	OSPT	09-02-2024	08:12:00	09-02-2024	19:04:00	0.45	10.87	0.00	0.00	0.00		* Shut down availed for AMP Works and attending shutdown nature defects in the line vide SRLDC code no. CR-02/1689.
							0.91	21.99	0.00	0.00	0.00	96.84	
CKT	400kV PUGALUR-ARASUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-ARASUR-2	OSPT	20-02-2024	18:58:00	20-02-2024	21:47:00	0.12	2.82	0.00	0.00	0.00		* Emergency Shut down availed for attending hot spot in line isolator vide SRLDC code no. CR-02/3907
							0.12	2.82	0.00	0.00	0.00	99.60	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PALAKKAD-TRICHUR-1	LCSD	28-02-2024	08:09:00	28-02-2024	20:17:00	0.51	0.00	0.00	0.00	12.13		* H/T FOR CONSTRUCTION: Erection works of Line Reactor under ADDCAP at Thrissur SS
							0.51	0.00	0.00	0.00	12.13	100.00	
CKT	400kV PALAKKAD-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUDUCHERRY-SVCHATRAM(TANTRANSCO)-1	OSPT	05-02-2024	16:20:00	05-02-2024	20:03:00	0.16	3.72	0.00	0.00	0.00		* Emergency Shut down availed for B-ph LA replacement vide SRLDC code no. CR-02/884.
							0.16	3.72	0.00	0.00	0.00	99.47	
CKT	400kV PUGALUR HVAC-KARUR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR HVAC-KARUR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400 KV PAVAGADA-DEVANAHALLI(KPTCL)-1	OSPT	18-02-2024	08:11:00	18-02-2024	18:20:00	0.42	10.15	0.00	0.00	0.00		* Shut down availed for attending line defects vide SRLDC code no. CR-02/3414.
							0.42	10.15	0.00	0.00	0.00	98.54	
CKT	400 kv PAVAGADA-DEVANAHALLI(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PAVAGADA-HIRIYUR-1	OSPT	29-02-2024	11:10:00	29-02-2024	13:16:00	0.09	2.10	0.00	0.00	0.00		* Emergency shutdown availed for attending alignment issue of 41489A at Hiriur SS vide CR-02/5569
							0.09	2.10	0.00	0.00	0.00	99.70	
CKT	400KV PAVAGADA-TUMKUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PAVAGADA-TUMKUR-2	LVRD	18-02-2024	18:12:00	19-02-2024	06:52:00	0.53	0.00	0.00	0.00	12.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3514 (430 - 427 Kv).
CKT	400KV PAVAGADA-TUMKUR-2	LVRD	21-02-2024	20:59:00	23-02-2024	09:46:00	1.53	0.00	0.00	0.00	36.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4142 ( 424 - 421 Kv).
							2.06	0.00	0.00	0.00	49.45	100.00	
CKT	400KV PAVAGADA-TUMKUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PAVAGADA-TUMKUR-4	LVRD	04-02-2024	21:17:00	05-02-2024	06:25:00	0.38	0.00	0.00	0.00	9.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/760 (428 - 426 Kv).
CKT	400KV PAVAGADA-TUMKUR-4	LVRD	18-02-2024	18:13:00	19-02-2024	06:31:00	0.51	0.00	0.00	0.00	12.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3515 (427 - 425 Kv).
CKT	400KV PAVAGADA-TUMKUR-4	LVRD	21-02-2024	21:01:00	23-02-2024	10:45:00	1.57	0.00	0.00	0.00	37.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4143 (421 - 418 Kv).
							2.46	0.00	0.00	0.00	59.16	100.00	
CKT	400KV PAVAGADA-MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SALEM-DHARMAPURI-1	OSPT	12-02-2024	09:26:00	12-02-2024	18:04:00	0.36	8.63	0.00	0.00	0.00		* Shut down availed for AMP works and for attending S/D nature defects in the line vide SRLDC code no. CR-02/2258
							0.36	8.63	0.00	0.00	0.00	98.76	
CKT	400KV SALEM-DHARMAPURI-2	OSPT	13-02-2024	09:37:00	13-02-2024	18:01:00	0.35	8.40	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-02/2480.
							0.35	8.40	0.00	0.00	0.00	98.79	
CKT	400KV SALEM-NNTPS(NLC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SALEM-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SALEM-UDUMALPET-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-SOMANAHALLI-BIDADI-1	OSPT	14-02-2024	10:08:00	14-02-2024	23:40:00	0.56	13.53	0.00	0.00	0.00		* Shut down availed for LBB relay retrofitting at Somanahalli <-&<-> AMP works vide SRLDC code no. CR-02/2685
							0.56	13.53	0.00	0.00	0.00	98.06	
CKT	400KV SOMANAHALLI-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SOMANAHALLI-DHARMAPURI-1	OSPT	10-02-2024	09:31:00	10-02-2024	18:12:00	0.36	8.68	0.00	0.00	0.00		* Shutdown availed for AMP Works and attending shutdown nature defects in the line
							0.36	8.68	0.00	0.00	0.00	98.75	
CKT	400KV SOMANAHALLI-DHARMAPURI-2	LART	23-02-2024	15:56:00	23-02-2024	15:56:00	0.00	0.00	0.00	0.00	0.00		* Auto reclosed successfully on R -G fault. Somanahalli end details: M1: FLR: 63.26 KM, FC: 3.945 Kamps, M2: FLR: 65.67 KM, FC: 4.302 Kamps. Dharmapuri end details:M1: FLR: 81.65 KM, FC: 3.3 Kamps, M2: FLR: 78.3 KM, FC: 3.3 Kamps* Fault is in Hosur TLM Jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SOMANAHALLI-HOSUR	LART	04-02-2024	19:50:00	04-02-2024	19:50:00	0.00	0.00	0.00	0.00	0.00		* Line autoreclosed successfully on Y-G fault.* Hosur end details: M1: FLR: 31 KM, FC: 6.59 Kamps, M2: FLR: 30.95 KM, FC: 6.23 Kamps.* Somanahalli end details:M1: FLR: 38.98 KM, FC: 7.3 Kamps, M2: FLR: 39.47 KM, FC: 7.2 Kamps* Fault is in Hosur TLM Jurisdiction.
CKT	400KV SOMANAHALLI-HOSUR	LCSD	05-02-2024	11:04:00	09-02-2024	16:22:00	4.22	0.00	0.00	0.00	101.30		* Shut down availed for ADDCAP works at Somanahalli SS vide SRLDC code no. CR-02/853
							4.22	0.00	0.00	0.00	101.30	100.00	
CKT	400KV-SOMANAHALLI-MYLASANDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SVCHATRM(TANTRANSCO)-SRIPERMBUDR-1	OSPD	06-02-2024	10:27:00	06-02-2024	20:39:00	0.43	0.00	0.00	0.00	10.20		* Shutdown availed by TANTRANSCO for monthly maintenance works vide SRLDC code no. CR- 02/1049.
							0.43	0.00	0.00	0.00	10.20	100.00	
CKT	400KV TRICHUR HVDC-KOCHI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV TRICHUR HVDC-KOCHI-2	OSPT	14-02-2024	17:09:00	14-02-2024	17:34:00	0.02	0.42	0.00	0.00	0.00		* Emergency shut down availed for replacing auxiliary trip relay at Kochi SS vide SRLDC code no. CR-02/2732.
							0.02	0.42	0.00	0.00	0.00	99.94	
CKT	400kV TRICHUR HVDC-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV THIRUNELVELI-KOTTAYAM-1	LEFT	22-02-2024	02:36:00	22-02-2024	16:38:00	0.59	14.03	0.00	0.00	0.00		* Line tripped on Earth fault (RYB Indication) . TNVL end details: M1: FLR: 56.7 KM, FC: 10.7 (Rph), 12.1 (Y ph), 9.2 (B Ph) Kamps, M2: FLR: 61.08 KM, FC: 10.7 (Rph), 12.1 (Y ph), 9.2 (B Ph) Kamps. Kottayam end details:M1: FLR: 119 KM, FC: 5.6 (Rph), 3.7 (Y ph), 1.8 (B Ph) Kamps, M2: NR* Fault is in Tirunelveli TLM Jurisdiction.
CKT	400kV THIRUNELVELI-KOTTAYAM-1	LART	22-02-2024	01:22:00	22-02-2024	01:22:00	0.00	0.00	0.00	0.00	0.00		* Line autoreclosed successful on B -G fault. TNVL end details: M1: FLR: 54.4 KM, FC: 7.9 Kamps, M2: FLR: 51.9 KM, FC:6.68 Kamps. Kottayam end details:M1: FLR: 123.3 KM, FC:2.77 Kamps, M2: FLR: 125.9 KM, FC: 2.66 Kamps* Fault is in Tirunelveli TLM Jurisdiction.
CKT	400kV THIRUNELVELI-KOTTAYAM-1	LART	21-02-2024	04:07:00	21-02-2024	04:07:00	0.00	0.00	0.00	0.00	0.00		* Line autoreclosed successfully on R -G fault. TNVL end details: M1: FLR: 32.9 KM, FC: 9.09 Kamps, M2: FLR: 32.6 KM, FC: 9.47 Kamps. Kottayam end details:M1: FLR: 124.4 KM, FC:3.25 Kamps, M2: FLR: 166.5 KM, FC: 2.058 Kamps
							0.59	14.03	0.00	0.00	0.00	97.98	
CKT	400kV THIRUNELVELI-KOTTAYAM-2	OSPT	21-02-2024	10:17:00	21-02-2024	13:59:00	0.15	3.70	0.00	0.00	0.00		* Emergency S/D availed to attend de-capped insulator at R-phase Locn 83(Work planned by Thirunelveli TLM).
CKT	400kV THIRUNELVELI-KOTTAYAM-2	LEFT	22-02-2024	04:47:00	22-02-2024	16:25:00	0.49	11.63	0.00	0.00	0.00		* Line tripped on Earth Fault ( R-Y-B fault Indication). TNVL end details: M1: FLR: 55.2 KM, FC: 12.3 (Rph), 11.5 (Y ph), 9.4 (B Ph) Kamps, M2: FLR: 56 KM, FC: 12.3 (Rph), 11.5 (Y ph), 9.4 (B Ph) Kamps. Kottayam end details:M1: FLR: 118 KM, FC: 3.77 (Rph), 2.77 (Y ph), 3.8 (B Ph) Kamps, M2: NR* Fault is in Tirunelveli TLM Jurisdiction.
CKT	400kV THIRUNELVELI-KOTTAYAM-2	OMST	20-02-2024	16:51:00	20-02-2024	17:09:00	0.01	0.30	0.00	0.00	0.00		* Line tripped at Tirunelveli end and auto reclosed successfully at Kottayam end on R-G fault.* Tirunelveli end details: M1: FLR: 27.52 KM, FC: 10 Kamps, M2: FLR: 27.1 KM, FC: 10 Kamps.* Kottayam end details:M1: FLR: 181.7 KM, FC: 1.374 Kamps, M2: FLR: 190.4 KM, FC: 1.887 Kamps* Fault is in Tirunelveli Jurisdiction.
							0.65	15.63	0.00	0.00	0.00	97.75	
CKT	400kV TIRUNELVELI-TRIVANDRUM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TRIVANDRUM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TUTICORIN PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-UDUMALPET-2	LART	15-02-2024	04:39:00	15-02-2024	04:39:00	0.00	0.00	0.00	0.00	0.00		* Auto reclosed successfully on Y-N (Ph-earth) transient fault.* TNLV end: Main 1 - 232.9 kM/1.59 kA, Main 2 - 229.2 kM/1.56 kA* UDPT end: Main 1 - 36.58 kM/8.45 kA, Main 2 - 37.90 kM/8.20 kA
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-KARAIKUDI-1	SCSD	09-02-2024	09:15:00	13-02-2024	20:48:00	4.48	0.00	0.00	0.00	107.55		* Shut down availed for replacement of 03Nos old 390KV LA's with 336KV LA'S and 40989L,40989A,40889A Isolators and Retrofitting of Auto Reclose, 40852-<> 40952CB LBB protections and under Add Cap Works at Trichy Substation vide SRLDC code no. CR-02/1715.
							4.48	0.00	0.00	0.00	107.55	100.00	
CKT	400kV TRICHY-MADURAI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-NAGAPATTANAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-NAGAPATTANAM-2	LCSD	21-02-2024	11:00:00	21-02-2024	19:40:00	0.36	0.00	0.00	0.00	8.67		* S/D availed for Replacement of Reactor LA with 336 KV LA under add cap vide SRLDC code no. CR- 02/4024
							0.36	0.00	0.00	0.00	8.67	100.00	
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-KALVINDAPATTU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-KALVINDAPATTU-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV TIRUVALAM-SRIPERUMDUR-1	LPRD	01-02-2024	00:00:01	08-02-2024	12:56:00	7.54	0.00	0.00	0.00	180.93		* Line kept open as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 01/2919.
							7.54	0.00	0.00	0.00	180.93	100.00	
CKT	400KV TUTICORIN GIS -TUTICORIN PS- 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN GIS -TUTICORIN PS- 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN GIS -TUTICORIN PS- 4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-KUDAMKULAM(NPCIL)-2	LEFT	21-02-2024	05:01:00	21-02-2024	07:18:00	0.10	2.28	0.00	0.00	0.00		* Line tripped on R -G fault (persisting) . Tuticorin PS end details: M1: FLR: 41 KM, FC: 6.8 Kamps, M2: FLR: 41 KM, FC: 6.99 Kamps. Kudamkulam end details: M1: FLR: 61 KM, FC:5.1 Kamps, M2: FLR: 63 KM, FC: 5.2 Kamps
							0.10	2.28	0.00	0.00	0.00	99.67	
CKT	400kV TUTICORIN PS-TUTICORIN JV(NTPL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN PS-TUTICORIN JV(NTPL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV UDMALPET-ARASUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDMALPET-ARASUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV UDUMAPALET-E.PALAYM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV UDUMAPALET-E.PALAYM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET -PALLAKAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV UDUMAPALET -PALLAKAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VALLUR(NTECL)-KALIVANTHAPATTU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV VALLUR(NTECL)-KALIVANTHAPATTU-2	OSPD	15-02-2024	08:23:00	15-02-2024	19:26:00	0.46	0.00	0.00	0.00	11.05		* Shut down availed for attending <-&<-> liquidating defects sustained due to to michaung cyclone vide SRLDC code no. CR-02/2841.
							0.46	0.00	0.00	0.00	11.05	100.00	
CKT	400KV YELHANKA GIS-DEVANAHALLI(KPTCL)	OSPT	18-02-2024	08:09:00	18-02-2024	15:56:00	0.32	7.78	0.00	0.00	0.00		* Shut down availed for attending line defects <-&<-> AMP works at Substation vide SRLDC code no. CR-02/3413.
							0.32	7.78	0.00	0.00	0.00	98.88	
CKT	400KV YELHANKA-NELAMANGALA(KPTCL)-1	OMSU	17-02-2024	14:23:00	18-02-2024	01:03:00	0.44	0.00	10.67	0.00	0.00		* Line tripped on Y phase to Ground fault. Yelahanka End Details: M1: 17.9KM/9.3KA, M2: 18KM/8.96KA, Nelamangala End Details: M1: 16.4= KM/12.06KA, M2: Not recorded* Fault is in KPTCL portion Location 54 jumper cut reported.
							0.44	0.00	10.67	0.00	0.00	100.00	
CKT	400KV YELAHANKA GIS-TUMKUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV YELAHANKA GIS-TUMKUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV DHARAMPURI-TUMKUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KUDGI-KOLHAPUR GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KUDGI-KOLHAPUR GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN PS-DHARAMPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN PS-DHARAMPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF VALLUR-1 AT KALIVANTPATTU	SVRD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 12/1755( 393-394 Kv).
							29.00	0.00	0.00	0.00	696.00	100.00	

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	63MVAR,SWLR OF TIRUNALVELLI-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF TIRUNALVELLI-2 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF MYSORE-1 AT KOZIKODE	SVRD	01-02-2024	00:00:01	04-02-2024	17:37:00	3.73	0.00	0.00	0.00	89.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/1382( 400-402 Kv).
							3.73	0.00	0.00	0.00	89.62	100.00	
LNR	50MVAR,SWLR OF MYSORE-2 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF TRICHY AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF KARAIKUDI AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF HIRIYUR AT MYSORE	SVRD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5174( 391-394 Kv).
							29.00	0.00	0.00	0.00	696.00	100.00	
LNR	80MVAR,SWLR OF PAVAGADA AT MYSORE	SVRD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5175( 389-391 Kv).
							29.00	0.00	0.00	0.00	696.00	100.00	
LNR	80MVAR SWLR OF TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR SWLR OF TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NEYVELI-2 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NEYVELI-1 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF HOSUR-2 AT SALEM	SVRD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/283( 391 -392 Kv).
LNR	50MVAR,SWLR OF HOSUR-2 AT SALEM	SVRD	24-02-2024	10:44:00	29-02-2024	23:59:59	5.55	0.00	0.00	0.00	133.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4665( 392-392 Kv).
							34.55	0.00	0.00	0.00	829.27	100.00	
LNR	50MVAR,SWLR OF KOLAR AT SOMANHALLI	SVRD	26-02-2024	10:12:00	29-02-2024	23:59:59	3.58	0.00	0.00	0.00	85.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4975 (393-393Kv).
							3.58	0.00	0.00	0.00	85.80	100.00	
LNR	50MVAR,SWLR OF CHITTOOR AT SRIPERUMBUDUR	SVRD	17-02-2024	11:57:00	29-02-2024	23:59:59	12.50	0.00	0.00	0.00	300.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3280( 394-394 Kv).
LNR	50MVAR,SWLR OF CHITTOOR AT SRIPERUMBUDUR	SVRD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3056 (396 -396 Kv).
							41.50	0.00	0.00	0.00	996.05	100.00	
LNR	50MVAR,SWLR OF SVCHATRAM AT SRIPERUMBUDUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PALAKKAD-1 AT THRISSUR	SCSD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00		* Shutdown availed for replacement of old 50 MVAR reactor with New BHEL make 50MVAR reactor after foundation modification works under Add cap works at Trichur SS vide SRLDC code no. CR- 10/1637.
							29.00	0.00	0.00	0.00	696.00	100.00	
LNR	50MVAR,SWLR OF PALAKKAD-2 AT THRISSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF UDUMALPT-1 AT TIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF UDUMALPT-2 AT TIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF NAGAPATTINAM-1 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NAGAPATTINAM-2 AT TRICHY	SCSD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00		* Shut down availed for Construction: Replacement of existing 50MVAR LR with new 80MVAR LR under Add Cap works vide SRLDC code no. CR-12/3223.

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	50MVAR,SWLR OF KADAPA-1 AT TUMKUR	SVRD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5176( 398-399 Kv).
LNR	50MVAR,SWLR OF KADAPA-2 AT TUMKUR	SVRD	01-02-2024	00:00:01	29-02-2024	23:59:59	29.00	0.00	0.00	0.00	696.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5177( 399-401 Kv).
LNR	50MVAR,SWLR OF NELLORE-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NELLORE-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SALEM-2 AT UDUMALPET	SVRD	03-02-2024	09:02:00	29-02-2024	23:59:59	26.62	0.00	0.00	0.00	638.97	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/473 (398-398Kv).
LNR	63MVAR,SWLR OF TIRUNELVELI-2 AT UDUMALPT	SVRD	03-02-2024	09:00:00	29-02-2024	23:59:59	26.63	0.00	0.00	0.00	639.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/469 (398-398Kv).
LNR	63MVAR,SWLR OF TIRUNELVELI-1 AT UDUMALPT	SVRD	03-02-2024	09:00:00	29-02-2024	23:59:59	26.63	0.00	0.00	0.00	639.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/470 (398-398Kv).
STATCOM	-200/+200 MVAR STATCOM AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-200/+200 MVAR STATCOM AT UDUMALPET	OSPT	06-02-2024	10:06:00	07-02-2024	15:55:00	1.24	29.82	0.00	0.00	0.00	95.72	* Shutdown availed for AMP Works
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	OSPD	01-02-2024	00:00:01	03-02-2024	23:44:00	2.99	0.00	0.00	0.00	71.73	98.98	* Shut down availed for line diversion works by NHAi vide SRLDC code no. CR-01/2894/2666/1576.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	OMST	24-02-2024	07:16:00	24-02-2024	14:24:00	0.30	7.13	0.00	0.00	0.00	98.98	* Pole-1 Blocked at Kolar end, ESOF signal sent to Talcher end.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	OSPD	01-02-2024	00:00:01	03-02-2024	22:35:00	2.94	0.00	0.00	0.00	70.58	100.00	* Shut down availed for line diversion works by NHAi vide SRLDC code no. CR-01/2895/2667/1577.
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-1	LART	23-02-2024	14:19:00	23-02-2024	14:19:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line-1 LFL operated. Fault details:- 1295.5 KM from Pugalur, Tower No: 1244. Fault is in WR-1 TLM Jurisdiction
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-2	LART	04-02-2024	06:11:00	04-02-2024	06:11:00	0.00	0.00	0.00	0.00	0.00	100.00	* LFL operated due to +ve OHL to Ground fault (>&<) cleared in first attempt. Pugalur HVDC end: FLR= 3.87 Km, FC=1.254 kA, Loc.:17. Trichur HVDC end :FLR:134.7 kms, FC=1.33 kA.
XMER	315MVA,400/220kV ICT-1 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BIDADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BIDADI	OSPT	18-02-2024	09:53:00	18-02-2024	21:30:00	0.48	11.62	0.00	0.00	0.00	98.33	* Shut down availed for AMP works vide SRLDC code no. CR-02/3460.
XMER	315MVA,400/220kV ICT-1 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-2 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT KOLAR	SCSD	25-02-2024	17:34:00	25-02-2024	21:48:00	0.18	0.00	0.00	0.00	4.23	100.00	* ICT Shut down availed for "Testing of New busbar Relay in 220 kv side" vide SRLDC code no. CR-02/4856
XMER	500MVA,400/220kV ICT-2 AT KOLAR	SCSD	24-02-2024	19:02:00	24-02-2024	22:10:00	0.13	0.00	0.00	0.00	3.13	100.00	* Shutdown availed for 400KV Bus-1 Busbar stability works under ICT-3 bay extension works at Kolar SS.
XMER	315MVA,400/220kV ICT-1 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KOZIKODE	OSPT	01-02-2024	12:25:00	01-02-2024	14:20:00	0.08	1.92	0.00	0.00	0.00	99.72	* Emergency Shut down availed for attending ICT#3 IV side Y phase bushing hotspot (109 deg. temperature) vide SRLDC code no. CR-01/110.
XMER	315MVA,400/220kV ICT-1 AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MADURAI	OSPT	03-02-2024	09:45:00	03-02-2024	21:15:00	0.48	11.50	0.00	0.00	0.00	98.35	* Shutdown availed for AMP works of ICT-3 and associated Bay equipment. 42852 CB LBB retrofitting works.
XMER	315MVA,400/220kV ICT-1 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT NARENDRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT NARENDRA	OSPT	01-02-2024	07:01:00	01-02-2024	12:53:00	0.24	5.87	0.00	0.00	0.00	99.16	* Shut down availed for AMP works vide SRLDC code no. CR-02/32
XMER	315MVA,400/220kV ICT-1 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	500MVA,400/220kV ICT-3 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARUR	SPRD	01-02-2024	10:09:00	01-02-2024	11:33:00	0.06	0.00	0.00	0.00	1.40		* Hand tripped as per SRLDC instruction for physical regulation in the system wide SRLDC code no. CR- 02/97( 177, 178, 316-0,220,386 MW).
XMER	315MVA,400/220kV ICT-1 AT KARUR	OSPT	03-02-2024	09:49:00	03-02-2024	14:52:00	0.21	5.05	0.00	0.00	0.00		* Shutdown taken for Collecting Oil Sample from R-<><>Y Ph IV Bushings (Make:BHEL)
XMER	315MVA,400/220kV ICT-2 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KARUR	OSPT	05-02-2024	09:34:00	05-02-2024	18:45:00	0.38	9.18	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-02/833.
XMER	500MVA,400/220kV ICT-1 AT PAVAGADA	OSPT	07-02-2024	17:59:00	07-02-2024	22:31:00	0.19	4.53	0.00	0.00	0.00		* Shutdown availed for ICT-2 tertiary transformer LA, isolator, CT, PT erection activities which are close vicinity to ICT-1 vide SRLDC code no. CR- 02/1370.
XMER	500MVA,400/220kV ICT-2 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT TRICHY	SCSD	03-02-2024	07:35:00	04-02-2024	20:52:00	1.55	0.00	0.00	0.00	37.28		* Shutdown availed for Replacement of 41189A Isolator under Add cap works at Trichy SS.
XMER	315MVA,400/220kV ICT-1 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	TuticorinGIS ICT3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

**Standard of Performance data for the month of Feb-2024**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUMKUR	OSPT	06-02-2024	10:56:00	06-02-2024	20:19:00	0.39	9.38	0.00	0.00	0.00		* Shutdown availed for AMP works vide SRLDC code no. CR- 02/1058.
XMER	500MVA,400/220kV ICT-2 AT TUMKUR	OSPT	28-02-2024	08:27:00	29-02-2024	13:41:00	1.22	29.23	0.00	0.00	0.00		* Shutdown taken for replacement of 420KV B-PH HV Bushing vide code CR-02/5324
							1.61	38.61	0.00	0.00	0.00	94.45	
XMER	500MVA,400/220kV ICT-3 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT UDUMALPET	SCSD	01-02-2024	00:00:01	02-02-2024	21:56:00	1.91	0.00	0.00	0.00	45.93		* Shut down availed for replacement of ICT HV LAs and 413 <-&<-> 216 Bay LBB relays under Add cap works at Udumalpet SS vide SRLDC code no. CR-01/5161.
							1.91	0.00	0.00	0.00	45.93	100.00	
XMER	315MVA,400/220kV ICT-2 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	