

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	10-03-2024	09:30:00	10-03-2024	15:57:00	0.27	0.00	0.00	0.00	6.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1682(399 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	09-03-2024	09:00:00	09-03-2024	16:45:00	0.32	0.00	0.00	0.00	7.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1535(397 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	04-03-2024	07:58:00	06-03-2024	18:20:00	2.43	0.00	0.00	0.00	58.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/557(404-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	27-03-2024	09:02:00	27-03-2024	20:28:00	0.48	0.00	0.00	0.00	11.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4408(396-396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	23-03-2024	09:11:00	24-03-2024	17:07:00	1.33	0.00	0.00	0.00	31.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3797(394 - 394Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	19-03-2024	06:49:00	22-03-2024	17:46:00	3.46	0.00	0.00	0.00	82.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/ 3109 (405 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	26-03-2024	08:42:00	26-03-2024	20:18:00	0.48	0.00	0.00	0.00	11.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4237(397-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	25-03-2024	09:23:00	25-03-2024	17:20:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4106(392-392 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	18-03-2024	08:33:00	18-03-2024	20:23:00	0.49	0.00	0.00	0.00	11.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2962(401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	16-03-2024	08:47:00	16-03-2024	17:11:00	0.35	0.00	0.00	0.00	8.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2660 (398 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	28-03-2024	08:18:00	30-03-2024	18:15:00	2.42	0.00	0.00	0.00	57.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4557(401-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	17-03-2024	11:30:00	17-03-2024	17:06:00	0.23	0.00	0.00	0.00	5.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2841(394 - 395Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	31-03-2024	08:41:00	31-03-2024	17:21:00	0.36	0.00	0.00	0.00	8.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4967 (406 - 409 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	08-03-2024	10:43:00	08-03-2024	18:09:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1397 (393 - 393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	02-03-2024	08:46:00	03-03-2024	19:41:00	1.46	0.00	0.00	0.00	34.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/232(398-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	01-03-2024	07:49:00	01-03-2024	20:35:00	0.53	0.00	0.00	0.00	12.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/34(403 - 405Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	07-03-2024	08:03:00	07-03-2024	17:23:00	0.39	0.00	0.00	0.00	9.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1151(408 -408 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	11-03-2024	07:01:00	15-03-2024	17:19:00	4.43	0.00	0.00	0.00	106.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1380 (387 - 391 Kv).
							20.07	0.00	0.00	0.00	481.63	100.00	
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4443(393 - 396Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	OSPT	02-03-2024	17:24:00	14-03-2024	12:17:00	11.79	282.88	0.00	0.00	0.00		* Shut down availed for R-Ph Bushing replacement due to oil leakage <-> internal inspection of Bus Reactor as per recommendation of CPRI vide SRLDC code no. CR- 03/319.
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	01-03-2024	07:46:00	02-03-2024	17:24:00	1.40	0.00	0.00	0.00	33.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/35(407 - 408Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	27-03-2024	09:03:00	27-03-2024	18:14:00	0.38	0.00	0.00	0.00	9.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4428(399-399 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	18-03-2024	08:30:00	22-03-2024	21:01:00	4.52	0.00	0.00	0.00	108.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2954(403 - 406Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	14-03-2024	12:17:00	17-03-2024	17:41:00	3.23	0.00	0.00	0.00	77.40		* Bus reactor-1 kept out under voltage regulation vide SRLDC code no. CR- 03/2369.
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	25-03-2024	09:39:00	25-03-2024	17:11:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4116(397-400 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	26-03-2024	08:38:00	26-03-2024	17:13:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4234(399-402 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	29-03-2024	11:41:00	30-03-2024	18:24:00	1.28	0.00	0.00	0.00	30.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4718 (396-399Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	31-03-2024	08:43:00	31-03-2024	17:27:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4973 (408 - 411 Kv).
							23.63	282.88	0.00	0.00	284.29	61.98	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	13-03-2024	09:53:00	14-03-2024	16:54:00	1.29	0.00	0.00	0.00	31.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2176 (400 - 404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	12-03-2024	09:59:00	12-03-2024	17:32:00	0.32	0.00	0.00	0.00	7.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2018 (400-406 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	19-03-2024	08:41:00	22-03-2024	18:03:00	3.39	0.00	0.00	0.00	81.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3119(404-408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	23-03-2024	09:22:00	23-03-2024	17:58:00	0.36	0.00	0.00	0.00	8.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3802(397 - 402Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	27-03-2024	09:04:00	29-03-2024	16:57:00	2.33	0.00	0.00	0.00	55.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4401(399-404 Kv).

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	18-03-2024	08:31:00	18-03-2024	20:34:00	0.50	0.00	0.00	0.00	12.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2955(406 - 409Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	16-03-2024	08:50:00	16-03-2024	17:21:00	0.36	0.00	0.00	0.00	8.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2663 (401 - 406 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	31-03-2024	08:46:00	31-03-2024	17:31:00	0.37	0.00	0.00	0.00	8.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4975 (411 - 414 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	30-03-2024	08:49:00	30-03-2024	18:26:00	0.40	0.00	0.00	0.00	9.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4823 (403-407Kv).* 30.03.2024 12:41:20 INDIA (60031144) Phone 8179152567* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4822 (407-409Kv).*
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	15-03-2024	08:45:00	15-03-2024	17:22:00	0.36	0.00	0.00	0.00	8.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2492 (405 - 409 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	25-03-2024	09:40:00	25-03-2024	17:13:00	0.32	0.00	0.00	0.00	7.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4117(400-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	26-03-2024	08:38:00	26-03-2024	21:13:00	0.52	0.00	0.00	0.00	12.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4235(402-406 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	10-03-2024	09:29:00	10-03-2024	16:03:00	0.27	0.00	0.00	0.00	6.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1680(400 - 406Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	08-03-2024	10:26:00	08-03-2024	18:15:00	0.33	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1394 (394 - 399 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	09-03-2024	09:00:00	09-03-2024	16:52:00	0.33	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1533(402 - 406Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	11-03-2024	09:11:00	11-03-2024	16:47:00	0.32	0.00	0.00	0.00	7.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1839 (400-404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	03-03-2024	09:42:00	03-03-2024	16:22:00	0.28	0.00	0.00	0.00	6.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/436(395-398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	04-03-2024	07:59:00	05-03-2024	16:58:00	1.37	0.00	0.00	0.00	32.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/561(403-407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	01-03-2024	07:47:00	01-03-2024	18:11:00	0.43	0.00	0.00	0.00	10.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/36(408 - 410Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	02-03-2024	08:42:00	02-03-2024	17:44:00	0.38	0.00	0.00	0.00	9.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/230(400-404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	06-03-2024	07:49:00	06-03-2024	17:51:00	0.42	0.00	0.00	0.00	10.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/947 (408-413Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	07-03-2024	08:16:00	07-03-2024	17:34:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1164(412 -416 Kv).
							15.04	0.00	0.00	0.00	360.38	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	27-03-2024	08:55:00	27-03-2024	16:56:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4406(399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	13-03-2024	09:48:00	13-03-2024	09:48:00	0.00	0.00	0.00	0.00	0.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2174 (391 - 391 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	13-03-2024	09:48:00	13-03-2024	17:14:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2174 (391 - 391 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	20-03-2024	09:21:00	20-03-2024	16:38:00	0.30	0.00	0.00	0.00	7.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3302(392-392 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	28-03-2024	08:19:00	28-03-2024	16:13:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4558(403-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	18-03-2024	08:30:00	18-03-2024	16:24:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2957(401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	16-03-2024	08:46:00	16-03-2024	17:06:00	0.35	0.00	0.00	0.00	8.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2665 (396 - 397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	14-03-2024	10:34:00	15-03-2024	17:14:00	1.28	0.00	0.00	0.00	30.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2355 (392-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	19-03-2024	08:46:00	19-03-2024	18:21:00	0.40	0.00	0.00	0.00	9.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3120(400-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	22-03-2024	09:16:00	22-03-2024	16:29:00	0.30	0.00	0.00	0.00	7.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3620 (393 -939 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	21-03-2024	10:52:00	21-03-2024	17:09:00	0.26	0.00	0.00	0.00	6.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3474(389-395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	26-03-2024	08:47:00	26-03-2024	17:13:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4242(400-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	12-03-2024	10:12:00	12-03-2024	17:10:00	0.29	0.00	0.00	0.00	6.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2019 (391-391 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	10-03-2024	09:31:00	10-03-2024	15:56:00	0.27	0.00	0.00	0.00	6.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1683(398 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	04-03-2024	07:56:00	04-03-2024	16:15:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/562(401-401 Kv).

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	11-03-2024	09:53:00	11-03-2024	16:28:00	0.27	0.00	0.00	0.00	6.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1806 (393-393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	08-03-2024	10:26:00	08-03-2024	16:24:00	0.25	0.00	0.00	0.00	5.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1399 (387 - 389 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	07-03-2024	08:05:00	07-03-2024	17:20:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1160(408 -408 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	02-03-2024	08:49:00	02-03-2024	17:12:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/235(398-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	05-03-2024	09:04:00	05-03-2024	16:56:00	0.33	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/745 (399-399Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	06-03-2024	07:48:00	06-03-2024	16:42:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/949 (400-402Kv).
							7.41	0.00	0.00	0.00	177.70	100.00	
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	20-03-2024	09:22:00	20-03-2024	16:26:00	0.29	0.00	0.00	0.00	7.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3300(392-395 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	19-03-2024	07:03:00	19-03-2024	18:16:00	0.47	0.00	0.00	0.00	11.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/ 3112 (404 - 405 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	12-03-2024	07:36:00	12-03-2024	17:11:00	0.40	0.00	0.00	0.00	9.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1982 (400-402 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	13-03-2024	09:48:00	13-03-2024	17:17:00	0.31	0.00	0.00	0.00	7.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2175 (391 - 391 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	15-03-2024	08:54:00	15-03-2024	17:15:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2491 (399 - 400 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	25-03-2024	09:38:00	25-03-2024	17:15:00	0.32	0.00	0.00	0.00	7.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4118(392-397 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	18-03-2024	08:31:00	18-03-2024	20:22:00	0.49	0.00	0.00	0.00	11.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2958(401 - 401Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	21-03-2024	10:55:00	21-03-2024	17:11:00	0.26	0.00	0.00	0.00	6.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3475(395-395 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	22-03-2024	09:16:00	22-03-2024	16:30:00	0.30	0.00	0.00	0.00	7.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3621 (393 - 393 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	03-03-2024	09:48:00	03-03-2024	16:16:00	0.27	0.00	0.00	0.00	6.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/440(394-398 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	06-03-2024	07:50:00	06-03-2024	16:45:00	0.37	0.00	0.00	0.00	8.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/950 (402-405Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	09-03-2024	10:31:00	09-03-2024	16:49:00	0.26	0.00	0.00	0.00	6.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1556(390 - 390Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	11-03-2024	10:02:00	11-03-2024	16:29:00	0.27	0.00	0.00	0.00	6.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1808 (393-393 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	10-03-2024	09:32:00	10-03-2024	15:58:00	0.27	0.00	0.00	0.00	6.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1684(398 - 398Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	05-03-2024	09:06:00	05-03-2024	16:58:00	0.33	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/746 (399-399Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	01-03-2024	09:31:00	01-03-2024	17:22:00	0.33	0.00	0.00	0.00	7.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/67(390 - 390Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	02-03-2024	08:50:00	02-03-2024	17:34:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/234(398-398 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	04-03-2024	07:58:00	04-03-2024	16:16:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/563(401-407 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	08-03-2024	10:27:00	08-03-2024	16:27:00	0.25	0.00	0.00	0.00	6.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1401 (389 - 392 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	07-03-2024	08:06:00	07-03-2024	17:21:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1161(408 -408 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	27-03-2024	08:57:00	27-03-2024	20:27:00	0.48	0.00	0.00	0.00	11.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4407(399-399 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	16-03-2024	08:49:00	16-03-2024	17:08:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2666 (397 - 400 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	14-03-2024	10:37:00	14-03-2024	16:41:00	0.25	0.00	0.00	0.00	6.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2356 (394-396 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	28-03-2024	08:20:00	28-03-2024	16:12:00	0.33	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4559(403-403 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	26-03-2024	08:48:00	26-03-2024	21:16:00	0.52	0.00	0.00	0.00	12.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4243(400-400 Kv).
							8.57	0.00	0.00	0.00	205.47	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 01/4764(390 - 394Kv).

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR, BUS REACTOR-1 AT KARAIKUDI			00:00:00		00:00:00	31.00	0.00	0.00	0.00	744.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT KOCHI	SVRD	01-03-2024	10:26:00	31-03-2024	23:59:59	30.57	0.00	0.00	0.00	733.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/83(398 - 398Kv).
							30.57	0.00	0.00	0.00	733.57	100.00	
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	27-03-2024	09:07:00	31-03-2024	23:59:59	4.62	0.00	0.00	0.00	110.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4410(399-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	22-03-2024	09:35:00	26-03-2024	20:28:00	4.45	0.00	0.00	0.00	106.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3618 (402- 405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	10-03-2024	09:28:00	10-03-2024	17:16:00	0.33	0.00	0.00	0.00	7.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1678(399 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	09-03-2024	09:01:00	09-03-2024	18:23:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1536(398 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	01-03-2024	00:00:01	03-03-2024	19:42:00	2.82	0.00	0.00	0.00	67.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5527 (399 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	11-03-2024	07:04:00	21-03-2024	23:17:00	10.68	0.00	0.00	0.00	256.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1401 (400-402kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	04-03-2024	07:52:00	06-03-2024	18:13:00	2.43	0.00	0.00	0.00	58.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/555(402-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	07-03-2024	08:03:00	07-03-2024	17:12:00	0.38	0.00	0.00	0.00	9.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1150(408- 409Kv).
							26.10	0.00	0.00	0.00	626.35	100.00	
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	01-03-2024	00:00:01	03-03-2024	19:45:00	2.82	0.00	0.00	0.00	67.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3787 (395-396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	07-03-2024	08:22:00	18-03-2024	20:21:00	11.50	0.00	0.00	0.00	275.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1148(401 -401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	06-03-2024	07:56:00	06-03-2024	18:16:00	0.43	0.00	0.00	0.00	10.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/951 (403-405Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	28-03-2024	08:15:00	30-03-2024	18:18:00	2.42	0.00	0.00	0.00	58.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4553(400-401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	26-03-2024	08:34:00	26-03-2024	21:25:00	0.54	0.00	0.00	0.00	12.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4244(403-406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	27-03-2024	09:05:00	27-03-2024	18:22:00	0.39	0.00	0.00	0.00	9.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4417(399-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	31-03-2024	08:55:00	31-03-2024	17:23:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4969 (407 - 409 Kv).
							18.45	0.00	0.00	0.00	442.71	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	01-03-2024	00:00:01	03-03-2024	19:42:00	2.82	0.00	0.00	0.00	67.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/3788 (396-398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	07-03-2024	08:37:00	18-03-2024	20:25:00	11.49	0.00	0.00	0.00	275.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1149(401 -401 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	06-03-2024	08:02:00	06-03-2024	18:19:00	0.43	0.00	0.00	0.00	10.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/952 (405-406Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	27-03-2024	09:11:00	30-03-2024	18:20:00	3.38	0.00	0.00	0.00	81.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4419(402-405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	31-03-2024	09:01:00	31-03-2024	17:26:00	0.35	0.00	0.00	0.00	8.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4970 (409 - 409 Kv).
							18.47	0.00	0.00	0.00	443.35	100.00	
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	06-03-2024	07:50:00	06-03-2024	16:55:00	0.38	0.00	0.00	0.00	9.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/948 (408-408Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	01-03-2024	07:48:00	02-03-2024	17:40:00	1.41	0.00	0.00	0.00	33.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/33(396 - 396Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	04-03-2024	08:02:00	05-03-2024	17:00:00	1.37	0.00	0.00	0.00	32.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/560(402-402 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	07-03-2024	08:09:00	07-03-2024	17:29:00	0.39	0.00	0.00	0.00	9.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1162(408 -408 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	03-03-2024	09:49:00	03-03-2024	16:25:00	0.28	0.00	0.00	0.00	6.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/435(396-397 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	11-03-2024	09:09:00	11-03-2024	16:39:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1838 (394 - 396 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	09-03-2024	09:01:00	09-03-2024	17:06:00	0.34	0.00	0.00	0.00	8.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1534(399 - 399Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	08-03-2024	10:28:00	08-03-2024	18:19:00	0.33	0.00	0.00	0.00	7.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1396 (393 - 395 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	10-03-2024	09:27:00	10-03-2024	16:14:00	0.28	0.00	0.00	0.00	6.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1679(397 - 397Kv).

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	16-03-2024	08:54:00	16-03-2024	17:16:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2664 (399 - 400 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	12-03-2024	10:19:00	12-03-2024	17:43:00	0.31	0.00	0.00	0.00	7.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2017 (399-401 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	15-03-2024	08:58:00	15-03-2024	17:23:00	0.35	0.00	0.00	0.00	8.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2493 (404 - 407 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	23-03-2024	09:08:00	23-03-2024	17:51:00	0.36	0.00	0.00	0.00	8.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3804(393 - 394Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	13-03-2024	09:55:00	14-03-2024	16:57:00	1.29	0.00	0.00	0.00	31.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2177 (398 - 400 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	19-03-2024	06:58:00	22-03-2024	18:06:00	3.46	0.00	0.00	0.00	83.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/ 3111 (404 - 405 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	25-03-2024	09:28:00	25-03-2024	17:23:00	0.33	0.00	0.00	0.00	7.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4111(391 -392 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	28-03-2024	08:18:00	30-03-2024	18:15:00	2.42	0.00	0.00	0.00	57.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4550(399-399 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	26-03-2024	08:34:00	26-03-2024	17:38:00	0.38	0.00	0.00	0.00	9.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4233(396 - 396Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	18-03-2024	08:29:00	18-03-2024	20:38:00	0.51	0.00	0.00	0.00	12.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2953(401 - 401Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	27-03-2024	09:02:00	27-03-2024	18:05:00	0.38	0.00	0.00	0.00	9.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4402(396-396 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	31-03-2024	08:39:00	31-03-2024	17:32:00	0.37	0.00	0.00	0.00	8.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4966 (404 - 406 Kv).
							15.60	0.00	0.00	0.00	374.15	100.00	
BSR	125MVAR, BUS REACTOR-1 AT NAGAPATTINAM	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5143 (402-402Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	09-03-2024	10:32:00	09-03-2024	16:51:00	0.26	0.00	0.00	0.00	6.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1555(395 - 395Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	08-03-2024	10:23:00	08-03-2024	16:32:00	0.26	0.00	0.00	0.00	6.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1398 (394 - 396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	03-03-2024	09:47:00	03-03-2024	16:37:00	0.29	0.00	0.00	0.00	6.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/437(394-398 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	23-03-2024	09:06:00	23-03-2024	17:59:00	0.37	0.00	0.00	0.00	8.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3803(393 - 394Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	12-03-2024	07:33:00	12-03-2024	17:19:00	0.41	0.00	0.00	0.00	9.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1983 (392 - 398 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	21-03-2024	09:21:00	21-03-2024	16:56:00	0.32	0.00	0.00	0.00	7.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3448(395-395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	15-03-2024	08:52:00	15-03-2024	17:25:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2494 (404 - 407 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	18-03-2024	08:29:00	18-03-2024	16:27:00	0.33	0.00	0.00	0.00	7.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2956(403 - 406Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	16-03-2024	09:34:00	16-03-2024	16:50:00	0.30	0.00	0.00	0.00	7.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2686 (397 - 399 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	20-03-2024	09:14:00	20-03-2024	16:35:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3296(394-397 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	13-03-2024	09:51:00	13-03-2024	16:54:00	0.29	0.00	0.00	0.00	7.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2190 (395- 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	14-03-2024	09:22:00	14-03-2024	16:58:00	0.32	0.00	0.00	0.00	7.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2338 (403 -406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	24-03-2024	12:02:00	24-03-2024	17:14:00	0.22	0.00	0.00	0.00	5.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4004 (395 - 401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	26-03-2024	08:40:00	26-03-2024	17:09:00	0.35	0.00	0.00	0.00	8.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4236(404-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	19-03-2024	08:43:00	19-03-2024	18:18:00	0.40	0.00	0.00	0.00	9.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3121(406-406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	27-03-2024	09:05:00	27-03-2024	16:56:00	0.33	0.00	0.00	0.00	7.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4414(402-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	31-03-2024	08:37:00	31-03-2024	16:47:00	0.34	0.00	0.00	0.00	8.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4965 (401 - 403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	29-03-2024	11:34:00	29-03-2024	16:54:00	0.22	0.00	0.00	0.00	5.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4716 (391-395Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	30-03-2024	08:51:00	30-03-2024	18:18:00	0.39	0.00	0.00	0.00	9.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4823 (403-407Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	01-03-2024	09:23:00	01-03-2024	17:21:00	0.33	0.00	0.00	0.00	7.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/59(390 - 390Kv).

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	10-03-2024	09:29:00	10-03-2024	16:13:00	0.28	0.00	0.00	0.00	6.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1681(397 - 402Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	07-03-2024	08:11:00	07-03-2024	17:22:00	0.38	0.00	0.00	0.00	9.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1163(409 -409 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	05-03-2024	09:01:00	05-03-2024	17:42:00	0.36	0.00	0.00	0.00	8.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/744 (401-406Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	11-03-2024	09:13:00	11-03-2024	16:39:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1840 (398-400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	02-03-2024	08:48:00	02-03-2024	17:09:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/233(400-403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	04-03-2024	07:57:00	04-03-2024	16:23:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/564(404-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	06-03-2024	07:47:00	06-03-2024	16:45:00	0.37	0.00	0.00	0.00	8.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/946 (404-407Kv).
							8.80	0.00	0.00	0.00	211.12	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2224 (414 - 417 Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/2225 (419 - 422 Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT PALAKKAD	SVRD	01-03-2024	00:00:01	31-03-2024	17:28:00	30.73	0.00	0.00	0.00	737.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4944 (415-416Kv).
							30.73	0.00	0.00	0.00	737.47	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5144 (403-406Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	22-03-2024	09:18:00	22-03-2024	16:20:00	0.29	0.00	0.00	0.00	7.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3615 (399 - 400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	14-03-2024	09:19:00	14-03-2024	16:40:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2334 (400 -401 Kv)
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	26-03-2024	09:47:00	26-03-2024	15:59:00	0.26	0.00	0.00	0.00	6.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4258(399-401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	21-03-2024	09:04:00	21-03-2024	16:51:00	0.32	0.00	0.00	0.00	7.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3443(400-400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	11-03-2024	09:18:00	11-03-2024	16:40:00	0.31	0.00	0.00	0.00	7.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1844 (401-403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	04-03-2024	09:15:00	04-03-2024	16:16:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/581(400-403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	05-03-2024	09:20:00	05-03-2024	16:47:00	0.31	0.00	0.00	0.00	7.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/760 (401-401Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	01-03-2024	09:25:00	01-03-2024	17:14:00	0.33	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/61(397 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	06-03-2024	09:15:00	06-03-2024	16:48:00	0.32	0.00	0.00	0.00	7.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/970 (398-400Kv)
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	03-03-2024	09:44:00	03-03-2024	16:20:00	0.28	0.00	0.00	0.00	6.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/441(400-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	08-03-2024	09:24:00	08-03-2024	16:24:00	0.29	0.00	0.00	0.00	7.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1384 (394 - 395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	02-03-2024	11:46:00	02-03-2024	17:02:00	0.22	0.00	0.00	0.00	5.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/267(396-396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	09-03-2024	10:34:00	09-03-2024	16:42:00	0.26	0.00	0.00	0.00	6.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1557(397 - 400Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	07-03-2024	07:54:00	07-03-2024	17:26:00	0.40	0.00	0.00	0.00	9.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1156(414 -416 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	16-03-2024	09:16:00	16-03-2024	17:14:00	0.33	0.00	0.00	0.00	7.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2675 (402 - 403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	29-03-2024	11:42:00	29-03-2024	16:49:00	0.21	0.00	0.00	0.00	5.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4719 (394-396Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	25-03-2024	09:33:00	25-03-2024	17:06:00	0.32	0.00	0.00	0.00	7.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4112(399-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	13-03-2024	10:01:00	13-03-2024	16:39:00	0.28	0.00	0.00	0.00	6.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2171(402 - 405 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	20-03-2024	09:18:00	20-03-2024	16:22:00	0.29	0.00	0.00	0.00	7.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3297(400-400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	18-03-2024	08:38:00	18-03-2024	16:21:00	0.32	0.00	0.00	0.00	7.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2964(406 - 408Kv).

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	23-03-2024	08:55:00	23-03-2024	16:57:00	0.34	0.00	0.00	0.00	8.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3784(404 - 405Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	12-03-2024	10:00:00	12-03-2024	17:11:00	0.30	0.00	0.00	0.00	7.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2020 (399-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	27-03-2024	09:30:00	27-03-2024	16:54:00	0.31	0.00	0.00	0.00	7.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4434(402-405 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	28-03-2024	08:14:00	28-03-2024	16:10:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4555(406-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	19-03-2024	08:48:00	19-03-2024	16:50:00	0.34	0.00	0.00	0.00	8.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3124(405-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	15-03-2024	08:39:00	15-03-2024	17:09:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2487 (404 - 406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	30-03-2024	08:52:00	30-03-2024	17:15:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4824 (408-409Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	31-03-2024	08:45:00	31-03-2024	16:28:00	0.32	0.00	0.00	0.00	7.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4976 (411 - 414 Kv).
							8.58	0.00	0.00	0.00	205.33	100.00	
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	16-03-2024	09:18:00	16-03-2024	17:16:00	0.33	0.00	0.00	0.00	7.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2678 (403 - 406 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	22-03-2024	09:18:00	22-03-2024	16:21:00	0.29	0.00	0.00	0.00	7.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3616 (400 -403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	15-03-2024	08:42:00	15-03-2024	17:10:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2488 (406 - 409 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	12-03-2024	10:02:00	12-03-2024	17:13:00	0.30	0.00	0.00	0.00	7.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2021 (402-405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	28-03-2024	08:16:00	28-03-2024	16:13:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4556(408-410 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	26-03-2024	09:49:00	26-03-2024	16:03:00	0.26	0.00	0.00	0.00	6.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4259(401-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	21-03-2024	09:06:00	21-03-2024	16:54:00	0.33	0.00	0.00	0.00	7.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3444(400-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	25-03-2024	09:35:00	25-03-2024	17:16:00	0.32	0.00	0.00	0.00	7.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4113(402-402 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	31-03-2024	08:50:00	31-03-2024	16:31:00	0.32	0.00	0.00	0.00	7.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4977 (414 - 418 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	30-03-2024	08:53:00	30-03-2024	16:54:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4825 (409-411Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	29-03-2024	11:44:00	29-03-2024	16:53:00	0.22	0.00	0.00	0.00	5.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4720 (396-398Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	14-03-2024	09:22:00	14-03-2024	16:41:00	0.31	0.00	0.00	0.00	7.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2335 (401 -403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	03-03-2024	09:45:00	03-03-2024	16:22:00	0.28	0.00	0.00	0.00	6.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/442(402-404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	04-03-2024	09:17:00	04-03-2024	16:18:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/583(403-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	02-03-2024	11:47:00	02-03-2024	17:03:00	0.22	0.00	0.00	0.00	5.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/268(396-400 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	08-03-2024	09:25:00	08-03-2024	16:26:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1385 (395 - 398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	07-03-2024	07:56:00	07-03-2024	17:27:00	0.40	0.00	0.00	0.00	9.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1157(416 -416 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	05-03-2024	09:23:00	05-03-2024	16:53:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/762 (401-403Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	06-03-2024	09:16:00	06-03-2024	16:50:00	0.32	0.00	0.00	0.00	7.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/971 (400-400Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	09-03-2024	10:35:00	09-03-2024	16:43:00	0.26	0.00	0.00	0.00	6.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1558(400 - 400Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	11-03-2024	09:19:00	11-03-2024	16:44:00	0.31	0.00	0.00	0.00	7.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1845 (403-405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	01-03-2024	09:27:00	01-03-2024	17:15:00	0.33	0.00	0.00	0.00	7.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/62(399 - 399Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	19-03-2024	08:50:00	19-03-2024	16:51:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3125(408-408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	13-03-2024	10:05:00	13-03-2024	16:44:00	0.28	0.00	0.00	0.00	6.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2172(405 - 407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	27-03-2024	09:32:00	27-03-2024	16:58:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4435(405-405 Kv).

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	20-03-2024	08:31:00	20-03-2024	16:17:00	0.32	0.00	0.00	0.00	7.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3292(406-406 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	23-03-2024	08:56:00	23-03-2024	17:00:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3785(405 - 407Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	18-03-2024	08:39:00	18-03-2024	16:22:00	0.32	0.00	0.00	0.00	7.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2965(408 - 411Kv).
							8.60	0.00	0.00	0.00	206.03	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	01-03-2024	00:00:01	27-03-2024	20:42:00	26.86	0.00	0.00	0.00	644.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4629(394-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	29-03-2024	09:15:00	31-03-2024	23:59:59	2.62	0.00	0.00	0.00	62.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4699 (394-394 Kv).
							29.48	0.00	0.00	0.00	707.45	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	01-03-2024	00:00:01	01-03-2024	20:36:00	0.86	0.00	0.00	0.00	20.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5523(396 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	02-03-2024	08:44:00	03-03-2024	16:50:00	1.34	0.00	0.00	0.00	32.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/231(395-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	07-03-2024	08:08:00	07-03-2024	17:56:00	0.41	0.00	0.00	0.00	9.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1152(406 -407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	08-03-2024	10:24:00	08-03-2024	18:14:00	0.33	0.00	0.00	0.00	7.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1400 (390 - 392 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	11-03-2024	09:16:00	16-03-2024	17:14:00	5.33	0.00	0.00	0.00	127.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1843 (394-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	04-03-2024	07:53:00	06-03-2024	18:19:00	2.44	0.00	0.00	0.00	58.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/556(400-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	09-03-2024	09:04:00	10-03-2024	16:05:00	1.29	0.00	0.00	0.00	31.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1537(395 - 395Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	25-03-2024	09:24:00	25-03-2024	17:41:00	0.35	0.00	0.00	0.00	8.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4107(390-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	23-03-2024	09:20:00	23-03-2024	17:36:00	0.34	0.00	0.00	0.00	8.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3798(394 - 394Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	18-03-2024	08:43:00	18-03-2024	20:33:00	0.49	0.00	0.00	0.00	11.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2963(403 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	26-03-2024	08:44:00	30-03-2024	18:41:00	4.42	0.00	0.00	0.00	105.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4238(398-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	19-03-2024	06:54:00	22-03-2024	20:41:00	3.57	0.00	0.00	0.00	85.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/ 3110 (404 - 405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	31-03-2024	08:40:00	31-03-2024	18:29:00	0.41	0.00	0.00	0.00	9.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4968 (405 - 407 Kv).
							21.58	0.00	0.00	0.00	517.68	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SRIPERUMBUDUR	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/816 (397-397 Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TIRUNELVELLI	SVRD	01-03-2024	10:42:00	31-03-2024	23:59:59	30.55	0.00	0.00	0.00	733.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/87(405 - 406Kv).
							30.55	0.00	0.00	0.00	733.30	100.00	
BSR	63MVAR, BUS REACTOR-2 AT TIRUNELVELLI	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/861 (408-410 Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TRIVANDRUM	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/480 (405-411Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	05-03-2024	08:53:00	05-03-2024	16:53:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/747 (407-407Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	01-03-2024	09:28:00	01-03-2024	17:10:00	0.32	0.00	0.00	0.00	7.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/64(399 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	08-03-2024	09:27:00	08-03-2024	16:28:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1386 (396 - 397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	02-03-2024	11:44:00	02-03-2024	16:51:00	0.21	0.00	0.00	0.00	5.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/269(397-397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	04-03-2024	09:12:00	04-03-2024	16:23:00	0.30	0.00	0.00	0.00	7.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/585(403-403 Kv).

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	16-03-2024	09:29:00	16-03-2024	17:03:00	0.32	0.00	0.00	0.00	7.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2676 (407 - 408 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	27-03-2024	09:24:00	27-03-2024	17:02:00	0.32	0.00	0.00	0.00	7.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4436(404-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	23-03-2024	08:54:00	23-03-2024	16:56:00	0.34	0.00	0.00	0.00	8.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3786(408 - 410Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	19-03-2024	08:44:00	19-03-2024	16:54:00	0.34	0.00	0.00	0.00	8.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3122(408-408 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	22-03-2024	09:25:00	22-03-2024	16:29:00	0.29	0.00	0.00	0.00	7.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3617(403 - 405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	15-03-2024	08:43:00	15-03-2024	17:18:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2489 (408 - 408 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	14-03-2024	09:11:00	14-03-2024	16:43:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2355 (392-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	26-03-2024	09:51:00	26-03-2024	16:08:00	0.26	0.00	0.00	0.00	6.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4260(405-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	20-03-2024	09:20:00	20-03-2024	16:19:00	0.29	0.00	0.00	0.00	6.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3298(405-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	21-03-2024	09:11:00	21-03-2024	17:12:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3446(403-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	25-03-2024	09:34:00	25-03-2024	17:29:00	0.33	0.00	0.00	0.00	7.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4114(404-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	28-03-2024	08:49:00	28-03-2024	16:14:00	0.31	0.00	0.00	0.00	7.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4560(410-410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	31-03-2024	08:48:00	31-03-2024	16:28:00	0.32	0.00	0.00	0.00	7.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4978 (416 - 418 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	30-03-2024	08:49:00	30-03-2024	17:00:00	0.34	0.00	0.00	0.00	8.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4826 (411-411Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	29-03-2024	11:38:00	29-03-2024	16:48:00	0.22	0.00	0.00	0.00	5.17		
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	07-03-2024	07:59:00	07-03-2024	17:37:00	0.40	0.00	0.00	0.00	9.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1158 (417 -417 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	06-03-2024	09:17:00	06-03-2024	16:47:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/972 (400-402Kv).
							6.84	0.00	0.00	0.00	164.37	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	01-03-2024	09:29:00	01-03-2024	17:13:00	0.32	0.00	0.00	0.00	7.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/65(402 - 405Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	07-03-2024	08:01:00	07-03-2024	17:39:00	0.40	0.00	0.00	0.00	9.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1159(408 -408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	05-03-2024	08:54:00	05-03-2024	16:54:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/748 (407-411Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	08-03-2024	09:28:00	08-03-2024	16:29:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1387 (397 - 401 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	02-03-2024	11:45:00	02-03-2024	16:48:00	0.21	0.00	0.00	0.00	5.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/270(397-399 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	06-03-2024	09:19:00	06-03-2024	17:04:00	0.32	0.00	0.00	0.00	7.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/973 (402-405Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	04-03-2024	09:13:00	04-03-2024	16:26:00	0.30	0.00	0.00	0.00	7.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/588(403-405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	22-03-2024	09:27:00	22-03-2024	16:28:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3618 (405 -408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	13-03-2024	10:08:00	13-03-2024	16:43:00	0.27	0.00	0.00	0.00	6.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2173 (398 - 401 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	23-03-2024	09:01:00	23-03-2024	17:05:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3787(410 - 410Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	19-03-2024	08:46:00	19-03-2024	17:00:00	0.34	0.00	0.00	0.00	8.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3123(408-410 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	12-03-2024	10:13:00	12-03-2024	17:28:00	0.30	0.00	0.00	0.00	7.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2022 (405-407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	18-03-2024	08:41:00	18-03-2024	16:26:00	0.32	0.00	0.00	0.00	7.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2966(413 - 415Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	20-03-2024	09:19:00	20-03-2024	16:24:00	0.30	0.00	0.00	0.00	7.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3299(403-405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	14-03-2024	09:13:00	14-03-2024	16:49:00	0.32	0.00	0.00	0.00	7.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2337 (403 -406 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	28-03-2024	08:50:00	28-03-2024	16:18:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4561(410-412 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	26-03-2024	09:53:00	26-03-2024	16:15:00	0.27	0.00	0.00	0.00	6.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4261(407-409 Kv).

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	21-03-2024	09:17:00	21-03-2024	17:18:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3447(401-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	16-03-2024	09:25:00	16-03-2024	17:02:00	0.32	0.00	0.00	0.00	7.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2677(407 - 408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	27-03-2024	09:27:00	27-03-2024	17:01:00	0.32	0.00	0.00	0.00	7.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4437(404-405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	15-03-2024	08:44:00	15-03-2024	17:19:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2490(408 - 411 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	25-03-2024	09:36:00	25-03-2024	17:28:00	0.33	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4115(406-409 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	31-03-2024	08:49:00	31-03-2024	16:36:00	0.32	0.00	0.00	0.00	7.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4979(418 - 420 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	29-03-2024	11:39:00	29-03-2024	16:51:00	0.22	0.00	0.00	0.00	5.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4722(398-398Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	30-03-2024	08:50:00	30-03-2024	17:04:00	0.34	0.00	0.00	0.00	8.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4827(411-413Kv).
							7.77	0.00	0.00	0.00	186.69	100.00	
BSR	63MVAR, BUS REACTOR AT TUTICORIN PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	PUGALUR-1_LINE_REACTOR_63MVAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	04-03-2024	12:26:00	05-03-2024	16:55:00	1.19	0.00	0.00	0.00	28.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/611/383(743-751 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	11-03-2024	07:33:00	12-03-2024	18:06:00	1.44	0.00	0.00	0.00	34.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1819(750 - 761 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	02-03-2024	11:52:00	02-03-2024	18:05:00	0.26	0.00	0.00	0.00	6.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/274/181(743-753 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	06-03-2024	09:00:00	08-03-2024	17:50:00	2.37	0.00	0.00	0.00	56.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/956(757-769Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	01-03-2024	00:00:01	01-03-2024	17:16:00	0.72	0.00	0.00	0.00	17.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5155(756-764Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	31-03-2024	09:19:00	31-03-2024	17:13:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4982(760 - 767 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	30-03-2024	09:15:00	30-03-2024	17:06:00	0.33	0.00	0.00	0.00	7.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4831(760-771Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	28-03-2024	09:22:00	29-03-2024	14:09:00	1.20	0.00	0.00	0.00	28.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4582/2857(762-769 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	17-03-2024	09:21:00	17-03-2024	17:15:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2837(745 - 753Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	18-03-2024	06:42:00	18-03-2024	17:18:00	0.44	0.00	0.00	0.00	10.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2934(756 -763 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	23-03-2024	09:55:00	23-03-2024	17:13:00	0.30	0.00	0.00	0.00	7.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3822(758 - 765Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	19-03-2024	09:25:00	21-03-2024	18:28:00	2.38	0.00	0.00	0.00	57.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3135/2042(751-760 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	14-03-2024	09:39:00	16-03-2024	18:03:00	2.35	0.00	0.00	0.00	56.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2341/1505(742 -757 Kv)
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	09-03-2024	11:09:00	10-03-2024	17:22:00	1.26	0.00	0.00	0.00	30.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1559(746 - 758Kv).
							14.90	0.00	0.00	0.00	357.35	100.00	
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	05-03-2024	12:52:00	08-03-2024	18:18:00	3.23	0.00	0.00	0.00	77.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/797/496 (763-771 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	01-03-2024	10:40:00	01-03-2024	18:10:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/84(749 - 758Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	02-03-2024	11:54:00	03-03-2024	16:31:00	1.19	0.00	0.00	0.00	28.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/275/182(753-765 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	09-03-2024	11:12:00	10-03-2024	18:06:00	1.29	0.00	0.00	0.00	30.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1561(758 - 763Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	11-03-2024	07:35:00	14-03-2024	17:50:00	3.43	0.00	0.00	0.00	82.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1820(761 - 770 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	23-03-2024	09:58:00	23-03-2024	17:17:00	0.31	0.00	0.00	0.00	7.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3823(765 - 774Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	18-03-2024	06:46:00	18-03-2024	17:11:00	0.43	0.00	0.00	0.00	10.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2935(763 -774 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	15-03-2024	08:55:00	16-03-2024	18:08:00	1.38	0.00	0.00	0.00	33.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2496(760 - 771 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	29-03-2024	11:36:00	29-03-2024	17:18:00	0.24	0.00	0.00	0.00	5.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4717(755-766Kv).

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							11.81	0.00	0.00	0.00	283.36	100.00	
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	07-03-2024	08:09:00	07-03-2024	17:31:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1154(407 -408 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	02-03-2024	08:54:00	03-03-2024	16:18:00	1.31	0.00	0.00	0.00	31.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/237(398-400 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	09-03-2024	09:05:00	09-03-2024	16:50:00	0.32	0.00	0.00	0.00	7.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1539(397 - 397Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	11-03-2024	09:16:00	15-03-2024	17:23:00	4.34	0.00	0.00	0.00	104.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1841 (394-396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	08-03-2024	09:30:00	08-03-2024	18:13:00	0.36	0.00	0.00	0.00	8.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1382 (393 - 393 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	04-03-2024	07:59:00	06-03-2024	17:40:00	2.40	0.00	0.00	0.00	57.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/559(404-406 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	01-03-2024	07:52:00	01-03-2024	20:34:00	0.53	0.00	0.00	0.00	12.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/38(408 - 410Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	26-03-2024	08:40:00	26-03-2024	20:19:00	0.49	0.00	0.00	0.00	11.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4240(397 -399 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	18-03-2024	08:37:00	18-03-2024	20:24:00	0.49	0.00	0.00	0.00	11.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2960(401 - 403Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	27-03-2024	09:06:00	27-03-2024	20:27:00	0.47	0.00	0.00	0.00	11.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4403(396-397 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	19-03-2024	09:26:00	19-03-2024	18:20:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3144(397-397 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	17-03-2024	11:33:00	17-03-2024	17:07:00	0.23	0.00	0.00	0.00	5.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2844(395 - 397Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	23-03-2024	09:18:00	23-03-2024	17:50:00	0.36	0.00	0.00	0.00	8.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3800(396 - 396Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	16-03-2024	08:48:00	16-03-2024	17:09:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2661 (398 - 399 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	28-03-2024	08:17:00	30-03-2024	17:23:00	2.38	0.00	0.00	0.00	57.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4552(401-401 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	10-03-2024	09:37:00	10-03-2024	17:15:00	0.32	0.00	0.00	0.00	7.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1688(402 - 402Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	25-03-2024	09:30:00	25-03-2024	17:21:00	0.33	0.00	0.00	0.00	7.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 034109/(393-393 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	20-03-2024	08:31:00	22-03-2024	17:52:00	2.39	0.00	0.00	0.00	57.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3289(399-399 Kv).
							17.83	0.00	0.00	0.00	427.80	100.00	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	25-03-2024	09:33:00	25-03-2024	17:24:00	0.33	0.00	0.00	0.00	7.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4110(393-396 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	27-03-2024	09:10:00	30-03-2024	17:27:00	3.35	0.00	0.00	0.00	80.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4405(397-399 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	18-03-2024	08:39:00	19-03-2024	18:24:00	1.41	0.00	0.00	0.00	33.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2961(403 - 403Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	23-03-2024	09:22:00	24-03-2024	17:06:00	1.32	0.00	0.00	0.00	31.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3801(396 - 396Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	07-03-2024	08:11:00	07-03-2024	17:35:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1155(408-410 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	09-03-2024	09:09:00	09-03-2024	16:55:00	0.32	0.00	0.00	0.00	7.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1540(397 - 397Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	03-03-2024	09:52:00	03-03-2024	19:40:00	0.41	0.00	0.00	0.00	9.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/439(400-400 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	04-03-2024	09:15:00	06-03-2024	17:45:00	2.35	0.00	0.00	0.00	56.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/591(396-396 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	08-03-2024	09:39:00	08-03-2024	18:16:00	0.36	0.00	0.00	0.00	8.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1383 (393 - 396 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	01-03-2024	00:00:01	01-03-2024	20:40:00	0.86	0.00	0.00	0.00	20.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/5526 (392 - 392Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	20-03-2024	08:33:00	22-03-2024	20:42:00	2.51	0.00	0.00	0.00	60.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/3288(399-400 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	26-03-2024	08:43:00	26-03-2024	20:22:00	0.49	0.00	0.00	0.00	11.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/4241(399-400 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	11-03-2024	09:19:00	16-03-2024	17:12:00	5.33	0.00	0.00	0.00	127.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/1842 (396-398 Kv).
							19.43	0.00	0.00	0.00	466.05	100.00	
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	16-03-2024	08:45:00	16-03-2024	17:09:00	0.35	0.00	0.00	0.00	8.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/2662 (396 - 398 Kv).

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	230kV NEYVELI(NLC)-KARAIKAL(PED)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV NEYVELI(NLC)-VILLIANUR(PED)-1	LPRD	26-03-2024	17:14:00	31-03-2024	23:59:59	5.28	0.00	0.00	0.00	126.77		* Hand tripped at Neyveli end only as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 03/4326.
CKT	230kV NEYVELI(NLC)-VILLIANUR(PED)-1	LPRD	01-03-2024	00:00:01	26-03-2024	15:10:00	25.63	0.00	0.00	0.00	615.17		* Line idly charged from Villianur end only as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 02/4501.
CKT	220kV PUNNAPRA(KSEB)-POLLAM(KSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV TIRUNELVELI-EDAMON(KSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV TIRUNELVELI-EDAMON(KSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV ALMATY-TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV ALMATY-TIRUVALAM-2	OSPD	25-03-2024	14:43:00	25-03-2024	18:10:00	0.14	0.00	0.00	0.00	3.45		* Emergency Shut down availed for jumper tightness work and glow attending work at Loc. No. 62 <> 66 vide SRLDC code no. CR-03/4133.
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(INTECL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(INTECL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHITTOOR(APTRANSCO)-SRIPERUMBUDUR	OSPD	02-03-2024	19:20:00	03-03-2024	16:07:00	0.87	0.00	0.00	0.00	20.78		* Emergency shutdown availed by AP TRANSCO for attending critical hotspot in line isolator at Chittor SS vide SRLDC code no. CR- 02/372.
CKT	400kV GOOTY-SOMANAHALLI	LNCC	15-03-2024	17:34:00	15-03-2024	20:29:00	0.12	0.00	0.00	2.92	0.00		* Line tripped on R-G fault.* Somanahalli end details: M1: FLR: 81.3 KM, FC: 3.87 Kamps, M2: FLR: 80.8 KM, FC: 4.5 Kamps.* Gooty end details:M1: FLR: 232.9 KM, FC: 1.735 Kamps, M2: FLR: 224.6 KM, FC: 1.81 Kamps* Fault is in Yelahanka TLM Jurisdiction.
CKT	400kV GOOTY-SOMANAHALLI	LART	17-03-2024	10:55:00	17-03-2024	10:55:00	0.00	0.00	0.00	0.00	0.00		* Line autoreclosed successfully on B-G fault.* Somanahalli end details: M1: FLR: 43.9 KM, FC: 5.1 Kamps, M2: FLR: 43.7 KM, FC: 5.14 Kamps.* Gooty end details:M1: FLR: 240.6 KM, FC: 1.63 Kamps, M2: FLR: 276.89 KM, FC: 1.8 Kamps* Fault is in Yelahanka TLM Jurisdiction.
CKT	400kV HASSAN-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-TALAGUPPA(KPTCL)-1	OMSU	11-03-2024	17:24:00	11-03-2024	19:13:00	0.08	0.00	1.82	0.00	0.00		* Line tripped on Y phase to Ground fault. Hassan end details: M1: 71.6KM/3.93KA, M2: 73.7KM/3.92KA, Talaguppa end details: M1: 220.2K= M/1.13KA, M2: 225.2KM/1.127KA, Fault angle: 73 deg, Fault in KPTCL portion.
CKT	400kV HOSUR-SALEM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HOSUR-SALEM-2	LMAC	27-03-2024	12:26:00	27-03-2024	15:30:00	0.13	0.00	0.00	3.07	0.00		* Line tripped on B-G fault. Hosur end details: M1: FLR: 33.61 KM, FC: 5.9 Kamps, M2: FLR: 33.26 KM, FC: 5.9 Kamps. Salem end details:M1: FLR: 84.32 KM, FC:3.53 Kamps, M2: FLR: 83.59 KM, FC: 3.5 Kamps* Fault is in Dharmapuri TLM Jurisdiction.
CKT	400kV KAIGA(NPCIL)-NARENDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-NARENDRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OMSU	12-03-2024	07:18:00	12-03-2024	15:46:00	0.35	0.00	8.47	0.00	0.00		* Line tripped on receipt of DT from Guttur SS due to bus bar protection operated at Guttur SS.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	24-03-2024	10:58:00	24-03-2024	12:56:00	0.08	0.00	1.97	0.00	0.00		* Line tripped at Kaiga end only after receipt of DT from Guttur end. Bay at Guttur end belongs to KPTCL.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	12-03-2024	07:18:00	12-03-2024	10:19:00	0.13	0.00	3.02	0.00	0.00		* Line tripped at Guttur end only SS due to bus bar protection operated at Guttur SS.
CKT	400kV KARAIKUDI-MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV NAGAPATTINAM-NEYVELI TS1(NLC) EXP			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGAPATTINAM-NEYVELI TS2(NLC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	21-03-2024	15:10:00	21-03-2024	15:31:00	0.02	0.00	0.00	0.00	0.35		* Emergency shutdown availed by KPTCL for attending hotspot at their end.
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	05-03-2024	13:24:00	05-03-2024	22:14:00	0.37	0.00	0.00	0.00	8.83		* Emergency shutdown taken by KPTCL for attending critical hotspot in line isolator clamp of R phase at Nelamangala end vide SRLDC code no. CR-03/799. Bay at Nelamangala belong to KPTCL.
							0.39	0.00	0.00	0.00	9.18	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-PUDUCHERRY-1	OSPT	26-03-2024	15:31:00	26-03-2024	16:55:00	0.06	1.40	0.00	0.00	0.00		* Emergency shutdown availed for attending critical hotspot on B-Ph Isolator towards Wave Trap side vide SRLDC code no. CR-03/4302.
							0.06	1.40	0.00	0.00	0.00	99.81	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-1	OMSU	12-03-2024	07:18:00	12-03-2024	09:39:00	0.10	0.00	2.35	0.00	0.00		* Line tripped on receipt of DT from Guttur SS due to bus bar protection operated at Guttur SS.
							0.10	0.00	2.35	0.00	0.00	100.00	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-2	OMSU	12-03-2024	07:18:00	12-03-2024	10:28:00	0.13	0.00	3.17	0.00	0.00		* Line tripped on receipt of DT from Guttur SS due to bus bar protection operated at Guttur SS.
							0.13	0.00	3.17	0.00	0.00	100.00	
CKT	400kV PUGALUR-ARASUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-ARASUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PALAKKAD-TRICHUR-1	LCSD	23-03-2024	10:29:00	24-03-2024	02:15:00	0.66	0.00	0.00	0.00	15.77		* Shut down availed for construction works (jumper connection) vide SRLDC code no. CR-03/3832
							0.66	0.00	0.00	0.00	15.77	100.00	
CKT	400kV PALAKKAD-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUDUCHERRY-SVCHATHRAM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR HVAC-KARUR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR HVAC-KARUR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-1	OSPD	19-03-2024	10:52:00	19-03-2024	17:02:00	0.26	0.00	0.00	0.00	6.17		* Shut down availed by BPS for fixing of opened spacers and opened/damaged conductor leads on 400KV BPS-Pavagada line 1 <(><>>2 vide SRLDC code no. CR-03/3169.
							0.26	0.00	0.00	0.00	6.17	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400 KV PAVAGADA-DEVANAHALLI(KPTCL)-1	SRMT	19-03-2024	04:14:00	19-03-2024	05:03:00	0.03	0.82	0.00	0.00	0.00		* Line tripped due to bay unit pertaining to 400KV Pavagada-Devanahalli line 1 hanged while rebooting .
							0.03	0.82	0.00	0.00	0.00	99.89	
CKT	400 kv PAVAGADA-DEVANAHALLI(KPTCL)-2	SRMT	19-03-2024	04:14:00	19-03-2024	05:02:00	0.03	0.80	0.00	0.00	0.00		* Line tripped at Pavagada end only due to bay unit pertaining to 400KV Pavagada-Devanahalli line 1 hanged while rebooting .
							0.03	0.80	0.00	0.00	0.00	99.89	
CKT	400kV PAVAGADA-HIRIYUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-2	LVRD	01-03-2024	19:27:00	01-03-2024	21:48:00	0.10	0.00	0.00	0.00	2.35		* Line kept open as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/167.
CKT	400kV PAVAGADA-TUMKUR-2	OMSU	02-03-2024	15:03:00	02-03-2024	15:26:00	0.02	0.00	0.38	0.00	0.00		* Line tripped on R -G fault at Tumkur end only and AR success at Pavagada end. Pavagada end details: M1: FLR: 116.2 KM, FC: 1.4 K Amps, M2: FLR: 114.8 KM, FC: 1.128 Kamps. Tumkur end details:M1: FLR: 27.1 KM, FC: 8.49 Kamps.* Fault is in KPTCL Jurisdiction.
CKT	400kV PAVAGADA-TUMKUR-2	OMSU	01-03-2024	14:20:00	01-03-2024	19:27:00	0.21	0.00	5.12	0.00	0.00		* Line tripped on R -G fault. Pavagada end details: M1: FLR: 157.1 KM, FC: 2.75 Kamps, M2: FLR: 155.6 KM, FC: 3.7 Kamps. Tumkur end details:M1: FLR: 7.5 KM, FC: 10.45 Kamps, M2: FLR: 7.4 KM, FC: 16.0 Kamps* Fault is in KPTCL Jurisdiction.
							0.33	0.00	5.50	0.00	2.35	100.00	
CKT	400kV PAVAGADA-TUMKUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SALEM-NINTPS(NLC)	OSPT	13-03-2024	09:33:00	13-03-2024	17:00:00	0.31	7.45	0.00	0.00	0.00		* Line Shut down availed for AMP works vide SRLDC code no. CR-03/2181
							0.31	7.45	0.00	0.00	0.00	99.00	
CKT	400kV SALEM-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-UDUMALPET-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-SOMANHALLI-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SOMANAHALLI-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SOMANAHALLI-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SOMANAHALLI-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANAHALLI-HOSUR	LART	15-03-2024	17:20:00	15-03-2024	17:20:00	0.00	0.00	0.00	0.00	0.00		* Line autoreclosed successfully on Y-G fault.* Hosur end details: M1: FLR: 43.96 KM, FC: 4.82 Kamps, M2: FLR: 43.53 KM, FC: 4.66 Kamps.* Somanahalli end details:M1: FLR: 29.0 KM, FC: 7.89 Kamps, M2: FLR: 28.9 KM, FC: 8.09 Kamps* Fault is in border of Hosur TLM <(>&<> Somanahalli TLM Jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-SOMANHALLI-MYLASANDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SVCHATRM(TANTRANSCO)-SRIPERMBUDR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-KOCHI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-KOCHI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV THIRUNELVELI-KOTTAYAM-1	OSPD	09-03-2024	09:31:00	09-03-2024	18:48:00	0.39	0.00	0.00	0.00	9.28		* Shut down availed for relay testing at Kottayam vide SRLDC code no. CR-03/1548
							0.39	0.00	0.00	0.00	9.28	100.00	
CKT	400kV THIRUNELVELI-KOTTAYAM-2	OSPD	16-03-2024	09:26:00	16-03-2024	17:09:00	0.32	0.00	0.00	0.00	7.72		* Shut down availed by KSEB for relay testing works at Kottayam SS vide SRLDC code no. CR-03/2682.
							0.32	0.00	0.00	0.00	7.72	100.00	

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV TIRUNELVELI-TRIVANDRUM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TRIVANDRUM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TUTICORIN PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-UDUMALPET-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-KARAIKUDI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-MADURAI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-NAGAPATTANAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-NAGAPATTANAM-2	LCSD	22-03-2024	09:50:00	23-03-2024	17:26:00	1.32	0.00	0.00	0.00	31.60		* Shut down availed for reconnection of Line Reactor after replacement And AMP works vide SRLDC code no. CR-03/3626.
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-KALVINDAPATTU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-KALVINDAPATTU-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-SRIPERUMDUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-KUDAMKULAM(NPCIL)-2	OSPD	17-03-2024	07:14:00	17-03-2024	19:25:00	0.51	0.00	0.00	0.00	12.18		* Shut down availed for maintenance works vide SRLDC code no. CR-03/2803
CKT	400kV TUTICORIN PS-TUTICORIN JV(NTPL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-TUTICORIN JV(NTPL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDMALPET-ARASUR-1	OSPT	19-03-2024	12:15:00	19-03-2024	23:06:00	0.45	10.85	0.00	0.00	0.00		* Shut down availed for LBB relay retrofitting works vide SRLDC code no. CR-03/3181.
CKT	400kV UDMALPET-ARASUR-2	OSPT	21-03-2024	09:11:00	21-03-2024	19:05:00	0.41	9.90	0.00	0.00	0.00		* Shut down availed for LBB Relay retrofitting works vide SRLDC code no. CR-03/3445.
CKT	400kV UDUMAPALET-E.PALAYM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET-E.PALAYM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET -PALLAKAD-1	OSPT	01-03-2024	10:00:00	01-03-2024	12:51:00	0.12	2.85	0.00	0.00	0.00		* Emergency Shut down availed for insulator replacement works vide SRLDC code no. CR-03/74
CKT	400kV UDUMAPALET -PALLAKAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VALLUR(NTECL)-KALIVANTHAPATTU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VALLUR(NTECL)-KALIVANTHAPATTU-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV YELHANKA GIS-DEVANAHALLI(KPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV YELHANKA-NELAMANGALA(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV YELAHANKA GIS-TUMKUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV YELAHANKA GIS-TUMKUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DHARAMPURI-TUMKUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDGI-KOLHAPUR GIS-1	OSPT	23-03-2024	08:48:00	23-03-2024	19:41:00	0.45	10.88	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-03/3793
							0.45	10.88	0.00	0.00	0.00	98.54	
CKT	400kV KUDGI-KOLHAPUR GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF VALLUR-1 AT KALIVANTPATTU	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 12/1755(393-394 Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	63MVAR,SWLR OF TIRUNALVELLI-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF TIRUNALVELLI-2 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF MYSORE-1 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF MYSORE-2 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF TRICHY AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF KARAIKUDI AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF HIRIYUR AT MYSORE	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5174(391-394 Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	80MVAR,SWLR OF PAVAGADA AT MYSORE	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5175(389-391 Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	80MVAR SWLR OF TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR SWLR OF TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NEYVELI-2 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NEYVELI-1 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF HOSUR-2 AT SALEM	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4665(392-392 Kv).
							31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/283 (391 -392 Kv).
LNR	50MVAR,SWLR OF HOSUR-2 AT SALEM	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4975 (393-393Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	50MVAR,SWLR OF CHITTOOR AT SRIPERUMBUDUR	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3280(394-394 Kv).
							31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3056 (396 -396 Kv).
LNR	50MVAR,SWLR OF CHITTOOR AT SRIPERUMBUDUR	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3056 (396 -396 Kv).
							62.00	0.00	0.00	0.00	1,488.00	100.00	

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	50MVAR,SWLR OF SVCHATRAM AT SRIPERUMBUDUR	SVRD	07-03-2024	10:31:00	31-03-2024	23:59:59	24.56	0.00	0.00	0.00	589.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1201(397 -397 Kv).
							24.56	0.00	0.00	0.00	589.48	100.00	
LNR	50MVAR,SWLR OF PALAKKAD-1 AT THRISSUR	SCSD	01-03-2024	00:00:01	27-03-2024	16:46:00	26.70	0.00	0.00	0.00	640.77		* Shutdown availed for replacement of old 50 MVAR reactor with New BHEL make 50MVAR reactor after foundation modification works under Add cap works at Trichur SS vide SRLDC code no. CR-10/1637.
							26.70	0.00	0.00	0.00	640.77	100.00	
LNR	50MVAR,SWLR OF PALAKKAD-2 AT THRISSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF UDUMALPT-1 AT TIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF UDUMALPT-2 AT TIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF NAGAPATTINAM-1 AT TRICHY	SVRD	01-03-2024	11:17:00	31-03-2024	23:59:59	30.53	0.00	0.00	0.00	732.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/92(395 - 395Kv).
							30.53	0.00	0.00	0.00	732.72	100.00	
LNR	50MVAR,SWLR OF NAGAPATTINAM-2 AT TRICHY	SCSD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Shut down availed for Construction: Replacement of existing 50MVAR LR with new 80MVAR LR under Add Cap works vide SRLDC code no. CR-12/3223.
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	50MVAR,SWLR OF KADAPA-1 AT TUMKUR	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5176(398-399 Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	50MVAR,SWLR OF KADAPA-2 AT TUMKUR	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5177(399-401 Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	50MVAR,SWLR OF NELLORE-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NELLORE-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SALEM-2 AT UDUMALPET	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/473 (398-398Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	63MVAR,SWLR OF TIRUNELVELI-2 AT UDUMALPT	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/469 (398-398Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	63MVAR,SWLR OF TIRUNELVELI-1 AT UDUMALPT	SVRD	01-03-2024	00:00:01	31-03-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/470 (398-398Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
STATCOM	-200/+200 MVAR STATCOM AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-200/+200 MVAR STATCOM AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	OSPT	15-03-2024	10:47:00	15-03-2024	12:44:00	0.08	1.95	0.00	0.00	0.00		* Emergency Shutdown availed to attend SF6 low Alarm in Star Bushing of B Phase Converter Transformer at Kolar SS vide SRLDC code CR-03/2524
							0.08	1.95	0.00	0.00	0.00	99.74	
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	OMST	07-03-2024	18:43:00	07-03-2024	22:32:00	0.16	3.82	0.00	0.00	0.00		* Pole-2 blocked due to ESOF signal received at Kolar from Talcher End. AC O/C stage-4 alarm, High Voltage DC Busbar protection operated at Talcher end. Flashover observed in valve bushing
							0.16	3.82	0.00	0.00	0.00	99.49	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-3	OSPT	26-03-2024	19:49:00	26-03-2024	21:34:00	0.07	1.75	0.00	0.00	0.00		* Emergency Shut down availed for attending SF6 stage-1 alarm (Loss of SF6 gas) in Raigarh-Pugalur Pole-3 T1 convertor transformer towards Valve side bushing at Pugalur end vide SRLDC code no. CR-03/4356/2717.
							0.07	1.75	0.00	0.00	0.00	99.76	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-2	OSPT	02-03-2024	09:24:00	03-03-2024	19:51:00	1.44	34.45	0.00	0.00	0.00		* Shut down availed for AMP works at Pugalur HVDC, Thrissur HVDC and line maintenance works vide SRLDC code no. CR-02/223/145.
							1.44	34.45	0.00	0.00	0.00	95.37	
XMER	315MVA,400/220kV ICT-1 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BIDADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BIDADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT HOSUR	SCSD	23-03-2024	07:57:00	23-03-2024	13:24:00	0.23	0.00	0.00	0.00	5.45		* Shut down availed for ICT-3 construction works vide SRLDC code no. CR-03/3772
XMER	315MVA,400/220kV ICT-3 AT HOSUR	SCSD	24-03-2024	08:12:00	24-03-2024	13:43:00	0.23	0.00	0.00	0.00	5.52		* Shut down availed for construction activities of upcoming ICT-4 vide code SR-03/3972
							0.46	0.00	0.00	0.00	10.97	100.00	
XMER	315MVA,400/220kV ICT-1 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT KOLAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT KOLAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Mar-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-1 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT NARENDRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT NARENDRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PUDUCHERRY	OSPT	22-03-2024	11:13:00	22-03-2024	12:36:00	0.06	1.38	0.00	0.00	0.00	99.81	* Emergency Shut down availed for attending Hot spot in 202 bay CT Rph- jumper vide SRLDC code no. CR-03/3649.
XMER	500MVA,400/220kV ICT-3 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT THIRUNELVELI	OSPT	27-03-2024	09:05:00	27-03-2024	15:19:00	0.26	6.23	0.00	0.00	0.00	99.16	* Shut down availed for Modification of PRD,Replacement of Buchholz relay due to oil leaks, Measurement of CT capacitance (><) Tan delta of 230kV side CT and oil sampling of 230kV CT. vide SRLDC code no. CR-03/4427.
XMER	315MVA,400/220kV ICT-2 AT THIRUNELVELI	OSPT	26-03-2024	08:59:00	26-03-2024	20:58:00	0.50	11.98	0.00	0.00	0.00	98.39	* Shut down availed for AMP works vide SRLDC code no. CR-03/4249
XMER	315MVA,400/220kV ICT-1 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

