

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	15-02-2025	09:33:00	15-02-2025	17:14:00	0.32	0.00	0.00	0.00	7.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3025(392- 392 Kv)
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	13-02-2025	07:25:00	13-02-2025	16:32:00	0.38	0.00	0.00	0.00	9.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2534 (401-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	17-02-2025	06:47:00	17-02-2025	16:15:00	0.39	0.00	0.00	0.00	9.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3376(409 - 409Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	16-02-2025	10:06:00	16-02-2025	17:20:00	0.30	0.00	0.00	0.00	7.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3241(396 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	14-02-2025	07:11:00	14-02-2025	18:15:00	0.46	0.00	0.00	0.00	11.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2760 (399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	28-02-2025	07:57:00	28-02-2025	23:59:59	0.67	0.00	0.00	0.00	16.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5881 (401-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	25-02-2025	08:05:00	25-02-2025	20:52:00	0.53	0.00	0.00	0.00	12.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5228(399 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	27-02-2025	07:25:00	27-02-2025	21:21:00	0.58	0.00	0.00	0.00	13.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5638(399 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	24-02-2025	08:03:00	24-02-2025	17:01:00	0.37	0.00	0.00	0.00	8.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4989(402 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	21-02-2025	07:49:00	21-02-2025	21:48:00	0.58	0.00	0.00	0.00	13.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4352 (400-401Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	23-02-2025	09:09:00	23-02-2025	15:14:00	0.25	0.00	0.00	0.00	6.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4810 (397-397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	26-02-2025	08:24:00	26-02-2025	17:14:00	0.37	0.00	0.00	0.00	8.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5444 (395-395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	22-02-2025	08:29:00	22-02-2025	21:25:00	0.54	0.00	0.00	0.00	12.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4592(401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	18-02-2025	07:53:00	18-02-2025	17:51:00	0.42	0.00	0.00	0.00	9.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3616 (397 -397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	20-02-2025	08:05:00	20-02-2025	19:27:00	0.47	0.00	0.00	0.00	11.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4099 (400-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	08-02-2025	06:58:00	08-02-2025	17:35:00	0.44	0.00	0.00	0.00	10.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1504 (408-410Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	19-02-2025	06:50:00	19-02-2025	16:56:00	0.42	0.00	0.00	0.00	10.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3831(403 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	09-02-2025	06:43:00	09-02-2025	16:43:00	0.42	0.00	0.00	0.00	10.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1705 (411-411 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	02-02-2025	09:20:00	02-02-2025	16:55:00	0.32	0.00	0.00	0.00	7.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1225 (396 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	01-02-2025	07:55:00	01-02-2025	22:53:00	0.62	0.00	0.00	0.00	14.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/32(404 - 404Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	05-02-2025	08:12:00	05-02-2025	20:53:00	0.53	0.00	0.00	0.00	12.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/781 (403-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	10-02-2025	08:01:00	10-02-2025	17:31:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1838 (400 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	06-02-2025	08:58:00	06-02-2025	21:38:00	0.53	0.00	0.00	0.00	12.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1022(406-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	07-02-2025	06:35:00	07-02-2025	20:06:00	0.56	0.00	0.00	0.00	13.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1256 (408-409 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	04-02-2025	08:18:00	04-02-2025	16:46:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/571 (406-408Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	03-02-2025	08:25:00	03-02-2025	16:19:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/364 (397-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	11-02-2025	07:35:00	11-02-2025	18:13:00	0.44	0.00	0.00	0.00	10.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2050 (402 - 402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	12-02-2025	08:01:00	12-02-2025	17:26:00	0.39	0.00	0.00	0.00	9.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2306 (401-402Kv).
							12.38	0.00	0.00	0.00	297.52	100.00	
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	10-02-2025	09:35:00	15-02-2025	20:28:00	5.45	0.00	0.00	0.00	130.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1870 (396 -399 Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	03-02-2025	09:27:00	03-02-2025	18:43:00	0.39	0.00	0.00	0.00	9.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/398 (401-401 Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	04-02-2025	10:53:00	08-02-2025	21:11:00	4.43	0.00	0.00	0.00	106.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/618 (404-406Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	18-02-2025	08:57:00	28-02-2025	23:59:59	10.63	0.00	0.00	0.00	255.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3641 (395 -397 Kv).
							20.90	0.00	0.00	0.00	501.50	100.00	
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	01-02-2025	07:33:00	01-02-2025	20:18:00	0.53	0.00	0.00	0.00	12.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/33(404 -405 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	08-02-2025	09:40:00	08-02-2025	18:05:00	0.35	0.00	0.00	0.00	8.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1551(399 - 401Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	15-02-2025	08:12:00	15-02-2025	19:22:00	0.47	0.00	0.00	0.00	11.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3005(406- 406 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	17-02-2025	09:18:00	17-02-2025	16:39:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3423(393 - 396Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	14-02-2025	07:13:00	14-02-2025	18:39:00	0.48	0.00	0.00	0.00	11.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2761 (403-408 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	16-02-2025	10:13:00	16-02-2025	17:29:00	0.30	0.00	0.00	0.00	7.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3242(396 - 398Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	26-02-2025	08:19:00	26-02-2025	17:24:00	0.38	0.00	0.00	0.00	9.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5445 (398-400 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	27-02-2025	08:03:00	27-02-2025	16:13:00	0.34	0.00	0.00	0.00	8.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5657 (406-408 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	25-02-2025	08:07:00	25-02-2025	17:51:00	0.41	0.00	0.00	0.00	9.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5229(405 - 408Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	23-02-2025	09:54:00	23-02-2025	15:29:00	0.23	0.00	0.00	0.00	5.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4828(397-400 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	21-02-2025	07:58:00	21-02-2025	17:29:00	0.40	0.00	0.00	0.00	9.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4353 (402-404Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	24-02-2025	08:19:00	24-02-2025	17:01:00	0.36	0.00	0.00	0.00	8.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4995(405 - 407Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	19-02-2025	06:46:00	19-02-2025	17:21:00	0.44	0.00	0.00	0.00	10.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3832(402 -406 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	20-02-2025	08:07:00	20-02-2025	17:29:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4100 (408-410Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	18-02-2025	07:56:00	18-02-2025	17:58:00	0.42	0.00	0.00	0.00	10.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3617 (402 -405 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	28-02-2025	08:05:00	28-02-2025	17:50:00	0.41	0.00	0.00	0.00	9.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5882 (404-406Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	06-02-2025	08:30:00	06-02-2025	17:14:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1023 (408-410 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	04-02-2025	08:19:00	04-02-2025	17:17:00	0.37	0.00	0.00	0.00	8.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/572 (410-411Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	03-02-2025	08:30:00	03-02-2025	17:05:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/365 (402-406 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	11-02-2025	07:56:00	11-02-2025	16:57:00	0.38	0.00	0.00	0.00	9.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2065 (410 - 413 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	07-02-2025	07:52:00	07-02-2025	16:41:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1265(402-406 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	10-02-2025	09:20:00	10-02-2025	17:40:00	0.35	0.00	0.00	0.00	8.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1867 (395 -396 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	05-02-2025	09:30:00	05-02-2025	19:01:00	0.40	0.00	0.00	0.00	9.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/826 (400-401Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	13-02-2025	10:00:00	13-02-2025	16:34:00	0.27	0.00	0.00	0.00	6.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2559 (400-401Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	12-02-2025	08:05:00	12-02-2025	18:00:00	0.41	0.00	0.00	0.00	9.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2307 (407-408Kv).
							9.49	0.00	0.00	0.00	227.36	100.00	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	25-02-2025	08:08:00	25-02-2025	17:56:00	0.41	0.00	0.00	0.00	9.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5230(405 - 408Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	28-02-2025	08:06:00	28-02-2025	17:54:00	0.41	0.00	0.00	0.00	9.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5883 (406-410Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	27-02-2025	08:04:00	27-02-2025	16:15:00	0.34	0.00	0.00	0.00	8.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5658 (408-412 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	22-02-2025	08:30:00	22-02-2025	17:58:00	0.39	0.00	0.00	0.00	9.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4593(402 - 404Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	24-02-2025	08:20:00	24-02-2025	16:52:00	0.36	0.00	0.00	0.00	8.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4996(407 - 411Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	23-02-2025										

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	12-02-2025	08:08:00	12-02-2025	17:24:00	0.39	0.00	0.00	0.00	9.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2308 (408-409Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	11-02-2025	07:37:00	11-02-2025	16:41:00	0.38	0.00	0.00	0.00	9.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2051 (402 - 407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	07-02-2025	07:53:00	07-02-2025	16:43:00	0.37	0.00	0.00	0.00	8.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1266 (406-409 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	04-02-2025	08:25:00	04-02-2025	16:50:00	0.35	0.00	0.00	0.00	8.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/573 (411-413Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	06-02-2025	08:32:00	06-02-2025	17:16:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1024 (410-413 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	05-02-2025	08:14:00	05-02-2025	18:58:00	0.45	0.00	0.00	0.00	10.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/782 (406-408Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	02-02-2025	09:20:00	02-02-2025	17:14:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/226 (396 - 400Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	08-02-2025	09:15:00	08-02-2025	17:47:00	0.36	0.00	0.00	0.00	8.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1532(395 - 398Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	19-02-2025	06:47:00	19-02-2025	16:24:00	0.40	0.00	0.00	0.00	9.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3833(406 -411 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	18-02-2025	07:57:00	18-02-2025	18:34:00	0.44	0.00	0.00	0.00	10.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3618 (405 -408 Kv).
							10.26	0.00	0.00	0.00	245.99	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	03-02-2025	08:33:00	03-02-2025	16:23:00	0.33	0.00	0.00	0.00	7.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/367 (399-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	08-02-2025	10:28:00	08-02-2025	17:38:00	0.30	0.00	0.00	0.00	7.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1552(392 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	19-02-2025	08:29:00	19-02-2025	16:48:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3874 (400 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	05-02-2025	09:38:00	05-02-2025	17:10:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/827 (400-400Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	10-02-2025	09:30:00	10-02-2025	17:27:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1868 (391 -395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	11-02-2025	07:57:00	11-02-2025	16:37:00	0.36	0.00	0.00	0.00	8.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2066 (408 - 412 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	07-02-2025	07:54:00	07-02-2025	16:30:00	0.36	0.00	0.00	0.00	8.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1267 (402-405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	13-02-2025	10:02:00	13-02-2025	16:45:00	0.28	0.00	0.00	0.00	6.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2560 (400-400Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	12-02-2025	08:15:00	12-02-2025	16:54:00	0.36	0.00	0.00	0.00	8.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2309 (401-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	04-02-2025	08:28:00	04-02-2025	16:37:00	0.34	0.00	0.00	0.00	8.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/574 (405-407Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	01-02-2025	07:55:00	01-02-2025	16:22:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/351 (403-405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	06-02-2025	08:45:00	06-02-2025	17:14:00	0.35	0.00	0.00	0.00	8.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1025 (404-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	17-02-2025	09:23:00	17-02-2025	16:20:00	0.29	0.00	0.00	0.00	6.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3425(392 - 395Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	14-02-2025	09:42:00	14-02-2025	16:41:00	0.29	0.00	0.00	0.00	6.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2802 (393- 393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	16-02-2025	10:13:00	16-02-2025	15:58:00	0.24	0.00	0.00	0.00	5.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3244(396 - 397Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	25-02-2025	08:09:00	25-02-2025	17:22:00	0.38	0.00	0.00	0.00	9.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5231(398 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	27-02-2025	08:14:00	27-02-2025	16:08:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5659 (404-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	28-02-2025	08:09:00	28-02-2025	17:10:00	0.38	0.00	0.00	0.00	9.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5884 (408-409Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	23-02-2025	10:00:00	23-02-2025	15:17:00	0.22	0.00	0.00	0.00	5.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4830 (396 - 400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	21-02-2025	08:05:00	21-02-2025	17:16:00	0.38	0.00	0.00	0.00	9.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4355 (400-401Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	20-02-2025	08:20:00	20-02-2025	17:42:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4102 (401-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	18-02-2025	08:00:00	18-02-2025	17:55:00	0.41	0.00	0.00	0.00	9.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3619 (401 -402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	24-02-2025	08:24:00	24-02-2025	16:43:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4997(404 - 404Kv).
							7.68	0.00	0.00	0.00	184.41	100.00	
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	26-02-2025	08:32:00	26-02-2025	17:18:00	0.37	0.00	0.00	0.00	8.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5447 (396-401 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	18-02-2025	08:01:00	18-02-2025	18:05:00	0.42	0.00	0.00	0.00	10.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3620 (402 -405 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	20-02-2025	08:22:00	20-02-2025	17:44:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4103 (403-403Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	19-02-2025	08:30:00	19-02-2025	16:49:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3875 (400 -400 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	22-02-2025	08:40:00	22-02-2025	17:56:00	0.39	0.00	0.00	0.00	9.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4594(401 - 401Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	23-02-2025	09:16:00	23-02-2025	15:18:00	0.25	0.00	0.00	0.00	6.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4811 (392-392 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	25-02-2025	08:10:00	25-02-2025	17:24:00	0.39	0.00	0.00	0.00	9.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5232(398 - 398Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	28-02-2025	08:10:00	28-02-2025	17:37:00	0.39	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5885 (409-409Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	24-02-2025	08:26:00	24-02-2025	16:45:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4998(404 - 409Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	21-02-2025	08:08:00	21-02-2025	17:23:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4356 (401-402Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	27-02-2025	08:16:00	27-02-2025	16:09:00	0.33	0.00	0.00	0.00	7.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5660 (404-408 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	14-02-2025	09:40:00	14-02-2025	16:42:00	0.29	0.00	0.00	0.00	7.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2803 (387- 393 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	17-02-2025	09:29:00	17-02-2025	16:22:00	0.29	0.00	0.00	0.00	6.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3426(395 - 395Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	01-02-2025	07:56:00	01-02-2025	16:26:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/36(405 - 409Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	07-02-2025	07:55:00	07-02-2025	16:31:00	0.36	0.00	0.00	0.00	8.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1268 (405-408 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	11-02-2025	07:40:00	11-02-2025	16:41:00	0.38	0.00	0.00	0.00	9.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2052 (403 - 403 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	13-02-2025	07:40:00	13-02-2025	16:46:00	0.38	0.00	0.00	0.00	9.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2536 (408-409Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	04-02-2025	08:31:00	04-02-2025	16:39:00	0.34	0.00	0.00	0.00	8.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/575 (407-408Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	02-02-2025	09:23:00	02-02-2025	16:57:00	0.32	0.00	0.00	0.00	7.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/227 (391 - 396Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	06-02-2025	08:49:00	06-02-2025	17:16:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1026 (404-406 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	03-02-2025	08:34:00	03-02-2025	16:24:00	0.33	0.00	0.00	0.00	7.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/368 (401-403 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	10-02-2025	08:07:00	10-02-2025	17:30:00	0.39	0.00	0.00	0.00	9.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1840 (400 -401 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	12-02-2025	08:17:00	12-02-2025	16:58:00	0.36	0.00	0.00	0.00	8.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2310 (402-403Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	05-02-2025	08:18:00	05-02-2025	17:12:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/783 (404-406Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	08-02-2025	09:17:00	08-02-2025	17:39:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1533(393 - 393Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	16-02-2025	10:15:00	16-02-2025	16:00:00	0.24	0.00	0.00	0.00	5.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3245(397 - 400Kv).
							9.12	0.00	0.00	0.00	218.15	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	11-02-2025	09:16:00	11-02-2025	21:10:00	0.50	0.00	0.00	0.00	11.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2093 (390 - 390 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	17-02-2025	06:54:00	28-02-2025	23:59:59	11.71	0.00	0.00	0.00	281.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3384(402 - 402Kv).
							12.21	0.00	0.00	0.00	293.00	100.00	
BSR	125MVAR												

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	15-02-2025	08:50:00	15-02-2025	17:27:00	0.36	0.00	0.00	0.00	8.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3014(392- 393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	17-02-2025	06:48:00	17-02-2025	18:26:00	0.49	0.00	0.00	0.00	11.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3377(411 - 413Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	03-02-2025	08:40:00	03-02-2025	18:36:00	0.41	0.00	0.00	0.00	9.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/369 (404-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	16-02-2025	07:57:00	16-02-2025	18:59:00	0.46	0.00	0.00	0.00	11.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3220(412 - 413Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	22-02-2025	08:13:00	22-02-2025	21:25:00	0.55	0.00	0.00	0.00	13.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4595(401 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	28-02-2025	08:18:00	28-02-2025	23:59:59	0.65	0.00	0.00	0.00	15.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5886 (403-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	25-02-2025	08:04:00	25-02-2025	17:28:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5233(398 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	24-02-2025	08:11:00	24-02-2025	16:43:00	0.36	0.00	0.00	0.00	8.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4990(401 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	26-02-2025	08:18:00	26-02-2025	17:23:00	0.38	0.00	0.00	0.00	9.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5448 (398-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	23-02-2025	09:23:00	23-02-2025	15:19:00	0.25	0.00	0.00	0.00	5.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4818 (399-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	19-02-2025	08:30:00	19-02-2025	21:44:00	0.55	0.00	0.00	0.00	13.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3876 (396 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	18-02-2025	07:59:00	18-02-2025	17:58:00	0.42	0.00	0.00	0.00	9.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3621 (403 -404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	27-02-2025	07:25:00	27-02-2025	21:21:00	0.58	0.00	0.00	0.00	13.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5639 (402 - 404Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	20-02-2025	08:07:00	21-02-2025	22:12:00	1.59	0.00	0.00	0.00	38.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4104 (400-400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	04-02-2025	08:22:00	04-02-2025	16:41:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/576 (406-408Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	07-02-2025	06:36:00	07-02-2025	16:28:00	0.41	0.00	0.00	0.00	9.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1257 (408-410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	01-02-2025	09:03:00	02-02-2025	17:15:00	1.34	0.00	0.00	0.00	32.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/54 (398 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	08-02-2025	07:17:00	08-02-2025	17:28:00	0.42	0.00	0.00	0.00	10.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1505 (407-409Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	12-02-2025	08:12:00	12-02-2025	17:39:00	0.39	0.00	0.00	0.00	9.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2311 (400-401Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	10-02-2025	08:07:00	10-02-2025	17:45:00	0.40	0.00	0.00	0.00	9.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1841 (404 -406 Kv).
							13.50	0.00	0.00	0.00	324.37	100.00	
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	03-02-2025	08:38:00	05-02-2025	20:57:00	2.51	0.00	0.00	0.00	60.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/370 (400-403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	11-02-2025	08:04:00	11-02-2025	18:21:00	0.43	0.00	0.00	0.00	10.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2067 (401 - 404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	08-02-2025	09:43:00	08-02-2025	17:36:00	0.33	0.00	0.00	0.00	7.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1553(397 - 397Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	12-02-2025	08:24:00	12-02-2025	17:47:00	0.39	0.00	0.00	0.00	9.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2312 (401-402Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	07-02-2025	07:59:00	07-02-2025	16:33:00	0.36	0.00	0.00	0.00	8.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1269 (399-403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	10-02-2025	08:11:00	10-02-2025	17:39:00	0.39	0.00	0.00	0.00	9.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1842 (399 -402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	15-02-2025	08:44:00	15-02-2025	20:24:00	0.49	0.00	0.00	0.00	11.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3015(402- 403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	17-02-2025	09:17:00	17-02-2025	16:19:00	0.29	0.00	0.00	0.00	7.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3416(395 - 397Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	06-02-2025	08:46:00	06-02-2025	21:40:00	0.54	0.00	0.00	0.00	12.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1028 (401-403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	13-02-2025	09:56:00	14-02-2025	18:18:00	1.35	0.00	0.00	0.00	32.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2561 (401-402Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	16-02-2025	08:11:00	16-02-2025	20:22:00	0.51	0.00	0.00	0.00	12.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3221(405 - 405Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	22-02-2025	08:32:00	22-02-2025	21:32:00	0.54	0.00	0.00	0.00	13.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4608(401 - 402Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	26-02-2025	08:30:00	26-02-2025	17:27:00	0.37	0.00	0.00	0.00	8.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5449 (401-401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	24-02-2025	08:23:00	25-02-2025	21:06:00	1.53	0.00	0.00	0.00	36.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4999(403 - 405Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	27-02-2025	08:13:00	28-02-2025	18:06:00	1.41	0.00	0.00	0.00	33.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5661 (404-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	18-02-2025	08:09:00	18-02-2025	18:09:00	0.42	0.00	0.00	0.00	10.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3622 (400 -401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	19-02-2025	06:50:00	20-02-2025	17:31:00	1.45	0.00	0.00	0.00	34.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3835(396 -399 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	23-02-2025	10:02:00	23-02-2025	15:31:00	0.23	0.00	0.00	0.00	5.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4831 (403 - 403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	21-02-2025	08:16:00	21-02-2025	21:48:00	0.56	0.00	0.00	0.00	13.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4357 (402-403Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	01-02-2025	09:03:00	02-02-2025	17:01:00	1.33	0.00	0.00	0.00	31.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/55 (397 - 396Kv).
							15.43	0.00	0.00	0.00	370.26	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	19-02-2025	06:57:00	20-02-2025	17:37:00	1.44	0.00	0.00	0.00	34.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3835(399 -399 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	10-02-2025	08:15:00	10-02-2025	18:38:00	0.43	0.00	0.00	0.00	10.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1843 (402 -404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	07-02-2025	08:07:00	07-02-2025	20:44:00	0.53	0.00	0.00	0.00	12.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1270 (403-405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	13-02-2025	10:04:00	14-02-2025	18:23:00	1.35	0.00	0.00	0.00	32.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2562 (402-402Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	01-02-2025	09:07:00	02-02-2025	16:59:00	1.33	0.00	0.00	0.00	31.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/56 (396 - 396Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	12-02-2025	08:35:00	12-02-2025	17:53:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2313 (402-402Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	08-02-2025	07:07:00	08-02-2025	17:39:00	0.44	0.00	0.00	0.00	10.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1506 (401-403Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	06-02-2025	08:49:00	06-02-2025	21:46:00	0.54	0.00	0.00	0.00	12.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1029 (403-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	17-02-2025	09:21:00	18-02-2025	18:14:00	1.37	0.00	0.00	0.00	32.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3417(397 - 397Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	15-02-2025	09:37:00	15-02-2025	17:23:00	0.32	0.00	0.00	0.00	7.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3026(397- 399 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	03-02-2025	08:45:00	05-02-2025	21:04:00	2.51	0.00	0.00	0.00	60.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/371 (400-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	16-02-2025	08:16:00	16-02-2025	20:27:00	0.51	0.00	0.00	0.00	12.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3222(405- 406Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	11-02-2025	08:13:00	11-02-2025	18:27:00	0.43	0.00	0.00	0.00	10.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2068 (404 - 404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	23-02-2025	09:28:00	23-02-2025	17:27:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4812 (398 - 400 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	25-02-2025	08:17:00	25-02-2025	21:14:00	0.54	0.00	0.00	0.00	12.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5234(401 - 404Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	27-02-2025	08:21:00	28-02-2025	23:59:59	1.65	0.00	0.00	0.00	39.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5662 (404-407 Kv).
							14.11	0.00	0.00	0.00	338.60	100.00	
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	17-02-2025	09:31:00	17-02-2025	16:52:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3418(396 - 396Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	20-02-2025	08:25:00	20-02-2025	17:59:00	0.40	0.00	0.00	0.00	9.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4105 (406-408Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	01-02-2025	09:01:00	01-02-2025	16:35:00	0.32	0.00	0.00	0.00	7.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/57 (398 - 393Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	08-02-2025	09:11:00	08-02-2025	17:49:00	0.36	0.00	0.00	0.00	8.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1534(390 - 393Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	04-02-2025	08:12:00	04-02-2025	16:53:00	0.36	0.00	0.00	0.00	8.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/577 (404-404Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	03-02-2025	08:37:00	03-02-2025	16:27:00	0.33	0.00	0.00	0.00	7.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/372 (40

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	28-02-2025	08:15:00	28-02-2025	18:07:00	0.41	0.00	0.00	0.00	9.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5887 (407-410Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	24-02-2025	08:26:00	24-02-2025	16:50:00	0.35	0.00	0.00	0.00	8.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5000(409 - 409Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	22-02-2025	08:35:00	22-02-2025	17:49:00	0.39	0.00	0.00	0.00	9.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4596(402 - 402Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	27-02-2025	08:10:00	27-02-2025	16:05:00	0.33	0.00	0.00	0.00	7.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5663 (409-410 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	19-02-2025	06:50:00	19-02-2025	16:55:00	0.42	0.00	0.00	0.00	10.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3836(407- 407Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	18-02-2025	08:09:00	18-02-2025	18:25:00	0.43	0.00	0.00	0.00	10.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3623 (406- 406 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	21-02-2025	08:13:00	21-02-2025	17:35:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4358 (402-402Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	23-02-2025	09:47:00	23-02-2025	15:23:00	0.23	0.00	0.00	0.00	5.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4832 (390 - 393 Kv).
							9.36	0.00	0.00	0.00	224.11	100.00	
BSR	125MVAR, BUS REACTOR-1 AT NAGAPATTINAM	SVRD	20-02-2025	10:00:00	28-02-2025	23:59:59	8.58	0.00	0.00	0.00	206.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4130 (402-404Kv).
							8.58	0.00	0.00	0.00	206.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	24-02-2025	08:27:00	24-02-2025	16:55:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5001(407 - 409Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	18-02-2025	08:08:00	18-02-2025	18:02:00	0.41	0.00	0.00	0.00	9.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3624 (397 -399 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	19-02-2025	06:53:00	19-02-2025	15:11:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3837(402- 404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	04-02-2025	08:11:00	04-02-2025	16:32:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/578 (404-407Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	05-02-2025	08:21:00	05-02-2025	18:43:00	0.43	0.00	0.00	0.00	10.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/785 (404-406Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	01-02-2025	08:00:00	01-02-2025	16:35:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/371(403 -408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	06-02-2025	08:55:00	06-02-2025	17:18:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1031 (405-409 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	11-02-2025	07:42:00	11-02-2025	16:59:00	0.39	0.00	0.00	0.00	9.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2053 (401 - 405 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	07-02-2025	07:59:00	07-02-2025	16:27:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1271 (405-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	10-02-2025	08:01:00	10-02-2025	17:38:00	0.40	0.00	0.00	0.00	9.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1845 (401- 403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	02-02-2025	09:27:00	02-02-2025	17:02:00	0.32	0.00	0.00	0.00	7.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1288 (395 - 398Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	12-02-2025	08:30:00	12-02-2025	17:42:00	0.38	0.00	0.00	0.00	9.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2315 (404-405Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	08-02-2025	09:19:00	08-02-2025	17:52:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1535(396 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	03-02-2025	08:39:00	03-02-2025	16:36:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/373 (405-406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	13-02-2025	09:40:00	13-02-2025	16:52:00	0.30	0.00	0.00	0.00	7.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2564 (402-404Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	15-02-2025	09:24:00	15-02-2025	17:36:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3028(393- 396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	17-02-2025	09:32:00	17-02-2025	16:41:00	0.30	0.00	0.00	0.00	7.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3419(396 - 400Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	14-02-2025	07:16:00	14-02-2025	16:55:00	0.40	0.00	0.00	0.00	9.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2764 (402-404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	16-02-2025	08:06:00	16-02-2025	17:31:00	0.39	0.00	0.00	0.00	9.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3224(408 - 411Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	26-02-2025	08:25:00	26-02-2025	17:24:00	0.37	0.00	0.00	0.00	8.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5451 (400- 402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	23-02-2025	09:32:00	23-02-2025	15:26:00	0.25	0.00	0.00	0.00	5.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4813 (396 - 396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	21-02-2025	08:22:00	21-02-2025	17:28:00	0.38	0.00	0.00	0.00	9.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4359 (404-405Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	22-02-2025	08:26:00	22-02-2025	17:52:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4597(397 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	27-02-2025	08:12:00	27-02-2025	17:53:00	0.40	0.00	0.00	0.00	9.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5664 (403-406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	28-02-2025	08:14:00	28-02-2025	18:04:00	0.41	0.00	0.00	0.00	9.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5888 (402-404Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	25-02-2025	08:16:00	25-02-2025	17:33:00	0.39	0.00	0.00	0.00	9.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5236(402 - 405Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	20-02-2025	08:28:00	20-02-2025	17:25:00	0.37	0.00	0.00	0.00	8.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4106 (410-412Kv).
							9.82	0.00	0.00	0.00	235.77	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC	SVRD	17-02-2025	07:01:00	28-02-2025	23:59:59	11.71	0.00	0.00	0.00	280.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3385(403 - 405Kv).
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC	SVRD	01-02-2025	00:00:01	15-02-2025	20:20:00	14.85	0.00	0.00	0.00	356.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3352 (410 - 412 Kv).
							26.56	0.00	0.00	0.00	637.31	100.00	
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC	SVRD	01-02-2025	00:00:01	15-02-2025	20:22:00	14.85	0.00	0.00	0.00	356.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3353 (412 -414 Kv).
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC	SVRD	17-02-2025	07:03:00	28-02-2025	23:59:59	11.71	0.00	0.00	0.00	280.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3386(405 - 407Kv).
							26.56	0.00	0.00	0.00	637.32	100.00	
BSR	63MVAR, BUS REACTOR-1 AT PALAKKAD	SVRD	21-02-2025	08:58:00	22-02-2025	18:04:00	1.38	0.00	0.00	0.00	33.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4379 (406-408Kv).
							1.38	0.00	0.00	0.00	33.10	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR	SVRD	11-02-2025	09:22:00	11-02-2025	20:54:00	0.48	0.00	0.00	0.00	11.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2094 (400 - 402 Kv).
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR	SVRD	19-02-2025	09:59:00	28-02-2025	23:59:59	9.58	0.00	0.00	0.00	230.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3900 (397 -397 Kv).
							10.06	0.00	0.00	0.00	241.55	100.00	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	27-02-2025	08:11:00	27-02-2025	16:16:00	0.34	0.00	0.00	0.00	8.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5665 (410-413 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	21-02-2025	09:03:00	21-02-2025	17:55:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4381 (406-406Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	26-02-2025	09:27:00	26-02-2025	17:34:00	0.34	0.00	0.00	0.00	8.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5471 (398-401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	13-02-2025	07:44:00	13-02-2025	16:35:00	0.37	0.00	0.00	0.00	8.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2538 (415-417Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	14-02-2025	07:18:00	14-02-2025	16:29:00	0.38	0.00	0.00	0.00	9.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2765 (405-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	15-02-2025	08:22:00	15-02-2025	17:06:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3007 (411- 413 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	05-02-2025	08:10:00	05-02-2025	17:09:00	0.37	0.00	0.00	0.00	8.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/786 (406-408Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	12-02-2025	08:54:00	12-02-2025	16:37:00	0.32	0.00	0.00	0.00	7.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2316 (410-411Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	01-02-2025	09:24:00	01-02-2025	19:55:00	0.44	0.00	0.00	0.00	10.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/65 (400 - 400Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	04-02-2025	08:08:00	04-02-2025	16:14:00	0.34	0.00	0.00	0.00	8.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/579 (411-411Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	03-02-2025	08:30:00	03-02-2025	16:50:00	0.35	0.00	0.00	0.00	8.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/374 (407-409 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	07-02-2025	07:54:00	07-02-2025	16:41:00	0.37	0.00	0.00	0.00	8.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1272 (410-412 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	11-02-2025	09:16:00	11-02-2025	16:44:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2091 (404 - 405 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	06-02-2025	08:23:00	06-02-2025	17:11:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1032 (411-414 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	08-02-2025	09:21:00	08-02-2025	17:32:00	0.34	0.00	0.00	0.00	8.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1536(402 - 402Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	18-02-2025	08:12:00	18-02-2025	18:28:00	0.43	0.00	0.00	0.00	10.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3625 (410 - 411 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	17-02-2025	09:23:00	17-02-2025	16:26:00	0.29						

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	26-02-2025	09:29:00	26-02-2025	17:36:00	0.34	0.00	0.00	0.00	8.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5472 (401-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	20-02-2025	08:25:00	20-02-2025	17:19:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4108 (412-415Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	16-02-2025	10:17:00	16-02-2025	16:07:00	0.24	0.00	0.00	0.00	5.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3247(403 - 406Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	18-02-2025	08:14:00	18-02-2025	18:32:00	0.43	0.00	0.00	0.00	10.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3626 (411 -411 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	19-02-2025	08:33:00	19-02-2025	16:44:00	0.34	0.00	0.00	0.00	8.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3877 (408 -411 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	04-02-2025	08:09:00	04-02-2025	16:17:00	0.34	0.00	0.00	0.00	8.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/580 (411-413Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	06-02-2025	08:26:00	06-02-2025	17:12:00	0.37	0.00	0.00	0.00	8.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1033 (411-419 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	05-02-2025	09:43:00	05-02-2025	16:58:00	0.30	0.00	0.00	0.00	7.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/829 (402-404Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	07-02-2025	07:56:00	07-02-2025	16:44:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1273 (412-413 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	11-02-2025	09:17:00	11-02-2025	16:46:00	0.31	0.00	0.00	0.00	7.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2092 (405 - 405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	12-02-2025	08:55:00	12-02-2025	16:40:00	0.32	0.00	0.00	0.00	7.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2317 (411-411Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	03-02-2025	08:33:00	03-02-2025	16:52:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/375 (409-409 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	01-02-2025	09:25:00	01-02-2025	16:30:00	0.30	0.00	0.00	0.00	7.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/66 (400 - 401Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	13-02-2025	07:48:00	13-02-2025	16:38:00	0.37	0.00	0.00	0.00	8.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2539 (417-418Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	15-02-2025	08:24:00	15-02-2025	17:07:00	0.36	0.00	0.00	0.00	8.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3008(411- 414 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	14-02-2025	09:32:00	14-02-2025	16:32:00	0.29	0.00	0.00	0.00	7.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2792 (399- 399 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	23-02-2025	09:49:00	23-02-2025	15:26:00	0.23	0.00	0.00	0.00	5.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4834 (400 - 403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	21-02-2025	09:05:00	21-02-2025	17:24:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4382 (406-408Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	27-02-2025	08:16:00	27-02-2025	16:16:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5666 (412-414 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	25-02-2025	08:14:00	25-02-2025	17:29:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5238(406 - 409Kv).
							7.00	0.00	0.00	0.00	167.80	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	01-02-2025	00:00:01	08-02-2025	21:25:00	7.89	0.00	0.00	0.00	189.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3760(404 - 404Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	10-02-2025	09:24:00	28-02-2025	23:59:59	18.61	0.00	0.00	0.00	446.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1869 (398 -401 Kv).
							26.50	0.00	0.00	0.00	636.02	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	01-02-2025	07:58:00	01-02-2025	20:10:00	0.51	0.00	0.00	0.00	12.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/38(405- 406Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	12-02-2025	08:38:00	12-02-2025	17:29:00	0.37	0.00	0.00	0.00	8.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2318 (400-401Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	11-02-2025	07:42:00	11-02-2025	18:17:00	0.44	0.00	0.00	0.00	10.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2054 (401 - 404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	13-02-2025	07:48:00	13-02-2025	16:43:00	0.37	0.00	0.00	0.00	8.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2540 (408-409Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	10-02-2025	08:10:00	10-02-2025	17:22:00	0.38	0.00	0.00	0.00	9.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1846 (398 -401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	02-02-2025	09:28:00	02-02-2025	17:07:00	0.32	0.00	0.00	0.00	7.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/229 (397 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	09-02-2025	06:45:00	09-02-2025	16:46:00	0.42	0.00	0.00	0.00	10.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1707 (410-410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	04-02-2025	08:06:00	04-02-2025	16:33:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/581 (401-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	15-02-2025	09:26:00	15-02-2025	19:16:00	0.41	0.00	0.00	0.00	9.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3029(392- 393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	17-02-2025	06:50:00	17-02-2025	16:50:00	0.42	0.00	0.00	0.00	10.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3378(409 - 409Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	14-02-2025	07:25:00	14-02-2025	18:47:00	0.47	0.00	0.00	0.00	11.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2766 (397-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	16-02-2025	07:59:00	16-02-2025	17:24:00	0.39	0.00	0.00	0.00	9.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3225(408 - 408Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	24-02-2025	08:07:00	24-02-2025	20:02:00	0.50	0.00	0.00	0.00	11.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4991(400 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	23-02-2025	09:36:00	23-02-2025	15:31:00	0.25	0.00	0.00	0.00	5.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4814 (392 - 392 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	22-02-2025	07:58:00	22-02-2025	21:30:00	0.56	0.00	0.00	0.00	13.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4591(- 398-401Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	25-02-2025	08:01:00	25-02-2025	22:13:00	0.59	0.00	0.00	0.00	14.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5239(398 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	21-02-2025	08:15:00	21-02-2025	21:45:00	0.56	0.00	0.00	0.00	13.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4360 (402-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	26-02-2025	08:30:00	26-02-2025	17:49:00	0.39	0.00	0.00	0.00	9.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5452 (395-395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	28-02-2025	08:10:00	28-02-2025	23:59:59	0.66	0.00	0.00	0.00	15.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5890 (402-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	18-02-2025	08:12:00	18-02-2025	18:22:00	0.42	0.00	0.00	0.00	10.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3627 (400 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	20-02-2025	08:20:00	20-02-2025	19:28:00	0.46	0.00	0.00	0.00	11.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4109 (400-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	27-02-2025	07:24:00	27-02-2025	21:30:00	0.59	0.00	0.00	0.00	14.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5640 (398 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	19-02-2025	08:32:00	19-02-2025	21:45:00	0.55	0.00	0.00	0.00	13.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3878 (398 -398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	03-02-2025	08:45:00	03-02-2025	17:13:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/376 (400-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	06-02-2025	08:57:00	06-02-2025	21:36:00	0.53	0.00	0.00	0.00	12.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1034 (402-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	07-02-2025	06:48:00	07-02-2025	20:15:00	0.56	0.00	0.00	0.00	13.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1259 (408-410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	05-02-2025	08:09:00	05-02-2025	21:20:00	0.55	0.00	0.00	0.00	13.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/787 (400-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	08-02-2025	07:08:00	08-02-2025	18:10:00	0.46	0.00	0.00	0.00	11.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1507 (405-407Kv).
							12.83	0.00	0.00	0.00	308.11	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SRIPERUMBUDUR	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3374 (402 -402 Kv).
							28.00	0.00	0.00	0.00	672.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TIRUNELVELLI	SVRD	07-02-2025	11:40:00	28-02-2025	23:59:59	21.51	0.00	0.00	0.00	516.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1350 (398-399 Kv).
							21.51	0.00	0.00	0.00	516.33	100.00	
BSR	63MVAR, BUS REACTOR-2 AT TIRUNELVELLI	SVRD	07-02-2025	11:44:00	28-02-2025	23:59:59	21.51	0.00	0.00	0.00	516.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1351 (399-401 Kv).
							21.51	0.00	0.00	0.00	516.27	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TRIVANDRUM	SVRD	05-02-2025	11:33:00	28-02-2025	23:59:59	23.52	0.00	0.00	0.00	564.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/845 (760-768Kv).
							23.52	0.00	0.00	0.00	564.45	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	03-02-2025	08:28:00	03-02-2025	16:46:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/377 (409-409 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	01-02-2025	09:27:00	01-02-2025	16:42:00	0.30	0.00	0.00	0.00	7.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/67 (401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	08-02-2025	09:23:00	08-02-2025	17:35:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1537(403 - 405Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	26-02-2025	09:25:0									

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	28-02-2025	08:08:00	28-02-2025	17:34:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5891 (410-411Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	11-02-2025	08:00:00	11-02-2025	16:38:00	0.36	0.00	0.00	0.00	8.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2070 (417 - 420 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	17-02-2025	07:02:00	17-02-2025	16:48:00	0.41	0.00	0.00	0.00	9.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3379(414 - 414Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	15-02-2025	08:00:00	15-02-2025	17:18:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3009(413- 413 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	16-02-2025	10:26:00	16-02-2025	16:29:00	0.25	0.00	0.00	0.00	6.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3248(406 - 409Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	14-02-2025	10:01:00	14-02-2025	16:43:00	0.28	0.00	0.00	0.00	6.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2793 (402- 402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	13-02-2025	07:51:00	13-02-2025	17:18:00	0.39	0.00	0.00	0.00	9.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2542 (422-422Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	12-02-2025	08:53:00	12-02-2025	16:56:00	0.34	0.00	0.00	0.00	8.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2319 (411-412Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	04-02-2025	08:03:00	04-02-2025	16:24:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/582 (411-412Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	05-02-2025	08:06:00	05-02-2025	16:45:00	0.36	0.00	0.00	0.00	8.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/788 (413-415Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	07-02-2025	07:58:00	07-02-2025	16:37:00	0.36	0.00	0.00	0.00	8.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1274 (415-415 Kv).
							8.12	0.00	0.00	0.00	194.15	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	21-02-2025	09:23:00	21-02-2025	17:35:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4385 (406-406Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	23-02-2025	10:10:00	23-02-2025	17:37:00	0.31	0.00	0.00	0.00	7.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4835 (408 - 411 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	27-02-2025	08:07:00	27-02-2025	16:13:00	0.34	0.00	0.00	0.00	8.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5668 (410-412 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	28-02-2025	08:07:00	28-02-2025	17:37:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5892 (408-409Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	24-02-2025	09:46:00	24-02-2025	17:09:00	0.31	0.00	0.00	0.00	7.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5026(401 - 404Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	25-02-2025	08:22:00	25-02-2025	17:27:00	0.38	0.00	0.00	0.00	9.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5240(409 - 412Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	17-02-2025	07:02:00	17-02-2025	16:44:00	0.40	0.00	0.00	0.00	9.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3380(414 - 416Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	12-02-2025	08:55:00	12-02-2025	16:54:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2320 (412-412Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	13-02-2025	07:53:00	13-02-2025	17:13:00	0.39	0.00	0.00	0.00	9.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2542 (422-422Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	10-02-2025	09:29:00	10-02-2025	17:29:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1865 (400 -403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	11-02-2025	08:02:00	11-02-2025	16:35:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2071 (419 - 419 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	04-02-2025	11:37:00	04-02-2025	16:26:00	0.20	0.00	0.00	0.00	4.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/621 (400-402Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	07-02-2025	08:00:00	07-02-2025	16:40:00	0.36	0.00	0.00	0.00	8.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1275 (415-419 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	05-02-2025	09:22:00	05-02-2025	16:54:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/830 (404-405Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	16-02-2025	10:26:00	16-02-2025	16:31:00	0.25	0.00	0.00	0.00	6.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3249(406 - 406Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	01-02-2025	09:29:00	01-02-2025	16:49:00	0.31	0.00	0.00	0.00	7.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/168 (401 - 403Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	06-02-2025	08:16:00	06-02-2025	17:21:00	0.38	0.00	0.00	0.00	9.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1036 (411-411 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	26-02-2025	09:26:00	26-02-2025	17:27:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5474 (400-402 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	14-02-2025	10:03:00	14-02-2025	16:39:00	0.28	0.00	0.00	0.00	6.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2794 (402- 405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	15-02-2025	08:07:00	15-02-2025	17:22:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3010 (413- 413 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	18-02-2025	08:17:00	18-02-2025	17:56:00	0.40	0.00	0.00	0.00	9.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3629 (413 -410 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	19-02-2025	08:40:00	19-02-2025	16:39:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3880 (410 -413 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	20-02-2025	08:13:00	20-02-2025	17:22:00	0.38	0.00	0.00	0.00	9.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4111 (410-412Kv).
							7.81	0.00	0.00	0.00	187.43	100.00	
BSR	63MVAR, BUS REACTOR AT TUTICORIN PS	SVRD	07-02-2025	11:55:00	28-02-2025	23:59:59	21.50	0.00	0.00	0.00	516.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1349(400-402 Kv).
							21.50	0.00	0.00	0.00	516.08	100.00	
BSR	PUGALUR-1 LINE REACTOR 63MVAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	20-02-2025	09:19:00	21-02-2025	21:46:00	1.52	0.00	0.00	0.00	36.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4129 (761-764Kv).
							1.52	0.00	0.00	0.00	36.45	100.00	
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	20-02-2025	09:30:00	26-02-2025	21:48:00	6.51	0.00	0.00	0.00	156.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4134 (764-767Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	05-02-2025	10:18:00	08-02-2025	20:17:00	3.42	0.00	0.00	0.00	81.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/845 (760-768Kv).
							9.93	0.00	0.00	0.00	238.28	100.00	
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	07-02-2025	06:41:00	07-02-2025	16:28:00	0.41	0.00	0.00	0.00	9.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1261 (412-412 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	01-02-2025	09:03:00	01-02-2025	23:00:00	0.58	0.00	0.00	0.00	13.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/59 (401 - 401Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	03-02-2025	08:51:00	03-02-2025	16:40:00	0.33	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/379 (404-404 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	11-02-2025	07:47:00	11-02-2025	16:39:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2056 (406 - 408 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	13-02-2025	07:29:00	13-02-2025	16:36:00	0.38	0.00	0.00	0.00	9.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2544 (405-407Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	17-02-2025	06:48:00	17-02-2025	16:47:00	0.42	0.00	0.00	0.00	9.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3382(410 - 412Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	05-02-2025	08:09:00	05-02-2025	16:40:00	0.36	0.00	0.00	0.00	8.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/790 (404-405Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	10-02-2025	08:13:00	10-02-2025	17:31:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1848 (403 -405 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	02-02-2025	09:32:00	02-02-2025	16:55:00	0.31	0.00	0.00	0.00	7.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/231 (401 - 401Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	08-02-2025	09:28:00	08-02-2025	17:43:00	0.34	0.00	0.00	0.00	8.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1539(398 - 398Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	06-02-2025	08:09:00	06-02-2025	21:41:00	0.56	0.00	0.00	0.00	13.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1038 (403-403 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	20-02-2025	08:07:00	20-02-2025	17:22:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4113 (401-401Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	14-02-2025	07:31:00	14-02-2025	16:48:00	0.39	0.00	0.00	0.00	9.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2788 (405-406 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	23-02-2025	09:10:00	23-02-2025	15:19:00	0.26	0.00	0.00	0.00	6.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4816 (395-395 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	18-02-2025	07:59:00	18-02-2025	17:57:00	0.42	0.00	0.00	0.00	9.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3631 (401 -402 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	19-02-2025	06:58:00	19-02-2025	17:03:00	0.42	0.00	0.00	0.00	10.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3840(403 -403 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	22-02-2025	08:19:00	22-02-2025	21:32:00	0.55	0.00	0.00	0.00	13.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4599(399 - 399Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	27-02-2025	07:28:00	28-02-2025	17:11:00	1.41	0.00	0.00	0.00	33.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5642 (402 - 402Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	24-02-2025	08:13:00	25-02-2025	21:03:00	1.54	0.00	0.00	0.00	36.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4993(401 - 402Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	21-02-2025	08:12:00	21-02-2025	17:21:00	0.38	0.00	0.00	0.00	9.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4362 (402-403Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	26-02-2025	08:23:00	26-02-2025	17:32:00	0.38	0.00	0.00	0.00	9.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5454 (395-397 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	16-02-2025	08:01:00	16-02-2025	16:09:0							

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	21-02-2025	08:15:00	21-02-2025	17:25:00	0.38	0.00	0.00	0.00	9.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4363 (403-404Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	16-02-2025	08:05:00	16-02-2025	16:06:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3228(412 - 414Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	04-02-2025	08:07:00	04-02-2025	16:25:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/585 (403-405Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	17-02-2025	06:51:00	17-02-2025	17:00:00	0.42	0.00	0.00	0.00	10.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3383(412 - 412Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	07-02-2025	08:09:00	07-02-2025	16:31:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1276 (409-409 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	15-02-2025	09:33:00	15-02-2025	20:22:00	0.45	0.00	0.00	0.00	10.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3030(396- 396 Kv)
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	20-02-2025	08:15:00	20-02-2025	17:27:00	0.38	0.00	0.00	0.00	9.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4114 (401-402Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	06-02-2025	08:19:00	06-02-2025	21:48:00	0.56	0.00	0.00	0.00	13.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1039 (403-406 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	01-02-2025	09:08:00	02-02-2025	16:53:00	1.32	0.00	0.00	0.00	31.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/60 (401 - 401Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	05-02-2025	08:11:00	05-02-2025	20:52:00	0.53	0.00	0.00	0.00	12.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/791 (405-405Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	13-02-2025	07:31:00	14-02-2025	16:51:00	1.39	0.00	0.00	0.00	33.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2545 (407-407Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	03-02-2025	08:54:00	03-02-2025	16:43:00	0.33	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/380 (404-407 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	11-02-2025	07:50:00	11-02-2025	16:42:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2057 (408 - 408 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	08-02-2025	09:32:00	08-02-2025	17:46:00	0.34	0.00	0.00	0.00	8.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1540(398 - 398Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	10-02-2025	08:17:00	10-02-2025	17:37:00	0.39	0.00	0.00	0.00	9.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1849 (405-406 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	12-02-2025	08:45:00	12-02-2025	17:31:00	0.37	0.00	0.00	0.00	8.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2323 (404-405Kv).
							13.66	0.00	0.00	0.00	327.86	100.00	
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	03-02-2025	08:48:00	03-02-2025	16:35:00	0.32	0.00	0.00	0.00	7.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/378 (404-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	11-02-2025	07:44:00	11-02-2025	16:37:00	0.37	0.00	0.00	0.00	8.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2055 (402 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	10-02-2025	08:09:00	10-02-2025	17:25:00	0.39	0.00	0.00	0.00	9.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1587 (401 -403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	01-02-2025	08:58:00	01-02-2025	22:56:00	0.58	0.00	0.00	0.00	13.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/58 (399 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	05-02-2025	08:05:00	05-02-2025	16:35:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/789 (404-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	07-02-2025	06:38:00	07-02-2025	16:26:00	0.41	0.00	0.00	0.00	9.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1260 (410-412 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	04-02-2025	08:01:00	04-02-2025	16:21:00	0.35	0.00	0.00	0.00	8.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/583 (403-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	06-02-2025	08:05:00	06-02-2025	17:19:00	0.39	0.00	0.00	0.00	9.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1037 (403-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	12-02-2025	08:34:00	12-02-2025	17:12:00	0.36	0.00	0.00	0.00	8.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2321 (403-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	02-02-2025	09:28:00	02-02-2025	17:00:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/230 (399 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	08-02-2025	09:25:00	08-02-2025	17:41:00	0.34	0.00	0.00	0.00	8.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1538(395 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	26-02-2025	08:20:00	26-02-2025	17:19:00	0.37	0.00	0.00	0.00	8.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5443 (395-395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	23-02-2025	09:01:00	23-02-2025	15:16:00	0.26	0.00	0.00	0.00	6.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/9815 (397-395) Kv.
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	20-02-2025	08:03:00	20-02-2025	17:18:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4112 (400-400Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	18-02-2025	07:55:00	18-02-2025	17:52:00	0.42	0.00	0.00	0.00	9.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3630 (400 -401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	19-02-2025	06:54:00	19-02-2025	16:58:00	0.42	0.00	0.00	0.00	10.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3839(403 -403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	28-02-2025	08:04:00	28-02-2025	17:05:00	0.38	0.00	0.00	0.00	9.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5893 (401-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	27-02-2025	07:26:00	27-02-2025	21:25:00	0.58	0.00	0.00	0.00	13.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5641 (399 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	21-02-2025	08:03:00	21-02-2025	17:14:00	0.38	0.00	0.00	0.00	9.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4361 (402-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	24-02-2025	08:09:00	24-02-2025	16:57:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4992(400 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	25-02-2025	08:18:00	25-02-2025	20:55:00	0.53	0.00	0.00	0.00	12.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5241(399 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	22-02-2025	08:15:00	22-02-2025	21:29:00	0.55	0.00	0.00	0.00	13.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4598(399 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	16-02-2025	07:57:00	16-02-2025	16:03:00	0.34	0.00	0.00	0.00	8.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3226(409 - 410Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	14-02-2025	07:20:00	14-02-2025	17:10:00	0.41	0.00	0.00	0.00	9.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2767 (403-403 KV).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	17-02-2025	06:45:00	17-02-2025	16:44:00	0.42	0.00	0.00	0.00	9.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3381(410 - 410Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	15-02-2025	08:36:00	15-02-2025	17:11:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3016(402- 402 KV).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	13-02-2025	07:26:00	13-02-2025	16:31:00	0.38	0.00	0.00	0.00	9.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/2543 (402-405Kv).
							10.73	0.00	0.00	0.00	257.09	100.00	
CKT	230kV BHAVINI-ARANI(TANTRANSCO)-1	OSPD	07-02-2025	08:39:00	07-02-2025	20:15:00	0.48	0.00	0.00	0.00	11.60		* Shut down availed by BHAVINI for Relay calibration <>&<-> testing vide SRLDC CR.02/1278. Opp shutdown availed by KVPT TLM ,TVLM SS <->&<-> TLM for maintenance works.
							0.48	0.00	0.00	0.00	11.60	100.00	
CKT	230kV BHAVINI-ARANI(TANTRANSCO)-2	OSPD	10-02-2025	08:53:00	10-02-2025	20:10:00	0.47	0.00	0.00	0.00	11.28		* Shutdown availed by Bhavini for relay calibration and testing works vide code CR-02/1859.
							0.47	0.00	0.00	0.00	11.28	100.00	
CKT	230kV BHAVINI-KANCHIPURAM(TANTRANSCO)-1	OSPD	03-02-2025	09:07:00	04-02-2025	19:28:00	1.43	0.00	0.00	0.00	34.35		* Shutdown availed by Bhavini for relay calibration and testing works vide code CR-02/385
							1.43	0.00	0.00	0.00	34.35	100.00	
CKT	230kV BHAVINI-KANCHIPURAM(TANTRANSCO)-2	OSPD	05-02-2025	09:29:00	06-02-2025	18:54:00	1.39	0.00	0.00	0.00	33.42		* Shutdown availed by Bhavini for relay calibration <->&<-> relay testing works
							1.39	0.00	0.00	0.00	33.42	100.00	
CKT	230 KV-BHAVINI-SIRUSERI-1	OSPD	01-02-2025	16:56:00	01-02-2025	20:24:00	0.14	0.00	0.00	0.00	3.47		* Emergency shutdown availed by Siruseri for attending hotspot in Yph Isolator of Bus coupler vide code CR-01/118.
							0.14	0.00	0.00	0.00	3.47	100.00	
CKT	230 KV-BHAVINI-SIRUSERI-2	OSPD	01-02-2025	16:56:00	01-02-2025	20:24:00	0.14	0.00	0.00	0.00	3.47		* Emergency shutdown availed by Siruseri for attending hotspot in Yph Isolator of Bus coupler vide code CR-01/118.
							0.14	0.00	0.00	0.00	3.47	100.00	
CKT	220kV EDAPPON(KSEB)-EDAMON(KSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV KARAikal(PED)-BAHOUR(PED)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KUNDRa(KSEB)-EDAMON(KSEB)	OSPD	03-02-2025	08:20:00	03-02-2025	18:32:00	0.43	0.00	0.00	0.00	10.20		* Shutdown availed by KSEB for relay setting modification vide code CR-02/355
							0.43	0.00	0.00	0.00	10.20	100.00	
CKT	220kV KAYAMKULAM(KSEB)-EDAPPON(KSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAYAMKULAM(KSEB)-KUNDRa(KSEB)	OSPD	04-02-2025	09:11:00	04-02-2025	17:41:00	0.35	0.00	0.00	0.00	8.50		* Shutdown availed by KSEB for Modification of relay setting.
							0.35	0.00	0.00	0.00	8.50	100.00	
CKT	220kV KAYAMKULAM(KSEB)-POLLAM(KSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAYAMKULAM(KSEB)-PUNNAPRA(KSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV NEYVELI(NLC)-KARAikal(PED)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV NEYVELI(NLC)-VILLIANUR(PED)-1	LPRD	19-02-2025	10:29:00	28-02-2025	23:59:59	9.56	0.0					

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	230kV NEYVELI(NLC)-VILLIANUR(PED)-1	LCSD	21-02-2025	10:29:00	28-02-2025	20:46:00	7.43	0.00	0.00	0.00	178.28		* Shutdown availed for NHAI Diversion works vide SRLDC code: 02/4401
CKT	230kV NEYVELI(NLC)-VILLIANUR(PED)-1	LPRD	01-02-2025	00:00:01	11-02-2025	09:41:00	10.40	0.00	0.00	0.00	249.68		* Hand tripped from Neyveli end only as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 01/66
							27.53	0.00	0.00	0.00	660.71	100.00	
CKT	220kV PUNNAPRA(KSEB)-POLLAM(KSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV TIRUNELVELI-EDAMON(KSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV TIRUNELVELI-EDAMON(KSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV ALMATY-TIRUVALAM-1	OMSU	28-02-2025	11:12:00	28-02-2025	11:12:00	0.00	0.00	0.00	0.00	0.00		* Line Autoreclose Successful on B Phase to Ground Fault. Almaty end details: M1: 52.3KMS/5.6KA, M2: 63KMS/5.5KA, Thiruvallam end details: M1: 62.8KMS/ 5.16KA, M2: 55.8KMS/ 4.9KA, Fault is in TANTRANSCO Jurisdiction.
CKT	400 KV ALMATY-TIRUVALAM-1	OMSU	20-02-2025	12:30:00	20-02-2025	12:30:00	0.00	0.00	0.00	0.00	0.00		* Auto reclosed successfully on B-N (Ph-earth) transient fault. Fault details:- Almaty End: M1/M2 FLR: 53.93/70.1 km FC: 5.377/5.340 Kamps Thiruvallam End: M1/M2 FLR: 63.7/58.42 KM, FC:4.906/4.977 Kamps.Fault is in TANTRANSCO jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV ALMATY-TIRUVALAM-2	OSPD	26-02-2025	09:16:00	26-02-2025	16:49:00	0.32	0.00	0.00	0.00	7.55		* Shutdown availed by TANTRANSCO for Bimonthly mainatance works vide SRLDC code no. CR- 02/5469.
							0.32	0.00	0.00	0.00	7.55	100.00	
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(NTECL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(NTECL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHITTOOR(APTRANSCO)-SRIPERUMBUDUR	OSPD	09-02-2025	10:06:00	09-02-2025	18:31:00	0.35	0.00	0.00	0.00	8.42		* Shut down availed by Chittoor vide SRLDC code no. CR-01/1731
							0.35	0.00	0.00	0.00	8.42	100.00	
CKT	400kV GOOTY-SOMANAHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-TALAGUPPA(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HOSUR-SALEM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HOSUR-SALEM-2	LCSD	07-02-2025	09:15:00	08-02-2025	18:59:00	1.41	0.00	0.00	0.00	33.73		* Shutdown availed for replacement of 402 <(> & <(> 403 Bay CT MB boxes <(> & <(> CT interpole cable laying under ADD CAP works at Salem SS vide SRLDC CR.02/1305. Opp Shutdown availed by Hosur SS, Dharmapur <(> & <(> Hosur TLM.
							1.41	0.00	0.00	0.00	33.73	100.00	
CKT	400kV KAIGA(NPCIL)-NARENDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-NARENDRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OMSU	18-02-2025	04:54:00	19-02-2025	13:38:00	1.36	0.00	32.73	0.00	0.00		* Line tripped on R -Y fault. Kaiga end details: M1: FLR: 93.1 KM, FC: 2.9(R-ph) K&Amps, M2: FLR: 127.5 KM, FC: 3.24/3.26 K&Amps. Guttur end details:M1: FLR: 90.87 KM, FC:8.14/8.19 K&Amps, M2: FLR: 90.87 KM, FC: 7.44/8.13 K&Amps.Fault is in KPTCL Jurisdiction.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OMSU	22-02-2025	10:35:00	22-02-2025	16:40:00	0.25	0.00	6.08	0.00	0.00		* Line tripped on R and B-phase TEE-1 protection at Kaiga end and without any indication at Guttur end.
							1.61	0.00	38.81	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	18-02-2025	04:54:00	18-02-2025	21:12:00	0.68	0.00	16.30	0.00	0.00		* Line tripped on B -G fault. KAIGA end details: M1: FLR: 122 KM, FC: 2.44 K&Amps, M2: FLR: 127.3 KM, FC: 2.49 K&Amps. Guttur end details:M1: FLR: NR KM, FC:7.55 K&Amps, M2: FLR: 23 KM, FC: 7.7 K&Amps* Fault is in KPTCL Jurisdiction.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	21-02-2025	05:21:00	21-02-2025	12:36:00	0.30	0.00	7.25	0.00	0.00		* Line tripped on B phase to Ground fault. Kaiga end details: M1: 120kms/2.3KA, M2: NR, Sirsi end details: M1: 66.8KMS/5.6KA
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OSPD	05-02-2025	12:30:00	05-02-2025	22:27:00	0.42	0.00	0.00	0.00	9.95		* Shutdown availed by KPTCL vide SRLDC code: 02/850
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OSPD	19-02-2025	08:59:00	19-02-2025	14:08:00	0.22	0.00	0.00	0.00	5.15		* Emergency shutdown availed by KPTCL for attending fault (between tower location 115-116) in 400kV Kaiga-Guttur circuit-1 vide code CR-02/3882.
							1.62	0.00	23.55	0.00	15.10	100.00	
CKT	400kV KARAUKUDI-MADURAI	LCSD	23-02-2025	08:26:00	24-02-2025	18:21:00	1.41	0.00	0.00	0.00	33.92		* Line Shut down availed for Construction works: Replacement of 404 Bay <(> & <(> 405 Bay CT MB boxes and interpole CT cables and Testing under Add cap works at Madurai SS vide SRLDC code no. CR-02/4797
							1.41	0.00	0.00	0.00	33.92	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-3	OSPD	06-02-2025	08:17:00	06-02-2025	17:55:00	0.40	0.00	0.00	0.00	9.63		* Shut down availed by NPCIL for terminal equipment maint works vide SRLDC CR.02/1041.* Opp shutdown availed by Tirunelveli TLM <(> & <(> SS for maint works.
							0.40	0.00	0.00	0.00	9.63	100.00	
CKT	400KV-KOCHI-KOTTAYAM-1	OSPD	11-02-2025	08:50:00	11-02-2025	18:16:00	0.39	0.00	0.00	0.00	9.43		* Shutdown availed by KSEB for routine maintenance works vide code CR-02/2078.
							0.39	0.00	0.00	0.00	9.43	100.00	
CKT	400KV-KOCHI-KOTTAYAM-2	OSPD	13-02-2025	09:11:00	13-02-2025	18:41:00	0.40	0.00	0.00	0.00	9.50		* Shutdown availed by KSEB for routine maintenance works
							0.40	0.00	0.00	0.00	9.50	100.00	
CKT	400kV KOLAR-HOODY(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-HOODY(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-HOSUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-HOSUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-MYLASANDRA (KPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-THIRUVALAM-1	LMAC	22-02-2025	12:11:00	22-02-2025	12:44:00	0.02	0.00	0.00	0.55	0.00		* "Line tripped on R -G fault." Kolar end details: M1: FLR: 35.14 KM, FC: 6.40 K&Amps, M2: Not recorded.* Sriperumbudur end details:M1: FLR: 202.2 KM, FC: 1.5 K&Amps, M2: FLR: 206.4 KM, FC: 1.58 K&Amps* Fault is in Kolar TLM Jurisdiction."

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.02	0.00	0.00	0.55	0.00	100.00	
CKT	400kV KUDGI GIS-NARENDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDGI GIS-NARENDRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NP KUNTA-KOLAR	LEFT	07-02-2025	20:16:00	07-02-2025	21:32:00	0.05	1.27	0.00	0.00	0.00		* Line tripped on Y -G fault. KOLAR end details: M1: FLR: 115.1 KM, FC: 2.99 Kamps, M2: FLR: N/R KM, FC: 3.01 Kamps. NP KUNTA end details:M1: FLR: 15.65 KM, FC:12.47 Kamps, M2: FLR: 15.70 KM, FC: 12.56 Kamps* Fault is in SR-I Jurisdiction.
							0.05	1.27	0.00	0.00	0.00	99.81	
CKT	400kV MADURAI-PUGALUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-PUGALUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TIRUNELVELI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TIRUNELVELI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TUTICORIN PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TUTICORIN PS-2	LPRD	24-02-2025	14:28:00	24-02-2025	17:00:00	0.11	0.00	0.00	0.00	2.53		* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 02/5060 (520.520 to 741, 0 MW).
CKT	400kV MADURAI-TUTICORIN PS-2	LPRD	09-02-2025	13:04:00	09-02-2025	17:23:00	0.18	0.00	0.00	0.00	4.32		* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 02/1735.
							0.29	0.00	0.00	0.00	6.85	100.00	
CKT	400kV UDUMALPET-MADURAI	SCSD	05-02-2025	09:52:00	06-02-2025	19:39:00	1.41	0.00	0.00	0.00	33.78		* Shutdown availed for replacement of 401 bay <(> 402 bay CT MB boxes and interpolate CT cables
							1.41	0.00	0.00	0.00	33.78	100.00	
CKT	400kV MYSORE-HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-KOZHICODE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-KOZHICODE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELLI TS2-NEYVELLI TS1 EXP			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELLI TS2(NLC)-KARUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELLI TS2 EXP(NLC) EXP-KARUR	OSPD	08-02-2025	07:19:00	08-02-2025	18:35:00	0.47	0.00	0.00	0.00	11.27		* Shutdown availed by NLC vide SRLDC code: 02/1490
							0.47	0.00	0.00	0.00	11.27	100.00	
CKT	400kV NEYVELLI(NLC)-SALEM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGAPATTINAM-NEYVELLI TS1(NLC) EXP			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGAPATTINAM-NEYVELLI TS2(NLC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	18-02-2025	07:09:00	18-02-2025	20:27:00	0.55	0.00	0.00	0.00	13.30		* Shutdown availed by KPTCL for maintenance works vide code CR-02/3596.
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	20-02-2025	07:20:00	20-02-2025	19:35:00	0.51	0.00	0.00	0.00	12.25		* Shut down availed by KPTCL for insulator replacement works vide SRLDC code no. CR-01/4088
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	23-02-2025	06:53:00	23-02-2025	22:16:00	0.84	0.00	0.00	0.00	15.38		* Shutdown availed by KPTCL for replacement of defective insulators in the line vide SRLDC code: 02/4777
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	28-02-2025	06:37:00	28-02-2025	19:47:00	0.55	0.00	0.00	0.00	13.17		* Shutdown availed by KPTCL for insulator replacement work vide SRLDC code CR-02/5844
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	27-02-2025	06:23:00	27-02-2025	18:35:00	0.51	0.00	0.00	0.00	12.20		* Shutdown availed by KPTCL for replacement of insulator string in line vide SRLDC code CR-02/5617
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	25-02-2025	07:07:00	25-02-2025	19:19:00	0.51	0.00	0.00	0.00	12.20		* Shutdown availed by KPTCL for replacement of defective insulators in the line vide SRLDC code: 02/5208
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	26-02-2025	06:49:00	26-02-2025	20:38:00	0.58	0.00	0.00	0.00	13.82		* Shut down availed by KPTCL for defective insulator replacement works in their portion of the line vide SRLDC code no. CR-02/5425.
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	24-02-2025	06:27:00	24-02-2025	21:27:00	0.63	0.00	0.00	0.00	15.00		* Shutdown availed by KPTCL for replacement of defective insulators in the line vide SRLDC code: 02/4954
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	22-02-2025	06:28:00	22-02-2025	19:19:00	0.54	0.00	0.00	0.00	12.85		* Shut down availed by KPTCL for defective Insulators replacement works vide SRLDC code no. CR- 02/ 4562.
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	21-02-2025	06:44:00	21-02-2025	19:44:00	0.54	0.00	0.00	0.00	13.00		* Shutdown availed by KPTCL for defective Insulators replacement vide SRLDC code no. CR- 02/ 4347.
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	16-02-2025	06:48:00	16-02-2025	21:08:00	0.60	0.00	0.00	0.00	14.33		* Shut down availed by KPTCL for insulator replacement works vide SRLDC code no. CR-01/3202
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	17-02-2025	06:57:00	17-02-2025	18:51:00	0.50	0.00	0.00	0.00	11.90		* Shut down availed by KPTCL for insulator replaement works vide SRLDC code no. CR-01/3389
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	11-02-2025	17:52:00	11-02-2025	19:56:00	0.09	0.00	0.00	0.00	2.07		* Emergency Shut down availed by KPTCL for Line safety clearance during works in KPTCL line Talguppa- Neelmangla vide SRLDC code no. CR-02/2208.
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OSPD	19-02-2025	06:39:00	19-02-2025	20:07:00	0.56	0.00	0.00	0.00	13.47		* Shutdown availed by KPTCL for replacement of insulator string in line vide SRLDC code CR-02/3817.
							7.31	0.00	0.00	0.00	174.94	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-PUDUCHERRY-1	OSPD	01-02-2025	00:00:01	06-02-2025	20:20:00	5.85	0.00	0.00	0.00	140.33		* Shut down availed for NHA1 diversion works vide SRLDC code no. CR-01/3991.
							5.85	0.00	0.00	0.00	140.33	100.00	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-1	OSPT	12-02-2025	10:20:00	12-02-2025	10:34:00	0.01	0.23	0.00	0.00	0.00		* Emergency Hand tripped vide SRLDC code: 02/2354
							0.01	0.23	0.00	0.00	0.00	99.97	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-ARASUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-ARASUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PALAKKAD-TRICHUR-1	LCSD	14-02-2025	08:35:00	15-02-2025	19:09:00	1.44	0.00	0.00	0.00	34.57		* Shut down availed for Construction Works: Replacement of 402 Bay <(>&<)> 403Bay CT MB boxes and interpolate CT cables and Testing under Add cap works at Trichur SS vide SRLDC code no. CR-02/2778.
							1.44	0.00	0.00	0.00	34.57	100.00	
CKT	400kV PALAKKAD-TRICHUR-2	LCSD	18-02-2025	08:24:00	19-02-2025	19:49:00	1.48	0.00	0.00	0.00	35.42		* Shutdown availed for Construction:For replacement of Bay CT MB boxes and interpolate cabling works at Thrissur SS under ADDCAP vide code CR-02/3634.
							1.48	0.00	0.00	0.00	35.42	100.00	
CKT	400kV PUDUCHERRY-SVCHATRAM(TANTRANSCO)-1	OMSU	16-02-2025	13:33:00	16-02-2025	17:43:00	0.17	0.00	4.17	0.00	0.00		* Line tripped on B -G fault. Puducherry end details: M1: FLR: 132.61 KM, FC: 2.16 Kamps, M2: FLR: 134.6 KM, FC: 2.05 Kamps. SV CHATRAM end details:M1: FLR: 4.6 KM, FC:18.76 Kamps, M2: FLR: 4.6 KM, FC: 18.76 Kamps. Fault is in TANTRANSCO Jurisdiction.
CKT	400kV PUDUCHERRY-SVCHATRAM(TANTRANSCO)-1	OMSU	16-02-2025	11:57:00	16-02-2025	12:33:00	0.03	0.00	0.60	0.00	0.00		* Line autoreclosed at Puducherry end <(>&<)> tripped at SV Chatram end on B-G fault. Puducherry end details: M1: FLR: 134.1 KM, FC: 2.08 Kamps, M2: FLR: 135 KM, FC: 2.31 Kamps. SV Chatram end details:M1: FLR: 5 KM, FC: 1.88 Kamps, M2: NR. Fault is in TNEB Jurisdiction.
							0.20	0.00	4.77	0.00	0.00	100.00	
CKT	400kV PUGALUR HVAC-KARUR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR HVAC-KARUR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV PAVAGADA-DEVANAHALLI(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV PAVAGADA-DEVANAHALLI(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-HIRIYUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	16-02-2025	20:26:00	17-02-2025	09:11:00	0.53	0.00	0.00	0.00	12.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3337 (425 -423 Kv).
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	08-02-2025	20:23:00	10-02-2025	08:41:00	1.51	0.00	0.00	0.00	36.30		* Line kept open as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1670 (421-419KV)
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	01-02-2025	00:00:01	03-02-2025	08:27:00	2.35	0.00	0.00	0.00	56.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5187(423 - 421Kv).
							4.39	0.00	0.00	0.00	105.50	100.00	
CKT	400kV PAVAGADA-TUMKUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-DHARMAPURI-1	OSPT	28-02-2025	09:17:00	28-02-2025	14:30:00	0.22	5.22	0.00	0.00	0.00		* Shutdown availed for AMP works of Terminal equipments and to attend shutdown nature defects in the line.
							0.22	5.22	0.00	0.00	0.00	99.22	
CKT	400kV SALEM-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SALEM-NNTPS(NLC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-UDUMALPET-2	OSPT	11-02-2025	09:36:00	11-02-2025	16:01:00	0.27	6.42	0.00	0.00	0.00		* Shutdown availed for AMP works and for attending shutdown nature defects in the line vide code CR-02/2095.
							0.27	6.42	0.00	0.00	0.00	99.05	
CKT	400KV-SOMANHALLI-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANHALLI-BIDADI-2	LMAC	15-02-2025	17:21:00	15-02-2025	19:35:00	0.09	0.00	0.00	2.23	0.00		* Line tripped on Y-B fault. Bidadi end details: M1: FLR: 7.4 KM, FC: IY-17.22, IB-17.01 Kamps, M2: FLR: 7.69 KM, FC: IY-16.21, IB-16.12 Kamps. Somanahalli end details:M1: FLR: 8.974 KM, FC: IY-13.15, IB-13.29 Kamps, M2: FLR: 8.2 KM, FC: IY-12.3, IB-12.43 Kamps* Fault is in Somanahalli TLM Jurisdiction.
							0.09	0.00	0.00	2.23	0.00	100.00	
CKT	400kV SOMANHALLI-DHARMAPURI-1	LMAC	15-02-2025	12:31:00	15-02-2025	14:38:00	0.09	0.00	0.00	2.12	0.00		* Line tripped on Y-G fault. Somanahalli end details: M1: FLR: 7.52 KM, FC: 4.8 Kamps, M2: FLR: 6.38 KM, FC: 5.39 Kamps. Dharmapuri end details:M1: FLR: 114.5 KM, FC: 1.979 Kamps, M2: FLR: 119.3 KM, FC: 1.939 Kamps. Fault is in Somanahalli TLM Jurisdiction.
CKT	400kV SOMANHALLI-DHARMAPURI-1	LART	15-02-2025	12:29:00	15-02-2025	12:29:00	0.00	0.00	0.00	0.00	0.00		* Line auto reclosed successfully on Y-G fault. Somanahalli end details: M1: FLR: 6.3 KM, FC: 0.89 Kamps, M2: FLR: 7.5 KM, FC: 0.96 Kamps. Dharmapuri end details:M1:NR. Fault is in Somanahalli TLM Jurisdiction.
							0.09	0.00	0.00	2.12	0.00	100.00	
CKT	400kV SOMANHALLI-DHARMAPURI-2	LART	15-02-2025	12:29:00	15-02-2025	12:29:00	0.00	0.00	0.00	0.00	0.00		* Line auto reclosed successfully on Y-G fault. Somanahalli end details: M1: FLR: 8.27 KM, FC: 5.49 Kamps, M2: FLR: 7.5 KM, FC: 5.5 Kamps. Dharmapuri end details:M1: FLR: 101.5 KM, FC: 1.525 Kamps, M2: FLR: NR, FC: 1.554 Kamps. Fault is in Somanahalli TLM Jurisdiction.
CKT	400kV SOMANHALLI-DHARMAPURI-2	LMAC	15-02-2025	12:30:00	15-02-2025	14:41:00	0.09	0.00	0.00	2.18	0.00		* Line tripped on Y-G fault. Somanahalli end details: M1: FLR: 7.59 KM, FC: 5.925 Kamps, M2: FLR: 7.529 KM, FC: 5.76 Kamps. Dharmapuri end details:M1: FLR: 86.03 KM, FC: 3.70 Kamps, M2: FLR: NR, FC: 1.554 Kamps. Fault is in Somanahalli TLM Jurisdiction.

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.09	0.00	0.00	2.18	0.00	100.00	
CKT	400kV SOMANAHALLI-HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-SOMANHALLI-MYLASANDRA-1	OSPD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Shut down availed by KPTCL for construction and commissioning of Dommasandra substation vide SRLDC code CR.12/283.
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	400kV SVCHATRM(TANTRANSCO)-SRIPERMBUDR-1	LCSD	27-02-2025	09:17:00	28-02-2025	19:55:00	1.44	0.00	0.00	0.00	34.63		* Shutdown availed for replacement of 408 <(>&<)> 409 Bay CT MB boxes, Interpole CT cables and testing under ADD Cap works vide SRLDC code no. CR- 02/5680.
							1.44	0.00	0.00	0.00	34.63	100.00	
CKT	400kV TRICHUR HVDC-KOCHI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-KOCHI-2	LMAC	28-02-2025	17:11:00	28-02-2025	18:35:00	0.06	0.00	0.00	1.40	0.00		* Line tripped on B -G fault. Thrissur end details: M1: FLR: 15.3 KM, FC: 3.93 Kamps, M2: FLR: 14.37 KM, FC: 3.94 Kamps. Kochi end details:M1: FLR: 54.9 KM, FC: 3.37 Kamps, M2: FLR: 61.64 KM, FC: 5.09 Kamps* Fault is in Thrissur HVDC TLM Jurisdiction.
							0.06	0.00	0.00	1.40	0.00	100.00	
CKT	400kV TRICHUR HVDC-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV THIRUNELVELI-KOTTAYAM-1	OSPD	01-02-2025	09:29:00	01-02-2025	19:40:00	0.42	0.00	0.00	0.00	10.18		* Shut down availed by KSEB for AMP works vide SRLDC code no. CR-01/64.
							0.42	0.00	0.00	0.00	10.18	100.00	
CKT	400kV THIRUNELVELI-KOTTAYAM-2	OSPD	07-02-2025	10:03:00	07-02-2025	19:21:00	0.39	0.00	0.00	0.00	9.30		* Shutdown availed by KSEB vide SRLDC CR.02/1323. Opp Shutdown availed by Tirunelveli SS <(>&<)> TLM, Kochi TLM <(>&<)> Trivendrum TLM.
							0.39	0.00	0.00	0.00	9.30	100.00	
CKT	400kV TIRUNELVELI-TRIVANDRUM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TRIVANDRUM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TUTICORIN PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-UDUMALPET-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-KARAIKUDI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-MADURAI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-NAGAPATTANAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-NAGAPATTANAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-KALVINDAPATTU-1	OSPT	20-02-2025	10:03:00	20-02-2025	14:39:00	0.19	4.60	0.00	0.00	0.00		* Shutdown availed for AMP works and attending shutdown nature defects in the line
							0.19	4.60	0.00	0.00	0.00	99.32	
CKT	400kV TIRUVALAM-KALVINDAPATTU-2	OSPT	21-02-2025	10:01:00	21-02-2025	14:31:00	0.19	4.50	0.00	0.00	0.00		* Shutdown availed for AMP Works and attending shutdown nature defects in the line
							0.19	4.50	0.00	0.00	0.00	99.33	
CKT	400kV TIRUVALAM-SRIPERUMDUR-1	LMAC	22-02-2025	12:11:00	22-02-2025	12:44:00	0.02	0.00	0.00	0.55	0.00		* "Line tripped on R -G fault.* Kolar end details: M1: FLR: 35.14 KM, FC: 6.40 Kamps, M2: Not recorded.* Sriperumbudur end details:M1: FLR: 202.2 KM, FC: 1.5 Kamps, M2: FLR: 206.4 KM, FC: 1.58 Kamps* Fault is in Kolar TLM Jurisdiction."
							0.02	0.00	0.00	0.55	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-KUDAMKULAM(NPCIL)-2	OSPD	13-02-2025	08:09:00	13-02-2025	19:09:00	0.46	0.00	0.00	0.00	11.00		* Shutdown availed by NPCIL for maintenance works vide SRLDC code: 02/2552
							0.46	0.00	0.00	0.00	11.00	100.00	
CKT	400kV TUTICORIN PS-TUTICORIN JV(NTPL)-1	OMSU	01-02-2025	00:00:01	02-02-2025	13:18:00	1.55	0.00	37.30	0.00	0.00		* Line tripped at NTPL end only.SF6 gas pressure low observed at NTPL end.
							1.55	0.00	37.30	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-TUTICORIN JV(NTPL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDMALPET-ARASUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDMALPET-ARASUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET-E.PALAYM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET-E.PALAYM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET -PALLAKAD-1	SCSD	03-02-2025	09:49:00	04-02-2025	18:34:00	1.37	0.00	0.00	0.00	32.75		* Shutdown availed for construction works,replacement of CT MB and Interpole cabling works vide code CR-02/405.
							1.37	0.00	0.00	0.00	32.75	100.00	
CKT	400kV UDUMAPALET -PALLAKAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

[illegible]

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	50MVAR,SWLR OF NELLORE-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SALEM-2 AT UDUMALPET	SVRD	08-02-2025	10:47:00	28-02-2025	23:59:59	20.55	0.00	0.00	0.00	493.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1566(401 - 401Kv).
							20.55	0.00	0.00	0.00	493.22	100.00	
LNR	63MVAR,SWLR OF TIRUNELVELI-2 AT UDUMALPT	SVRD	07-02-2025	11:30:00	28-02-2025	23:59:59	21.52	0.00	0.00	0.00	516.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1347(393 -393 Kv).
							21.52	0.00	0.00	0.00	516.50	100.00	
LNR	63MVAR,SWLR OF TIRUNELVELI-1 AT UDUMALPT	SVRD	07-02-2025	11:33:00	28-02-2025	23:59:59	21.52	0.00	0.00	0.00	516.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1348(393 -393 Kv).
							21.52	0.00	0.00	0.00	516.45	100.00	
STATCOM	-200/+200 MVAR STATCOM AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-200/+200 MVAR STATCOM AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BIDADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BIDADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/230kV ICT-4 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARAUKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KARAUKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KARAUKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT KOLAR	OSPT	04-02-2025	12:39:00	04-02-2025	19:57:00	0.30	7.30	0.00	0.00	0.00		* Shutdown availed for AMP works of ICT 1

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	500MVA,400/220kV ICT-1 AT KOLAR	SBBT	22-02-2025	16:28:00	22-02-2025	18:39:00	0.09	2.18	0.00	0.00	0.00		* ICT tripped on operation of Bus Bar protection of 220kV Bus-1 at Kolar due to flashover of 20489A isolator.
							0.39	9.48	0.00	0.00	0.00	98.59	
XMER	500MVA,400/220kV ICT-2 AT KOLAR	OSPT	01-02-2025	09:28:00	01-02-2025	19:36:00	0.42	10.13	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-01/63.
XMER	500MVA,400/220kV ICT-2 AT KOLAR	SBBT	22-02-2025	16:28:00	22-02-2025	17:48:00	0.06	1.33	0.00	0.00	0.00		* ICT tripped on operation of Bus Bar protection of 220kV Bus-1 at Kolar due to flashover of 20489A isolator.
							0.48	11.46	0.00	0.00	0.00	98.29	
XMER	500MVA,400/220kV ICT-3 AT KOLAR	OSPT	07-02-2025	10:08:00	07-02-2025	18:58:00	0.37	8.83	0.00	0.00	0.00		* ICT Shut Down availed for warranty tsets <(>&<)> oil sampling works vide SRLDC CR 02/1328.
XMER	500MVA,400/220kV ICT-3 AT KOLAR	SBBT	22-02-2025	16:28:00	22-02-2025	17:42:00	0.05	1.23	0.00	0.00	0.00		* ICT tripped on operation of Bus Bar protection of 220kV Bus-1 at Kolar due to flashover of 20489A isolator.
							0.42	10.06	0.00	0.00	0.00	98.50	
XMER	315MVA,400/220kV ICT-1 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MADURAI	SCSD	28-02-2025	08:43:00	28-02-2025	23:59:59	0.64	0.00	0.00	0.00	15.28		* Shutdown availed for Retrofitting of CT MB Box in 413 and 414 CTA
							0.64	0.00	0.00	0.00	15.28	100.00	
XMER	315MVA,400/220kV ICT-2 AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MADURAI	OSPT	13-02-2025	10:13:00	13-02-2025	17:51:00	0.32	7.63	0.00	0.00	0.00		* Shutdown availed for AMP works vide SRLDC code: 02/2574
							0.32	7.63	0.00	0.00	0.00	98.86	
XMER	315MVA,400/220kV ICT-1 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT NARENDRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT NARENDRA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KARUR	OSPT	08-02-2025	08:55:00	08-02-2025	17:20:00	0.35	8.42	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-01/1518
							0.35	8.42	0.00	0.00	0.00	98.75	
XMER	500MVA,400/220kV ICT-1 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-6 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT THIRUNELVELI	OSPT	08-02-2025	09:03:00	08-02-2025	19:04:00	0.42	10.02	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-01/1530

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE To ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.42	10.02	0.00	0.00	0.00	98.51	
XMER	315MVA,400/220kV ICT-1 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	TuticorinGIS ICT3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUMKUR	OSPT	15-02-2025	09:58:00	15-02-2025	19:01:00	0.38	9.05	0.00	0.00	0.00		* Shutdown availed for AMP works.(LA IR test 2. Bushing Tan delta 3. Earth pit measurement 4.DR trigger on overcurrent pickup 5.New settings implementation)
							0.38	9.05	0.00	0.00	0.00	98.65	
XMER	500MVA,400/220kV ICT-3 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	