

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	06-01-2025	08:27:00	07-01-2025	20:20:00	1.50	0.00	0.00	0.00	35.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/874(398 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	01-01-2025	08:48:00	01-01-2025	18:17:00	0.40	0.00	0.00	0.00	9.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/34 (403 - 405Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	03-01-2025	08:03:00	03-01-2025	17:49:00	0.41	0.00	0.00	0.00	9.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/342 (403-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	04-01-2025	08:18:00	04-01-2025	22:32:00	0.59	0.00	0.00	0.00	14.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/547 (401-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	02-01-2025	09:57:00	02-01-2025	16:21:00	0.27	0.00	0.00	0.00	6.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/195 (395 -397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	22-01-2025	09:09:00	22-01-2025	17:09:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3571(398 - 399 Kv)
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	15-01-2025	09:01:00	15-01-2025	16:26:00	0.31	0.00	0.00	0.00	7.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2409(396 - 396Kv)
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	05-01-2025	09:57:00	05-01-2025	15:32:00	0.23	0.00	0.00	0.00	5.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/732 (399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	21-01-2025	07:48:00	21-01-2025	16:38:00	0.37	0.00	0.00	0.00	8.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3358 (400 - 401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	13-01-2025	08:36:00	13-01-2025	16:31:00	0.33	0.00	0.00	0.00	7.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2150 (402 -402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	24-01-2025	07:07:00	24-01-2025	16:49:00	0.40	0.00	0.00	0.00	9.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3952(403 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	11-01-2025	08:35:00	11-01-2025	17:02:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1869 (406 -406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	28-01-2025	07:56:00	28-01-2025	21:04:00	0.55	0.00	0.00	0.00	13.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4836 (404-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	25-01-2025	08:37:00	25-01-2025	21:34:00	0.54	0.00	0.00	0.00	12.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4152 (399 - 399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	10-01-2025	07:54:00	10-01-2025	17:20:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1684 (400-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	18-01-2025	08:19:00	18-01-2025	17:07:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2882 (399 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	23-01-2025	07:35:00	23-01-2025	16:16:00	0.36	0.00	0.00	0.00	8.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3750(403 - 405Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	19-01-2025	09:21:00	19-01-2025	14:27:00	0.21	0.00	0.00	0.00	5.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3040 (403-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	29-01-2025	08:04:00	30-01-2025	20:50:00	1.53	0.00	0.00	0.00	36.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4837(401-401) Kv.
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	09-01-2025	08:58:00	09-01-2025	17:50:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1491 (397 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	16-01-2025	09:36:00	16-01-2025	17:40:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2563 (389 - 389Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	27-01-2025	08:18:00	27-01-2025	17:21:00	0.38	0.00	0.00	0.00	9.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4445 (402-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	17-01-2025	08:26:00	17-01-2025	17:14:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2706 (401-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	12-01-2025	08:27:00	12-01-2025	17:05:00	0.36	0.00	0.00	0.00	8.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2028 (405-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	08-01-2025	07:09:00	08-01-2025	17:03:00	0.41	0.00	0.00	0.00	9.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1291(408 - 408Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	20-01-2025	08:18:00	20-01-2025	17:26:00	0.38	0.00	0.00	0.00	9.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3166 (410 - 413 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	31-01-2025	07:04:00	31-01-2025	16:15:00	0.38	0.00	0.00	0.00	9.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5235 (402-405Kv).
							12.43	0.00	0.00	0.00	298.15	100.00	
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	20-01-2025	08:45:00	20-01-2025	21:33:00	0.53	0.00	0.00	0.00	12.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3181 (414 -414 Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	25-01-2025	09:49:00	26-01-2025	17:55:00	1.34	0.00	0.00	0.00	32.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4185 (398 - 400Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	29-01-2025	10:51:00	30-01-2025	20:49:00	1.42	0.00	0.00	0.00	33.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4862 (397 - 397 Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	27-01-2025	09:52:00	27-01-2025	20:04:00	0.43	0.00	0.00	0.00	10.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4482 (400-401Kv).
							3.72	0.00	0.00	0.00	89.07	100.00	
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	04-01-2025	10:02:00	04-01-2025	17:56:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/579 (401-403Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	03-01-2025	08:04:00	03-01-2025	16:59:00	0.37	0.00	0.00	0.00	8.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/343 (403-406Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	23-01-2025	07:56:00	23-01-2025	16:47:00	0.37	0.00	0.00	0.00	8.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3761(411 - 413Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	18-01-2025	09:09:00	18-01-2025	17:42:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2900 (399-401 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	17-01-2025	08:23:00	17-01-2025	17:32:00	0.38	0.00	0.00	0.00	9.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2707 (402-405 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	19-01-2025	09:25:00	19-01-2025	14:38:00	0.22	0.00	0.00	0.00	5.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3041 (404-406Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	21-01-2025	07:49:00	21-01-2025	20:51:00	0.54	0.00	0.00	0.00	13.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3359 (404 - 407 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	20-01-2025	08:19:00	20-01-2025	17:49:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3167 (406 - 409 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	27-01-2025	08:30:00	27-01-2025	17:59:00	0.40	0.00	0.00	0.00	9.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4446 (406-408Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	26-01-2025	08:30:00	26-01-2025	14:43:00	0.26	0.00	0.00	0.00	6.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4317 (408 -411 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	06-01-2025	10:19:00	06-01-2025	17:17:00	0.29	0.00	0.00	0.00	6.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/902 (400 -402 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	24-01-2025	09:09:00	25-01-2025	17:42:00	1.36	0.00	0.00	0.00	32.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3976 (393 - 395Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	07-01-2025	09:19:00	07-01-2025	20:10:00	0.45	0.00	0.00	0.00	10.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1105(396 - 400Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	13-01-2025	08:48:00	13-01-2025	16:53:00	0.34	0.00	0.00	0.00	8.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2151 (408 -410 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	10-01-2025	07:57:00	10-01-2025	16:19:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1685 (404-408 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	09-01-2025	09:00:00	09-01-2025	16:24:00	0.31	0.00	0.00	0.00	7.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1492 (401 - 403 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	29-01-2025	08:36:00	29-01-2025	17:12:00	0.36	0.00	0.00	0.00	8.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4838(402-403) Kv.
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	22-01-2025	09:06:00	22-01-2025	17:59:00	0.37	0.00	0.00	0.00	8.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3572(396 - 398 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	28-01-2025	07:58:00	28-01-2025	16:46:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4637 (404-405Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	31-01-2025	10:08:00	31-01-2025	16:35:00	0.27	0.00	0.00	0.00	6.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5272 (395 - 398Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	30-01-2025	08:36:00	30-01-2025	19:34:00	0.46	0.00	0.00	0.00	10.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5028(399-399 Kv).
							8.56	0.00	0.00	0.00	204.74	100.00	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	25-01-2025	09:56:00	25-01-2025	17:44:00	0.33	0.00	0.00	0.00	7.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4180 (396 - 401Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	28-01-2025	08:00:00	28-01-2025	16:48:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4838 (406-408Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	26-01-2025	08:32:00	26-01-2025	14:45:00	0.26	0.00	0.00	0.00	6.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4318 (410 -414 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	10-01-2025	09:35:00	10-01-2025	16:22:00	0.28	0.00	0.00	0.00	6.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1715 (395-400 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	09-01-2025	09:01:00	09-01-2025	16:24:00	0.31	0.00	0.00	0.00	7.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1493 (403 - 405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	08-01-2025	07:04:00	08-01-2025	17:37:00	0.44	0.00	0.00	0.00	10.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1292(409 - 413Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	05-01-2025	09:55:00	05-01-2025	15:42:00	0.24	0.00	0.00	0.00	5.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1733 (399-404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	29-01-2025	08:40:00	29-01-2025	17:14:00	0.36	0.00	0.00	0.00	8.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4839(405-408) Kv.
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	24-01-2025	09:12:00	24-01-2025	16:55:00	0.32	0.00	0.00	0.00	7.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3977 (395 - 399Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	11-01-2025	08:20:00	11-01-2025	17:52:00	0.40	0.00	0.00	0.00	9.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1870 (400 -405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	22-01-2025	09:07:									

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	06-01-2025	08:35:00	06-01-2025	17:23:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/875 (407 -411 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	15-01-2025	09:04:00	15-01-2025	16:40:00	0.32	0.00	0.00	0.00	7.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2410(392 - 396Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	20-01-2025	08:22:00	20-01-2025	21:21:00	0.54	0.00	0.00	0.00	12.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/ 3161 (410 - 413 Kv).
							8.90	0.00	0.00	0.00	212.95	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	10-01-2025	08:01:00	10-01-2025	16:05:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1686 (401-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	24-01-2025	09:19:00	25-01-2025	17:19:00	1.33	0.00	0.00	0.00	32.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3978 (391 - 393Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	22-01-2025	09:10:00	22-01-2025	17:17:00	0.34	0.00	0.00	0.00	8.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3574 (398 - 399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	27-01-2025	08:32:00	27-01-2025	20:11:00	0.49	0.00	0.00	0.00	11.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4447 (400-401Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	06-01-2025	10:21:00	06-01-2025	17:13:00	0.29	0.00	0.00	0.00	6.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/903 (393 -394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	26-01-2025	08:37:00	26-01-2025	14:33:00	0.25	0.00	0.00	0.00	5.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4319 (407 -407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	28-01-2025	08:02:00	28-01-2025	16:22:00	0.35	0.00	0.00	0.00	8.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4639 (402-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	21-01-2025	07:51:00	21-01-2025	20:37:00	0.53	0.00	0.00	0.00	12.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3361 (404 - 405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	29-01-2025	08:09:00	29-01-2025	16:44:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4840 (401-402) Kv.
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	20-01-2025	11:10:00	20-01-2025	17:29:00	0.26	0.00	0.00	0.00	6.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3215 (395 - 396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	17-01-2025	09:50:00	17-01-2025	17:19:00	0.31	0.00	0.00	0.00	7.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2733 (391 - 391Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	31-01-2025	10:09:00	31-01-2025	16:21:00	0.26	0.00	0.00	0.00	6.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5273 (392 - 392Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	30-01-2025	08:43:00	30-01-2025	19:31:00	0.45	0.00	0.00	0.00	10.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5030 (396-400 Kv).
							5.56	0.00	0.00	0.00	133.12	100.00	
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	27-01-2025	09:44:00	27-01-2025	20:09:00	0.43	0.00	0.00	0.00	10.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4474 (401-403Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	21-01-2025	07:52:00	21-01-2025	16:44:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3362 (405 -408 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	25-01-2025	08:44:00	25-01-2025	17:20:00	0.36	0.00	0.00	0.00	8.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4153 (402 -405 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	10-01-2025	09:37:00	10-01-2025	16:16:00	0.28	0.00	0.00	0.00	6.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1716 (392-392 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	28-01-2025	08:05:00	28-01-2025	16:27:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4640 (402-404Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	24-01-2025	09:21:00	24-01-2025	16:20:00	0.29	0.00	0.00	0.00	6.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3979 (393 - 396Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	20-01-2025	11:11:00	20-01-2025	17:30:00	0.26	0.00	0.00	0.00	6.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3216 (396 -397 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	23-01-2025	07:44:00	23-01-2025	16:19:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3752(405 - 405Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	29-01-2025	08:11:00	29-01-2025	16:42:00	0.36	0.00	0.00	0.00	8.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4841 (402-405) Kv.
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	15-01-2025	09:06:00	15-01-2025	16:32:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2411(392 - 392Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	22-01-2025	09:06:00	22-01-2025	17:14:00	0.34	0.00	0.00	0.00	8.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3575 (396 - 398 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	07-01-2025	09:19:00	07-01-2025	20:18:00	0.46	0.00	0.00	0.00	10.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1106(392 - 396Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	11-01-2025	08:38:00	11-01-2025	17:55:00	0.39	0.00	0.00	0.00	9.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1871 (403 -404 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	31-01-2025	08:53:00	31-01-2025	16:23:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5251 (397 - 398Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	30-01-2025	08:45:00	30-01-2025	19:32:00	0.45	0.00	0.00	0.00	10.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5031 (400-400 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	06-01-2025	08:32:00	06-01-2025	17:16:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/876 (402 -406 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	18-01-2025	09:11:00	18-01-2025	17:08:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2902 (396-397 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	08-01-2025	07:06:00	08-01-2025	17:10:00	0.42	0.00	0.00	0.00	10.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1293(405 - 410Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	03-01-2025	10:39:00	03-01-2025	17:11:00	0.27	0.00	0.00	0.00	6.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/387 (399-401Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	01-01-2025	08:46:00	01-01-2025	18:19:00	0.40	0.00	0.00	0.00	9.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/35 (404 - 405Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	09-01-2025	09:27:00	09-01-2025	16:25:00	0.29	0.00	0.00	0.00	6.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1514 (391 - 395 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	05-01-2025	09:29:00	05-01-2025	15:34:00	0.25	0.00	0.00	0.00	6.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/734 (391-393 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	17-01-2025	09:52:00	17-01-2025	17:24:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2734 (391 - 391Kv).
							7.95	0.00	0.00	0.00	190.82	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	20-01-2025	08:10:00	21-01-2025	20:55:00	1.53	0.00	0.00	0.00	36.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3172 (405 -406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	22-01-2025	06:57:00	22-01-2025	20:24:00	0.56	0.00	0.00	0.00	13.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3562 (404-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	25-01-2025	09:53:00	26-01-2025	17:53:00	1.33	0.00	0.00	0.00	32.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4187 (393 - 395Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	06-01-2025	07:06:00	10-01-2025	20:53:00	4.57	0.00	0.00	0.00	109.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/854 (400-400Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	02-01-2025	10:03:00	03-01-2025	23:37:00	1.57	0.00	0.00	0.00	37.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/196 (395 -395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	01-01-2025	09:55:00	01-01-2025	22:55:00	0.54	0.00	0.00	0.00	13.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/53 (394 - 394Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	04-01-2025	08:14:00	04-01-2025	22:43:00	0.60	0.00	0.00	0.00	14.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/557 (401-401Kv).
							10.70	0.00	0.00	0.00	257.03	100.00	
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	21-01-2025	08:17:00	21-01-2025	21:01:00	0.53	0.00	0.00	0.00	12.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3373 (403 - 406Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	04-01-2025	08:16:00	04-01-2025	22:40:00	0.60	0.00	0.00	0.00	14.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/558 (401-403Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	02-01-2025	10:05:00	03-01-2025	23:20:00	1.55	0.00	0.00	0.00	37.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/197 (395 -399 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	01-01-2025	09:59:00	01-01-2025	22:31:00	0.52	0.00	0.00	0.00	12.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/54 (394 - 396Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	06-01-2025	07:08:00	07-01-2025	18:18:00	1.47	0.00	0.00	0.00	35.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/855 (400-401Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	22-01-2025	06:58:00	22-01-2025	20:20:00	0.56	0.00	0.00	0.00	13.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3563 (404-406Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	27-01-2025	09:46:00	31-01-2025	23:59:59	4.59	0.00	0.00	0.00	110.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4481 (399-400Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	16-01-2025	09:37:00	19-01-2025	16:40:00	3.29	0.00	0.00	0.00	79.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2561 (390 - 393Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	20-01-2025	08:12:00	20-01-2025	21:45:00	0.57	0.00	0.00	0.00	13.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3173 (406 -409 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	25-01-2025	08:43:00	26-01-2025	17:51:00	1.38	0.00	0.00	0.00	33.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4159 (395 - 397Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	23-01-2025	07:34:00	23-01-2025	16:46:00	0.38	0.00	0.00	0.00	9.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3759(398 - 400Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	08-01-2025	07:11:00	10-01-2025	20:50:00	2.57	0.00	0.00	0.00	61.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1288(401 - 403Kv).
							18.01	0.00	0.00	0.00	432.26	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	02-01										

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	27-01-2025	08:29:00	27-01-2025	18:08:00	0.40	0.00	0.00	0.00	9.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4448 (400-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	06-01-2025	07:02:00	06-01-2025	15:46:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/853 (398-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	17-01-2025	09:51:00	17-01-2025	17:29:00	0.32	0.00	0.00	0.00	7.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2735 (397 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	05-01-2025	10:09:00	05-01-2025	15:35:00	0.23	0.00	0.00	0.00	5.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/735 (404-405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	23-01-2025	07:33:00	23-01-2025	16:58:00	0.39	0.00	0.00	0.00	9.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3753(404 - 406Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	29-01-2025	07:22:00	29-01-2025	07:22:00	0.00	0.00	0.00	0.00	0.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4823 (399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	29-01-2025	07:22:00	29-01-2025	16:59:00	0.40	0.00	0.00	0.00	9.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4823 (399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	29-01-2025	07:22:00	29-01-2025	07:22:00	0.00	0.00	0.00	0.00	0.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4823 (399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	15-01-2025	09:04:00	15-01-2025	16:30:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2412(397 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	11-01-2025	08:25:00	11-01-2025	20:06:00	0.49	0.00	0.00	0.00	11.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1872 (408 -409Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	30-01-2025	07:07:00	30-01-2025	19:35:00	0.52	0.00	0.00	0.00	12.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5023 (404 - 406Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	24-01-2025	07:10:00	24-01-2025	22:55:00	0.66	0.00	0.00	0.00	15.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3953(404 - 406Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	16-01-2025	09:08:00	16-01-2025	17:46:00	0.36	0.00	0.00	0.00	8.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2548 (398-400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	13-01-2025	08:53:00	13-01-2025	19:43:00	0.45	0.00	0.00	0.00	10.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2153 (408 -409 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	31-01-2025	07:13:00	31-01-2025	16:31:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5236 (404-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	03-01-2025	08:00:00	03-01-2025	16:31:00	0.36	0.00	0.00	0.00	8.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/344 (400-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	19-01-2025	09:22:00	19-01-2025	14:34:00	0.22	0.00	0.00	0.00	5.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3043 (402-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	26-01-2025	08:40:00	26-01-2025	15:06:00	0.27	0.00	0.00	0.00	6.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4320 (416 -417 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	10-01-2025	08:07:00	10-01-2025	17:21:00	0.39	0.00	0.00	0.00	9.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1687 (404-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	09-01-2025	08:58:00	09-01-2025	17:52:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1494 (402 - 404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	12-01-2025	08:36:00	12-01-2025	17:07:00	0.36	0.00	0.00	0.00	8.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2029 (407-409Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	04-01-2025	08:24:00	04-01-2025	18:14:00	0.41	0.00	0.00	0.00	9.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/549 (404-405Kv).
							12.19	0.00	0.00	0.00	291.54	100.00	
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	23-01-2025	07:49:00	23-01-2025	16:19:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3754(401 - 404Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	05-01-2025	09:21:00	05-01-2025	15:42:00	0.27	0.00	0.00	0.00	6.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/736 (392-392 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	08-01-2025	07:02:00	08-01-2025	17:09:00	0.42	0.00	0.00	0.00	10.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1295(403 - 405Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	07-01-2025	07:38:00	07-01-2025	20:20:00	0.53	0.00	0.00	0.00	12.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1091(400 - 400Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	06-01-2025	08:36:00	06-01-2025	20:30:00	0.50	0.00	0.00	0.00	11.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/877 (395 -396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	21-01-2025	07:56:00	21-01-2025	20:38:00	0.53	0.00	0.00	0.00	12.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3363 (398 -400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	27-01-2025	08:25:00	28-01-2025	21:07:00	1.53	0.00	0.00	0.00	36.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4449 (400-401Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	22-01-2025	09:00:00	22-01-2025	17:23:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3576 (399 - 400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	29-01-2025	08:23:00	30-01-2025	20:51:00	1.52	0.00	0.00	0.00	36.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4842 (399-401) Kv.
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	09-01-2025	09:22:00	09-01-2025	23:16:00	0.58	0.00	0.00	0.00	13.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1506 (397 - 400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	19-01-2025	09:31:00	19-01-2025	16:33:00	0.29	0.00	0.00	0.00	7.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3044 (397-399Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	31-01-2025	07:00:00	31-01-2025	20:29:00	0.56	0.00	0.00	0.00	13.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5237 (404-405Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	26-01-2025	08:31:00	26-01-2025	17:54:00	0.39	0.00	0.00	0.00	9.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4321 (403 -403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	04-01-2025	08:22:00	04-01-2025	22:35:00	0.59	0.00	0.00	0.00	14.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/553 (402-404Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	03-01-2025	08:16:00	03-01-2025	17:05:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/345 (399-399Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	24-01-2025	07:30:00	25-01-2025	17:25:00	1.41	0.00	0.00	0.00	33.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3954(400 - 402Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	10-01-2025	08:00:00	10-01-2025	17:24:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1688 (396-399 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	17-01-2025	08:28:00	17-01-2025	17:24:00	0.37	0.00	0.00	0.00	8.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2708 (400-401 Kv).
							10.95	0.00	0.00	0.00	262.90	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	08-01-2025	07:07:00	08-01-2025	17:16:00	0.42	0.00	0.00	0.00	10.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1296(405 - 407Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	18-01-2025	09:19:00	18-01-2025	17:15:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2903 (396-398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	21-01-2025	08:03:00	21-01-2025	16:46:00	0.36	0.00	0.00	0.00	8.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3364 (401 - 401 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	19-01-2025	09:46:00	19-01-2025	16:39:00	0.29	0.00	0.00	0.00	6.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3045 (399-399Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	17-01-2025	08:38:00	17-01-2025	17:29:00	0.37	0.00	0.00	0.00	8.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2709 (401-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	27-01-2025	08:31:00	28-01-2025	21:11:00	1.53	0.00	0.00	0.00	36.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4450 (401-403Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	05-01-2025	09:25:00	05-01-2025	15:47:00	0.27	0.00	0.00	0.00	6.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/737 (392-393 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	06-01-2025	08:43:00	06-01-2025	20:35:00	0.49	0.00	0.00	0.00	11.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/878 (395 -396 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	20-01-2025	08:33:00	20-01-2025	21:20:00	0.53	0.00	0.00	0.00	12.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/ 3162 (403 - 404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	29-01-2025	08:32:00	29-01-2025	16:51:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4843 (401-403) Kv.
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	07-01-2025	09:25:00	07-01-2025	20:25:00	0.46	0.00	0.00	0.00	11.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1107(398 - 401Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	10-01-2025	08:06:00	10-01-2025	17:30:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1689 (- Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	26-01-2025	08:37:00	26-01-2025	17:59:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4322 (403 -406 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	09-01-2025	09:29:00	09-01-2025	23:21:00	0.58	0.00	0.00	0.00	13.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1507 (400 - 401 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	31-01-2025	07:06:00	31-01-2025	20:34:00	0.56	0.00	0.00	0.00	13.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5238 (405-406Kv).
							7.32	0.00	0.00	0.00	175.65	100.00	
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	03-01-2025	10:46:00	03-01-2025	17:35:00	0.28	0.00	0.00	0.00	6.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/389 (391-393Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	04-01-2025	10:02:00	04-01-2025	17:48:00	0.32	0.00	0.00	0.00	7.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/580 (400-402Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	01-01-2025	10:04:00	01-01-2025	20:39:00	0.44	0.00	0.00	0.00	10.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/47 (395 - 396Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	15-01-2025	09:05:00	15-01-2025	20:36:00	0.48	0.00	0.00	0.00	11.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2418(386 - 389Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	21-01-2025	07:55:00	21-01-2025	16:46:00	0.37	0.00	0.00	0.00	8.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3365 (409 -409 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	20-01-2025	08:23:00	20-01-2025	17:49:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3169 (410 - 411 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	18-01-2025	08:31:00	18-01-2025	17:37:00	0.38	0.00	0.00	0.00	9.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2884 (402 - 402Kv).
BSR	50MVAR												

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	22-01-2025	08:54:00	22-01-2025	17:41:00	0.37	0.00	0.00	0.00	8.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3577 (401 - 401 kV)
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	17-01-2025	08:28:00	17-01-2025	17:41:00	0.38	0.00	0.00	0.00	9.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2710 (399-403 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	11-01-2025	08:40:00	11-01-2025	18:14:00	0.40	0.00	0.00	0.00	9.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1873 (404 -405Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	16-01-2025	09:47:00	16-01-2025	17:56:00	0.34	0.00	0.00	0.00	8.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2571 (385 - 388Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	19-01-2025	09:29:00	19-01-2025	14:39:00	0.22	0.00	0.00	0.00	5.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3046 (405-406Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	13-01-2025	09:14:00	13-01-2025	16:50:00	0.32	0.00	0.00	0.00	7.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2154 (404 -404 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	31-01-2025	08:55:00	31-01-2025	16:38:00	0.32	0.00	0.00	0.00	7.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5252 (397 - 399Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	30-01-2025	08:51:00	30-01-2025	20:00:00	0.47	0.00	0.00	0.00	11.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5032 (400-401 Kv).
							9.26	0.00	0.00	0.00	221.95	100.00	
BSR	125MVAR, BUS REACTOR-1 AT NAGAPATTINAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	27-01-2025	12:32:00	27-01-2025	18:02:00	0.23	0.00	0.00	0.00	5.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4503 (400-402Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	23-01-2025	09:21:00	23-01-2025	16:28:00	0.30	0.00	0.00	0.00	7.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3784(395 - 398Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	16-01-2025	09:54:00	16-01-2025	17:52:00	0.33	0.00	0.00	0.00	7.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2571 (385 - 388Kv).* 16.01.2025 11:51:24 INDIA (60070092)* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2573 (393 - 397Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	21-01-2025	07:58:00	21-01-2025	17:08:00	0.38	0.00	0.00	0.00	8.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3366 (407- 409Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	22-01-2025	08:48:00	22-01-2025	17:28:00	0.36	0.00	0.00	0.00	8.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3578 (403 - 405 kV)
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	08-01-2025	09:35:00	08-01-2025	17:25:00	0.33	0.00	0.00	0.00	7.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1322(399 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	13-01-2025	09:27:00	13-01-2025	16:40:00	0.30	0.00	0.00	0.00	7.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2155 (398 -400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	25-01-2025	08:40:00	25-01-2025	17:33:00	0.37	0.00	0.00	0.00	8.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4155 (401 -404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	28-01-2025	08:12:00	28-01-2025	16:57:00	0.37	0.00	0.00	0.00	8.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4643 (404-406Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	20-01-2025	08:15:00	20-01-2025	18:08:00	0.41	0.00	0.00	0.00	9.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3170 (406 - 409 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	11-01-2025	08:22:00	11-01-2025	17:59:00	0.40	0.00	0.00	0.00	9.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1874 (403-404Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	07-01-2025	09:22:00	07-01-2025	18:44:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1108(398 - 401Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	06-01-2025	08:25:00	06-01-2025	17:33:00	0.38	0.00	0.00	0.00	9.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/880 (403 -406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	05-01-2025	09:49:00	05-01-2025	15:48:00	0.25	0.00	0.00	0.00	5.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/739 (397-399 Kv)
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	29-01-2025	08:20:00	29-01-2025	17:50:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4844 (403-406) Kv.
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	17-01-2025	08:30:00	17-01-2025	17:30:00	0.38	0.00	0.00	0.00	9.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2711 (403-405 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	24-01-2025	09:26:00	24-01-2025	16:30:00	0.29	0.00	0.00	0.00	7.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3981 (396 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	09-01-2025	09:22:00	09-01-2025	18:01:00	0.36	0.00	0.00	0.00	8.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1508 (397 - 400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	31-01-2025	07:00:00	31-01-2025	16:40:00	0.40	0.00	0.00	0.00	9.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5239 (410-412Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	30-01-2025	08:57:00	30-01-2025	19:34:00	0.44	0.00	0.00	0.00	10.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5033 (400-402 Kv).
							7.07	0.00	0.00	0.00	169.60	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC	SVRD	06-01-2025	09:13:00	07-01-2025	20:19:00	1.46	0.00	0.00	0.00	35.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/891 (396 -398 Kv).
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC	SVRD	18-01-2025	08:27:00	19-01-2025	16:25:00	1.33	0.00	0.00	0.00	31.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2894 (403 - 405Kv).
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC	SVRD	21-01-2025	07:21:00	31-01-2025	23:59:59	10.69	0.00	0.00	0.00	256.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3352 (410 -412 Kv).
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC	SVRD	01-01-2025	00:00:01	05-01-2025	17:19:00	4.72	0.00	0.00	0.00	113.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 12/4173(403 - 405Kv).
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC	SVRD	08-01-2025	06:58:00	14-01-2025	20:38:00	6.57	0.00	0.00	0.00	157.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1300(400 - 403Kv).
							24.77	0.00	0.00	0.00	594.71	100.00	
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC	SVRD	08-01-2025	07:00:00	14-01-2025	20:40:00	6.57	0.00	0.00	0.00	157.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1301(404 - 406Kv).
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC	SVRD	06-01-2025	09:15:00	07-01-2025	20:23:00	1.46	0.00	0.00	0.00	35.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/892 (398 -400 Kv).
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC	SVRD	18-01-2025	08:29:00	19-01-2025	16:27:00	1.33	0.00	0.00	0.00	31.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2895 (405-407 Kv).
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC	SVRD	21-01-2025	07:25:00	31-01-2025	23:59:59	10.69	0.00	0.00	0.00	256.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3353 (412 -414 Kv).
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC	SVRD	01-01-2025	00:00:01	05-01-2025	17:23:00	4.72	0.00	0.00	0.00	113.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 12/4174(404 - 406Kv).
							24.77	0.00	0.00	0.00	594.73	100.00	
BSR	63MVAR, BUS REACTOR-1 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	11-01-2025	08:23:00	11-01-2025	17:28:00	0.38	0.00	0.00	0.00	9.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1875 (408 -410 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	12-01-2025	10:47:00	12-01-2025	17:10:00	0.27	0.00	0.00	0.00	6.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2048 (400-401Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	22-01-2025	08:37:00	22-01-2025	17:29:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3579 (405 - 405 Kv)
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	24-01-2025	09:30:00	24-01-2025	16:53:00	0.31	0.00	0.00	0.00	7.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3982 (400 - 400Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	10-01-2025	09:59:00	10-01-2025	16:09:00	0.26	0.00	0.00	0.00	6.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1718 (399-399 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	25-01-2025	09:55:00	25-01-2025	17:13:00	0.30	0.00	0.00	0.00	7.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4181 (399 - 401Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	21-01-2025	08:01:00	21-01-2025	17:04:00	0.38	0.00	0.00	0.00	9.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3367 (411 -414 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	03-01-2025	08:10:00	03-01-2025	16:29:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/346 (409-411Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	04-01-2025	10:05:00	04-01-2025	17:25:00	0.31	0.00	0.00	0.00	7.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/581 (400-400Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	02-01-2025	09:57:00	02-01-2025	16:22:00	0.27	0.00	0.00	0.00	6.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/192 (400 -403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	23-01-2025	10:58:00	23-01-2025	16:18:00	0.22	0.00	0.00	0.00	5.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3803(394 - 397Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	17-01-2025	10:01:00	17-01-2025	17:26:00	0.31	0.00	0.00	0.00	7.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2736 (399 - 403Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	15-01-2025	09:35:00	15-01-2025	16:25:00	0.29	0.00	0.00	0.00	6.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2424(399 - 402Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	30-01-2025	08:58:00	30-01-2025	19:40:00	0.45	0.00	0.00	0.00	10.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5034 (405-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	31-01-2025	10:12:00	31-01-2025	16:42:00	0.27	0.00	0.00	0.00	6.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5274 (396 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	29-01-2025	10:59:00	29-01-2025	16:58:00	0.25	0.00	0.00	0.00	5.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4863 (400- 401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	28-01-2025	08:09:00	28-01-2025	16:32:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4644 (417-419Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	07-01-2025	09:25:00	07-01-2025	20:17:00	0.45	0.00	0.00	0.00	10.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1109(400 - 400Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	06-01-2025	09:41:00	06-01-2025	17:22:00	0.32	0.00	0.00	0.00	7.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1904 (399 -400 Kv).
BSR	125MVAR, BUS REACTOR												

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	27-01-2025	09:39:00	27-01-2025	17:39:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4475 (405-407Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	28-01-2025	08:10:00	28-01-2025	16:35:00	0.35	0.00	0.00	0.00	8.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4845 (419-419Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	31-01-2025	09:00:00	31-01-2025	16:33:00	0.32	0.00	0.00	0.00	7.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5253 (404 - 405Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	02-01-2025	10:04:00	02-01-2025	16:24:00	0.26	0.00	0.00	0.00	6.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1193 (403 -403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	15-01-2025	09:39:00	15-01-2025	16:27:00	0.28	0.00	0.00	0.00	6.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2425(402 - 402Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	13-01-2025	09:38:00	13-01-2025	16:29:00	0.29	0.00	0.00	0.00	6.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2156 (403 -407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	29-01-2025	08:46:00	29-01-2025	16:59:00	0.34	0.00	0.00	0.00	8.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4845 (409-409) Kv.
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	03-01-2025	10:45:00	03-01-2025	16:35:00	0.24	0.00	0.00	0.00	5.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/384 (395-399Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	04-01-2025	10:08:00	04-01-2025	17:25:00	0.30	0.00	0.00	0.00	7.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/582 (400-402Kv).
							4.90	0.00	0.00	0.00	117.54	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	16-01-2025	09:46:00	19-01-2025	16:43:00	3.29	0.00	0.00	0.00	78.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2562 (397 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	23-01-2025	07:42:00	31-01-2025	23:59:59	8.68	0.00	0.00	0.00	208.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3760(404 - 404Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	07-01-2025	07:28:00	13-01-2025	19:58:00	6.52	0.00	0.00	0.00	156.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1097(402 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	04-01-2025	08:29:00	05-01-2025	17:39:00	1.38	0.00	0.00	0.00	33.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/559 (403-403Kv).
							19.87	0.00	0.00	0.00	476.92	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	08-01-2025	07:00:00	08-01-2025	17:40:00	0.44	0.00	0.00	0.00	10.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1297(403 - 406Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	04-01-2025	08:23:00	04-01-2025	17:20:00	0.37	0.00	0.00	0.00	8.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/550 (403-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	03-01-2025	08:15:00	03-01-2025	16:57:00	0.36	0.00	0.00	0.00	8.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/347 (401-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	02-01-2025	08:25:00	02-01-2025	16:48:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/182 (403 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	01-01-2025	08:53:00	01-01-2025	18:23:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/37 (403 - 404Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	13-01-2025	09:31:00	13-01-2025	16:25:00	0.29	0.00	0.00	0.00	6.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2157 (395 -395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	15-01-2025	09:08:00	15-01-2025	16:50:00	0.32	0.00	0.00	0.00	7.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2413(393 - 394Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	16-01-2025	09:41:00	16-01-2025	18:02:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2549 (390 - 390Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	18-01-2025	09:24:00	18-01-2025	17:12:00	0.33	0.00	0.00	0.00	7.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2904 (399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	09-01-2025	09:00:00	09-01-2025	18:10:00	0.38	0.00	0.00	0.00	9.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1495 (396 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	20-01-2025	08:20:00	20-01-2025	17:32:00	0.38	0.00	0.00	0.00	9.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3163 (405 - 405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	12-01-2025	08:31:00	12-01-2025	17:19:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2030 (403-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	25-01-2025	08:40:00	25-01-2025	17:29:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4156 (399 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	06-01-2025	08:47:00	06-01-2025	17:45:00	0.37	0.00	0.00	0.00	8.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/881 (400 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	28-01-2025	08:02:00	28-01-2025	16:52:00	0.37	0.00	0.00	0.00	8.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4846 (406-406Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	07-01-2025	07:31:00	07-01-2025	20:13:00	0.53	0.00	0.00	0.00	12.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1093(402 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	26-01-2025	08:43:00	26-01-2025	14:35:00	0.24	0.00	0.00	0.00	5.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4324 (410 -410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	27-01-2025	08:19:00	27-01-2025	17:52:00	0.40	0.00	0.00	0.00	9.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4453 (403-405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	11-01-2025	08:26:00	11-01-2025	17:09:00	0.36	0.00	0.00	0.00	8.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1877 (405-405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	21-01-2025	08:06:00	21-01-2025	17:07:00	0.38	0.00	0.00	0.00	9.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3368 (405 -406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	10-01-2025	08:03:00	10-01-2025	17:22:00	0.39	0.00	0.00	0.00	9.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1690 (403-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	17-01-2025	08:32:00	17-01-2025	17:21:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2712 (400-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	05-01-2025	09:53:00	05-01-2025	15:59:00	0.25	0.00	0.00	0.00	6.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/740 (395-396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	23-01-2025	07:31:00	23-01-2025	17:00:00	0.40	0.00	0.00	0.00	9.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3755(401 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	29-01-2025	07:12:00	29-01-2025	17:29:00	0.43	0.00	0.00	0.00	10.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4825 (397-397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	30-01-2025	07:07:00	30-01-2025	19:31:00	0.52	0.00	0.00	0.00	12.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5024 (403 - 405Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	24-01-2025	07:32:00	24-01-2025	18:27:00	0.46	0.00	0.00	0.00	10.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3955(397 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	22-01-2025	07:05:00	22-01-2025	19:27:00	0.52	0.00	0.00	0.00	12.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3559 (400-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	19-01-2025	09:28:00	19-01-2025	14:54:00	0.23	0.00	0.00	0.00	5.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3047 (405-407Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	29-01-2025	07:12:00	29-01-2025	07:12:00	0.00	0.00	0.00	0.00	0.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4825 (397-397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	31-01-2025	07:11:00	31-01-2025	16:43:00	0.40	0.00	0.00	0.00	9.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5240 (404-405Kv).
							11.33	0.00	0.00	0.00	271.25	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SRIPERUMBUDUR	SVRD	21-01-2025	08:21:00	31-01-2025	23:59:59	10.65	0.00	0.00	0.00	255.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3374 (402 -402 Kv).
							10.65	0.00	0.00	0.00	255.65	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TIRUNELVELLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-2 AT TIRUNELVELLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TRIVANDRUM	SVRD	01-01-2025	11:17:00	03-01-2025	19:27:00	2.34	0.00	0.00	0.00	56.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/165 (394 - 401Kv).
							2.34	0.00	0.00	0.00	56.17	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TUTICORIN GIS	SVRD	01-01-2025	11:28:00	04-01-2025	03:22:00	2.66	0.00	0.00	0.00	63.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/167 (398 - 401Kv).
							2.66	0.00	0.00	0.00	63.90	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUTICORIN GIS	SVRD	01-01-2025	11:34:00	05-01-2025	17:30:00	4.25	0.00	0.00	0.00	101.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/168 (401 - 403Kv).
							4.25	0.00	0.00	0.00	101.93	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	30-01-2025	09:02:00	30-01-2025	19:36:00	0.44	0.00	0.00	0.00	10.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5035 (403-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	31-01-2025	10:12:00	31-01-2025	16:53:00	0.28	0.00	0.00	0.00	6.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5275 (397 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	29-01-2025	10:52:00	29-01-2025	17:20:00	0.27	0.00	0.00	0.00	6.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4864 (401- 402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	17-01-2025	10:40:00	17-01-2025	17:32:00	0.29	0.00	0.00	0.00	6.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2737 (400 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	28-01-2025	08:05:00	28-01-2025	16:39:00	0.36	0.00	0.00	0.00	8.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4647 (416-416Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	25-01-2025	09:53:00	25-01-2025	17:31:00	0.32	0.00	0.00	0.00	7.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4183 (401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	27-01-2025	09:49:00	27-01-2025	17:27:00	0.32	0.00	0.00	0.00	7.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4476 (400-400Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	03-01-2025	10:48:00	03-01-2025	16:43:00	0.25	0.00	0.00	0.00	5.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/385 (398-398Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	21-01-2025	08:10:00	21-01-2025	17:08:00	0.37	0.00	0.00	0.00	8.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3369 (411 -414 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	11-01-2025	08:15:00	11-01-2025	17:27:00							

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	29-01-2025	08:51:00	29-01-2025	17:23:00	0.36	0.00	0.00	0.00	8.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4846 (412-414) Kv.
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	31-01-2025	10:13:00	31-01-2025	16:54:00	0.28	0.00	0.00	0.00	6.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5276 (400 - 402Kv).
							2.56	0.00	0.00	0.00	61.38	100.00	
BSR	63MVAR, BUS REACTOR AT TUTICORIN PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	PUGALUR-1, LINE, REACTOR, 63MVAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	02-01-2025	07:46:00	04-01-2025	20:08:00	2.52	0.00	0.00	0.00	60.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/169 (756 - 766 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	17-01-2025	09:34:00	19-01-2025	17:54:00	2.35	0.00	0.00	0.00	56.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2724 (751 - 759 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	24-01-2025	07:55:00	24-01-2025	18:19:00	0.43	0.00	0.00	0.00	10.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3967/767 - 774Kv).
							5.30	0.00	0.00	0.00	127.10	100.00	
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	31-01-2025	10:17:00	31-01-2025	20:26:00	0.42	0.00	0.00	0.00	10.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5279/4266 (756 - 764Kv).
							0.42	0.00	0.00	0.00	10.15	100.00	
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	02-01-2025	08:32:00	02-01-2025	16:33:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/184 (405 - 405Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	04-01-2025	08:24:00	04-01-2025	18:21:00	0.42	0.00	0.00	0.00	9.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/552 (404-400Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	03-01-2025	08:12:00	03-01-2025	17:03:00	0.37	0.00	0.00	0.00	8.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/349 (403-405Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	09-01-2025	09:04:00	09-01-2025	23:07:00	0.59	0.00	0.00	0.00	14.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1487 (396 - 397 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	11-01-2025	08:43:00	11-01-2025	17:05:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1880 (407 - 408 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	01-01-2025	08:50:00	01-01-2025	18:25:00	0.40	0.00	0.00	0.00	9.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/39 (404 - 404Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	26-01-2025	08:29:00	26-01-2025	14:51:00	0.27	0.00	0.00	0.00	6.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4326 (408 -410 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	17-01-2025	08:28:00	17-01-2025	17:25:00	0.37	0.00	0.00	0.00	8.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2714 (402-402 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	07-01-2025	07:26:00	07-01-2025	18:41:00	0.47	0.00	0.00	0.00	11.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1095/400 - 402Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	22-01-2025	06:59:00	22-01-2025	20:15:00	0.55	0.00	0.00	0.00	13.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3561 (402-403Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	05-01-2025	09:20:00	05-01-2025	15:50:00	0.27	0.00	0.00	0.00	6.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/742 (395-396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	23-01-2025	07:32:00	23-01-2025	16:17:00	0.37	0.00	0.00	0.00	8.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3757/400 - 401Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	18-01-2025	08:38:00	18-01-2025	17:10:00	0.36	0.00	0.00	0.00	8.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2886 (402 - 402Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	27-01-2025	08:21:00	27-01-2025	17:18:00	0.37	0.00	0.00	0.00	8.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4455 (401-401Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	20-01-2025	08:16:00	20-01-2025	17:33:00	0.39	0.00	0.00	0.00	9.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3164 (409 -410 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	13-01-2025	09:32:00	13-01-2025	16:26:00	0.29	0.00	0.00	0.00	6.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2159 (397 -400 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	31-01-2025	07:01:00	31-01-2025	16:20:00	0.39	0.00	0.00	0.00	9.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5242 (405-405Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	30-01-2025	09:08:00	30-01-2025	19:33:00	0.43	0.00	0.00	0.00	10.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5037 (397-398 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	29-01-2025	08:33:00	29-01-2025	16:45:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4848 (403-403) Kv.
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	25-01-2025	08:49:00	25-01-2025	17:15:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4158 (402 - 402Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	19-01-2025	09:22:00	19-01-2025	14:28:00	0.21	0.00	0.00	0.00	5.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3049 (403-404Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	24-01-2025	07:46:00	24-01-2025	16:56:00	0.38	0.00	0.00	0.00	9.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3957/406 - 406Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	21-01-2025	08:18:00	21-01-2025	17:18:00	0.38	0.00	0.00	0.00	9.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3371 (408 -410 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	10-01-2025	07:58:00	10-01-2025	16:21:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1692 (404-405 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	28-01-2025	08:00:00	28-01-2025	16:28:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4650 (410-410Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	15-01-2025	09:06:00	15-01-2025	16:34:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2415/395 - 396Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	06-01-2025	08:26:00	06-01-2025	17:33:00	0.38	0.00	0.00	0.00	9.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/883 (400 -401 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	08-01-2025	07:02:00	08-01-2025	17:06:00	0.42	0.00	0.00	0.00	10.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1299/407 - 410Kv).
							10.46	0.00	0.00	0.00	250.72	100.00	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	08-01-2025	09:32:00	08-01-2025	17:11:00	0.32	0.00	0.00	0.00	7.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1321/396 - 396Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	07-01-2025	07:30:00	07-01-2025	20:08:00	0.53	0.00	0.00	0.00	12.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1096/402 - 403Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	17-01-2025	09:51:00	17-01-2025	17:28:00	0.32	0.00	0.00	0.00	7.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2738 (393 - 395Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	06-01-2025	08:30:00	06-01-2025	17:36:00	0.38	0.00	0.00	0.00	9.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/884 (401 -401 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	21-01-2025	08:22:00	21-01-2025	20:34:00	0.51	0.00	0.00	0.00	12.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3372 (410 - 410 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	15-01-2025	09:09:00	15-01-2025	16:38:00	0.31	0.00	0.00	0.00	7.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2416/396 - 397Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	19-01-2025	09:27:00	19-01-2025	14:30:00	0.21	0.00	0.00	0.00	5.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3050 (404-406Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	18-01-2025	08:43:00	18-01-2025	17:14:00	0.36	0.00	0.00	0.00	8.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2887 (402 - 404Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	13-01-2025	09:39:00	13-01-2025	19:33:00	0.41	0.00	0.00	0.00	9.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2160 (400 -402 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	01-01-2025	08:53:00	01-01-2025	18:29:00	0.40	0.00	0.00	0.00	9.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/140 (404 - 407Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	02-01-2025	09:41:00	02-01-2025	16:36:00	0.29	0.00	0.00	0.00	6.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/194 (392 -393 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	03-01-2025	08:18:00	03-01-2025	17:06:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/350 (405-405Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	31-01-2025	07:03:00	31-01-2025	16:25:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5243 (405-406Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	11-01-2025	08:46:00	11-01-2025	17:24:00	0.36	0.00	0.00	0.00	8.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1881 (408 -408 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	22-01-2025	08:33:00	22-01-2025	20:18:00	0.49	0.00	0.00	0.00	11.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3581 (400 - 400) Kv.
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	10-01-2025	08:02:00	10-01-2025	16:24:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1693 (405-406 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	24-01-2025	09:25:00	25-01-2025	17:18:00	1.33	0.00	0.00	0.00	31.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3968 (393 - 394Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	09-01-2025	09:20:00	09-01-2025	23:10:00	0.58	0.00	0.00	0.00	13.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1509 (395 - 395 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	20-01-2025	08:19:00	20-01-2025	21:22:00	0.54	0.00	0.00	0.00	13.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3165 (406 - 409 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	29-01-2025	08:35:00	29-01-2025	16:50:00	0.34	0.00	0.00	0.00	8.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4849 (403-403) Kv.
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	23-01-2025	07:38:00	23-01-2025	16:20:00	0.36	0.00	0.00	0.00	8.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3758/401 - 403Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	05-01-2025	09:25:00	05-01-2025	15:53:00	0.27	0.00	0.00	0.00	6.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/743 (396-396 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	27-01-2025	08:23:00	28-01-2025	21:06:00	1.53	0.00	0.00	0.00	36.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4456 (401-403Kv).
							10.95	0.00	0.00	0.00	262.49	100.00	
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	08-01-2025	06:59:00	08-01-2025	23:22:00	0.68	0.00	0.00	0.00	16.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1298/407 - 407Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD											

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	13-01-2025	09:29:00	13-01-2025	16:21:00	0.29	0.00	0.00	0.00	6.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2158 (397 -397 Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	22-01-2025	06:55:00	22-01-2025	20:11:00	0.55	0.00	0.00	0.00	13.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3560 (401-402Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	12-01-2025	08:36:00	12-01-2025	17:14:00	0.36	0.00	0.00	0.00	8.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2031 (406-407Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	27-01-2025	08:19:00	27-01-2025	17:23:00	0.38	0.00	0.00	0.00	9.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4454 (400-401Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	06-01-2025	08:23:00	06-01-2025	17:30:00	0.38	0.00	0.00	0.00	9.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/882 (397 -400 Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	25-01-2025	08:45:00	25-01-2025	17:12:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4157 (400 - 402Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	20-01-2025	08:13:00	20-01-2025	17:28:00	0.39	0.00	0.00	0.00	9.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3171 (404 - 406 Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	10-01-2025	07:55:00	10-01-2025	16:18:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1691 (403-404 Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	26-01-2025	08:25:00	26-01-2025	14:47:00	0.27	0.00	0.00	0.00	6.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4325 (406 -408 Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	17-01-2025	08:25:00	17-01-2025	17:21:00	0.37	0.00	0.00	0.00	8.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2713 (400-402 Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	05-01-2025	09:17:00	05-01-2025	15:46:00	0.27	0.00	0.00	0.00	6.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/741 (395-395 Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	29-01-2025	08:28:00	29-01-2025	19:53:00	0.48	0.00	0.00	0.00	11.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4847 (403-403) Kv.
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	16-01-2025	09:08:00	16-01-2025	17:47:00	0.36	0.00	0.00	0.00	8.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2550 (394 - 394Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	07-01-2025	07:24:00	07-01-2025	18:36:00	0.47	0.00	0.00	0.00	11.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1094(400 - 400Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	28-01-2025	07:58:00	28-01-2025	16:18:00	0.35	0.00	0.00	0.00	8.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4649 (408-410Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	19-01-2025	09:19:00	19-01-2025	14:25:00	0.21	0.00	0.00	0.00	5.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3048 (402-403Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	29-01-2025	08:28:00	29-01-2025	08:28:00	0.00	0.00	0.00	0.00	0.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4847 (403-403) Kv.
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	30-01-2025	09:02:00	30-01-2025	19:28:00	0.44	0.00	0.00	0.00	10.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5036 (397-398 Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	31-01-2025	06:59:00	31-01-2025	16:17:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5241 (404-405Kv).
							11.25	0.00	0.00	0.00	269.07	100.00	
CKT	230kV BHAVINI-ARANI(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV BHAVINI-ARANI(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV BHAVINI-KANCHIPURAM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV BHAVINI-KANCHIPURAM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230 KV-BHAVNI-SIRUSERI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230 KV-BHAVNI-SIRUSERI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV EDAPPON(KSEB)-EDAMON(KSEB)	OSPD	21-01-2025	09:45:00	21-01-2025	17:14:00	0.31	0.00	0.00	0.00	7.48		* Shut down availed by KSEB opportunity utilised for attending SD nature defects in line vide SRLDC code no. CR-01/3379
							0.31	0.00	0.00	0.00	7.48	100.00	
CKT	230kV KARAIKAL(PED)-BAHOUR(PED)	OSPT	18-01-2025	08:55:00	18-01-2025	19:26:00	0.44	10.52	0.00	0.00	0.00		* Shutdown availed for replacement of suspected insulators in the line vide code CR-01/2875.
CKT	230kV KARAIKAL(PED)-BAHOUR(PED)	OSPT	19-01-2025	08:10:00	19-01-2025	18:19:00	0.42	10.15	0.00	0.00	0.00		* Shutdown availed for replacement of suspected CLR insulator in the line.
							0.86	20.67	0.00	0.00	0.00	97.22	
CKT	220kV KUNDRA(KSEB)-EDAMON(KSEB)	OMSU	04-01-2025	09:51:00	04-01-2025	10:22:00	0.02	0.00	0.52	0.00	0.00		* Line tripped at Kundra end only, no indication (Relay both end belong to KSEB)
							0.02	0.00	0.52	0.00	0.00	100.00	
CKT	220kV KAYAMKULAM(KSEB)-EDAPPON(KSEB)	OSPD	22-01-2025	08:51:00	22-01-2025	15:49:00	0.29	0.00	0.00	0.00	6.97		* Shut down availed for maintenance works by KSEB and Opp sd by patinamthitta TLM for attending sd nature defects vide SRLDC code no. CR- 01/3583.
							0.29	0.00	0.00	0.00	6.97	100.00	
CKT	220kV KAYAMKULAM(KSEB)-KUNDRA(KSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAYAMKULAM(KSEB)-POLLAM(KSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAYAMKULAM(KSEB)-PUNNAPRA(KSEB)-1	OSPD	08-01-2025	11:17:00	08-01-2025	18:09:00	0.29	0.00	0.00	0.00	6.87		* Shut down availed by KSEB for maintenance works vide SRLDC code no. CR-01/1341
							0.29	0.00	0.00	0.00	6.87	100.00	
CKT	230kV NEYVELI(NLC)-KARAICAL(PED)-1	OSPD	11-01-2025	09:34:00	12-01-2025	18:08:00	1.36	0.00	0.00	0.00	32.57		* Shut down availed for AMP works vide SRLDC code no. CR-01/1900.
							1.36	0.00	0.00	0.00	32.57	100.00	
CKT	230kV NEYVELI(NLC)-VILLIANUR(PED)-1	LPRD	01-01-2025	11:24:00	31-01-2025	23:59:59	30.53	0.00	0.00	0.00	732.60		* Hand tripped from Neyveli end only as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 01/66
							30.53	0.00	0.00	0.00	732.60	100.00	
CKT	220kV PUNNAPRA(KSEB)-POLLAM(KSEB)-1	OMSU	22-01-2025	10:32:00	22-01-2025	11:05:00	0.02	0.00	0.55	0.00	0.00		* Line tripped at New Pollam end only without any indication.
CKT	220kV PUNNAPRA(KSEB)-POLLAM(KSEB)-1	OSPD	18-01-2025	08:09:00	18-01-2025	17:58:00	0.41	0.00	0.00	0.00	9.82		* Shutdown availed by KSEB for annual maintenance and relay testing at Punnapra end vide code CR-01/2874.
CKT	220kV PUNNAPRA(KSEB)-POLLAM(KSEB)-1	OSPD	08-01-2025	11:08:00	08-01-2025	18:07:00	0.29	0.00	0.00	0.00	6.98		* Shut down availed by KSEB for maintenance works vide SRLDC code no. CR-01/1341
							0.72	0.00	0.55	0.00	16.80	100.00	
CKT	220kV TIRUNELVELI-EDAMON(KSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV TIRUNELVELI-EDAMON(KSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV ALMATY-TIRUVALAM-1	OSPD	07-01-2025	10:09:00	07-01-2025	15:15:00	0.21	0.00	0.00	0.00	5.10		* Shut down availed by TNEB for attending jumper cut at loc. 187 vide SRLDC code no. CR-01/1128
							0.21	0.00	0.00	0.00	5.10	100.00	
CKT	400 KV ALMATY-TIRUVALAM-2	OSPD	18-01-2025	10:14:00	18-01-2025	16:20:00	0.25	0.00	0.00	0.00	6.10		* Emergency shutdown availed by TNEB for rectification of opened jumper at Loc no:193 (TNEB Jurisdiction) vide SRLDC code no. CR- 01/2911.
CKT	400 KV ALMATY-TIRUVALAM-2	OSPT	30-01-2025	08:35:00	30-01-2025	17:31:00	0.37	8.93	0.00	0.00	0.00		* Shutdown availed by SPDR SS for 406-Bay LBB retrofitting works vide SRLDC CR.01/5026.
							0.62	8.93	0.00	0.00	6.10	98.80	
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(NTECL)-1	OSPT	24-01-2025	10:58:00	24-01-2025	18:57:00	0.33	7.98	0.00	0.00	0.00		* Shut Down availed for reterofitting of 403bay LBB relay at Almathy end vide SRLDC code no. CR-01/4010.
							0.33	7.98	0.00	0.00	0.00	98.93	
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(NTECL)-2	OSPT	31-01-2025	11:10:00	31-01-2025	17:52:00	0.28	6.70	0.00	0.00	0.00		* Shut down availed for LBB relays retrofitting works at Almathy SS vide SRLDC code no. CR-01/5283.
							0.28	6.70	0.00	0.00	0.00	99.10	
CKT	400kV CHITTOOR(APTRANSCO)-SRIPERUMBUDUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GOOTY-SOMANAHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV MYSORE-KOZHICODE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELLI TS2-NEYVELLI TS1 EXP			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELI TS2(NLC)-KARUR-1	OSPD	02-01-2025	09:27:00	02-01-2025	18:20:00	0.37	0.00	0.00	0.00	8.88		* Shutdown availed by NLC to carry out CB timings and transducer replacement works vide code CR-01/190.
							0.37	0.00	0.00	0.00	8.88	100.00	
CKT	400kV NEYVELLI TS2 EXP(NLC) EXP-KARUR	OSPD	29-01-2025	08:04:00	30-01-2025	19:01:00	1.46	0.00	0.00	0.00	34.95		* Shut down availed by Neyveli TS2 for Maint works vide SRLDC code no. CR-01/4829.Under Opp by Karur SS <-> TLM, Neyveli TLM
CKT	400kV NEYVELLI TS2 EXP(NLC) EXP-KARUR	LART	24-01-2025	06:37:00	24-01-2025	06:37:00	0.00	0.00	0.00	0.00	0.00		* Line AR Successful on Y -G fault. Neyveli TS II end details: M1: FLR: 137.7 KM, FC: 2.31 Kamps, M2: NR . Pugalur end details:M1: FLR: 50.3 KM, FC: 5.80 Kamps, M2: FLR: 51.20 KM, FC: 5.48 Kamps* Fault is in Karur TLM Jurisdiction.
							1.46	0.00	0.00	0.00	34.95	100.00	
CKT	400kV NEYVELI(NLC)-SALEM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGAPATTINAM-NEYVELI TS1(NLC) EXP			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGAPATTINAM-NEYVELI TS2(NLC)	OSPD	17-01-2025	09:09:00	18-01-2025	18:06:00	1.37	0.00	0.00	0.00	32.95		* Shutdown availed by NLC for relay testing and annunciator replacement works vide code CR-01/2718.
							1.37	0.00	0.00	0.00	32.95	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OMSU	25-01-2025	15:17:00	25-01-2025	16:36:00	0.06	0.00	1.32	0.00	0.00		* Line tripped on B Phase to Ground fault. Hassan end details: M1: 153.9KM, 2.0KA, M2: 166.5KM, 2.08KA, Nelamangala end details: M1: 3= 9.8KM, 6.6KA, M2: 39KM, 4.5KA, Fault in KPTCL Jurisdiction.
							0.06	0.00	1.32	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-PUDUCHERRY-1	OSPD	24-01-2025	09:34:00	31-01-2025	23:59:59	7.60	0.00	0.00	0.00	182.43		* Shut down availed for NHAI diversion works vide SRLDC code no. CR-01/3991.
							7.60	0.00	0.00	0.00	182.43	100.00	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-2	LVRD	01-01-2025	02:24:00	01-01-2025	07:43:00	0.22	0.00	0.00	0.00	5.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/03 (426 - 424 Kv).
							0.22	0.00	0.00	0.00	5.32	100.00	
CKT	400kV PUGALUR-ARASUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-ARASUR-2	OSPT	04-01-2025	11:59:00	04-01-2025	14:38:00	0.11	2.65	0.00	0.00	0.00		* Emergency shutdown availed to attend hsspot in 401-89L (y phase) isolator
							0.11	2.65	0.00	0.00	0.00	99.64	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PALAKKAD-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PALAKKAD-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUDUCHERRY-SVCHATRAM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR HVAC-KARUR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR HVAC-KARUR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-1	OSPD	16-01-2025	09:30:00	16-01-2025	18:57:00	0.39	0.00	0.00	0.00	9.45		* Shut down availed by KPTCL vide SRLDC code no. CR-01/2560.
							0.39	0.00	0.00	0.00	9.45	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-2	OSPD	17-01-2025	09:37:00	17-01-2025	16:38:00	0.29	0.00	0.00	0.00	7.02		* Shutdown availed by KPTCL for maintenance works vide code CR-01/2723.
							0.29	0.00	0.00	0.00	7.02	100.00	
CKT	400 KV PAVAGADA-DEVANAHALLI(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV PAVAGADA-DEVANAHALLI(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-HIRIYUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	30-01-2025	20:55:00	31-01-2025	23:59:59	1.13	0.00	0.00	0.00	27.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/5187(423 - 421Kv).
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	13-01-2025	21:02:00	17-01-2025	07:28:00	3.44	0.00	0.00	0.00	82.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2260 (418-416 Kv).
CKT	400kV PAVAGADA-TUMKUR-1	OSPD	27-01-2025	08:22:00	27-01-2025	15:37:00	0.30	0.00	0.00	0.00	7.25		* Line shutdown availed by KPTCL vide SRLDC code: 01/4463
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	26-01-2025	17:45:00	27-01-2025	08:22:00	0.61	0.00	0.00	0.00	14.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4382 (412-412Kv).

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	27-01-2025	15:37:00	29-01-2025	13:09:00	1.90	0.00	0.00	0.00	45.53		* After completion of KPTCL Works, Line kept open as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4518.
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	01-01-2025	00:00:01	13-01-2025	13:36:00	12.57	0.00	0.00	0.00	301.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 12/4288(423-421Kv).
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	18-01-2025	19:40:00	23-01-2025	08:21:00	4.53	0.00	0.00	0.00	108.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3000 (418 - 418 Kv).
							24.48	0.00	0.00	0.00	587.19	100.00	
CKT	400kV PAVAGADA-TUMKUR-2	OSPD	28-01-2025	09:13:00	28-01-2025	16:55:00	0.32	0.00	0.00	0.00	7.70		* Shutdown availed for KPTCL vide SRLDC code: 01/4663
							0.32	0.00	0.00	0.00	7.70	100.00	
CKT	400kV PAVAGADA-TUMKUR-3	LVRD	14-01-2025	20:30:00	15-01-2025	06:19:00	0.41	0.00	0.00	0.00	9.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2351(427 - 427Kv).
							0.41	0.00	0.00	0.00	9.82	100.00	
CKT	400kV PAVAGADA-TUMKUR-4	LVRD	14-01-2025	20:32:00	16-01-2025	09:44:00	1.55	0.00	0.00	0.00	37.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2352(427 - 427Kv).
CKT	400kV PAVAGADA-TUMKUR-4	LVRD	26-01-2025	16:30:00	27-01-2025	08:27:00	0.67	0.00	0.00	0.00	15.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4367 (413-412Kv).
CKT	400kV PAVAGADA-TUMKUR-4	LVRD	19-01-2025	18:06:00	20-01-2025	10:17:00	0.67	0.00	0.00	0.00	16.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3105
CKT	400kV PAVAGADA-TUMKUR-4	LVRD	01-01-2025	00:00:01	02-01-2025	09:57:00	1.42	0.00	0.00	0.00	33.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 12/4425 (414 -413 Kv).
CKT	400kV PAVAGADA-TUMKUR-4	LVRD	05-01-2025	20:22:00	06-01-2025	11:43:00	0.64	0.00	0.00	0.00	15.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/827(424 - 422Kv).
							4.95	0.00	0.00	0.00	118.63	100.00	
CKT	400kV PAVAGADA-MYSORE	LVRD	13-01-2025	19:48:00	17-01-2025	06:44:00	3.46	0.00	0.00	0.00	82.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/2254 (413 - 412 Kv).
CKT	400kV PAVAGADA-MYSORE	LVRD	05-01-2025	17:23:00	08-01-2025	09:59:00	2.69	0.00	0.00	0.00	64.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/809(413 410- Kv). LR converted as BR.
CKT	400kV PAVAGADA-MYSORE	LVRD	26-01-2025	16:27:00	27-01-2025	08:46:00	0.68	0.00	0.00	0.00	16.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/4366 (415-413Kv).
							6.83	0.00	0.00	0.00	163.85	100.00	
CKT	400kV SALEM-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-NNTPS(NLC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-UDUMALPET-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV-SOMANHALI-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANHALI-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANHALI-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANHALI-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANHALI-HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV-SOMANHALI-MYLASANDRA-1	OSPD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Shut down availed by KPTCL for construction and commissioning of Dommasandra substation vide SRLDC code CR.12/283.
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	400kV SVCHATRM(TANTRANSCO)-SRIPERMBUDR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-KOCHI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-KOCHI-2	OSPT	07-01-2025	09:41:00	07-01-2025	19:42:00	0.42	10.02	0.00	0.00	0.00		
							0.42	10.02	0.00	0.00	0.00	98.65	
CKT	400kV TRICHUR HVDC-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV THIRUNELVELI-KOTTAYAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV THIRUNELVELI-KOTTAYAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TRIVANDRUM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TRIVANDRUM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-TUTICORIN PS	OSPT	27-01-2025	09:06:00	27-01-2025	14:00:00	0.20	4.90	0.00	0.00	0.00		* Shutdown availed for AMP works vide SRLDC code: 01/4464
							0.20	4.90	0.00	0.00	0.00	99.34	
CKT	400kV TIRUNELVELI-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-UDUMALPET-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-KARAIKUDI-1	LCSD	20-01-2025	09:16:00	21-01-2025	22:03:00	1.53	0.00	0.00	0.00	36.78		* Shut down availed for MB box replacement works @ Trichy SS vide SRLDC code no. CR-01/3186
							1.53	0.00	0.00	0.00	36.78	100.00	
CKT	400kV TRICHY-MADURAI-1	LCSD	10-01-2025	08:51:00	12-01-2025	13:07:00	2.18	0.00	0.00	0.00	52.27		* Shutdown availed for replacement of 410 <(>&< > 411 Bay CT's MB and interpolate CT cabling <(>&< > testing under ADD cap vide SRLDC code no. CR- 01/1699.
							2.18	0.00	0.00	0.00	52.27	100.00	
CKT	400kV TRICHY-NAGAPATTANAM-1	LCSD	06-01-2025	08:59:00	07-01-2025	23:02:00	1.59	0.00	0.00	0.00	38.05		* Replacement of 402 <(>&< > 403 CT MBs at Trichy SS under ADD CAP and Maintenance works at Trichy TLM, Nagapattinum SS <(>&< > TL.
							1.59	0.00	0.00	0.00	38.05	100.00	
CKT	400kV TRICHY-NAGAPATTANAM-2	LCSD	23-01-2025	09:46:00	25-01-2025	00:43:00	1.62	0.00	0.00	0.00	38.95		* Shut down availed for replacement of CT MB boxes <(>&< > interpolate cables vide SRLDC code no. CR-01/3788
							1.62	0.00	0.00	0.00	38.95	100.00	
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-KALVINDAPATTU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-KALVINDAPATTU-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-SRIPERUMDUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN GIS -TUTICORIN PS- 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-KUDAMKULAM(NPCIL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-TUTICORIN JV(NTPL)-1	OMSU	26-01-2025	08:04:00	31-01-2025	23:59:59	5.66	0.00	135.93	0.00	0.00		* Line tripped at NTPL end only.SF6 gas pressure low observed at NTPL end.
CKT	400kV TUTICORIN PS-TUTICORIN JV(NTPL)-1	OSPT	21-01-2025	09:21:00	21-01-2025	18:00:00	0.36	8.65	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-01/3380
CKT	400kV TUTICORIN PS-TUTICORIN JV(NTPL)-1	OSPT	02-01-2025	09:31:00	02-01-2025	19:14:00	0.41	9.72	0.00	0.00	0.00		* Shutdown availed by Tuticorin PS TLM for applying antirust painting on Tower structure vide code CR-01/189.
							6.43	18.37	135.93	0.00	0.00	96.98	
CKT	400kV TUTICORIN PS-TUTICORIN JV(NTPL)-2	OSPT	04-01-2025	09:23:00	04-01-2025	19:00:00	0.40	9.62	0.00	0.00	0.00		* Shutdown availed for applying anti rust painting on structure/ tower parts/ cross arms to avoid damages
							0.40	9.62	0.00	0.00	0.00	98.71	
CKT	400kV UDMALPET-ARASUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDMALPET-ARASUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET-E.PALAYM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET-E.PALAYM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET -PALLAKAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV UDUMAPALET -PALLAKAD-2	LCSD	29-01-2025	09:42:00	30-01-2025	18:16:00	1.36	0.00	0.00	0.00	32.57		* Replacement of 405 <(>&<)> 406 CT MBs at Udumalpet SS under ADD CAP and Maintenance works at Udumalpet TLM, Palakkad SS <(>&<)> TL.
							1.36	0.00	0.00	0.00	32.57	100.00	
CKT	400kV VALLUR(NTECL)-KALIVANTHAPATTU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VALLUR(NTECL)-KALIVANTHAPATTU-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV YELHANKA GIS-DEVANAHALLI(KPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV YELHANKA-NELAMANGALA(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV YELAHANKA GIS-TUMKUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV YELAHANKA GIS-TUMKUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DHARAMPURI-TUMKUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KUDGI-KOLHAPUR GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KUDGI-KOLHAPUR GIS-2	OSPT	05-01-2025	08:50:00	05-01-2025	20:06:00	0.47	11.27	0.00	0.00	0.00		* Shut down availed for AMP works at SS <(>&<)> Attending critical shutdown nature defects in TLM vide SRLDC code no. CR-01/726
							0.47	11.27	0.00	0.00	0.00	98.49	
CKT	400KV TUTICORIN PS-DHARAMPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN PS-DHARAMPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF VALLUR-1 AT KALIVANTPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF KOTTAYAM-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF KOTTAYAM-2 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF MYSORE-1 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF MYSORE-2 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF TRICHY AT MADURAI	SVRD	01-01-2025	00:00:01	29-01-2025	13:26:00	28.56	0.00	0.00	0.00	885.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/81(389 - 389Kv).
							28.56	0.00	0.00	0.00	885.43	100.00	
LNR	63MVAR,SWLR OF KARAUKUDI AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF HIRIYUR AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF PAVAGADA AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR SWLR OF TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR SWLR OF TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NEYVELI-2 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NEYVELI-1 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF HOSUR-2 AT SALEM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KOLAR AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF CHITTOOR AT SRIPERUMBUDUR	SVRD	24-01-2025	08:46:00	31-01-2025	23:59:59	7.64	0.00	0.00	0.00	183.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3970(401 - 401Kv).
							7.64	0.00	0.00	0.00	183.23	100.00	
LNR	50MVAR,SWLR OF SVCHATRAM AT SRIPERUMBUR	SVRD	24-01-2025	08:33:00	31-01-2025	23:59:59	7.64	0.00	0.00	0.00	183.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3971(401 - 401Kv).
							7.64	0.00	0.00	0.00	183.45	100.00	
LNR	50MVAR,SWLR OF PALAKKAD-1 AT THRISSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PALAKKAD-2 AT THRISSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF UDUMALPT-1 AT TIRUNELVELI	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/84(399 - 399Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	63MVAR,SWLR OF UDUMALPT-2 AT TIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF NAGAPATTINAM-1 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF NAGAPATTINAM-2 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KADAPA-1 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KADAPA-2 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NELLORE-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NELLORE-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SALEM-2 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF TIRUNELVELI-2 AT UDUMALPT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF TIRUNELVELI-1 AT UDUMALPT			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-200/+200 MVAR STATCOM AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-200/+200 MVAR STATCOM AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	LART	07-01-2025	07:13:00	07-01-2025	07:13:00	0.00	0.00	0.00	0.00	0.00		* LFL and DC line fault recovery sequence operated <(>&<)> cleared in second attempt. Kolar SS end: 126.4 km, Tower no. 3352. Fault is in SR-I, Kadapa jurisdiction.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	LART	03-01-2025	06:14:00	03-01-2025	06:14:00	0.00	0.00	0.00	0.00	0.00		* LFL and DC line fault recovery sequence operated and cleared in second attempt at 114.4 km from Kolar end (Tower no. 3386). Fault is in SR-I Jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-2	OSPT	23-01-2025	09:18:00	23-01-2025	22:31:00	0.55	13.22	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-01/3772.
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-2	OSPT	22-01-2025	09:39:00	23-01-2025	01:39:00	0.67	16.00	0.00	0.00	0.00		* Shut down availed for AMP works at Pugalur SS , Thrissur SS <(>&<)> Shutdown nature defects attn works at Palakkad TLM,Pugalur TLM, Udumalpet TLM vide SRLDC code no. CR-01/3582.
XMER	315MVA,400/220kV ICT-1 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT ARASUR	OSPT	17-01-2025	06:00:00	18-01-2025	06:48:00	1.03	24.80	0.00	0.00	0.00		* Shut down availed for attending oil mixing from main tank to OLTC by OEM vide SRLDC code no. CR-01/2663
							1.03	24.80	0.00	0.00	0.00	96.67	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage In Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyn	Detailed Reasons for Outage
XMER	500MVA,400/220kV ICT-1 AT BIDADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BIDADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/230kV ICT-4 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KARAIKUDI	OSPT	08-01-2025	09:00:00	08-01-2025	15:36:00	0.28	6.60	0.00	0.00	0.00		* Shut down availed for bushing capacitance <(>&<)> Tan delta testing works vide SRLDC code no. CR-01/1310
							0.28	6.60	0.00	0.00	0.00	99.11	
XMER	500MVA,400/220kV ICT-3 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-1 AT PUDUCHERRY	OSFT	20-01-2025	17:36:00	20-01-2025	18:08:00	0.02	0.53	0.00	0.00	0.00		* Emergecny Shut down taken for removal of kite thread which is hanging from 230 kV side LA to Tertiary side of the ICT-1 vide SRLDC code no. CR-01/3280.
							0.02	0.53	0.00	0.00	0.00	99.93	
XMER	315MVA,400/220kV ICT-2 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PUDUCHERRY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KARUR	SPRD	31-01-2025	09:27:00	31-01-2025	09:57:00	0.02	0.00	0.00	0.00	0.50		* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 01/5260 (194/263, 194/0, 0/0).
							0.02	0.00	0.00	0.00	0.50	100.00	
XMER	500MVA,400/220kV ICT-3 AT KARUR	SPRD	31-01-2025	09:22:00	31-01-2025	12:53:00	0.15	0.00	0.00	0.00	3.52		* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 01/5261 (138/202, 138/202, 250/0).
							0.15	0.00	0.00	0.00	3.52	100.00	
XMER	500MVA,400/220kV ICT-1 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-6 AT PAVAGADA	SICT	06-01-2025	21:37:00	07-01-2025	02:59:00	0.22	5.37	0.00	0.00	0.00		* ICT tripped due to fault in 220kV side R ph Bushing connected Cable fault.* 04.02.2025 11:36:10 INDIA (60001965) Phone 08212402529* Tripped due to damage in 220kV Cable connection to air Bushing
							0.22	5.37	0.00	0.00	0.00	99.28	
XMER	500MVA,400/220kV ICT-1 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT THIRUNELVELI	OSPT	01-01-2025	00:00:01	02-01-2025	23:19:00	1.97	47.32	0.00	0.00	0.00		* ICT Shut down availed for IV side Yph Bushing replacement works vide SRLDC code no. CR-12/4028.
							1.97	47.32	0.00	0.00	0.00	93.64	
XMER	315MVA,400/220kV ICT-1 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRICHY	SCSD	27-01-2025	09:58:00	28-01-2025	18:32:00	1.36	0.00	0.00	0.00	32.57		* Shutdown availed for replacement of 413 bay <*> 414 bay CT MB boxes and interpolate CT Cables and testing under add cap works at Trichy SS
							1.36	0.00	0.00	0.00	32.57	100.00	
XMER	500MVA,400/220kV ICT-2 AT TRICHY	SCSD	18-01-2025	10:32:00	19-01-2025	22:41:00	1.51	0.00	0.00	0.00	36.15		* Shutdown availed for replacement of 415 <*> 414 Bay CT's along with MB boxes, Interpole CT cables and testing under ADD Cap works vide SRLDC code no. CR- 01/2919.
							1.51	0.00	0.00	0.00	36.15	100.00	
XMER	500MVA,400/220kV ICT-3 AT TRICHY	SCSD	11-01-2025	09:23:00	12-01-2025	12:57:00	1.15	0.00	0.00	0.00	27.57		* Shut down availed for replacement of CT MB boxes vide SRLDC code no. CR-01/1900 .
							1.15	0.00	0.00	0.00	27.57	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRIVENDRAM	OSPT	02-01-2025	09:47:00	02-01-2025	15:35:00	0.24	5.80	0.00	0.00	0.00		* Shutdown availed for 205 Bay LBB relay retrofitting works vide code CR-01/191.
							0.24	5.80	0.00	0.00	0.00	99.22	
XMER	315MVA,400/220kV ICT-2 AT TRIVENDRAM	OSPT	04-01-2025	09:33:00	04-01-2025	14:59:00	0.23	5.43	0.00	0.00	0.00		* Shutdown availed for retrofitting 206 bay LBB Relay vide SRLDC code: 01/571
							0.23	5.43	0.00	0.00	0.00	99.27	
XMER	315MVA,400/220kV ICT-3 AT TRIVENDRAM	OSPT	06-01-2025	09:39:00	06-01-2025	16:55:00	0.30	7.27	0.00	0.00	0.00		* ICT Shut down availed for Retrofitting of LBB Realy vide SRLDC code no. CR-01/910.
							0.30	7.27	0.00	0.00	0.00	99.02	
XMER	500MVA,400/220kV ICT-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	TuticorinGIS ICT3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT UDUMALPET	OSPD	07-01-2025	10:26:00	11-01-2025	16:39:00	4.26	0.00	0.00	0.00	102.22		

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							4.26	0.00	0.00	0.00	102.22	100.00	
XMER	315MVA,400/220kV ICT-2 AT UDUMALPET	OSPD	02-01-2025	11:04:00	04-01-2025	22:11:00	2.46	0.00	0.00	0.00	59.12		* Shutdown availed by TANTRANSCO for dismantling of existing LV side Isolator RCC structure and erection of new metal structure at 230kV Myvadi Substation vide code CR-01/207
							2.46	0.00	0.00	0.00	59.12	100.00	
XMER	315MVA,400/220kV ICT-3 AT UDUMALPET	OSPD	20-01-2025	10:13:00	24-01-2025	18:25:00	4.34	0.00	0.00	0.00	104.20		* ICT#2 Shut down availed by TNEB for Isolator replacement works by TNEB vide SRLDC code no. CR-01/3200* 21.01.2025 06:38:19 INDIA (60003469)** ICT#3 Shut down availed by TNEB for Isolator replacement works at Myvadi SS(TNEB) vide SRLDC code no. CR-01/3200.
							4.34	0.00	0.00	0.00	104.20	100.00	
XMER	500MVA,400/220kV ICT-1 AT YELHANKA	OSPT	13-01-2025	13:18:00	13-01-2025	14:55:00	0.07	1.62	0.00	0.00	0.00		* Emergency Shutdown availed for IV side 209 B-Ph LA Replacement work vide SRLDC code 01/2187.
							0.07	1.62	0.00	0.00	0.00	99.78	
XMER	500MVA,400/220kV ICT-2 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	