

Standard of Performance data for the month of Mar-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	17-03-2025	07:52:00	17-03-2025	18:10:00	0.43	0.00	0.00	0.00	10.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3322 (400-401Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	03-03-2025	07:04:00	03-03-2025	17:23:00	0.43	0.00	0.00	0.00	10.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/377 (406-409 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	02-03-2025	08:15:00	02-03-2025	16:42:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/234 (408 -408) Kv.
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	18-03-2025	08:05:00	18-03-2025	17:27:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3522(400 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	01-03-2025	00:00:01	01-03-2025	17:16:00	0.72	0.00	0.00	0.00	17.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5881 (401-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	07-03-2025	06:52:00	07-03-2025	18:05:00	0.47	0.00	0.00	0.00	11.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1335(398 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	06-03-2025	08:16:00	06-03-2025	17:18:00	0.38	0.00	0.00	0.00	9.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1122 (396 -396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	08-03-2025	08:13:00	08-03-2025	17:41:00	0.39	0.00	0.00	0.00	9.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1610 (402-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	11-03-2025	08:01:00	11-03-2025	18:00:00	0.42	0.00	0.00	0.00	9.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2184 (401-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	12-03-2025	07:13:00	12-03-2025	20:08:00	0.54	0.00	0.00	0.00	12.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2394(401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	10-03-2025	06:58:00	10-03-2025	18:30:00	0.48	0.00	0.00	0.00	11.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1976(401-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	09-03-2025	08:02:00	09-03-2025	17:02:00	0.38	0.00	0.00	0.00	9.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1791 (406-408 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	05-03-2025	08:45:00	05-03-2025	17:11:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/875 (396 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	04-03-2025	06:53:00	04-03-2025	16:16:00	0.39	0.00	0.00	0.00	9.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/600 (405 -405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	31-03-2025	08:33:00	31-03-2025	23:59:59	0.64	0.00	0.00	0.00	15.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6076 (402 -402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	27-03-2025	08:38:00	28-03-2025	16:57:00	1.35	0.00	0.00	0.00	32.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5306 (405 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	29-03-2025	10:06:00	29-03-2025	17:13:00	0.30	0.00	0.00	0.00	7.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5716(391 - 391Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	25-03-2025	08:41:00	25-03-2025	16:56:00	0.34	0.00	0.00	0.00	8.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4906 (400-401Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	24-03-2025	07:50:00	24-03-2025	18:09:00	0.43	0.00	0.00	0.00	10.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4715 (405 -406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	21-03-2025	06:26:00	22-03-2025	16:38:00	1.43	0.00	0.00	0.00	34.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4166 (404-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	23-03-2025	08:02:00	23-03-2025	16:19:00	0.35	0.00	0.00	0.00	8.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4597 (415 - 417 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	26-03-2025	08:21:00	26-03-2025	17:00:00	0.36	0.00	0.00	0.00	8.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5098 (405 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	20-03-2025	06:54:00	20-03-2025	16:32:00	0.40	0.00	0.00	0.00	9.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3959 (401-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	16-03-2025	08:13:00	16-03-2025	17:35:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3179 (408-408Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	14-03-2025	08:14:00	14-03-2025	19:24:00	0.47	0.00	0.00	0.00	11.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2819 (405 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	13-03-2025	06:43:00	13-03-2025	17:01:00	0.43	0.00	0.00	0.00	10.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2613 (407-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	15-03-2025	08:38:00	15-03-2025	17:31:00	0.37	0.00	0.00	0.00	8.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2997 (398 - 400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	19-03-2025	08:03:00	19-03-2025	17:52:00	0.41	0.00	0.00	0.00	9.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3745 (400-402 Kv).
							13.79	0.00	0.00	0.00	330.43	100.00	
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	15-03-2025	10:36:00	31-03-2025	23:59:59	16.56	0.00	0.00	0.00	397.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3038 (397 - 400 Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	13-03-2025	07:00:00	14-03-2025	19:44:00	1.53	0.00	0.00	0.00	36.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2621 (408-410 Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	12-03-2025	07:21:00	12-03-2025	20:14:00	0.54	0.00	0.00	0.00	12.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2402(404 - 407Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	01-03-2025	00:00:01	11-03-2025	21:04:00	10.88	0.00	0.00	0.00	261.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3641 (395 -397 Kv).
							29.51	0.00	0.00	0.00	708.08	100.00	
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	18-03-2025	08:08:00	18-03-2025	17:34:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3523(403 -406 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	15-03-2025	06:57:00	15-03-2025	17:33:00	0.44	0.00	0.00	0.00	10.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2979(409 - 409Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	03-03-2025	07:09:00	03-03-2025	17:37:00	0.44	0.00	0.00	0.00	10.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/378 (408-411) Kv.
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	17-03-2025	07:56:00	17-03-2025	17:36:00	0.40	0.00	0.00	0.00	9.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3323 (400-401Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	01-03-2025	08:39:00	01-03-2025	17:10:00	0.36	0.00	0.00	0.00	8.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/53 (404-405Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	08-03-2025	08:28:00	09-03-2025	17:41:00	1.38	0.00	0.00	0.00	33.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1611 (408-409Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	07-03-2025	06:59:00	07-03-2025	17:09:00	0.42	0.00	0.00	0.00	10.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1336(402 - 404Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	05-03-2025	08:47:00	05-03-2025	17:16:00	0.35	0.00	0.00	0.00	8.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/876 (399 - 399Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	06-03-2025	08:19:00	06-03-2025	17:39:00	0.39	0.00	0.00	0.00	9.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1123 (401 -401 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	04-03-2025	09:37:00	04-03-2025	16:46:00	0.30	0.00	0.00	0.00	7.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/639 (394 - 394Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	11-03-2025	08:03:00	11-03-2025	18:17:00	0.43	0.00	0.00	0.00	10.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2185 (406-406 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	12-03-2025	08:59:00	12-03-2025	16:48:00	0.33	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2405(399 - 402Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	10-03-2025	06:58:00	10-03-2025	18:40:00	0.49	0.00	0.00	0.00	11.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1977(400-402 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	21-03-2025	06:37:00	21-03-2025	17:46:00	0.47	0.00	0.00	0.00	11.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4167 (408-410 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	26-03-2025	08:17:00	26-03-2025	17:47:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5099 (409 - 411 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	24-03-2025	07:52:00	25-03-2025	17:20:00	1.39	0.00	0.00	0.00	33.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4716 (410 - 411 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	22-03-2025	09:20:00	22-03-2025	16:46:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4406 (385 - 391 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	23-03-2025	08:00:00	23-03-2025	16:37:00	0.36	0.00	0.00	0.00	8.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4598 (411 - 414 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	28-03-2025	08:47:00	28-03-2025	17:08:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5530(402 -402 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	27-03-2025	07:54:00	27-03-2025	17:51:00	0.42	0.00	0.00	0.00	9.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5307 (406 - 409 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	29-03-2025	09:58:00	29-03-2025	17:26:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5717(399 - 394Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	31-03-2025	08:28:00	31-03-2025	16:56:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6077 (401 -404 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	20-03-2025	08:38:00	20-03-2025	16:30:00	0.33	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3990 (405 - 405Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	19-03-2025	08:13:00	19-03-2025	18:14:00	0.42	0.00	0.00	0.00	10.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3746 (406-408 Kv).
							11.23	0.00	0.00	0.00	269.09	100.00	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	08-03-2025	08:29:00	08-03-2025	17:18:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1612 (411-413Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	01-03-2025	08:41:00	01-03-2025	17:14:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/54 (404-405Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	03-03-2025	07:10:00	03-03-2025	17:32:00	0.43	0.00	0.00	0.00	10.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/379 (411-413 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	15-03-2025	08:35:00	15-03-2025	17:38:00	0.38	0.00	0.00	0.00	9.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2998 (400 - 403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	19-03-2025	08:14:00	19-03-2025	18:10:00	0.41	0.00	0.00	0.00	9.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3747 (408-412 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	16-03-2025	08:17:00	16-03-2025	18:50:00	0.44	0.00	0.00	0.00	10.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3180 (410-411Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	18-03-2025										

Standard of Performance data for the month of Mar-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	21-03-2025	06:38:00	21-03-2025	17:41:00	0.46	0.00	0.00	0.00	11.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4168 (410-415 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	26-03-2025	08:32:00	26-03-2025	17:12:00	0.36	0.00	0.00	0.00	8.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5115 (411 - 415 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	22-03-2025	09:21:00	22-03-2025	16:54:00	0.32	0.00	0.00	0.00	7.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4407 (391 - 394 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	04-03-2025	09:39:00	04-03-2025	16:52:00	0.30	0.00	0.00	0.00	7.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/640 (394 - 398Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	11-03-2025	08:05:00	11-03-2025	18:20:00	0.43	0.00	0.00	0.00	10.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2186 (406-409 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	12-03-2025	09:01:00	12-03-2025	16:52:00	0.33	0.00	0.00	0.00	7.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2406(402 - 405Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	09-03-2025	09:40:00	09-03-2025	17:00:00	0.31	0.00	0.00	0.00	7.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1824 (400-402 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	10-03-2025	08:25:00	10-03-2025	18:37:00	0.43	0.00	0.00	0.00	10.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1984 (409-414 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	06-03-2025	08:21:00	06-03-2025	17:43:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1124 (401 -405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	07-03-2025	08:13:00	07-03-2025	17:12:00	0.37	0.00	0.00	0.00	8.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1349 (404 - 408Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	05-03-2025	08:50:00	05-03-2025	17:38:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/877 (399 - 404Kv).
							11.03	0.00	0.00	0.00	264.49	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	01-03-2025	08:43:00	01-03-2025	17:05:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/55 (405-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	08-03-2025	08:41:00	09-03-2025	17:01:00	1.35	0.00	0.00	0.00	32.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1613 (401-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	06-03-2025	08:21:00	06-03-2025	17:23:00	0.38	0.00	0.00	0.00	9.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1125 (397 -398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	05-03-2025	08:52:00	05-03-2025	17:18:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/878 (398 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	10-03-2025	08:10:00	11-03-2025	18:08:00	1.42	0.00	0.00	0.00	33.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1985 (398-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	07-03-2025	06:56:00	07-03-2025	17:24:00	0.44	0.00	0.00	0.00	10.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1337(401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	31-03-2025	08:37:00	31-03-2025	16:33:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6079 (400 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	22-03-2025	09:26:00	22-03-2025	17:00:00	0.32	0.00	0.00	0.00	7.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4408 (390 - 390 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	21-03-2025	06:31:00	21-03-2025	17:37:00	0.46	0.00	0.00	0.00	11.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4169 (402-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	20-03-2025	06:55:00	20-03-2025	16:24:00	0.40	0.00	0.00	0.00	9.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3961 (399- 401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	29-03-2025	10:08:00	29-03-2025	17:18:00	0.30	0.00	0.00	0.00	7.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5719(394 - 394Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	27-03-2025	07:57:00	27-03-2025	17:35:00	0.40	0.00	0.00	0.00	9.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5309 (403-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	28-03-2025	08:40:00	28-03-2025	17:05:00	0.35	0.00	0.00	0.00	8.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5532(398- 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	23-03-2025	08:06:00	23-03-2025	16:20:00	0.34	0.00	0.00	0.00	8.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4599 (408 - 408 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	24-03-2025	07:55:00	25-03-2025	17:06:00	1.38	0.00	0.00	0.00	33.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4718 (406 - 407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	12-03-2025	08:54:00	12-03-2025	17:06:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2407(392 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	15-03-2025	08:38:00	15-03-2025	17:31:00	0.37	0.00	0.00	0.00	8.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2999 (398 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	18-03-2025	08:12:00	18-03-2025	17:44:00	0.40	0.00	0.00	0.00	9.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3525(401 -401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	14-03-2025	08:17:00	14-03-2025	19:19:00	0.46	0.00	0.00	0.00	11.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2821 (405 - 405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	19-03-2025	08:08:00	19-03-2025	17:57:00	0.41	0.00	0.00	0.00	9.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3748 (400-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	03-03-2025	07:05:00	03-03-2025	17:25:00	0.43	0.00	0.00	0.00	10.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/380 (405-405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	04-03-2025	09:24:00	04-03-2025	20:19:00	0.46	0.00	0.00	0.00	10.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/641 (390 - 391Kv).
							11.44	0.00	0.00	0.00	274.02	100.00	
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	03-03-2025	07:06:00	03-03-2025	17:26:00	0.43	0.00	0.00	0.00	10.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/381 (405-407 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	04-03-2025	09:25:00	04-03-2025	20:20:00	0.46	0.00	0.00	0.00	10.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/642 (391 - 392Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	17-03-2025	08:00:00	17-03-2025	17:51:00	0.41	0.00	0.00	0.00	9.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3325 (404-405Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	19-03-2025	08:58:00	19-03-2025	17:59:00	0.38	0.00	0.00	0.00	9.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3749 (405-408 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	13-03-2025	09:54:00	14-03-2025	19:34:00	1.40	0.00	0.00	0.00	33.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2648 (398 - 394Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	18-03-2025	08:14:00	18-03-2025	17:45:00	0.40	0.00	0.00	0.00	9.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3526(401 -406 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	16-03-2025	08:15:00	16-03-2025	18:34:00	0.43	0.00	0.00	0.00	10.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3181 (403-403Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	25-03-2025	08:45:00	25-03-2025	17:09:00	0.35	0.00	0.00	0.00	8.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4908 (408-410Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	21-03-2025	06:33:00	21-03-2025	18:17:00	0.49	0.00	0.00	0.00	11.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4170 (407-407 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	31-03-2025	08:38:00	31-03-2025	16:33:00	0.33	0.00	0.00	0.00	7.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6080 (400 -404 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	20-03-2025	09:27:00	20-03-2025	16:35:00	0.30	0.00	0.00	0.00	7.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3991 (393 - 398Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	22-03-2025	09:40:00	22-03-2025	17:02:00	0.31	0.00	0.00	0.00	7.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4409 (391 - 394 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	07-03-2025	08:16:00	07-03-2025	17:25:00	0.38	0.00	0.00	0.00	9.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1350 (401 - 406Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	06-03-2025	08:24:00	06-03-2025	17:26:00	0.38	0.00	0.00	0.00	9.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1126 (398 -401 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	08-03-2025	08:39:00	08-03-2025	17:23:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1614 (404-405Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	01-03-2025	08:44:00	01-03-2025	17:14:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/56 (405-406Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	29-03-2025	10:10:00	29-03-2025	17:20:00	0.30	0.00	0.00	0.00	7.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5720(394 - 394Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	27-03-2025	08:01:00	27-03-2025	17:36:00	0.40	0.00	0.00	0.00	9.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5310 (403-409 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	24-03-2025	07:56:00	24-03-2025	18:38:00	0.45	0.00	0.00	0.00	10.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4719 (407 - 409Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	26-03-2025	08:44:00	26-03-2025	17:04:00	0.35	0.00	0.00	0.00	8.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5100 (402 - 403 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	28-03-2025	08:45:00	28-03-2025	17:07:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5533(398 - 402Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	11-03-2025	08:18:00	11-03-2025	18:13:00	0.41	0.00	0.00	0.00	9.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2187 (402-405 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	12-03-2025	08:56:00	12-03-2025	17:07:00	0.34	0.00	0.00	0.00	8.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2408(396 - 396Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	10-03-2025	08:12:00	10-03-2025	18:10:00	0.42	0.00	0.00	0.00	9.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1986 (403-407 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HIRIYUR	SVRD	05-03-2025	08:55:00	05-03-2025	17:20:00	0.35	0.00	0.00	0.00	8.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/879 (398 - 402Kv).
							10.53	0.00	0.00	0.00	252.23	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	10-03-2025	08:18:00	31-03-2025	23:59:59	21.65	0.00	0.00	0.00	519.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2018 (398-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	01-03-2025	00:00:01	09-03-2025	21:16:00	8.89	0.00	0.00	0.00	213.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3384(402 - 402Kv).
							30.54	0.00	0.00	0.00	732.97	100.00	
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	10-03-2025	08:20:00	31-03-2025	23:59:59	21.65	0.00	0.00	0.00	519.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2019

Standard of Performance data for the month of Mar-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE TO Others	OUTAGE ATTRIBUTA BLE TO System Constraint	OUTAGE ATTRIBUTA BLE TO Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	10-03-2025	06:57:00	10-03-2025	18:18:00	0.47	0.00	0.00	0.00	11.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1978(398-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	06-03-2025	08:17:00	06-03-2025	17:31:00	0.39	0.00	0.00	0.00	9.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1127 (398 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	20-03-2025	07:02:00	20-03-2025	16:26:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3962 (402-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	31-03-2025	08:40:00	31-03-2025	23:59:59	0.64	0.00	0.00	0.00	15.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6081 (400 -402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	23-03-2025	08:00:00	23-03-2025	21:35:00	0.57	0.00	0.00	0.00	13.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4600 (415 - 417 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	29-03-2025	10:08:00	29-03-2025	17:18:00	0.30	0.00	0.00	0.00	7.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5721(401 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	01-03-2025	00:00:01	02-03-2025	16:46:00	1.70	0.00	0.00	0.00	40.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5886 (403-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	21-03-2025	06:52:00	22-03-2025	18:35:00	1.49	0.00	0.00	0.00	35.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4171 (410-412 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	18-03-2025	08:20:00	19-03-2025	17:42:00	1.39	0.00	0.00	0.00	33.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3527(408 -410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	13-03-2025	06:43:00	13-03-2025	17:06:00	0.43	0.00	0.00	0.00	10.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2614 (405-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	14-03-2025	08:23:00	14-03-2025	19:34:00	0.47	0.00	0.00	0.00	11.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2822 (408 - 410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	24-03-2025	08:29:00	28-03-2025	17:27:00	4.37	0.00	0.00	0.00	104.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4720 (409 - 410Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	15-03-2025	08:50:00	16-03-2025	17:22:00	1.36	0.00	0.00	0.00	32.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3006 (401 - 402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	17-03-2025	06:57:00	17-03-2025	17:47:00	0.45	0.00	0.00	0.00	10.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3307 (398-400Kv).
							19.20	0.00	0.00	0.00	480.23	100.00	
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	01-03-2025	08:49:00	03-03-2025	17:29:00	2.36	0.00	0.00	0.00	56.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/57 (408-410Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	09-03-2025	08:18:00	09-03-2025	17:30:00	0.38	0.00	0.00	0.00	9.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1792 (405-404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	06-03-2025	09:01:00	06-03-2025	17:27:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1137 (396 -398 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	10-03-2025	08:28:00	14-03-2025	19:40:00	4.47	0.00	0.00	0.00	107.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1987 (403-406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	28-03-2025	07:00:00	28-03-2025	17:11:00	0.42	0.00	0.00	0.00	10.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5501 (400-400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	23-03-2025	08:14:00	26-03-2025	18:03:00	3.41	0.00	0.00	0.00	81.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4601 (404 - 407 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	27-03-2025	10:51:00	27-03-2025	19:03:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5352 (393-396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	29-03-2025	10:14:00	30-03-2025	20:52:00	1.44	0.00	0.00	0.00	34.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5722(394 - 398Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	15-03-2025	08:42:00	17-03-2025	17:24:00	2.36	0.00	0.00	0.00	56.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3000 (397 - 399 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	18-03-2025	08:20:00	22-03-2025	18:16:00	4.41	0.00	0.00	0.00	105.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3528(405 -407 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	05-03-2025	06:38:00	05-03-2025	17:19:00	0.45	0.00	0.00	0.00	10.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/845 (400-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	07-03-2025	07:04:00	08-03-2025	17:38:00	1.44	0.00	0.00	0.00	34.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1339(399 - 399Kv).
							21.83	0.00	0.00	0.00	524.21	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	06-03-2025	09:05:00	06-03-2025	17:32:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1138 (396 -398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	01-03-2025	00:00:01	01-03-2025	16:50:00	0.70	0.00	0.00	0.00	16.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5662 (404-407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	08-03-2025	08:22:00	09-03-2025	20:38:00	1.51	0.00	0.00	0.00	36.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1616 (402-404Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	10-03-2025	08:17:00	10-03-2025	18:22:00	0.42	0.00	0.00	0.00	10.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1988 (402-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	11-03-2025	09:33:00	15-03-2025	17:42:00	4.34	0.00	0.00	0.00	104.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2208(397 -397 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	05-03-2025	06:47:00	05-03-2025	17:25:00	0.44	0.00	0.00	0.00	10.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/846 (402-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	28-03-2025	07:06:00	28-03-2025	17:14:00	0.42	0.00	0.00	0.00	10.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5502 (400-401 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	23-03-2025	08:22:00	26-03-2025	18:05:00	3.41	0.00	0.00	0.00	81.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4602 (407 - 409 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	29-03-2025	10:18:00	30-03-2025	20:57:00	1.44	0.00	0.00	0.00	34.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5723(398 - 400Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	18-03-2025	08:26:00	22-03-2025	18:25:00	4.42	0.00	0.00	0.00	105.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3529(407 -409 Kv).
							17.45	0.00	0.00	0.00	418.89	100.00	
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	02-03-2025	08:56:00	02-03-2025	16:56:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/236 (406 -406) Kv.
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	07-03-2025	08:19:00	07-03-2025	17:30:00	0.38	0.00	0.00	0.00	9.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1351(407 - 407Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	09-03-2025	09:39:00	09-03-2025	17:15:00	0.32	0.00	0.00	0.00	7.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1825 (399-399 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	06-03-2025	08:24:00	06-03-2025	17:54:00	0.40	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1128 (401 -402 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	01-03-2025	08:29:00	01-03-2025	17:20:00	0.37	0.00	0.00	0.00	8.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/58 (404-405Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	12-03-2025	09:04:00	12-03-2025	16:56:00	0.33	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2409(400 - 400Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	10-03-2025	07:09:00	10-03-2025	18:27:00	0.47	0.00	0.00	0.00	11.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1979(401-403 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	08-03-2025	08:18:00	08-03-2025	17:18:00	0.38	0.00	0.00	0.00	9.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1617 (404-405Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	05-03-2025	06:56:00	05-03-2025	17:30:00	0.44	0.00	0.00	0.00	10.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/847 (408-408 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	11-03-2025	08:25:00	11-03-2025	18:09:00	0.41	0.00	0.00	0.00	9.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2189(402 -404 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	21-03-2025	06:38:00	21-03-2025	17:52:00	0.47	0.00	0.00	0.00	11.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4172 (408-408 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	19-03-2025	08:15:00	19-03-2025	18:05:00	0.41	0.00	0.00	0.00	9.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3750 (408-408 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	29-03-2025	10:08:00	29-03-2025	17:55:00	0.32	0.00	0.00	0.00	7.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5724(390 - 390Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	28-03-2025	08:57:00	28-03-2025	17:12:00	0.34	0.00	0.00	0.00	8.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5534(400 - 402Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	26-03-2025	08:05:00	26-03-2025	17:15:00	0.38	0.00	0.00	0.00	9.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5101 (408 - 408 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	20-03-2025	08:43:00	20-03-2025	16:38:00	0.33	0.00	0.00	0.00	7.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3992 (401 - 404Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	22-03-2025	09:25:00	22-03-2025	16:56:00	0.31	0.00	0.00	0.00	7.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4410 (389 - 390 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	27-03-2025	08:23:00	27-03-2025	17:52:00	0.40	0.00	0.00	0.00	9.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5311 (409 - 409 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	31-03-2025	08:39:00	31-03-2025	17:01:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6082 (403 -404 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	24-03-2025	07:58:00	24-03-2025	18:25:00	0.44	0.00	0.00	0.00	10.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4721 (410 - 412 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	23-03-2025	08:08:00	23-03-2025	16:34:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4603 (415 - 419 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	25-03-2025	08:47:00	25-03-2025	17:33:00	0.37	0.00	0.00	0.00	8.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4922 (406-407Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	13-03-2025	09:03:00	13-03-2025	17:07:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2650(398 - 398Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	18-03-2025	08:19:00	18-03-2025	18:06:00	0.41	0.00	0.00	0.00	9.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3530(408 -408 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	17-03-2025	08:04:00	17-03-2025	18:06:00	0.42	0.00	0.00	0.00	10.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3326 (410-411Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	03-03-2025	07:08:00	03-03-2025	17:34:00	0.44	0.00	0.00	0.00	10.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/383 (409-410Kv).

Standard of Performance data for the month of Mar-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	19-03-2025	08:16:00	19-03-2025	18:16:00	0.42	0.00	0.00	0.00	10.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3751 (400-403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	28-03-2025	07:02:00	28-03-2025	17:10:00	0.42	0.00	0.00	0.00	10.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5503 (402-403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	26-03-2025	08:20:00	26-03-2025	17:29:00	0.38	0.00	0.00	0.00	9.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5102 (402 - 406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	29-03-2025	10:11:00	29-03-2025	17:39:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5725(394 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	21-03-2025	06:40:00	21-03-2025	17:40:00	0.46	0.00	0.00	0.00	11.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4173 (405-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	25-03-2025	08:53:00	25-03-2025	17:41:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4909 (400-402Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	27-03-2025	08:01:00	27-03-2025	17:53:00	0.41	0.00	0.00	0.00	9.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5312 (403 - 407 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	22-03-2025	09:29:00	22-03-2025	16:46:00	0.30	0.00	0.00	0.00	7.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4411 (393 - 395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	31-03-2025	08:41:00	31-03-2025	17:00:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6083 (401 -404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	13-03-2025	06:47:00	13-03-2025	16:39:00	0.41	0.00	0.00	0.00	9.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2615 (396-400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	18-03-2025	08:19:00	18-03-2025	17:58:00	0.40	0.00	0.00	0.00	9.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3531(402 -404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	16-03-2025	08:19:00	16-03-2025	18:01:00	0.40	0.00	0.00	0.00	9.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3182 (403-404Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	15-03-2025	08:43:00	15-03-2025	17:18:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3001 (398 - 401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	14-03-2025	08:22:00	14-03-2025	19:33:00	0.47	0.00	0.00	0.00	11.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2823 (403 - 406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	17-03-2025	07:59:00	17-03-2025	17:51:00	0.41	0.00	0.00	0.00	9.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3327 (403-404Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	03-03-2025	07:10:00	03-03-2025	17:30:00	0.43	0.00	0.00	0.00	10.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/384 (401-405 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	04-03-2025	09:31:00	04-03-2025	17:56:00	0.35	0.00	0.00	0.00	8.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/644 (391 - 395Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	02-03-2025	08:09:00	02-03-2025	16:58:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/237 (402 -407) Kv
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	07-03-2025	07:09:00	07-03-2025	17:15:00	0.42	0.00	0.00	0.00	10.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1340(400 - 401Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	09-03-2025	08:04:00	09-03-2025	17:23:00	0.39	0.00	0.00	0.00	9.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1793 (402-404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	05-03-2025	06:54:00	05-03-2025	17:41:00	0.45	0.00	0.00	0.00	10.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1271 (402-405 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	08-03-2025	08:19:00	08-03-2025	17:31:00	0.38	0.00	0.00	0.00	9.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1618 (403-405Kv).
							11.82	0.00	0.00	0.00	283.61	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR HVDC	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3385(403 - 405Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT PUGALUR HVDC	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3386(405 - 407Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT PALAKKAD	SVRD	17-03-2025	11:52:00	30-03-2025	21:02:00	13.38	0.00	0.00	0.00	321.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3380 (405 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT PALAKKAD	SVRD	04-03-2025	06:56:00	04-03-2025	16:54:00	0.42	0.00	0.00	0.00	9.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/605 (405 -405 Kv).
							13.80	0.00	0.00	0.00	331.14	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR	SVRD	17-03-2025	10:17:00	31-03-2025	23:59:59	14.57	0.00	0.00	0.00	349.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3361 (405-407Kv).
BSR	125MVAR,BUS REACTOR-1 AT PUGALUR	SVRD	01-03-2025	00:00:01	11-03-2025	20:52:00	10.87	0.00	0.00	0.00	260.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/3900 (397 -397 Kv).
							25.44	0.00	0.00	0.00	610.59	100.00	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	01-03-2025	08:16:00	01-03-2025	16:55:00	0.36	0.00	0.00	0.00	8.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/60 (413-413Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	10-03-2025	08:07:00	10-03-2025	18:15:00	0.42	0.00	0.00	0.00	10.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1990 (410-414 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	08-03-2025	08:20:00	08-03-2025	17:06:00	0.37	0.00	0.00	0.00	8.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1619 (405-405Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	06-03-2025	09:17:00	06-03-2025	17:29:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1139 (402 -403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	02-03-2025	08:21:00	02-03-2025	16:54:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/238 (412 -414) Kv.
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	09-03-2025	08:06:00	09-03-2025	17:04:00	0.37	0.00	0.00	0.00	8.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1794 (414-414 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	07-03-2025	08:13:00	07-03-2025	17:11:00	0.37	0.00	0.00	0.00	8.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1352 (408 - 412Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	03-03-2025	07:06:00	03-03-2025	17:24:00	0.43	0.00	0.00	0.00	10.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/385 (406-408 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	12-03-2025	09:07:00	12-03-2025	16:49:00	0.32	0.00	0.00	0.00	7.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2410(402 - 403Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	18-03-2025	08:21:00	18-03-2025	17:47:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3532(413 -416 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	17-03-2025	08:03:00	17-03-2025	17:56:00	0.41	0.00	0.00	0.00	9.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3328 (415-416Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	15-03-2025	06:50:00	15-03-2025	17:27:00	0.44	0.00	0.00	0.00	10.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2977(408 - 409Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	16-03-2025	08:18:00	16-03-2025	17:26:00	0.38	0.00	0.00	0.00	9.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3183 (414-415Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	26-03-2025	08:07:00	26-03-2025	17:31:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5103 (409 - 409 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	21-03-2025	06:41:00	21-03-2025	17:27:00	0.45	0.00	0.00	0.00	10.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4174 (412-415 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	31-03-2025	08:31:00	31-03-2025	16:35:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6084 (407 -409 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	19-03-2025	08:09:00	19-03-2025	17:41:00	0.40	0.00	0.00	0.00	9.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3752(409 - 412 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	24-03-2025	08:00:00	25-03-2025	17:15:00	1.39	0.00	0.00	0.00	33.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4723 (413-417 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	22-03-2025	09:32:00	22-03-2025	16:45:00	0.30	0.00	0.00	0.00	7.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4412 (398 - 401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	20-03-2025	06:59:00	20-03-2025	16:25:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3964 (413-415 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	27-03-2025	09:39:00	27-03-2025	17:42:00	0.34	0.00	0.00	0.00	8.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5335 (401 - 404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	28-03-2025	08:52:00	28-03-2025	17:05:00	0.34	0.00	0.00	0.00	8.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5535(406 - 406Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	04-03-2025	09:25:00	04-03-2025	16:26:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/635 (398-401Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	11-03-2025	09:21:00	11-03-2025	18:04:00	0.36	0.00	0.00	0.00	8.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2209(401 - 401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	05-03-2025	08:53:00	05-03-2025	17:16:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/880 (404 - 406Kv).
							10.30	0.00	0.00	0.00	247.36	100.00	
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	09-03-2025	11:46:00	09-03-2025	17:24:00	0.24	0.00	0.00	0.00	5.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1831 (400-402 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	08-03-2025	08:22:00	08-03-2025	17:08:00	0.37	0.00	0.00	0.00	8.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1620 (404-404Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	07-03-2025	08:16:00	07-03-2025	17:13:00	0.37	0.00	0.00	0.00	8.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1353 (412 - 414Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	05-03-2025	08:56:00	05-03-2025	17:19:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/881 (406 - 407Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	06-03-2025	09:19:00	06-03-2025	17:31:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1140 (403 -405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	01-03-2025	08:25:00	01-03-2025	16:58:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/61 (413-413Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	10-03-2025	08:14:00	10-03-2025	18:17:00	0.42	0.00	0.00	0.00	10.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1991 (414-416 Kv

Standard of Performance data for the month of Mar-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyn	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	18-03-2025	08:25:00	18-03-2025	17:49:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3533 (416-416 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	17-03-2025	09:25:00	17-03-2025	18:00:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3353 (410-412Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	03-03-2025	07:08:00	03-03-2025	17:26:00	0.43	0.00	0.00	0.00	10.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/386 (411-412 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	04-03-2025	09:27:00	04-03-2025	16:29:00	0.29	0.00	0.00	0.00	7.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/636 (401 - 401Kv).
							9.05	0.00	0.00	0.00	216.87	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	01-03-2025	00:00:01	11-03-2025	20:57:00	10.87	0.00	0.00	0.00	260.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1869 (398 -401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	12-03-2025	08:00:00	12-03-2025	20:24:00	0.52	0.00	0.00	0.00	12.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2401(403 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	13-03-2025	06:56:00	14-03-2025	19:52:00	1.54	0.00	0.00	0.00	36.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2620 (407-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	15-03-2025	10:38:00	31-03-2025	23:59:59	16.56	0.00	0.00	0.00	397.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3037 (397 - 400 Kv).
							29.49	0.00	0.00	0.00	707.65	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	17-03-2025	07:58:00	17-03-2025	18:03:00	0.42	0.00	0.00	0.00	10.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3329 (404-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	16-03-2025	08:22:00	16-03-2025	17:30:00	0.38	0.00	0.00	0.00	9.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3184 (409-410Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	18-03-2025	08:15:00	18-03-2025	17:39:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3534(402 -405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	13-03-2025	06:49:00	13-03-2025	16:45:00	0.41	0.00	0.00	0.00	9.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2616 (406-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	04-03-2025	06:51:00	04-03-2025	16:16:00	0.39	0.00	0.00	0.00	9.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/602 (401 -402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	14-03-2025	08:24:00	14-03-2025	19:27:00	0.46	0.00	0.00	0.00	11.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2824 (404 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	07-03-2025	07:12:00	07-03-2025	18:12:00	0.46	0.00	0.00	0.00	11.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1341(398 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	03-03-2025	07:09:00	03-03-2025	17:46:00	0.44	0.00	0.00	0.00	10.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/387 (403-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	02-03-2025	08:27:00	02-03-2025	17:00:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/238 (408 -410) Kv.
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	09-03-2025	08:02:00	09-03-2025	17:47:00	0.41	0.00	0.00	0.00	9.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1795 (405-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	05-03-2025	06:45:00	05-03-2025	17:45:00	0.46	0.00	0.00	0.00	11.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1259 (405-405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	12-03-2025	07:57:00	12-03-2025	20:15:00	0.51	0.00	0.00	0.00	12.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2397(400 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	08-03-2025	08:14:00	08-03-2025	17:47:00	0.40	0.00	0.00	0.00	9.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1621 (408-410Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	10-03-2025	07:03:00	10-03-2025	18:35:00	0.48	0.00	0.00	0.00	11.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1980(398-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	06-03-2025	09:04:00	06-03-2025	17:49:00	0.37	0.00	0.00	0.00	8.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1141 (391 -391 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	01-03-2025	00:00:01	01-03-2025	17:26:00	0.73	0.00	0.00	0.00	17.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5890 (402-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	11-03-2025	08:29:00	11-03-2025	18:11:00	0.40	0.00	0.00	0.00	9.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2191(400 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	24-03-2025	07:55:00	24-03-2025	18:18:00	0.43	0.00	0.00	0.00	10.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4725 (403 -409 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	21-03-2025	06:48:00	22-03-2025	19:03:00	1.51	0.00	0.00	0.00	36.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4176 (408-409 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	20-03-2025	07:02:00	20-03-2025	16:55:00	0.41	0.00	0.00	0.00	9.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3966 (400-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	31-03-2025	08:37:00	31-03-2025	23:59:59	0.64	0.00	0.00	0.00	15.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6085 (400 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	19-03-2025	07:48:00	19-03-2025	18:25:00	0.44	0.00	0.00	0.00	10.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3754(395 - 397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	27-03-2025	08:05:00	30-03-2025	18:58:00	3.45	0.00	0.00	0.00	82.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5313 (402 - 402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	26-03-2025	08:16:00	26-03-2025	17:07:00	0.37	0.00	0.00	0.00	8.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5105 (400 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	25-03-2025	08:50:00	25-03-2025	17:45:00	0.37	0.00	0.00	0.00	8.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4910 (405-406Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	15-03-2025	08:46:00	15-03-2025	18:22:00	0.40	0.00	0.00	0.00	9.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3002 (399 - 399 Kv).
							15.49	0.00	0.00	0.00	371.95	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SRIPERUMBUDUR	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/1374 (402 -402 Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TIRUNELVELLI	SVRD	01-03-2025	00:00:01	11-03-2025	21:03:00	10.88	0.00	0.00	0.00	261.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1350 (398-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TIRUNELVELLI	SVRD	17-03-2025	10:05:00	31-03-2025	23:59:59	14.58	0.00	0.00	0.00	349.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3362 (406-408Kv).
							25.46	0.00	0.00	0.00	610.97	100.00	
BSR	63MVAR, BUS REACTOR-2 AT TIRUNELVELLI	SVRD	01-03-2025	00:00:01	11-03-2025	21:11:00	10.88	0.00	0.00	0.00	261.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1351 (399-401 Kv).
BSR	63MVAR, BUS REACTOR-2 AT TIRUNELVELLI	SVRD	17-03-2025	10:05:00	31-03-2025	23:59:59	14.58	0.00	0.00	0.00	349.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3363 (408-408Kv).
							25.46	0.00	0.00	0.00	611.10	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TRIVANDRUM	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/845 (760-768Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	08-03-2025	08:22:00	08-03-2025	17:12:00	0.37	0.00	0.00	0.00	8.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1622 (412-415Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	05-03-2025	08:57:00	05-03-2025	17:24:00	0.35	0.00	0.00	0.00	8.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/882 (407 - 409Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	04-03-2025	09:31:00	04-03-2025	16:36:00	0.30	0.00	0.00	0.00	7.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/637 (402 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	07-03-2025	08:21:00	07-03-2025	17:03:00	0.36	0.00	0.00	0.00	8.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1354 (413 - 413Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	02-03-2025	08:38:00	02-03-2025	17:04:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/240 (416 -416 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	01-03-2025	08:27:00	01-03-2025	17:17:00	0.37	0.00	0.00	0.00	8.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/62 (413-414Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	03-03-2025	07:01:00	03-03-2025	17:39:00	0.44	0.00	0.00	0.00	10.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/388 (405-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	11-03-2025	08:31:00	11-03-2025	17:53:00	0.39	0.00	0.00	0.00	9.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2192(411 -412 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	06-03-2025	09:09:00	06-03-2025	17:22:00	0.34	0.00	0.00	0.00	8.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1142 (400 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	10-03-2025	08:20:00	10-03-2025	18:17:00	0.42	0.00	0.00	0.00	9.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1992 (416-416 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	12-03-2025	10:21:00	12-03-2025	17:19:00	0.29	0.00	0.00	0.00	6.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2454(403 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	19-03-2025	07:56:00	19-03-2025	18:04:00	0.42	0.00	0.00	0.00	10.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3755(407 - 409 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	27-03-2025	08:04:00	27-03-2025	17:38:00	0.40	0.00	0.00	0.00	9.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5314 (412 - 412 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	21-03-2025	06:44:00	21-03-2025	17:48:00	0.46	0.00	0.00	0.00	11.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4177 (415-417 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	28-03-2025	08:38:00	28-03-2025	16:59:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5537(407 -407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	26-03-2025	08:11:00	26-03-2025	17:40:00	0.40	0.00	0.00	0.00	9.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5106 (410 - 410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	31-03-2025	08:27:00	31-03-2025	16:45:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6086 (408 -408 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	29-03-2025	10:14:00	29-03-2025								

Standard of Performance data for the month of Mar-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	04-03-2025	09:32:00	04-03-2025	16:40:00	0.30	0.00	0.00	0.00	7.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/638 (403 -405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	07-03-2025	08:23:00	07-03-2025	17:00:00	0.36	0.00	0.00	0.00	8.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1355 (413 - 415Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	03-03-2025	07:03:00	03-03-2025	17:40:00	0.44	0.00	0.00	0.00	10.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/389 (406-407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	12-03-2025	10:22:00	12-03-2025	17:16:00	0.29	0.00	0.00	0.00	6.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/24555(403 - 401Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	10-03-2025	08:24:00	10-03-2025	18:18:00	0.41	0.00	0.00	0.00	9.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1993 (416-419 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	11-03-2025	09:38:00	11-03-2025	17:55:00	0.35	0.00	0.00	0.00	8.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2211 (404 -404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	05-03-2025	08:58:00	05-03-2025	17:28:00	0.35	0.00	0.00	0.00	8.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/883 (409 - 411Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	22-03-2025	09:31:00	22-03-2025	16:43:00	0.30	0.00	0.00	0.00	7.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4414 (399 - 401 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	20-03-2025	06:58:00	20-03-2025	16:32:00	0.40	0.00	0.00	0.00	9.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3968 (413-415 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	21-03-2025	06:47:00	21-03-2025	17:45:00	0.46	0.00	0.00	0.00	10.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4178 (417-417 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	31-03-2025	08:29:00	31-03-2025	16:42:00	0.34	0.00	0.00	0.00	8.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6087 (408 -411 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	26-03-2025	08:13:00	26-03-2025	17:37:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5107 (410 - 412 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	27-03-2025	09:36:00	27-03-2025	17:34:00	0.33	0.00	0.00	0.00	7.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5107 (403 - 403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	19-03-2025	07:59:00	19-03-2025	18:02:00	0.42	0.00	0.00	0.00	10.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3756(409 - 411 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	28-03-2025	08:39:00	28-03-2025	17:00:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5538(407 - 409Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	25-03-2025	08:52:00	25-03-2025	17:32:00	0.36	0.00	0.00	0.00	8.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4911 (410-411Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	29-03-2025	10:15:00	29-03-2025	17:11:00	0.29	0.00	0.00	0.00	6.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5727(403 - 403Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	17-03-2025	07:58:00	17-03-2025	17:43:00	0.41	0.00	0.00	0.00	9.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3330 (410-412Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	13-03-2025	09:02:00	13-03-2025	16:51:00	0.33	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2649 (407 - 408Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	16-03-2025	08:20:00	16-03-2025	17:22:00	0.38	0.00	0.00	0.00	9.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3185 (418-418Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	15-03-2025	10:33:00	15-03-2025	17:14:00	0.28	0.00	0.00	0.00	6.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3036 (402 - 405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	18-03-2025	08:10:00	18-03-2025	17:42:00	0.40	0.00	0.00	0.00	9.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3536(409 -412 Kv).
							8.65	0.00	0.00	0.00	207.04	100.00	
BSR	63MVAR, BUS REACTOR AT TUTICORIN PS	SVRD	01-03-2025	00:00:01	11-03-2025	21:06:00	10.88	0.00	0.00	0.00	261.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1349(400-402 Kv).
							10.88	0.00	0.00	0.00	261.10	100.00	
BSR	PUGALUR-1 LINE REACTOR, 63MVAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	17-03-2025	09:54:00	17-03-2025	17:32:00	0.32	0.00	0.00	0.00	7.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3359* (768-774Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	18-03-2025	11:57:00	28-03-2025	17:42:00	10.24	0.00	0.00	0.00	245.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3588 (768 - 781 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	12-03-2025	08:51:00	12-03-2025	20:11:00	0.47	0.00	0.00	0.00	11.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2414(763 - 774Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	04-03-2025	09:53:00	04-03-2025	20:10:00	0.43	0.00	0.00	0.00	10.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/652 (771 - 779Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	06-03-2025	06:52:11	07-03-2025	18:09:00	1.47	0.00	0.00	0.00	35.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1105 (769-774 Kv).
							12.93	0.00	0.00	0.00	310.27	100.00	
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	18-03-2025	09:22:00	18-03-2025	18:16:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3562/1996(759 -768 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	28-03-2025	09:47:00	29-03-2025	21:54:00	1.51	0.00	0.00	0.00	36.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5546 (763 - 769Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	03-03-2025	09:53:00	04-03-2025	20:13:00	1.43	0.00	0.00	0.00	34.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code CR - 03/422 (752-7620Kv) and NLDC code 03/252.
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	05-03-2025	06:50:00	05-03-2025	21:53:00	0.63	0.00	0.00	0.00	15.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/852 (768-774 Kv).
							3.94	0.00	0.00	0.00	94.40	100.00	
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	02-03-2025	08:12:00	02-03-2025	16:48:00	0.36	0.00	0.00	0.00	8.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/241 (409 -409 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	06-03-2025	08:23:00	06-03-2025	17:17:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1131 (398 -400 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	07-03-2025	07:16:00	07-03-2025	18:14:00	0.46	0.00	0.00	0.00	10.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1343(399 - 399Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	08-03-2025	08:11:00	08-03-2025	17:45:00	0.40	0.00	0.00	0.00	9.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1625 (407-408Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	04-03-2025	06:54:00	04-03-2025	16:23:00	0.40	0.00	0.00	0.00	9.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/604 (403-404 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	01-03-2025	08:17:00	01-03-2025	16:52:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/64 (403-404Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	31-03-2025	08:39:00	31-03-2025	16:39:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6089 (401 -404 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	19-03-2025	08:03:00	19-03-2025	18:19:00	0.43	0.00	0.00	0.00	10.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3758(401 - 401 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	21-03-2025	06:46:00	22-03-2025	16:47:00	1.42	0.00	0.00	0.00	34.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4180 (407-409 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	09-03-2025	08:03:00	09-03-2025	17:07:00	0.38	0.00	0.00	0.00	9.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1797 (407-409 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	10-03-2025	08:09:00	10-03-2025	18:15:00	0.42	0.00	0.00	0.00	10.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1995 (404-407 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	05-03-2025	06:39:00	05-03-2025	17:29:00	0.45	0.00	0.00	0.00	10.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/851 (406-406 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	11-03-2025	08:03:00	11-03-2025	17:47:00	0.41	0.00	0.00	0.00	9.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2194(402 -403 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	12-03-2025	07:27:00	12-03-2025	16:54:00	0.39	0.00	0.00	0.00	9.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2399(402 - 402Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	03-03-2025	07:04:00	03-03-2025	17:36:00	0.44	0.00	0.00	0.00	10.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/391 (400-401Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	18-03-2025	08:12:00	18-03-2025	17:32:00	0.39	0.00	0.00	0.00	9.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3538(405 -405 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	15-03-2025	08:40:00	15-03-2025	17:17:00	0.36	0.00	0.00	0.00	8.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3004 (401 -401 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	13-03-2025	06:51:00	13-03-2025	16:49:00	0.42	0.00	0.00	0.00	9.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2618 (406-409 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	17-03-2025	08:00:00	17-03-2025	17:37:00	0.40	0.00	0.00	0.00	9.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3332 (403-405Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	14-03-2025	08:16:00	14-03-2025	20:41:00	0.52	0.00	0.00	0.00	12.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2825 (405 - 407 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	16-03-2025	08:17:00	16-03-2025	17:19:00	0.38	0.00	0.00	0.00	9.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3187 (407-408Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	27-03-2025	08:03:00	29-03-2025	17:27:00	2.39	0.00	0.00	0.00	57.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5316 (403 - 405 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	24-03-2025	08:02:00	24-03-2025	18:10:00	0.42	0.00	0.00	0.00	10.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4728 (411 - 413 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	25-03-2025	08:49:00	25-03-2025	17:07:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4913 (405-405Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	20-03-2025	06:57:00	20-03-2025	16:37:00	0.40	0.00	0.00	0.00	9.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3970 (402-402 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	26-03-2025	08:15:00	26-03-2025	17:14:00	0.37	0.00	0.00	0.00	8.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5109 (404 - 404 Kv).
							13.42	0.00	0.00	0.00	321.57	100.00	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	02-03-2025	08:16:00	03-03-2025	17:39:00	1.39	0.00	0.00	0.00	33.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/242 (409 -409) Kv.
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	31-03-2025	0									

Standard of Performance data for the month of Mar-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	04-03-2025	06:57:00	05-03-2025	17:33:00	1.44	0.00	0.00	0.00	34.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/605 (404 -404 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	17-03-2025	08:03:00	17-03-2025	17:33:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3333 (405-405Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	13-03-2025	06:57:00	13-03-2025	16:52:00	0.41	0.00	0.00	0.00	9.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2619 (409-411 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	18-03-2025	08:23:00	19-03-2025	18:22:00	1.42	0.00	0.00	0.00	33.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3539(409 -411 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	15-03-2025	08:44:00	15-03-2025	17:19:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3005 (401 - 403 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	27-03-2025	09:31:00	30-03-2025	18:55:00	3.39	0.00	0.00	0.00	81.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5338 (396-396Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	20-03-2025	06:59:00	20-03-2025	16:41:00	0.40	0.00	0.00	0.00	9.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3971 (402-403 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	21-03-2025	06:53:00	22-03-2025	18:10:00	1.47	0.00	0.00	0.00	35.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4181 (409-411 Kv).
							17.00	0.00	0.00	0.00	408.02	100.00	
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	10-03-2025	08:26:00	10-03-2025	18:12:00	0.41	0.00	0.00	0.00	9.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1994 (411-412 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	11-03-2025	07:58:00	11-03-2025	17:45:00	0.41	0.00	0.00	0.00	9.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2193(402 -402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	06-03-2025	08:19:00	06-03-2025	17:11:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1130 (396 -398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	07-03-2025	07:14:00	07-03-2025	18:10:00	0.46	0.00	0.00	0.00	10.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1342(396 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	01-03-2025	08:26:00	02-03-2025	16:45:00	1.35	0.00	0.00	0.00	32.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/63 (404-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	08-03-2025	08:14:00	08-03-2025	17:40:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1624 (408-410Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	05-03-2025	06:36:00	05-03-2025	17:26:00	0.45	0.00	0.00	0.00	10.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/850 (405-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	12-03-2025	07:23:00	12-03-2025	16:47:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2398(401 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	04-03-2025	06:50:00	04-03-2025	16:18:00	0.39	0.00	0.00	0.00	9.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/603 (403-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	09-03-2025	07:58:00	09-03-2025	17:03:00	0.38	0.00	0.00	0.00	9.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/1796 (407-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	03-03-2025	06:58:00	03-03-2025	17:34:00	0.44	0.00	0.00	0.00	10.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/390 (397-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	18-03-2025	08:04:00	18-03-2025	17:30:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3537(401 -401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	13-03-2025	06:42:00	13-03-2025	16:46:00	0.42	0.00	0.00	0.00	10.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2617 (406-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	16-03-2025	08:14:00	16-03-2025	17:32:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3186 (406-407Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	17-03-2025	07:57:00	17-03-2025	17:21:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3331 (403-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	21-03-2025	06:44:00	22-03-2025	16:42:00	1.42	0.00	0.00	0.00	33.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4179 (407-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	26-03-2025	08:07:00	26-03-2025	17:12:00	0.38	0.00	0.00	0.00	9.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5108 (403 - 404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	15-03-2025	08:36:00	15-03-2025	17:10:00	0.36	0.00	0.00	0.00	8.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3003 (399 - 401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	14-03-2025	08:12:00	14-03-2025	19:30:00	0.47	0.00	0.00	0.00	11.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/2825 (405 - 405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	19-03-2025	07:51:00	19-03-2025	18:13:00	0.43	0.00	0.00	0.00	10.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3757(398 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	31-03-2025	08:35:00	31-03-2025	16:37:00	0.34	0.00	0.00	0.00	8.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/6088 (401 -401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	24-03-2025	07:57:00	24-03-2025	18:08:00	0.42	0.00	0.00	0.00	10.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4727 (408 - 411 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	27-03-2025	07:50:00	28-03-2025	17:03:00	1.38	0.00	0.00	0.00	33.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5108 (399 - 399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	29-03-2025	10:18:00	29-03-2025	17:16:00	0.29	0.00	0.00	0.00	6.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/5728(399 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	25-03-2025	08:43:00	25-03-2025	16:55:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/4912 (403-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT YELAHANKA	SVRD	20-03-2025	06:54:00	20-03-2025	16:30:00	0.40	0.00	0.00	0.00	9.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 03/3969 (401-402 Kv).
							13.26	0.00	0.00	0.00	318.17	100.00	
CKT	230kV BHAVINI-ARANI(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV BHAVINI-ARANI(TANTRANSCO)-2	OMSU	25-03-2025	17:30:00	25-03-2025	18:08:00	0.03	0.00	0.63	0.00	0.00		* Line tripped at Bhavini end only. While changing of M2 relay HMI display, trip command extended to CB. Line is in charged condition from Arani end.
							0.03	0.00	0.63	0.00	0.00	100.00	
CKT	230kV BHAVINI-KANCHIPURAM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV BHAVINI-KANCHIPURAM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230 KV-BHAVNI-SIRUSERI-1	OMSU	11-03-2025	08:05:00	11-03-2025	18:01:00	0.41	0.00	9.93	0.00	0.00		* Line tripped at Bhavini end only and it is in charged condition from Siruseri end.Tripping was happened during tripping of 230kV Kal= ivanthatpattu-Siruseri TANTRANSCO line. Siruseri end details: No indication. Bhavini end details (R -G fault): FLR: 55.98 KM, FC: 1.209 Kamps.
CKT	230 KV-BHAVNI-SIRUSERI-1	OSPD	03-03-2025	09:31:00	03-03-2025	19:31:00	0.42	0.00	0.00	0.00	10.00		* shut down availed by Bhavini for testing of MICOM relays vide SRLDC code no. CR-03/409.
							0.83	0.00	9.93	0.00	10.00	100.00	
CKT	230 KV-BHAVNI-SIRUSERI-2	OSPD	06-03-2025	08:44:00	06-03-2025	18:42:00	0.42	0.00	0.00	0.00	9.97		* Shutdown availed by Bhavni SS for relay testing works Vide SRLDC code:03/1133.
CKT	230 KV-BHAVNI-SIRUSERI-2	LPRD	08-03-2025	08:59:00	08-03-2025	13:26:00	0.19	0.00	0.00	0.00	4.45		* Hand tripped as per SRLDC instruction for Power regulation in the system vide SRLDC code no. CR- 03/1631
							0.61	0.00	0.00	0.00	14.42	100.00	
CKT	220kV EDAPPON(KSEB)-EDAMON(KSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV KARAIKAL(PED)-BAHOUR(PED)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KUNDRA(KSEB)-EDAMON(KSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAYAMKULAM(KSEB)-EDAPPON(KSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAYAMKULAM(KSEB)-KUNDRA(KSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAYAMKULAM(KSEB)-POLLAM(KSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	8.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAYAMKULAM(KSEB)-PUNNAPRA(KSEB)-1	OSPD	12-03-2025	09:01:00	12-03-2025	16:43:00	0.32	0.00	0.00	0.00	7.70		* Emergency shut down availed by KSEB for attending hot spot at Punnapra end works vide SRLDC code no. CR-03/2418
							0.32	0.00	0.00	0.00	7.70	100.00	
CKT	230kV NEYVELI(NLC)-KARAIKAL(PED)-1	OSPT	27-03-2025	11:42:00	27-03-2025	14:52:00	0.13	3.17	0.00	0.00	0.00		* Emergency Shut down taken by Neyveli TS-II for Y-ph LA replacement works due to LCM violation vide SRLDC code no. CR-03/5360.
CKT	230kV NEYVELI(NLC)-KARAIKAL(PED)-1	OMSU	27-03-2025	14:52:00	27-03-2025	16:22:00	0.06	0.00	1.50	0.00	0.00		* Emergency SD returned and Line charging code issued Vide SRLDC code 03/1396/5374 but due to Overloading of ICTs at Neyveli TS-2 end the Line charging code is cancelled by SRLDC.* Vide SRLDC code 03/1397/5376- Line is kept idle charged from Karaikal end @ 16:22 hrs due ICT's overloading @ Neyveli TS-2 end.
CKT	230kV NEYVELI(NLC)-KARAIKAL(PED)-1	OSPT	14-03-2025	17:04:00	14-03-2025	18:28:00	0.06	1.40	0.00	0.00	0.00		* Emergency shutdown availed for attending low clearance at tower span between 384-385
CKT	230kV NEYVELI(NLC)-KARAIKAL(PED)-1	LPRD	27-03-2025	16:22:00	31-03-2025	23:59:59	4.32	0.00	0.00	0.00	103.63		* Line kept Idle charged from Karaikal end as per SRLDC instruction vide SRLDC code no. CR- 03/5376.
							4.57	4.57	1.50	0.00	103.63	99.38	
CKT	230kV NEYVELI(NLC)-VILLIANUR(PED)-1	LPRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction from Neyveli end only for power regulation in the system vide SRLDC code no. CR- 02/3907(205MW-0MW).
CKT	230kV NEYVELI(NLC)-VILLIANUR(PED)-1	LPRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line kept open from Neyveli end and charged from Villianur end as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 02/6017.

Standard of Performance data for the month of Mar-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	220kV PUNNAPRA(KSEB)-POLLAM(KSEB)-1	OSPD	04-03-2025	08:31:00	04-03-2025	17:51:00	62.00	0.00	0.00	0.00	1,488.00	100.00	
							0.39	0.00	0.00	0.00	9.33		* Shut down availed by KSEB for maintenance works at New Pollam vide SRLDC code no. CR-03/629.
							0.39	0.00	0.00	0.00	9.33	100.00	
CKT	220kV TIRUNELVELI-EDAMON(KSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	220kV TIRUNELVELI-EDAMON(KSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400 KV ALMATY-TIRUVALAM-1	OSPT	01-03-2025	10:42:00	01-03-2025	16:42:00	0.25	6.00	0.00	0.00	0.00		* Shutdown availed for LBB Retrofitting works at Almathy S/S vide SRLDC code: 03/86
CKT	400 KV ALMATY-TIRUVALAM-1	OMSU	27-03-2025	13:55:00	27-03-2025	18:34:00	0.19	0.00	4.65	0.00	0.00		* Line tripped on B -G fault. Almathy end details: M1: FLR: 35.47 KM, FC: 8.529 Kamps, M2: FLR: 34.7 KM, FC: 8.3 Kamps. Thiruvalem TN end details:M1: FLR: 80.10 KM, FC: 2.92 Kamps, M2: FLR: 70.42 KM, FC: 4.26 Kamps* Fault is in TNEB Jurisdiction.
CKT	400 KV ALMATY-TIRUVALAM-1	OSPD	17-03-2025	13:40:00	17-03-2025	18:29:00	0.20	0.00	0.00	0.00	4.82		* Emergency Shut down availed to attend faulty Almathy-Thiruvalem(TN)-II vide SRLDC code no. CR-03/3389
							0.64	6.00	4.65	0.00	4.82	99.19	
CKT	400 KV ALMATY-TIRUVALAM-2	OMSU	17-03-2025	10:55:00	17-03-2025	19:09:00	0.34	0.00	8.23	0.00	0.00		* Line tripped on Rph-G fault. Almathy end details: M1: FLR: 53.5 KM, FC: 5.4 Kamps, M2: FLR: 52.2 KM, FC: 5.3 Kamps. Thiruvalem(TN) end details:M1: FLR: 65.1 KM, FC: 4.9 Kamps, M2: FLR: 56.5 KM, FC: 5.2 Kamps* Fault is in TANTRANSCO portion of line.
							0.34	0.00	8.23	0.00	0.00	100.00	
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(NTECL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(NTECL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV CHITTOOR(APTRANSCO)-SRIPERUMBUDUR	LCSD	23-03-2025	05:14:00	23-03-2025	18:12:00	0.54	0.00	0.00	0.00	12.97		* Shut down availed for replacement of CT MB and interpolate cabling works at Sriperumbudur end under Add-Cap vide SRLDC code no. CR-03/4558.
							0.54	0.00	0.00	0.00	12.97	100.00	
CKT	400kV GOOTY-SOMANAHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-TALAGUPPA(KPTCL)-1	OMSU	14-03-2025	12:58:00	14-03-2025	14:05:00	0.05	0.00	1.12	0.00	0.00		* Line tripped on Y -G fault. HASSAN end details: M1: FLR: 91.5 KM, FC: 2.0 Kamps, M2: FLR: 92.18 KM, FC: 3.3 Kamps. Talaguppa end details:M1: Not recorded, M2: FLR: 160.3 KM, FC: 1.93 Kamps* Fault is in KPTCL Jurisdiction.
							0.05	0.00	1.12	0.00	0.00	100.00	
CKT	400kV HOSUR-SALEM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HOSUR-SALEM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-NARENDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-NARENDRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	13-03-2025	09:48:00	13-03-2025	16:29:00	0.28	0.00	0.00	0.00	6.68		* Shut down availed by KPTCL for replacement of insulator string at Loc No. 192 vide SRLDC code no. CR-03/2653.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OMSU	24-03-2025	17:09:00	25-03-2025	16:19:00	0.97	0.00	23.17	0.00	0.00		* Line tripped on B-G fault(SOTF) while charging from Guttur end.Guttur end details : M1: FLR: 59.9 KM, FC: 2.172 Kamps, M2: FLR: NR, FC: 2.257 Kamps. Fault is in KPTCL Jurisdiction.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	24-03-2025	10:44:00	24-03-2025	17:09:00	0.27	0.00	0.00	0.00	6.42		* Shut down availed by KPTCL for Quarterly maintenance works.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	LEFT	11-03-2025	14:43:00	11-03-2025	18:31:00	0.16	3.80	0.00	0.00	0.00		* Line tripped on B -G fault. KAIGA end details: M1: FLR: 33.8 KM, FC: 2.89 Kamps, M2: FLR: Not Recorded KM, FC: 1.732 Kamps. GUTTUR end details:M1: FLR: 125.9 KM, FC: Not Recorded, M2: FLR: 89.7 KM, FC: Not Recorded.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	10-03-2025	09:29:00	10-03-2025	19:53:00	0.43	0.00	0.00	0.00	10.40		* Emergency shutdown availed by KPTCL for attending fault on circuit-2 vide code SRLDC CR-03/2028.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OMSU	09-03-2025	02:53:00	09-03-2025	21:32:00	0.78	0.00	18.65	0.00	0.00		* Line tripped on B-G fault. Kaiga end details: M1: FLR: 101 KM, FC: NR, M2: FLR: NR, FC: 3.08 Kamps. Guttur end details:M1: FLR: 81.23 KM, FC: 5.79KA, M2: FLR: 74.9 KM, FC: 6.77 Kamps* Fault is in KPTCL Jurisdiction.
							2.89	3.80	41.82	0.00	23.50	99.46	
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	11-03-2025	22:20:00	13-03-2025	16:12:00	1.74	0.00	41.87	0.00	0.00		* 400kV Kaiga-Guttur Line-2 tripped on R-G fault while charging from Guttur end. Relay Details Guttur end: 110kM <=> 4.7kA.Fault is in KPTCL jurisdiction (Insulator decapping found at Loc. No. 192 in KPTCL portion)
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OSPT	11-03-2025	13:35:00	11-03-2025	22:20:00	0.37	8.75	0.00	0.00	0.00		* Shut down availed for replacement of damaged insulator string at Loc No.156 vide SRLDC code no. CR-03/2231.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	10-03-2025	20:53:00	10-03-2025	22:52:00	0.08	0.00	1.98	0.00	0.00		* Line Auto Reclosed Successful @ Kaiga end on R -G fault, but tripped @ Guttur end only. Guttur end details: M1: FLR: 139 KM, FC: 3.4 Kamps, M2: FLR: 125 KM, FC: 3.8 Kamps. Kaiga end details:M1:- FLR: 53.7 KM, FC: 4.5 Kamps, M2: FLR: 53.14 KM, FC: 4.55 Kamps* Fault is in Sirsi TLM Jurisdiction.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	09-03-2025	05:29:00	10-03-2025	20:05:00	1.61	0.00	38.60	0.00	0.00		* Line tripped on B-G fault. Kaiga end details: M1: FLR: 125.1 KM, FC: 1.12KA, M2: 123.4 KM, FC: 2.31KA. Guttur end details:M1: FLR: 60.88 KM, FC: 5.51KA, M2: FLR: 61.3 KM, FC: 5.54 Kamps* Fault is in KPTCL Jurisdiction.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	08-03-2025	02:06:00	08-03-2025	20:18:00	0.76	0.00	18.20	0.00	0.00		* Line tripped on B-G fault. Kaiga end details: M1: FLR: 124.9 KM, FC: 2.256 Kamps, M2: FLR: 111 KM, FC: 3.196 Kamps. Guttur end details:M1: Not Recorded, M2: FLR: 67.9 KM, FC: 5.71 Kamps* Fault is in KPTCL Jurisdiction.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	07-03-2025	13:18:00	07-03-2025	19:11:00	0.25	0.00	5.88	0.00	0.00		* Line tripped on B phase to Ground fault. Kaiga end details: M1: 85KMS/3.856KA, M2: NR, Sirsi end details: 108.8KMS/3.11KA, M2: NR, Fault is in KPTCL Jurisdiction.
							4.81	8.75	106.53	0.00	0.00	98.63	
CKT	400kV KARAISKUDI-MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-1	OSPD	05-03-2025	07:30:00	05-03-2025	17:38:00	0.42	0.00	0.00	0.00	10.13		* Shut down availed by NPCIL for maintenance works vide SRLDC code no. CR-03/865
							0.42	0.00	0.00	0.00	10.13	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-2	OSPD	17-03-2025	08:05:00	17-03-2025	18:50:00	0.45	0.00	0.00	0.00	10.75		* Shutdown availed by NPCIL for Line Isolator cleaning work, wave trap top side connectors CRM measurements vide SRLDC code: 03/3341
							0.45	0.00	0.00	0.00	10.75	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-KOCHI-KOTTAYAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-KOCHI-KOTTAYAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KOLAR-HOODY(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-HOODY(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-HOSUR-1	LART	07-03-2025	13:30:00	07-03-2025	13:30:00	0.00	0.00	0.00	0.00	0.00		* Line Autoreclose successful on R phase to Ground fault. Kolar end details: M1: 17.6KMS/6.9KA, M2: 13.5KMS/8.2KA, Hosur end details: M1: 62.81KMS/2.5KA, M2: NR/3.1KA, Fault in Kolar TLM jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-HOSUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-MYLASANDRA (KPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-THIRUVALAM-1	LART	16-03-2025	14:59:00	16-03-2025	14:59:00	0.00	0.00	0.00	0.00	0.00		* Line Auto reclosed on R ph-G fault. Kolar end details: M1: FLR: 41.39 KM, FC: 6.334 Kamps, M2: FLR: 42.7 KM, FC: 4.69 Kamps. Sriperumbudur end details:M1: FLR: 188.5 KM, FC: 1.7 Kamps, M2: FLR: 192.9 KM, FC: 1.7 Kamps.* Fault is in Kolar Jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDGI GIS-NARENDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDGI GIS-NARENDRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NP KUNTA-KOLAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-PUGALUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-PUGALUR-2	OSPT	19-03-2025	09:37:00	19-03-2025	19:24:00	0.41	9.78	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-03/3790.
							0.41	9.78	0.00	0.00	0.00	98.69	
CKT	400kV MADURAI-TIRUNELVELI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TIRUNELVELI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TUTICORIN PS-1	OSPT	13-03-2025	09:15:00	13-03-2025	20:18:00	0.46	11.05	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-03/2651.
							0.46	11.05	0.00	0.00	0.00	98.51	
CKT	400kV MADURAI-TUTICORIN PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMALPET-MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-KOZHICODE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-KOZHICODE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELLI TS2-NEYVELLI TS1 EXP			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELI TS2(NLC)-KARUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELLI TS2 EXP(NLC) EXP-KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELI(NLC)-SALEM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGAPATTINAM-NEYVELI TS1(NLC) EXP			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGAPATTINAM-NEYVELI TS2(NLC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-1	OSPT	07-03-2025	09:27:00	07-03-2025	17:07:00	0.32	7.67	0.00	0.00	0.00		* Shutdown availed for AMP works and for attending shutdown nature defects in the line vide code CR-03/1378.
							0.32	7.67	0.00	0.00	0.00	98.97	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1	OMSU	01-03-2025	15:40:00	01-03-2025	17:04:00	0.06	0.00	1.40	0.00	0.00		* Line tripped on B -G fault. Hassan end details: M1: FLR: 179.3 KM, FC: 1.81 Kamps, M2: FLR: 213 KM, FC: 1.042 Kamps. Nelamangala end details:M1: FLR: 4.3 KM, FC: 17.63 Kamps, M2: FLR: 4.712 KM, FC: 17.91 Kamps* Fault is in KPTCL Jurisdiction.
							0.06	0.00	1.40	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-2	OSPT	18-03-2025	10:59:00	18-03-2025	15:15:00	0.18	4.27	0.00	0.00	0.00		* Emergancy Shut down availed by TNEB for attending CT oil leakage in 402 (Tie Bay) at Ariyalur end without SRLDC code.
							0.18	4.27	0.00	0.00	0.00	99.43	
CKT	400kV NNTPS(NLC)-PUDUCHERRY-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-ARASUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-ARASUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Mar-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deamed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR PS-1	OSPD	21-03-2025	09:24:00	21-03-2025	14:12:00	0.20	0.00	0.00	0.00	4.80		* Shutdown availed by Karur PS Adani for maintenance works vide code CR-03/4207.
							0.20	0.00	0.00	0.00	4.80	100.00	
CKT	400kV PUGALUR GIS-KARUR PS-2	OSPD	18-03-2025	09:18:00	18-03-2025	19:34:00	0.43	0.00	0.00	0.00	10.27		* Shut down availed by Adani Karur TL for differential communication through FOTE and AMP works
							0.43	0.00	0.00	0.00	10.27	100.00	
CKT	400kV PUGALUR-TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PALAKKAD-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PALAKKAD-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUDUCHERRY-SVCHATRAM(TANTRANSCO)-1	LART	24-03-2025	22:53:00	24-03-2025	22:53:00	0.00	0.00	0.00	0.00	0.00		* Line Auto reclosed successfully on B -G fault. Pondicherry end details: M1: FLR: 111.7 KM, FC: 2.35 Kamps, M2: FLR: 110.3 KM, FC: 2.754 Kamps. SV CHATRAM end details:M1: FLR: 19.7 KM, FC: 11.12 Kamps, M2: FLR: 19.7 KM, FC: 11.12 Kamps* Fault is in Sriperumbudur TLM Jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR HVAC-KARUR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR HVAC-KARUR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV PAVAGADA-DEVANAHALLI(KPTCL)-1	LMAC	18-03-2025	16:45:00	18-03-2025	20:44:00	0.17	0.00	0.00	3.98	0.00		* Shut down availed for removal of foreign materail (Tarpuling plastic sheet) at location no. 389 vide SRLDC code no. CR-03/3609.
							0.17	0.00	0.00	3.98	0.00	100.00	
CKT	400 kV PAVAGADA-DEVANAHALLI(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-HIRIYUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-1	OMSU	05-03-2025	13:49:00	05-03-2025	15:53:00	0.09	0.00	2.07	0.00	0.00		* Line tripped on R ph to G. Fault details:- Pavagada End: M1/M2 FLR: 123.6/109.9 KM, FC: 4.92/2.99 KA, Tumkur End: M1/M2 FLR: 63.4/67.68 KM, 4.27/4.28 KA.Fault is in KPTCL Jurisdiction.
							0.09	0.00	2.07	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-TUMKUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SALEM-NNTPS(NLC)	OSPT	07-03-2025	09:57:00	07-03-2025	13:02:00	0.13	3.08	0.00	0.00	0.00		* Shutdown availed for AMP of non switchable line reactor at Salem end and also for attending shutdown nature defects in the line vide code CR-03/1386.
							0.13	3.08	0.00	0.00	0.00	99.59	
CKT	400kV SALEM-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-UDUMALPET-2	LMAC	10-03-2025	12:33:00	10-03-2025	13:33:00	0.04	0.00	0.00	1.00	0.00		* Line tripped on R -G fault. Salem end details: M1: FLR: 88.85 KM, FC: 2.81 Kamps, M2: FLR: 85.16 KM, FC: 3.627 Kamps. Udumalpet end details:M1: FLR: 70 KM, FC: 4.83 Kamps, M2: FLR: 68.3 KM, FC: 4.9 Kamps* Fault is in Pugalur HVDC TLM Jurisdiction.
							0.04	0.00	0.00	1.00	0.00	100.00	
CKT	400KV-SOMANHALLI-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANHALLI-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANHALLI-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANHALLI-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANHALLI-HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-SOMANHALLI-MYLASANDRA-1	OSPD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Shut down availed by KPTCL for construction and commissioning of Dommasandra substation vide SRLDC code CR.12/283.
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	400kV SVCHATRM(TANTRANSCO)-SRIPERMBUDR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-KOCHI-1	LART	23-03-2025	19:00:00	23-03-2025	19:00:00	0.00	0.00	0.00	0.00	0.00		* Auto reclosed successfully on Bph-N (Ph-earth) transient fault. Kochi End :- M1:- FLR- 12.16 KM, FC- 9.775 kA, M2:- FLR- 12.01 km, FC- 9.82 kA. Thrissur(HVDC) end :- M1:- FLR-64.5 km, FC- 6.72 kA, M2:- FLR-66.59 km , FC- 4.13kA. Fault is in Kochi TLM Jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-KOCHI-2	LART	11-03-2025	11:51:00	11-03-2025	11:51:00	0.00	0.00	0.00	0.00	0.00		* Line auto reclosed successfully at both ends on R -G fault. Kochi end details: M1: FLR: 49.8 KM, FC: 4.827 Kamps, M2: FLR: 47.8 KM, FC: 4.76 Kamps. Thrissur end details: M1: FLR: 43.8 KM, FC: 6 Kamps, M2: FLR: 48.73 KM, FC: 6.47 Kamps.* Fault is in Kochi-Thrissur TLM border Jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Mar-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyn	Detailed Reasons for Outage
CKT	400kV YELAHANKA GIS-TUMKUR-1	LMAC	19-03-2025	18:53:00	19-03-2025	20:22:00	0.06	0.00	0.00	1.48	0.00		* Emergency Shut down availed for removing foreign material at Loc 175 vide SRLDC code no. CR-03/3860
CKT	400kV YELAHANKA GIS-TUMKUR-2	LMAC	19-03-2025	17:40:00	19-03-2025	18:43:00	0.04	0.00	0.00	1.05	0.00	100.00	* Emergency Shut down availed for removing foreign material at Loc 175 vide SRLDC code no. CR-03/3860
CKT	400kV DHARAMPURI-TUMKUR-1			00:00:00		00:00:00	0.00	0.00	0.00	1.05	0.00	100.00	
CKT	400KV KUDGI-KOLHAPUR GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KUDGI-KOLHAPUR GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TUTICORIN PS-DHARMAPURI-1	OSPD	27-03-2025	09:35:00	27-03-2025	14:09:00	0.19	0.00	0.00	0.00	4.57	100.00	* Line Shut down availed for installation and commissioning of TWFL vide SRLDC code no. CR-03/5346.
CKT	400KV TUTICORIN PS-DHARMAPURI-2	OSPD	28-03-2025	09:28:00	28-03-2025	14:08:00	0.19	0.00	0.00	0.00	4.67	100.00	* Shut down availed for installation and commissioning of TWFL vide SRLDC code no. CR-03/5542.
LNR	50MVAR,SWLR OF VALLUR-1 AT KALIVANTPATTU	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4390 (396-399Kv).
LNR	63MVAR,SWLR OF KOTTAYAM-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF KOTTAYAM-2 AT KOCHI	OSPT	12-03-2025	13:56:00	19-03-2025	16:20:00	7.10	170.40	0.00	0.00	0.00		* Emergency shutdown availed due to high violation of Acetylene gas at Kochi SS.
LNR	50MVAR,SWLR OF MYSORE-1 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	77.10	
LNR	50MVAR,SWLR OF MYSORE-2 AT KOZIKODE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF TRICHY AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF KARAUKUDI AT MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF HIRIYUR AT MYSORE	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/620 (396-397Kv).
LNR	80MVAR,SWLR OF PAVAGADA AT MYSORE	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/619 (394-396Kv).
LNR	80MVAR SWLR OF TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR SWLR OF TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NEYVELI-2 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NEYVELI-1 AT KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF HOSUR-2 AT SALEM	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4411 (401-402Kv).
LNR	50MVAR,SWLR OF KOLAR AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF CHITTOOR AT SRIPERUMBUDUR	SVRD	01-03-2025	00:00:01	23-03-2025	18:42:00	22.78	0.00	0.00	0.00	546.70	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3970(401 - 401Kv).
LNR	50MVAR,SWLR OF SVCHATRAM AT SRIPERUMBUR	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 01/3971(401 - 401Kv).
LNR	50MVAR,SWLR OF PALAKKAD-1 AT THRISSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PALAKKAD-2 AT THRISSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF UDUMALPT-1 AT TIRUNELVELI	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/84(399 - 399Kv).
LNR	63MVAR,SWLR OF UDUMALPT-1 AT TIRUNELVELI	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4409 (400-400Kv).
LNR	63MVAR,SWLR OF UDUMALPT-2 AT TIRUNELVELI	SVRD	01-03-2025	00:00:01	03-03-2025	15:57:00	2.67	0.00	0.00	0.00	63.95	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/4410 (400-402Kv).
LNR	63MVAR,SWLR OF NAGAPATTINAM-1 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF NAGAPATTINAM-2 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KADAPA-1 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KADAPA-2 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NELLORE-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF NELLORE-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SALEM-2 AT UDUMALPET	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1566(401 - 401Kv).
LNR	63MVAR,SWLR OF TIRUNELVELI-2 AT UDUMALPT	SVRD	01-03-2025	00:00:01	03-03-2025	15:57:00	2.67	0.00	0.00	0.00	63.95	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1347(393 -393 Kv).
LNR	63MVAR,SWLR OF TIRUNELVELI-1 AT UDUMALPT	SVRD	01-03-2025	00:00:01	31-03-2025	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/1348(393 -393 Kv).
STATCOM	-200/+200 MVAR STATCOM AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Mar-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deamed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
STATCOM	-200/+200 MVAR STATCOM AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	LART	15-03-2025	05:39:00	15-03-2025	05:39:00	0.00	0.00	0.00	0.00	0.00		* LFL and DC line fault recovery sequence operated <(>&<> cleared in first attempt. FD- 850.8 km from Kolar end, Loc- Tower no. 1404. Fault is in SR-1 (Vizag TLM) Jurisdiction.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	LART	14-03-2025	05:06:00	14-03-2025	05:06:00	0.00	0.00	0.00	0.00	0.00		* HVDC Talcher - Kolar Pole-1 LFL with recovery sequence operated and fault cleared in second attempt.* FLR: 850.7 kms from Kolar end (Tower No: 1404).* Fault location comes under SR-I, Vizag TLM jurisdiction.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	LART	15-03-2025	05:24:00	15-03-2025	05:24:00	0.00	0.00	0.00	0.00	0.00		* LFL and DC line fault recovery sequence operated <(>&<> cleared in first attempt. FD- 850.7 km from Kolar end, Loc- Tower no. 1404. Fault is in SR-1 (Vizag TLM) Jurisdiction.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	OSPT	15-03-2025	12:45:00	15-03-2025	19:14:00	0.27	6.48	0.00	0.00	0.00		* Emergency shutdown availed by SR-1 for replacement of Insulator at Loc. No. 1405 at HVDC pole-1 vide code CR-03/3049.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	LART	15-03-2025	06:13:00	15-03-2025	06:13:00	0.00	0.00	0.00	0.00	0.00		* LFL and DC line fault recovery sequence operated <(>&<> cleared in first attempt. FD- 850.7 km from Kolar end, Loc- Tower no. 1404. Fault is in SR-1 (Vizag TLM) Jurisdiction.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	LART	15-03-2025	04:05:00	15-03-2025	04:05:00	0.00	0.00	0.00	0.00	0.00		* LFL and DC line fault recovery sequence operated <(>&<> cleared in first attempt. FD- 850.9 km from Kolar end, Loc- Tower no. 1404. Fault is in SR-1 (Vizag TLM) Jurisdiction.
							0.27	6.48	0.00	0.00	0.00	99.13	
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	LMAC	06-03-2025	13:38:00	06-03-2025	14:20:00	0.03	0.00	0.00	0.70	0.00		* Talcher - Kolar Pole-2 Blocked . Fit Dis- 1348 km from Kolar end - Tower-59 . Fault is under Talcher Jurisdiction. Forest bush fire with heavy smoke found @ Loc 59.* Pole-2 taken in RVO mode @ 14:20 hrs vide SRLDC/NLDC/ERLDC code:- 1181/695/289.* Pole-2 taken in normal operating mode @ 15:48 hrs vide SRLDC/NLDC/ERLDC code :- 1186/703/350.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	LART	06-03-2025	13:30:00	06-03-2025	13:30:00	0.00	0.00	0.00	0.00	0.00		* LFL and DC line fault recovery sequence operated and cleared in 3rd attempt . Fault location 20.7 km from Talcher end . 1348 km from Kolar end (Tower no. 59).
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	OMST	23-03-2025	02:34:00	28-03-2025	01:52:00	4.97	119.30	0.00	0.00	0.00		* Pole-2 blocked due to operation of converter transformer Differential Protection and Buchholz Trip (R-Phase) at Talcher end. Pole-1 is operating under Metallic Return mode.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	LART	14-03-2025	22:48:00	14-03-2025	22:48:00	0.00	0.00	0.00	0.00	0.00		* LFL and DC line fault recovery sequence operated <(>&<> cleared in second attempt. FD- 236.6 km from Kolar end, Loc- Tower no. 3044. Fault is in SR-1 (Cuddapa TLM) Jurisdiction.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	LART	15-03-2025	06:04:00	15-03-2025	06:04:00	0.00	0.00	0.00	0.00	0.00		* LFL and DC line fault recovery sequence operated <(>&<> cleared in first attempt. FD- 850.9 km from Kolar end, Loc- Tower no. 1404. Fault is in SR-1 (Vizag TLM) Jurisdiction.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	OSPT	15-03-2025	12:46:00	15-03-2025	19:14:00	0.27	6.47	0.00	0.00	0.00		** Emergency shutdown availed by SR-1 for replacement of Insulator at Loc. No. 1405 at HVDC pole-1 vide code CR-03/3049.
							5.27	125.77	0.00	0.70	0.00	83.08	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT ARASUR	OSPT	08-03-2025	18:44:00	08-03-2025	19:09:00	0.02	0.42	0.00	0.00	0.00		* Emergency ICT Shut down availed to attend hydraulic oil leakage of 412 bay R-Ph CB vide SRLDC code 03/1731.
							0.02	0.42	0.00	0.00	0.00	99.94	
XMER	500MVA,400/220kV ICT-3 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT ARASUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BIDADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BIDADI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HASSAN			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT HIRIYUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/230kV ICT-4 AT HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KALIVANTHPATTU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-2 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	TuticorinGIS ICT3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	