

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE TO Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	28-08-2023	08:49:00	28-08-2023	22:48:00	0.58	0.00	0.00	0.00	13.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4354 (404 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	12-08-2023	09:31:00	12-08-2023	17:31:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2014 (402 - 402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	14-08-2023	09:30:00	14-08-2023	17:17:00	0.32	0.00	0.00	0.00	7.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2251(393 - 393Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	07-08-2023	09:14:00	07-08-2023	17:31:00	0.35	0.00	0.00	0.00	8.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/9691(394-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	11-08-2023	09:41:00	11-08-2023	17:53:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1812 (397-397Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	03-08-2023	09:18:00	03-08-2023	17:46:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3571(393-396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	02-08-2023	09:21:00	02-08-2023	17:42:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1981(395-397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	08-08-2023	08:46:00	08-08-2023	19:33:00	0.45	0.00	0.00	0.00	10.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1129(400-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	27-08-2023	08:29:00	27-08-2023	16:27:00	0.33	0.00	0.00	0.00	7.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4232(410-411Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	20-08-2023	09:14:00	20-08-2023	16:28:00	0.33	0.00	0.00	0.00	7.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3273(398-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	31-08-2023	08:53:00	31-08-2023	16:30:00	0.28	0.00	0.00	0.00	6.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4986(391 - 393Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	22-08-2023	10:06:00	22-08-2023	15:49:00	0.24	0.00	0.00	0.00	5.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3341(391 - 391Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	18-08-2023	09:13:00	18-08-2023	21:18:00	0.50	0.00	0.00	0.00	12.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2817(394-395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	21-08-2023	09:46:00	21-08-2023	16:27:00	0.28	0.00	0.00	0.00	6.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3151(397 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	24-08-2023	11:03:00	24-08-2023	18:26:00	0.31	0.00	0.00	0.00	7.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3749(389-390 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	25-08-2023	08:07:00	25-08-2023	17:28:00	0.39	0.00	0.00	0.00	9.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3881(400-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	17-08-2023	09:25:00	17-08-2023	17:02:00	0.32	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2648(391-393 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	30-08-2023	08:32:00	30-08-2023	17:11:00	0.36	0.00	0.00	0.00	8.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4703(398-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	26-08-2023	08:36:00	26-08-2023	17:12:00	0.36	0.00	0.00	0.00	8.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4086(403-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	29-08-2023	06:24:00	29-08-2023	17:07:00	0.45	0.00	0.00	0.00	10.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4505(411 - 411 Kv).
							7.19	0.00	0.00	0.00	172.46	100.00	
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	07-08-2023	09:31:00	07-08-2023	19:38:00	0.42	0.00	0.00	0.00	10.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/9731(398-401 Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	03-08-2023	10:25:00	06-08-2023	23:17:00	3.54	0.00	0.00	0.00	84.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3821(404-406 Kv).
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	08-08-2023	11:49:00	11-08-2023	21:41:00	3.41	0.00	0.00	0.00	81.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1188(394-397 Kv).
							7.37	0.00	0.00	0.00	176.86	100.00	
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	17-08-2023	10:25:00	18-08-2023	16:56:00	1.27	0.00	0.00	0.00	30.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2673(394-397 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	30-08-2023	09:46:00	30-08-2023	17:18:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4736(396-398 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	27-08-2023	08:29:00	27-08-2023	16:34:00	0.34	0.00	0.00	0.00	8.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4225(405-407Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	24-08-2023	11:14:00	24-08-2023	17:16:00	0.25	0.00	0.00	0.00	6.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3750(395-395 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	25-08-2023	10:03:00	25-08-2023	16:58:00	0.29	0.00	0.00	0.00	6.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3918(400-401 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	29-08-2023	08:24:00	29-08-2023	17:28:00	0.38	0.00	0.00	0.00	9.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4524(400-404 Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	26-08-2023	08:26:00	26-08-2023	17:11:00	0.37	0.00	0.00	0.00	8.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4076(405-408Kv).
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	28-08-2023	08:45:00	28-08-2023	17:39:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4350(407 - 410 Kv).
							3.58	0.00	0.00	0.00	85.80	100.00	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	03-08-2023	09:18:00	03-08-2023	18:06:00	0.37	0.00	0.00	0.00	8.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3631(394-398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	06-08-2023	10:19:00	06-08-2023	17:20:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/860(398 - 402Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	04-08-2023	09:44:00	04-08-2023	18:17:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/5271(398-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	09-08-2023	09:16:00	09-08-2023	17:49:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1385(398-403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	14-08-2023	09:36:00	14-08-2023	18:28:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2248(400 - 403Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	15-08-2023	09:28:00	15-08-2023	17:02:00	0.32	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2385(401 - 406Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	05-08-2023	09:32:00	05-08-2023	16:55:00	0.31	0.00	0.00	0.00	7.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/710(389 - 394 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	29-08-2023	08:26:00	29-08-2023	17:31:00	0.38	0.00	0.00	0.00	9.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4525(404-408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	28-08-2023	08:46:00	28-08-2023	17:35:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4360(410 - 413 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	26-08-2023	09:16:00	26-08-2023	17:06:00	0.33	0.00	0.00	0.00	7.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4091(401-403Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	23-08-2023	09:52:00	23-08-2023	16:25:00	0.37	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3548(395 - 397Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	27-08-2023	08:29:00	27-08-2023	16:38:00	0.24	0.00	0.00	0.00	6.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4226(407-412Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	25-08-2023	08:29:00	25-08-2023	17:02:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3892(407-410 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	21-08-2023	09:51:00	21-08-2023	16:48:00	0.29	0.00	0.00	0.00	6.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3153(404 - 408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	22-08-2023	10:12:00	22-08-2023	15:47:00	0.23	0.00	0.00	0.00	5.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3344(398 - 402Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	24-08-2023	08:43:00	24-08-2023	17:18:00	0.36	0.00	0.00	0.00	8.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3708(401-404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	30-08-2023	08:37:00	30-08-2023	17:20:00	0.36	0.00	0.00	0.00	8.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4705(399-404 Kv).
							5.67	0.00	0.00	0.00	135.55	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	26-08-2023	09:17:00	26-08-2023	17:06:00	0.33	0.00	0.00	0.00	7.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4092(399-400Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	31-08-2023	10:37:00	31-08-2023	16:26:00	0.24	0.00	0.00	0.00	5.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4999(391 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	17-08-2023	10:30:00	17-08-2023	22:17:00	0.49	0.00	0.00	0.00	11.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2678(394-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	20-08-2023	09:20:00	22-08-2023	16:05:00	2.28	0.00	0.00	0.00	54.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3053(401 - 402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	24-08-2023	09:20:00	24-08-2023	18:44:00	0.39	0.00	0.00	0.00	9.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3723(396-396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	25-08-2023	10:01:00	25-08-2023	17:35:00	0.32	0.00	0.00	0.00	7.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3919(393-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	28-08-2023	08:43:00	28-08-2023	19:59:00	0.47	0.00	0.00	0.00	11.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4351(401 - 405 Kv).
							4.52	0.00	0.00	0.00	108.39	100.00	
BSR	125MVAR, BUS REACTOR-2 AT HIRIYUR	SVRD	25-08-2023	08:26:00	25-08-2023	17:37:00	0.38	0.00	0.00	0.00	9.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3891(401-405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HIRIYUR	SVRD	24-08-2023	11:09:00	24-08-2023								

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	07-08-2023	08:21:00	08-08-2023	21:41:00	1.56	0.00	0.00	0.00	37.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/959/ 392-396 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	09-08-2023	08:46:00	09-08-2023	21:46:00	0.54	0.00	0.00	0.00	13.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/137/1 395-397 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	10-08-2023	08:15:00	11-08-2023	21:42:00	1.56	0.00	0.00	0.00	37.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/1600 /403-406 Kv).
BSR	125MVAR,BUS REACTOR-2 AT HOSUR	SVRD	03-08-2023	08:30:00	03-08-2023	20:49:00	0.51	0.00	0.00	0.00	12.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/348/ 396-398 Kv).
							17.41	0.00	0.00	0.00	417.71	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	63MVAR, BUS REACTOR-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	30-08-2023	08:32:00	30-08-2023	17:06:00	0.36	0.00	0.00	0.00	8.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/470/1 398-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	17-08-2023	07:50:00	17-08-2023	22:13:00	0.60	0.00	0.00	0.00	14.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/262/4 408-410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	04-08-2023	09:14:00	04-08-2023	19:12:00	0.42	0.00	0.00	0.00	9.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/52/1 396-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	05-08-2023	08:30:00	05-08-2023	16:50:00	0.35	0.00	0.00	0.00	8.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/695 399 - 401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	07-08-2023	08:17:00	07-08-2023	19:37:00	0.47	0.00	0.00	0.00	11.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/960 /398-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	10-08-2023	07:55:00	10-08-2023	23:08:00	0.63	0.00	0.00	0.00	15.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/1595 /404-406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	12-08-2023	09:05:00	12-08-2023	17:29:00	0.35	0.00	0.00	0.00	8.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/1994 /401 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	13-08-2023	09:38:00	13-08-2023	17:06:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/2123/398 - 400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	15-08-2023	09:20:00	15-08-2023	16:40:00	0.31	0.00	0.00	0.00	7.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/2378/392 - 393Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	01-08-2023	09:24:00	01-08-2023	18:55:00	0.40	0.00	0.00	0.00	9.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/47 398-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	02-08-2023	07:25:00	02-08-2023	17:32:00	0.42	0.00	0.00	0.00	10.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/167/ 399-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	09-08-2023	08:01:00	09-08-2023	20:47:00	0.53	0.00	0.00	0.00	12.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/1357 /402-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	21-08-2023	09:34:00	21-08-2023	16:27:00	0.29	0.00	0.00	0.00	6.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/3154 /396 - 397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	27-08-2023	08:27:00	27-08-2023	16:23:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/4228 /412-414Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	24-08-2023	08:48:00	24-08-2023	20:09:00	0.47	0.00	0.00	0.00	11.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/3704 /399-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	28-08-2023	08:41:00	28-08-2023	21:36:00	0.54	0.00	0.00	0.00	12.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/4363 /400 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	26-08-2023	08:28:00	26-08-2023	16:39:00	0.34	0.00	0.00	0.00	8.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/4080 /400-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	16-08-2023	08:53:00	16-08-2023	20:42:00	0.49	0.00	0.00	0.00	11.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/247/4 395-395 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	20-08-2023	09:35:00	20-08-2023	16:23:00	0.28	0.00	0.00	0.00	6.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/3059/ 404- 406Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	19-08-2023	09:46:00	19-08-2023	17:14:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/297/0 400-401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	18-08-2023	08:03:00	18-08-2023	21:15:00	0.55	0.00	0.00	0.00	13.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/280/4 /406-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	23-08-2023	09:02:00	23-08-2023	16:42:00	0.32	0.00	0.00	0.00	7.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/352/6/394 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	31-08-2023	09:41:00	31-08-2023	16:36:00	0.29	0.00	0.00	0.00	6.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/498/4/397 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	25-08-2023	08:06:00	25-08-2023	17:31:00	0.39	0.00	0.00	0.00	9.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/3879 /399-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	29-08-2023	09:54:00	29-08-2023	17:01:00	0.30	0.00	0.00	0.00	7.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/4541 /399 - 401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	22-08-2023	09:04:00	22-08-2023	15:46:00	0.28	0.00	0.00	0.00	6.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/3312/396-398Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	06-08-2023	10:17:00	06-08-2023	17:12:00	0.29	0.00	0.00	0.00	6.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/859/399 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	03-08-2023	09:29:00	03-08-2023	20:42:00	0.47	0.00	0.00	0.00	11.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/365/ 398-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	11-08-2023	08:18:00	11-08-2023	21:26:00	0.55	0.00	0.00	0.00	13.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/1781 /405-406Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	14-08-2023	09:23:00	14-08-2023	17:17:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/2252/393 - 395Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	08-08-2023	08:42:00	08-08-2023	19:31:00	0.45	0.00	0.00	0.00	10.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/1127/ 397-399 Kv).
							12.42	0.00	0.00	0.00	297.78	100.00	
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	08-08-2023	09:39:00	08-08-2023	18:42:00	0.38	0.00	0.00	0.00	9.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/1157/ 397-400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	15-08-2023	09:36:00	15-08-2023	18:08:00	0.36	0.00	0.00	0.00	8.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/2383/397 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	13-08-2023	09:38:00	13-08-2023	17:08:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/2122/ 394-396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	14-08-2023	09:26:00	14-08-2023	17:22:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/2240/393 - 395Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	03-08-2023	09:52:00	03-08-2023	20:47:00	0.46	0.00	0.00	0.00	10.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/366 /395-395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	07-08-2023	09:49:00	07-08-2023	14:57:00	0.21	0.00	0.00	0.00	5.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/977/ 395-395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	16-08-2023	09:15:00	16-08-2023	20:47:00	0.48	0.00	0.00	0.00	11.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/2486/ 392-395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	17-08-2023	09:17:00	17-08-2023	17:16:00	0.33	0.00	0.00	0.00	7.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/2633/ 391-393 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	30-08-2023	08:41:00	30-08-2023	17:10:00	0.35	0.00	0.00	0.00	8.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/4706/ 394-399 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	27-08-2023	08:39:00	27-08-2023	21:38:00	0.54	0.00	0.00	0.00	12.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/4233 /404-406Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	05-08-2023	08:36:00	05-08-2023	20:33:00	0.50	0.00	0.00	0.00	11.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/698 /397 - 399 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	11-08-2023	08:23:00	11-08-2023	17:34:00	0.38	0.00	0.00	0.00	9.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/1777 /404-407Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	12-08-2023	10:42:00	12-08-2023	20:12:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/20255 /396 - 397 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	10-08-2023	09:34:00	10-08-2023	19:00:00	0.39	0.00	0.00	0.00	9.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/1614 /399-402Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	04-08-2023	08:27:00	04-08-2023	22:01:00	0.57	0.00	0.00	0.00	13.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/513/403 - 403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	31-08-2023	10:38:00	31-08-2023	23:59:59	0.56	0.00	0.00	0.00	13.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/4996/392 - 392Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	20-08-2023	09:31:00	23-08-2023	21:29:00	3.50	0.00	0.00	0.00	83.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/3072/ 393- 395Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	19-08-2023	09:23:00	19-08-2023	17:30:00	0.34	0.00	0.00	0.00	8.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/2973/ 395-398 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	24-08-2023	08:56:00	25-08-2023	17:31:00	1.36	0.00	0.00	0.00	32.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/3711 /396-398 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	18-08-2023	10:44:00	18-08-2023	21:18:00	0.44	0.00	0.00	0.00	10.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/2843 / 389-389 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	29-08-2023	08:38:00	29-08-2023	20:30:00	0.49	0.00	0.00	0.00	11		

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE TO Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	26-08-2023	08:23:00	26-08-2023	17:29:00	0.38	0.00	0.00	0.00	9.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4073 (400-401Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	30-08-2023	08:35:00	30-08-2023	17:48:00	0.38	0.00	0.00	0.00	9.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4704 (395-395 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	29-08-2023	08:38:00	29-08-2023	17:32:00	0.37	0.00	0.00	0.00	8.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4530 (403-405 Kv).
BSR	50MVAR, BUS REACTOR-1 AT MYSORE	SVRD	24-08-2023	09:29:00	24-08-2023	17:23:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3724 (396-396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NAGAPATTINAM	SVRD	01-08-2023	00:00:01	06-08-2023	21:23:00	5.89	0.00	0.00	0.00	141.38	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-05/1647(399 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	20-08-2023	09:25:00	20-08-2023	17:34:00	0.34	0.00	0.00	0.00	8.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3062(396 - 403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	25-08-2023	09:59:00	25-08-2023	17:27:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3917 (387-390 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	15-08-2023	09:23:00	15-08-2023	16:55:00	0.31	0.00	0.00	0.00	7.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/208 (396 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	13-08-2023	10:26:00	13-08-2023	17:21:00	0.29	0.00	0.00	0.00	6.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/5134(392 - 397 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	11-08-2023	11:44:00	11-08-2023	17:43:00	0.25	0.00	0.00	0.00	5.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1832 (391 - 395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	14-08-2023	09:25:00	14-08-2023	17:25:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2242(390 - 392Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	16-08-2023	09:12:00	16-08-2023	21:00:00	0.48	0.00	0.00	0.00	11.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2485 (391 - 392 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	30-08-2023	08:43:00	30-08-2023	17:13:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4708 (402-404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	12-08-2023	10:37:00	12-08-2023	17:38:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2024 (391 - 396 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	26-08-2023	11:12:00	26-08-2023	17:16:00	0.25	0.00	0.00	0.00	6.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4094 (394-397Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	28-08-2023	09:30:00	28-08-2023	20:06:00	0.44	0.00	0.00	0.00	10.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4374 (391 - 395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	22-08-2023	10:11:00	22-08-2023	15:57:00	0.24	0.00	0.00	0.00	5.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3333(389 - 392Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	18-08-2023	10:38:00	18-08-2023	18:21:00	0.32	0.00	0.00	0.00	7.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2842 (385-388 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	24-08-2023	09:18:00	24-08-2023	18:24:00	0.38	0.00	0.00	0.00	9.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3722 (394-395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	23-08-2023	09:48:00	23-08-2023	16:36:00	0.28	0.00	0.00	0.00	6.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3541(389 - 389Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	21-08-2023	09:34:00	21-08-2023	16:55:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3142 (397 - 400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	31-08-2023	09:49:00	31-08-2023	17:40:00	0.33	0.00	0.00	0.00	7.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4981(394 - 397Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	27-08-2023	09:33:00	27-08-2023	17:27:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4245 (392-395Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	17-08-2023	09:26:00	17-08-2023	17:19:00	0.33	0.00	0.00	0.00	7.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2649 (392-395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	29-08-2023	08:36:00	29-08-2023	17:33:00	0.37	0.00	0.00	0.00	8.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4529(406-409 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PUGALUR HVDC	SVRD	04-08-2023	09:45:00	11-08-2023	22:08:00	7.52	0.00	0.00	0.00	180.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/5281 (411-413 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PUGALUR HVDC	SVRD	21-08-2023	11:00:00	30-08-2023	19:27:00	9.35	0.00	0.00	0.00	224.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3177 (404 - 408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PUGALUR HVDC	SVRD	21-08-2023	11:03:00	30-08-2023	19:30:00	9.35	0.00	0.00	0.00	224.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3178 (408 - 412 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PUGALUR HVDC	SVRD	09-08-2023	13:06:00	11-08-2023	22:14:00	2.38	0.00	0.00	0.00	57.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1433
BSR	63MVAR, BUS REACTOR-1 AT PALAKKAD	OSPT	25-08-2023	17:09:00	31-08-2023	23:59:59	6.29	150.85	0.00	0.00	0.00		* EMERGENCY SD AVAILED FOR C2H2 VIOLATION
BSR	125MVAR, BUS REACTOR-1 AT PUGALUR	SVRD	28-08-2023	08:57:00	28-08-2023	21:49:00	0.54	0.00	0.00	0.00	12.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4364 (409 - 412 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PUGALUR	SVRD	17-08-2023	10:21:00	17-08-2023	16:43:00	10.27	0.00	0.00	0.00	246.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2627 (395-398 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PUGALUR	SVRD	04-08-2023	10:01:00	05-08-2023	20:44:00	1.45	0.00	0.00	0.00	34.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/538 (408-411 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PUGALUR	SVRD	11-08-2023	09:34:00	12-08-2023	20:22:00	1.45	0.00	0.00	0.00	34.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1806 (402-403Kv).
BSR	125MVAR, BUS REACTOR-1 AT PUGALUR	SVRD	09-08-2023	14:15:00	09-08-2023	21:21:00	1.30	0.00	0.00	0.00	7.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1451
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	07-08-2023	09:20:00	07-08-2023	17:32:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/9701 (401-405 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	14-08-2023	09:36:00	14-08-2023	17:22:00	0.32	0.00	0.00	0.00	7.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2249(401 - 404Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	10-08-2023	09:37:00	10-08-2023	16:31:00	0.29	0.00	0.00	0.00	6.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1612 (401-403Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	05-08-2023	10:08:00	05-08-2023	16:59:00	0.29	0.00	0.00	0.00	6.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/720 (398 - 400 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	28-08-2023	08:42:00	28-08-2023	17:28:00	0.37	0.00	0.00	0.00	8.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4355 (404 - 406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	30-08-2023	08:47:00	30-08-2023	17:23:00	0.36	0.00	0.00	0.00	8.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4174 (402-405 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	23-08-2023	09:14:00	23-08-2023	16:54:00	0.32	0.00	0.00	0.00	7.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3531(399 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	09-08-2023	08:46:00	09-08-2023	17:04:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1372(407-410 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	27-08-2023	08:25:00	27-08-2023	16:44:00	0.35	0.00	0.00	0.00	8.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4221 (409-411Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	22-08-2023	09:23:00	22-08-2023	16:00:00	0.28	0.00	0.00	0.00	6.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3316(398 - 400Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	31-08-2023	09:51:00	31-08-2023	16:36:00	0.28	0.00	0.00	0.00	6.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4982(397 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	18-08-2023	09:18:00	18-08-2023	16:53:00	0.32	0.00	0.00	0.00	7.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2819 (401-404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	19-08-2023	09:19:00	19-08-2023	17:19:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2971 (402-406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	20-08-2023	09:19:00	20-08-2023	16:29:00	0.30	0.00	0.00	0.00	7.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3054(403-405 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	29-08-2023	08:24:00	29-08-2023	17:16:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4522(406-406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	26-08-2023	08:23:00	26-08-2023	16:43:00	0.35	0.00	0.00	0.00	8.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4074 (405-409Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	25-08-2023	08:22:00	25-08-2023	17:06:00	0.36	0.00	0.00	0.00	8.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3887 (404-407 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	21-08-2023	09:36:00	21-08-2023	16:39:00	0.29	0.00	0.00	0.00	7.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3144 (398 - 401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	24-08-2023	08:46:00	24-08-2023	17:15:00	0.35	0.00	0.00	0.00	8.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3709 (400-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	16-08-2023	09:09:00	16-08-2023	17:21:00	0.34	0.00	0.00	0.00	8.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2483 (398-399 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	01-08-2023	10:22:00	01-08-2023	17:56:00	0.32	0.00	0.00	0.00	7.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/60 (399-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	08-08-2023	08:51:00	08-08-2023	16:29:00	0.32	0.00	0.00	0.00	7.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1133 (406-409 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	03-08-2023	09:32:00	03-08-2023	18:00:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3611 (405-405 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	04-08-2023	09:15:00	04-08-2023	18:13:00	0.37	0.00	0.00	0.00	8.97		

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	24-08-2023	08:47:00	24-08-2023	17:20:00	0.36	0.00	0.00	0.00	8.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3710 (402-404 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	23-08-2023	09:16:00	23-08-2023	16:56:00	0.32	0.00	0.00	0.00	7.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3532(399 - 403Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	25-08-2023	08:27:00	25-08-2023	17:12:00	0.37	0.00	0.00	0.00	8.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3889 (407-408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	16-08-2023	09:15:00	16-08-2023	17:25:00	0.34	0.00	0.00	0.00	8.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2484 (398-400 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	31-08-2023	09:52:00	31-08-2023	16:37:00	0.28	0.00	0.00	0.00	6.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4983(399 - 399Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	26-08-2023	08:37:00	26-08-2023	16:41:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4083 (409-413Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	12-08-2023	09:09:00	12-08-2023	20:34:00	0.48	0.00	0.00	0.00	11.42	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2005 (402 - 404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	07-08-2023	09:27:00	08-08-2023	21:43:00	1.51	0.00	0.00	0.00	36.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/5721 (395-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	11-08-2023	09:01:00	11-08-2023	21:42:00	0.53	0.00	0.00	0.00	12.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1730 (402-407Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	03-08-2023	10:22:00	03-08-2023	20:57:00	0.44	0.00	0.00	0.00	10.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/383 (397-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	04-08-2023	09:15:00	04-08-2023	22:13:00	0.54	0.00	0.00	0.00	12.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/825(395 -397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	28-08-2023	10:03:00	28-08-2023	20:40:00	0.44	0.00	0.00	0.00	10.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4544 (400 - 400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	17-08-2023	07:50:00	18-08-2023	20:42:00	2.54	0.00	0.00	0.00	69.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2627 (403-405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	30-08-2023	08:38:00	31-08-2023	16:47:00	1.24	0.00	0.00	0.00	32.16		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4709 (398-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	21-08-2023	10:57:00	26-08-2023	17:33:00	5.28	0.00	0.00	0.00	126.66		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3175 (399 - 399 Kv).
							13.10	0.00	0.00	0.00	314.16	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	20-08-2023	09:27:00	20-08-2023	17:30:00	0.34	0.00	0.00	0.00	8.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2056 (404 -404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	19-08-2023	09:17:00	19-08-2023	17:19:00	0.34	0.00	0.00	0.00	8.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2969 (396-396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	26-08-2023	08:30:00	26-08-2023	16:55:00	0.35	0.00	0.00	0.00	8.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4081 (400-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	24-08-2023	07:40:00	25-08-2023	17:20:00	1.40	0.00	0.00	0.00	33.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3698 (403-405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	27-08-2023	08:34:00	27-08-2023	16:45:00	0.34	0.00	0.00	0.00	8.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4231 (409-411Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	22-08-2023	09:10:00	22-08-2023	15:51:00	0.28	0.00	0.00	0.00	6.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3313(398 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	23-08-2023	09:05:00	23-08-2023	17:01:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3527(392 - 392Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	21-08-2023	09:54:00	21-08-2023	17:06:00	0.30	0.00	0.00	0.00	7.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3152 (397 - 397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	16-08-2023	08:51:00	16-08-2023	20:47:00	0.50	0.00	0.00	0.00	11.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2476(397-397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	07-08-2023	09:13:00	07-08-2023	20:33:00	0.47	0.00	0.00	0.00	11.33		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/966 (392-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	03-08-2023	09:27:00	03-08-2023	20:52:00	0.48	0.00	0.00	0.00	11.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/358(395-397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	31-08-2023	09:52:00	31-08-2023	16:34:00	0.28	0.00	0.00	0.00	6.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4985(391 - 393Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	17-08-2023	07:48:00	18-08-2023	21:35:00	1.57	0.00	0.00	0.00	37.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2625 (405-407 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	29-08-2023	06:27:00	29-08-2023	17:17:00	0.45	0.00	0.00	0.00	10.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4504 (410 - 410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	30-08-2023	08:31:00	30-08-2023	17:22:00	0.37	0.00	0.00	0.00	8.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4702(398-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	12-08-2023	09:11:00	12-08-2023	17:32:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2013 (403 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	13-08-2023	09:34:00	13-08-2023	17:15:00	0.32	0.00	0.00	0.00	7.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2126(399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	06-08-2023	10:20:00	06-08-2023	17:12:00	0.29	0.00	0.00	0.00	6.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/861(397 - 397Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	05-08-2023	08:31:00	05-08-2023	17:03:00	0.36	0.00	0.00	0.00	8.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/696 (399 - 401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	10-08-2023	08:06:00	10-08-2023	19:20:00	0.47	0.00	0.00	0.00	11.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1596 (409-410 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	08-08-2023	08:44:00	08-08-2023	19:46:00	0.46	0.00	0.00	0.00	11.03		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1128(397-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	14-08-2023	09:32:00	14-08-2023	20:02:00	0.44	0.00	0.00	0.00	10.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2250(394 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	04-08-2023	08:21:00	04-08-2023	22:22:00	0.58	0.00	0.00	0.00	14.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/512(405 -407Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	11-08-2023	08:24:00	11-08-2023	17:25:00	0.38	0.00	0.00	0.00	9.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1776 (409-411Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	02-08-2023	09:19:00	02-08-2023	17:30:00	0.34	0.00	0.00	0.00	8.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/193 (393-394 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	01-08-2023	09:19:00	01-08-2023	19:17:00	0.42	0.00	0.00	0.00	9.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/48 (394-396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	28-08-2023	08:55:00	28-08-2023	21:38:00	0.53	0.00	0.00	0.00	12.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4359 (404 - 407 Kv).
							12.74	0.00	0.00	0.00	305.10	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SRIPERUMBUDUR	SVRD	01-08-2023	12:17:00	15-08-2023	20:38:00	14.35	0.00	0.00	0.00	344.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/81 (389-391 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SRIPERUMBUDUR	SVRD	24-08-2023	11:23:00	31-08-2023	21:48:00	7.43	0.00	0.00	0.00	178.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3753 (395-390 Kv).
							21.78	0.00	0.00	0.00	522.77	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TIRUNELVELLI	SVRD	01-08-2023	12:17:00	05-08-2023	20:53:00	4.36	0.00	0.00	0.00	104.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/80 (397 -397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TIRUNELVELLI	SVRD	17-08-2023	10:34:00	31-08-2023	23:59:59	14.56	0.00	0.00	0.00	349.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2676 (394-398 Kv).
							18.92	0.00	0.00	0.00	454.03	100.00	
BSR	63MVAR, BUS REACTOR-2 AT TIRUNELVELLI	SVRD	03-08-2023	10:20:00	06-08-2023	21:46:00	3.48	0.00	0.00	0.00	83.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3771 (400-403 Kv).
BSR	63MVAR, BUS REACTOR-2 AT TIRUNELVELLI	SVRD	17-08-2023	10:36:00	31-08-2023	23:59:59	14.56	0.00	0.00	0.00	349.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2677 (398-400 Kv).
							18.04	0.00	0.00	0.00	432.83	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TRIVANDRUM	SVRD	03-08-2023	10:24:00	05-08-2023	20:36:00	2.43	0.00	0.00	0.00	58.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/384(400-406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT TRIVANDRUM	SVRD	17-08-2023	11:04:00	29-08-2023	23:34:00	12.52	0.00	0.00	0.00	300.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2683 (388-396 Kv).
							14.95	0.00	0.00	0.00	358.70	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TUTICORIN GIS	SVRD	01-08-2023	00:00:01	15-08-2023	20:50:00	14.87	0.00	0.00	0.00	356.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-07/2003(396- 398Kv).
							14.87	0.00	0.00	0.00	356.83	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	25-08-2023	09:54:00	25-08-2023	17:07:00	0.30	0.00	0.00	0.00	7.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3920 (399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	30-08-2023	09:47:00	30-08-2023	17:41:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4723 (398-400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	26-08-2023	08:22:00	26-08-2023	16:55:00	0.36	0.00	0.00	0.00			

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE TO Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	24-08-2023	11:32:00	24-08-2023	20:43:00	0.00	0.00	0.00	0.00	0.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3755/2132 (747-759 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	21-08-2023	11:02:00	21-08-2023	19:46:00	0.36	0.00	0.00	0.00	0.00	8.73	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3178 (757 - 767 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	22-08-2023	10:02:00	22-08-2023	20:26:00	0.43	0.00	0.00	0.00	0.00	10.40	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3331/745 - 751Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	16-08-2023	07:34:00	16-08-2023	20:54:00	0.56	0.00	0.00	0.00	0.00	13.33	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2462/1368(747-759 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	30-08-2023	09:59:00	30-08-2023	20:18:00	0.43	0.00	0.00	0.00	0.00	10.32	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4744/ 757-769 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	17-08-2023	09:21:00	17-08-2023	19:09:00	0.41	0.00	0.00	0.00	0.00	9.80	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2641/1473/ 747-754 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	03-08-2023	10:05:00	04-08-2023	18:59:00	1.37	0.00	0.00	0.00	0.00	32.90	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3781/991 (762-774 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	01-08-2023	00:00:01	01-08-2023	18:58:00	0.79	0.00	0.00	0.00	0.00	18.97	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-07/2855/747 - 756Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	07-08-2023	07:22:00	07-08-2023	20:14:00	0.54	0.00	0.00	0.00	0.00	12.87	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/352/760 - 773 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	06-08-2023	09:30:00	06-08-2023	20:28:00	0.46	0.00	0.00	0.00	0.00	10.87	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1533/630(745-757 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	14-08-2023	06:52:00	14-08-2023	16:14:00	0.39	0.00	0.00	0.00	0.00	9.37	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2208/1242 (751-764 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	09-08-2023	14:15:00	09-08-2023	20:53:00	0.28	0.00	0.00	0.00	0.00	6.63	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/145/40
							6.41	0.00	0.00	0.00	15.47	100.00	
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	24-08-2023	11:38:00	27-08-2023	17:10:00	3.23	0.00	0.00	0.00	0.00	7.53	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3754/2133 (759-770 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	21-08-2023	10:06:00	21-08-2023	19:49:00	0.41	0.00	0.00	0.00	0.00	9.72	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3155 (745 - 757 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	22-08-2023	11:15:00	22-08-2023	20:28:00	0.38	0.00	0.00	0.00	0.00	9.22	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3368/755 - 766Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	01-08-2023	12:18:00	05-08-2023	20:39:00	4.35	0.00	0.00	0.00	0.00	104.35	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/79/86 (747-757 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	11-08-2023	08:10:00	11-08-2023	22:05:00	0.58	0.00	0.00	0.00	0.00	13.92	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1765 (755-763Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	07-08-2023	07:09:00	07-08-2023	20:18:00	0.55	0.00	0.00	0.00	0.00	13.15	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/94/752 -756 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	08-08-2023	09:33:00	08-08-2023	20:30:00	0.48	0.00	0.00	0.00	0.00	10.95	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1154/631(757-765 Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	14-08-2023	09:41:00	14-08-2023	20:28:00	0.45	0.00	0.00	0.00	0.00	10.78	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2256/756 - 767Kv).
							10.41	0.00	0.00	0.00	24.82	100.00	
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	28-08-2023	08:53:00	28-08-2023	17:33:00	0.36	0.00	0.00	0.00	0.00	8.67	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4353 (405 - 408 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	18-08-2023	08:05:00	18-08-2023	16:57:00	0.37	0.00	0.00	0.00	0.00	8.87	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2806 (406-406 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	09-08-2023	08:55:00	09-08-2023	17:37:00	0.36	0.00	0.00	0.00	0.00	8.70	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1375 (405-408 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	11-08-2023	08:20:00	11-08-2023	17:25:00	0.38	0.00	0.00	0.00	0.00	8.92	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1774 (409-409Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	10-08-2023	08:06:00	10-08-2023	16:27:00	0.35	0.00	0.00	0.00	0.00	8.35	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1598 (409-410 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	15-08-2023	09:30:00	15-08-2023	16:45:00	0.30	0.00	0.00	0.00	0.00	7.25	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2379/401 - 401Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	05-08-2023	09:36:00	05-08-2023	16:53:00	0.30	0.00	0.00	0.00	0.00	7.28	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/713 (394 - 396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	07-08-2023	09:24:00	07-08-2023	17:35:00	0.34	0.00	0.00	0.00	0.00	8.18	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/968 (398-401 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	02-08-2023	09:24:00	02-08-2023	17:38:00	0.34	0.00	0.00	0.00	0.00	8.23	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1971 (397-399 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	08-08-2023	08:48:00	08-08-2023	16:24:00	0.32	0.00	0.00	0.00	0.00	7.60	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1131 (400-402 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	03-08-2023	09:34:00	03-08-2023	17:50:00	0.34	0.00	0.00	0.00	0.00	8.27	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/354 (399-399 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	30-08-2023	08:53:00	30-08-2023	17:12:00	0.35	0.00	0.00	0.00	0.00	8.32	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4712 (401-401 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	16-08-2023	08:52:00	16-08-2023	17:17:00	0.35	0.00	0.00	0.00	0.00	8.42	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2478 (397-399 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	27-08-2023	08:31:00	27-08-2023	17:25:00	0.37	0.00	0.00	0.00	0.00	8.90	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4230 (412-414Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	31-08-2023	09:58:00	31-08-2023	16:32:00	0.27	0.00	0.00	0.00	0.00	6.57	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4988/393 - 396Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	25-08-2023	08:56:00	25-08-2023	17:19:00	0.35	0.00	0.00	0.00	0.00	8.38	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3900 (403-403 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	04-08-2023	08:15:00	04-08-2023	18:10:00	0.41	0.00	0.00	0.00	0.00	9.92	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/5111 (404-405 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	21-08-2023	09:49:00	21-08-2023	16:49:00	0.29	0.00	0.00	0.00	0.00	7.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3149 (396 - 396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	24-08-2023	08:48:00	24-08-2023	18:31:00	0.41	0.00	0.00	0.00	0.00	9.72	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3706 (396-398 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	22-08-2023	09:17:00	22-08-2023	15:54:00	0.28	0.00	0.00	0.00	0.00	6.62	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3315/397 - 397Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	20-08-2023	09:20:00	20-08-2023	17:23:00	0.34	0.00	0.00	0.00	0.00	8.05	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3060(404-404 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	29-08-2023	06:28:00	29-08-2023	20:31:00	0.59	0.00	0.00	0.00	0.00	14.05	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4501 (411 - 411 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	23-08-2023	09:09:00	23-08-2023	16:37:00	0.31	0.00	0.00	0.00	0.00	7.47	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3529/391 - 391Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	17-08-2023	07:52:00	17-08-2023	17:11:00	0.39	0.00	0.00	0.00	0.00	9.32	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2629 (411-413 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	26-08-2023	08:40:00	26-08-2023	16:44:00	0.34	0.00	0.00	0.00	0.00	8.07	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4085 (404-407Kv).
							8.81	0.00	0.00	0.00	211.29	100.00	
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	17-08-2023	09:10:00	17-08-2023	22:13:00	0.54	0.00	0.00	0.00	0.00	13.05	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2637 (393-394 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	28-08-2023	09:32:00	28-08-2023	21:33:00	0.50	0.00	0.00	0.00	0.00	12.02	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4375 (392 - 394 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	05-08-2023	09:42:00	05-08-2023	16:58:00	0.30	0.00	0.00	0.00	0.00	7.27	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/714 (396 - 396 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	11-08-2023	08:23:00	11-08-2023	21:31:00	0.55	0.00	0.00	0.00	0.00	13.13	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1775 (409-412Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	09-08-2023	08:59:00	09-08-2023	20:48:00	0.49	0.00	0.00	0.00	0.00	11.82	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1376 (408-409Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	10-08-2023	09:16:00	10-08-2023	19:00:00	0.41	0.00	0.00	0.00	0.00	9.73	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/1616 (401-401Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	12-08-2023	09:06:00	12-08-2023	17:37:00	0.36	0.00	0.00	0.00	0.00	8.52	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2004 (402 - 403 Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	15-08-2023	09:32:00	15-08-2023	16:47:00	0.30	0.00	0.00	0.00	0.00	7.25	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/2380(401 - 404Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	26-08-2023	09:10:00	26-08-2023	16:46:00	0.32	0.00	0.00	0.00	0.00	7.60	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/4048 (400-400Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	23-08-2023	09:12:00	23-08-2023	16:41:00	0.31	0.00	0.00	0.00	0.00	7.48	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR-08/3530/391 - 394Kv).
BSR	63MVAR, BUS REACTOR-3 AT YELAHANKA	SVRD	30-08-2023	08:56:00	30-08-20								

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	28-08-2023	08:48:00	28-08-2023	21:29:00	0.53	0.00	0.00	0.00	12.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/4352 (403 - 405 Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	16-08-2023	08:49:00	16-08-2023	17:14:00	0.35	0.00	0.00	0.00	8.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/2477 (397-397 Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	23-08-2023	09:06:00	23-08-2023	16:34:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/3528(391 - 391Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	24-08-2023	08:45:00	24-08-2023	18:33:00	0.41	0.00	0.00	0.00	9.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/3705 (395-396 Kv).
BSR	63MVAR_BUS REACTOR-1 AT YELAHANKA	SVRD	31-08-2023	09:55:00	31-08-2023	16:28:00	0.27	0.00	0.00	0.00	6.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/4987(393 - 393Kv).
							9.48	0.00	0.00	0.00	227.20	100.00	
CKT	230KV BHAVINI-ARANI(TANTRANSCO)-1	LPRD	30-08-2023	13:20:00	30-08-2023	17:26:00	0.17	0.00	0.00	0.00	4.10		* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/4770.
CKT	230KV BHAVINI-ARANI(TANTRANSCO)-2	LPRD	30-08-2023	13:21:00	30-08-2023	17:28:00	0.17	0.00	0.00	0.00	4.10	100.00	
							0.17	0.00	0.00	0.00	4.12		* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/4771.
CKT	230KV BHAVINI-KANCHIPURAM(TANTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230KV BHAVINI-KANCHIPURAM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230 KV-BHAVINI-SIRUSERI-1	LPRD	23-08-2023	13:39:00	23-08-2023	17:40:00	0.17	0.00	0.00	0.00	4.02		* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/3574.
CKT	230 KV-BHAVINI-SIRUSERI-2	LPRD	23-08-2023	13:39:00	23-08-2023	17:40:00	0.17	0.00	0.00	0.00	4.02	100.00	
							0.17	0.00	0.00	0.00	4.02	100.00	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/3575.
CKT	220KV EDAPPON(KSEB)-EDAMON(KSEB)	OSPD	18-09-2023	09:23:00	18-09-2023	16:45:00	0.31	0.00	0.00	0.00	7.37		* Emergency shutdown availed by KSEB for attending Hot spot in Bus-1 Isolator at Edappon End.
							0.31	0.00	0.00	0.00	7.37	100.00	
CKT	230KV KARAİKAL(PED)-BAHOUR(PED)	OMSU	18-08-2023	00:15:00	18-08-2023	15:25:00	0.63	0.00	15.17	0.00	0.00		* Line hand tripped on Emergency basis at Bahour End only due to failure of 230 KV Main bus Y phase Isolator (89A) centre limb supporting insulator of 230 KV Karaikal –Bahour feeder.
							0.63	0.00	15.17	0.00	0.00	100.00	
CKT	220KV KUNDR(AKSEB)-EDAMON(KSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV KAYAMKULAM(KSEB)-EDAPPON(KSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV KAYAMKULAM(KSEB)-KUNDR(AKSEB)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV KAYAMKULAM(KSEB)-POLLAM(KSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV KAYAMKULAM(KSEB)-PUNNAPRA(KSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230KV NEYVELI(NLC)-KARAİKAL(PED)-1	OMSU	30-08-2023	15:23:00	30-08-2023	16:23:00	0.04	0.00	1.00	0.00	0.00		* Line tripped on R -G fault at Karaikal end and Auto reclosed successfully at Neyveli TS-II end. Neyveli TS-2 end details: M1: FLR: 50.6 KM, FC: 3.07 Kamps, M2: FLR: 51.05 KM, FC: 2.861 Kamps. Karaikal end details:M1: FLR: 43.8 KM, FC: 1.232 Kamps, M2: NR.* Fault is in Neyveli TLM Jurisdiction. Bay at Karaikal SS belongs to PED.
CKT	230KV NEYVELI(NLC)-KARAİKAL(PED)-1	OMSU	10-08-2023	05:39:00	10-08-2023	07:08:00	0.06	0.00	1.48	0.00	0.00		* Line autoreclosed at Neyveli TS2 <-&-> tripped at Karaikal end on B-G fault.* Neyveli TS2 end details: M1: FLR: 39.2 KM, FC: 3.91 Kamps, M2: FLR: 33.25 KM, FC: 3.94 Kamps.* Karaikal end details:M1: FLR: 57.9 KM, FC: 1.34 Kamps, M2: NR.* Fault is in Neyveli TLM Jurisdiction.
							0.10	0.00	2.48	0.00	0.00	100.00	
CKT	230KV NEYVELI(NLC)-VILLIANUR(PED)-1	LPRD	17-08-2023	09:21:00	31-08-2023	23:59:59	14.61	0.00	0.00	0.00	350.65		* Hand tripped at Neyveli end only as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/2651.
CKT	230KV NEYVELI(NLC)-VILLIANUR(PED)-1	LPRD	08-08-2023	13:31:00	17-08-2023	09:13:00	8.82	0.00	0.00	0.00	211.70		* Line kept open from Neyveli End only as per SRLDC instruction for Power regulation in the system vide SRLDC code no. CR- 08/1198.
CKT	230KV NEYVELI(NLC)-VILLIANUR(PED)-1	LEFT	07-08-2023	14:03:00	07-08-2023	14:40:00	0.03	0.62	0.00	0.00	0.00		* Line tripped on B -G fault. Neyveli end details: M1: FLR: 14.1 KM, FC: 3.12 Kamps, M2: FLR: 22.37 KM, FC: 1.74 Kamps. Villianur end details:M1: FLR: 51.61 KM, FC: 1.525 Kamps, M2: NR.* Fault is in Pondy TLM Jurisdiction.
CKT	230KV NEYVELI(NLC)-VILLIANUR(PED)-1	LEFT	08-08-2023	12:20:00	08-08-2023	13:31:00	0.05	1.18	0.00	0.00	0.00		* Line tripped on R -G fault on persisting Fault.* Neyveli end details: M1: FLR: 33.15 KM, FC: 3.13 Kamps; M2: FLR: 40.59 KM, FC: 2.918 Kamps* Villianur end details:M1: FLR: 40.11 KM, FC:1.49 Kamps.* Fault is in Pondy TLM Jurisdiction.
CKT	230KV NEYVELI(NLC)-VILLIANUR(PED)-1	OMSU	07-08-2023	14:40:00	07-08-2023	17:03:00	0.10	0.00	2.38	0.00	0.00		* Line idley charged at Neyveli end and not synchronized at Villianur end as PED official not allowed due to India President visit.* Line hand tripped at Neyveli end vide code no. CR- 08/353/1038 on 16:50. Line charged from Villianur end at 16:56 vide code no. CR-08/354/1039.
CKT	230KV NEYVELI(NLC)-VILLIANUR(PED)-1	OMSU	05-08-2023	14:10:00	06-08-2023	17:04:00	1.12	0.00	26.90	0.00	0.00		* Line tripped at Villianur <-&-&-> auto reclosed successfully at Neyveli end on B-G fault.* Neyveli end details: M1: FLR: 56.8 KM, FC: 2.8 Kamps, M2: FLR: 58.77 KM, FC: 2.81 Kamps.* Villianur end details:M1: FLR: 15.34 KM, FC: 0.38 Kamps, M2: NR.* Fault is in Pondy TLM Jurisdiction.
CKT	230KV NEYVELI(NLC)-VILLIANUR(PED)-1	LPRD	01-08-2023	00:00:01	05-08-2023	12:49:00	4.53	0.00	0.00	0.00	108.82		* Line kept open (idle charged from Villianur end only) as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 07/375
							29.26	1.80	29.28	0.00	671.17	99.75	
CKT	220KV PUNNAPRA(KSEB)-POLLAM(KSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV TIRUNELVELI-EDAMON(KSEB)-1	OSPD	11-08-2023	11:16:00	11-08-2023	12:52:00	0.07	0.00	0.00	0.00	1.60		* Shutdown availed by KSEB for modification in Merterring circuit in Relay Panel at Edamon.
CKT	220KV TIRUNELVELI-EDAMON(KSEB)-2	OSPD	11-08-2023	12:55:00	11-08-2023	14:05:00	0.05	0.00	0.00	0.00	1.17		* Shutdown availed by KSEB for modification in Merterring circuit in Relay Panel at Edamon vide SRLDC code no. CR- 08/1836.
							0.05	0.00	0.00	0.00	1.17	100.00	
CKT	400 KV ALMATHY-TIRUVALAM-1	OMSU	22-08-2023	22:45:00	22-08-2023	23:17:00	0.02	0.00	0.53	0.00	0.00		* Line hand tripped to facilitate synchronisation of 400 KV ALMATHY-THIRUVALAM(TN) II at Almathy end vide SRLDC code no. CR- 08/3476.
							0.02	0.00	0.53	0.00	0.00	100.00	
CKT	400 KV ALMATHY-TIRUVALAM-2	OSPD	22-08-2023	16:17:00	22-08-2023	23:13:00	0.29	0.00	0.00	0.00	6.93		* Line tripped on R -G fault. Almathy end details: M1: FLR: 65.31 KM, FC: 4.17 Kamps, M2: FLR: 77.7 KM, FC: 4.16 Kamps. Thiruvalem(TNEB) end details:M1: FLR: 55.6 KM, FC: 5.074 Kamps, M2: FLR: 48.41 KM, FC: 5.095 Kamps* Fault is in TNEB Jurisdiction.
CKT	400 KV ALMATHY-TIRUVALAM-2	OMSU	09-08-2023	13:52:00	09-08-2023	18:57:00	0.21	0.00	5.08	0.00	0.00		* Line tripped on R-G fault. Tiruvalem End details: FL: 7.10kms, FC: 14.6KA, Almathy end details: FL: 95.10kms. Fault in TNEB portion.
							0.50	0.00	5.08	0.00	6.93	100.00	
CKT	400KV ALMATHY(TANTRANSCO)-VALLUR(NTECL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV ALMATHY(TANTRANSCO)-VALLUR(NTECL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV CHITTOOR(APTRANSCO)-SRIPERUMBUDUR	OSPD	08-08-2023	10:37:00	08-08-2023	17:50:00	0.30	0.00	0.00	0.00	7.22		* Shut down availed by APTRANSCO for relay testing and bay maintenance works vide SRLDC code no. CR-08/1173
							0.30	0.00	0.00	0.00	7.22	100.00	
CKT	400KV GOOTY-SOMANAHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV HASSAN-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV HASSAN-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV HASSAN-TALAGUPPA(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV HOSUR-SALEM-1	OSPT	18-08-2023	15:43:00	18-08-2023	18:13:00	0.10	2.50	0.00	0.00	0.00		* Emergency shutdown availed for replacement of B phase LA at Hosur SS due to THRC limit violation.
							0.10	2.50	0.00	0.00	0.00	99.66	
CKT	400KV HOSUR-SALEM-2	OSPT	11-08-2023	08:59:00	11-08-2023	19:01:00	0.42	10.03	0.00	0.00	0.00		* Shut down availed for replacement of defective porcelain insulators which are in critical in nature observed during recent PID scanning of insulators works vide SRLDC code no. CR-08/1788.
							0.42	10.03	0.00	0.00	0.00	98.65	
CKT	400KV KAIGA(NPCIL)-NARENDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KAIGA(NPCIL)-NARENDRA-2	LVRD	05-08-2023	22:53:00	06-08-2023	06:30:00	0.32	0.00	0.00	0.00	7.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/821 (425 -423) kv
							0.32	0.00	0.00	0.00	7.62	100.00	
CKT	400KV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OMSU	21-08-2023	01:35:00	21-08-2023	20:39:00	0.79	0.00	19.07	0.00	0.00		* Line tripped on Teed Protection operation at Kaiga End.* Bay at Kaiga End belongs to NPC.

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400KV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OMSU	26-08-2023	23:09:00	31-08-2023	23:59:59	5.04	0.00	120.85	0.00	0.00	100.00	* Line tripped on B ph to G fault due to Lightning arrester falshover at Kaiga End. Fault details:- Kaiga End: FLR=0.876 KM, FC=12.63 Kamps,Z1, Guttur End: FLR=185.8 KM, FC=1.819 Kamps, Z2.
							5.83	0.00	139.92	0.00	0.00	100.00	
CKT	400KV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	27-08-2023	09:59:00	27-08-2023	10:10:00	0.01	0.00	0.18	0.00	0.00	100.00	* Line tripped from guttur end only without any indication
CKT	400KV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	21-08-2023	01:35:00	23-08-2023	19:40:00	2.75	0.00	66.08	0.00	0.00	100.00	* Line tripped on Teed Protection operation at Kaiga End due to Failure of R-Ph Line CT * Bay at Kaiga End belongs to NPC.
CKT	400KV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	04-08-2023	19:42:00	04-08-2023	21:15:00	0.07	0.00	1.55	0.00	0.00	100.00	* Line tripped at Guttur end only, No fault senced/recorded at Kaiga End.
							2.83	0.00	67.81	0.00	0.00	100.00	
CKT	400KV KARAUKUDI-MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KUDAMKULAM(NPCIL)-TIRUNELVELI-1	OSPD	14-08-2023	08:11:00	14-08-2023	18:46:00	0.44	0.00	0.00	0.00	10.58	100.00	* Shut down availed by KKNPP for line maintenance works vide SRLDC code no. CR-08/2226.
							0.44	0.00	0.00	0.00	10.58	100.00	
CKT	400KV KUDAMKULAM(NPCIL)-TIRUNELVELI-2	OSPD	23-08-2023	07:05:00	23-08-2023	18:29:00	0.48	0.00	0.00	0.00	11.40	100.00	* Shutdown is availed by NPCIL for maintenance work vide SRLDC code CR-08/3502
							0.48	0.00	0.00	0.00	11.40	100.00	
CKT	400KV KUDAMKULAM(NPCIL)-TIRUNELVELI-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-KOCHI-KOTTAYAM-1	OSPD	01-08-2023	08:07:00	01-08-2023	18:26:00	0.43	0.00	0.00	0.00	10.32	99.66	* Shutdown availed by KSEB vide SRLDC code no. CR-08/22 for construction related activities.
CKT	400KV-KOCHI-KOTTAYAM-1	OSPT	02-08-2023	10:33:00	02-08-2023	13:05:00	0.11	2.53	0.00	0.00	0.00	100.00	* Emergency Shut down availed to attend critical damaged insulator of middle phase at Loc. No. 439 vide SRLDC code no. CR-08/206.
							0.54	2.53	0.00	0.00	10.32	99.66	
CKT	400KV-KOCHI-KOTTAYAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KOLAR-HOODY(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KOLAR-HOODY(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KOLAR-HOSUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KOLAR-HOSUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KOLAR-MYLASANDRA (KPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KOLAR-THIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV KUDGI GIS-NARENDRA-1	OSPD	05-08-2023	14:23:00	05-08-2023	18:12:00	0.16	0.00	0.00	0.00	3.82	100.00	* Shut down availed by KTL for conductor repairing works of Kudgi-NTPC-3 <->-> 4 vide SRLDC code no. CR-08/748.
							0.16	0.00	0.00	0.00	3.82	100.00	
CKT	400KV KUDGI GIS-NARENDRA-2	OSPD	05-08-2023	14:18:00	05-08-2023	18:14:00	0.16	0.00	0.00	0.00	3.93	100.00	* Shut down availed by KTL for conductor repairing works of Kudgi-NTPC-3 <->-> 4 vide SRLDC code no. CR-08/748.
CKT	400KV KUDGI GIS-NARENDRA-2	LART	26-08-2023	06:09:00	26-08-2023	06:09:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line autoreclosed successfully on Y-G fault. Kudgi end details: M1: FLR: 212.1 KM, FC: 2.04 Kamps, M2: NR.* Narendra end details:M1: FLR: 1.2 KM, FC: 13.14 Kamps, M2: FLR: 1.11 KM, FC: 13.03 Kamps* Fault is in Narendra TLM Jurisdiction.
							0.16	0.00	0.00	0.00	3.93	100.00	
CKT	400KV NP KUNTA-KOLAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV MADURAI-PUGALUR-1	LEFT	07-08-2023	16:26:00	07-08-2023	18:08:00	0.07	1.70	0.00	0.00	0.00	99.77	* Line tripped on B -G fault. Karur end details: M1: FLR: 118.225 KM, FC: 2.57 Kamps, M2: FLR: 129.0 KM, FC: 2.57 Kamps. Madurai end details:M1: FLR: 15.57 KM, FC:11.7 Kamps, M2: FLR: 14.40 KM, FC: 9.8 Kamps* Fault is in Madurai TLM Jurisdiction.
CKT	400KV MADURAI-PUGALUR-1	LART	07-08-2023	16:17:00	07-08-2023	16:17:00	0.00	0.00	0.00	0.00	0.00	100.00	* Auto reclosed successfully on B -G fault. Karur end details: M1: FLR: 121.8 KM, FC: 3.959 Kamps, M2: FLR: 130.2 KM, FC: 2.47 Kamps. Madurai end details:M1: FLR: 15.911 KM, FC:11.28 Kamps, M2: FLR: 16.7 KM, FC: 10.46 Kamps* Fault is in Madurai TLM Jurisdiction.
							0.07	1.70	0.00	0.00	0.00	99.77	
CKT	400KV MADURAI-PUGALUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV MADURAI-TIRUNELVELI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV MADURAI-TIRUNELVELI-2	LART	12-08-2023	06:02:00	12-08-2023	06:02:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line Auto-reclosed successfully on Y-G fault. Madurai end details: M1: FLR: 82.9 KM, FC: 4.01 Kamps, M2: FLR: 81.98 KM, FC: 4.054 Kamps. Tirunelveli end details: M1: FLR: 77.6 KM, FC: 4.639 Kamps, M2: FLR: 75.6 KM, FC: 4.16 Kamps.* Fault is in the border of Madurai <->-> Tirunelveli TLMs and informed for line patrolling
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV MADURAI-TUTICORIN PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV MADURAI-TUTICORIN PS-2	LART	12-08-2023	16:31:00	12-08-2023	16:31:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line autoreclosed on R-G fault.* Madurai end details: M1: FLR: 73.21 KM, FC: 4.94 Kamps, M2: FLR: 77.75 KM, FC: 5.045 Kamps.* Tuticorin PS end details:M1: FLR: 20.3 KM, FC: 10 Kamps, M2: FLR: 22.1 KM, FC: 9.4 Kamps* Fault is in Tuticorin PS Jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV UDUMALPET-MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV MYSORE-HIRIYUR	OSPT	10-08-2023	10:02:00	10-08-2023	15:29:00	0.23	5.45	0.00	0.00	0.00	99.27	* Shutdown availed for CVT Replacement work at Mysore SS (B phase), Terminal Bay AMP at Hiriyrur SS and Line maintenance work by Hiriyrur, Mysore and Hassan TLM.
							0.23	5.45	0.00	0.00	0.00	99.27	
CKT	400KV MYSORE-KOZHICODE-1	OSPT	23-08-2023	09:45:00	23-08-2023	17:45:00	0.33	8.00	0.00	0.00	0.00	98.92	* Shut down availed for AMP works vide SRLDC code no. CR-08/3540.
							0.33	8.00	0.00	0.00	0.00	98.92	
CKT	400KV MYSORE-KOZHICODE-2	LART	10-08-2023	14:59:00	10-08-2023	14:59:00	0.00	0.00	0.00	0.00	0.00	100.00	* Auto reclosed successfully on R -G fault. Mysore end details: M1: FLR: 155.4 KM, FC: 2.59 Kamps, M2: FLR: 137.2 KM, FC: 2.61 Kamps. Kozhikode end details:M1: FLR: 40.8 KM, FC:5.1 Kamps, M2: FLR: 42.3 KM, FC: 4.64 Kamps* Fault is in Kozhikode Jurisdiction.
CKT	400KV MYSORE-KOZHICODE-2	OSPT	09-08-2023	09:26:00	09-08-2023	17:22:00	0.33	7.93	0.00	0.00	0.00	98.93	* Shut down availed for AMP works and to attend shutdown nature defects in line vide SRLDC code no. CR-08/1381.
							0.33	7.93	0.00	0.00	0.00	98.93	
CKT	400KV NEYVELLI TS2-NEYVELLI TS1 EXP			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NEYVELI TS2(NLC)-KARUR-1	OSPD	01-08-2023	09:17:00	04-08-2023	13:07:00	3.16	0.00	0.00	0.00	75.83	100.00	* Shutdown availed by NLC vide SRLDC Code: 08/53 for replacement of Circuit breaker. Opportunity shutdown availed by KARUR SS <->-> Karur, Nagapattinam, Neyveli, Trichy TLM's.
							3.16	0.00	0.00	0.00	75.83	100.00	
CKT	400KV NEYVELLI TS2 EXP(NLC) EXP-KARUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NEYVELI(NLC)-SALEM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NAGAPATTINAM-NEYVELI TS1(NLC) EXP			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NAGAPATTINAM-NEYVELI TS2(NLC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NELAMANGALA(KPTCL)-BIDADI-1	OSPD	09-08-2023	10:43:00	09-08-2023	20:48:00	0.42	0.00	0.00	0.00	10.08	100.00	* Shut down availed by KPTCL for annual relay testing work vide SRLDC code no. CR-08/1405.
							0.42	0.00	0.00	0.00	10.08	100.00	
CKT	400KV NELAMANGALA(KPTCL)-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NELAMANGALA(KPTCL)-HASSAN-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NELAMANGALA(KPTCL)-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NELAMANGALA(KPTCL)-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NNTPS(NLC)-KARUR-1	OSPD	14-08-2023	18:45:00	14-08-2023	18:53:00	0.01	0.00	0.00	0.00	0.13	100.00	* Line Handtripped at NNTPS end only for normalization of 400kv Bus-1 at NNTPS vide SRLDC code no. CR- 08/2326.
CKT	400KV NNTPS(NLC)-KARUR-1	OMSU	11-08-2023	17:54:00	11-08-2023	17:54:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line Auto/Reclosed successfully on R-G fault. Karur end details: M1: FLR: 263 KM, FC: 2.13 Kamps, M2: NR. NNTPS end details: BusBar protection operated at NNTPS.
CKT	400KV NNTPS(NLC)-KALVINDAPATTU-1	OMSU	11-08-2023	17:54:00	12-08-2023	11:36:00	0.74	0.00	17.70	0.00	0.00	100.00	* Line tripped on R -G fault. KALIVANTHAPATTU end details: M1: FLR: 278.7 KM, FC: 1.95 Kamps, M2: NR. NNTPS end details: BusBar protection operated at NNTPS.
CKT	400KV NNTPS(NLC)-KALVINDAPATTU-1	OSPD	24-08-2023	12:34:00	24-08-2023	19:42:00	0.30	0.00	0.00	0.00	7.13	100.00	* Emergency shut down availed by TANTRANSCO for replacing damaged porcelain insulator at Tower No 788 of TANTRANSCO portion vide SRLDC code no. CR- 08/3758.
CKT	400KV NNTPS(NLC)-KALVINDAPATTU-1	OMSU	12-08-2023	13:13:00	12-08-2023	13:13:00	0.00	0.00	0.00	0.00	0.00	100.00	* Auto reclosed successfully on B-N (Ph-earth) transient fault.* KVPT end details: M1/M2: 92.8/91.4 kms and 3.65/4.06 ka* NNTPS end details: M1/M2: 179/NR kms and 2.26/NR KA.* Fault in TNEB portion of the line.
CKT	400KV NNTPS(NLC)-PUDUCHERRY-1			00:00:00		00:00:00	1.04	0.00	17.70	0.00	7.13	100.00	
CKT	400KV NARENDRA-GUTTUR(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV NARENDRA-GUTTUR(KPTCL)-2	LVRD	07-08-2023	23:25:00	08-08-2023	09:42:00	0.43	0.00	0.00	0.00	10.28	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/1099 (423 - 421 Kv).
CKT	400KV NARENDRA-GUTTUR(KPTCL)-2	LEFT	01-08-2023	08:00:00	02-08-2023	21:43:00	1.57	37.72	0.00	0.00	0.00	100.00	* Line tripped on Y -G fault on SOTF during Normalization of Line from SVRD - Narenda end details: M1: FLR: 61.4 KM, FC: 4.47 Kamps, M2: FLR: 61.4 KM, FC: 4.47 Kamps.* Guttur end details:M1: FLR: 68.0 KM, FC:4.5 Kamps.* Fault is in Narenda TLM Jurisdiction.
CKT	400KV NARENDRA-GUTTUR(KPTCL)-2	LVRD	01-08-2023	00:00:01	01-08-2023	08:00:00	0.33	0.00	0.00	0.00	8.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3253(425-422 Kv).
CKT	400KV NARENDRA-GUTTUR(KPTCL)-2	LVRD	08-08-2023	23:53:00	09-08-2023	08:08:00	0.34	0.00	0.00	0.00	8.25	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/1316(424 - 420Kv).
CKT	400KV NARENDRA-GUTTUR(KPTCL)-2	LVRD	04-08-2023	00:17:00	04-08-2023	06:32:00	0.26	0.00	0.00	0.00	8.25	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/476 (423-420 Kv).
CKT	400KV PUGALUR-ARASUR-1			00:00:00		00:00:00	2.93	37.72	0.00	0.00	32.78	94.93	
CKT	400KV PUGALUR-ARASUR-2	GOVC	11-08-2023	19:58:00	11-08-2023	20:39:00	0.03	0.00	0.00	0.68	0.00	100.00	* Line Tripped on Overvoltage Stage-1 protection operation at Pugalur(HVDC) end and DT received at Arasur end.
CKT	400KV PUGALUR GIS-E.PALAYM(TANTRANSCO)-1			00:00:00		00:00:00	0.03	0.00	0.00	0.68	0.00	100.00	
CKT	400KV PUGALUR GIS-E.PALAYM(TANTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PUGALUR GIS-KARUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PUGALUR GIS-KARUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PUGALUR-TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PUGALUR-TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PALAKKAD-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PALAKKAD-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PUDUCHERRY-SVCHATRAM(TANTRANSCO)-1	OMSU	22-08-2023	05:48:00	22-08-2023	06:21:00	0.02	0.00	0.55	0.00	0.00	100.00	* Line Tripped on Bph- G Fault : at Pondicherry End (due to Fault in Zone 2 <-&-> Carrier signal not received from SV chitram end), AR successful at SV Chitram end. Fault Details:- Pody End :- Zone 2 optd .M1:- FLR :- 112.3 km, FC:- 2.58 kA , M2: FLR:- 109.7 KM, FC:- 2.44 kA. SV Chitram end:- Zone-1 optd. M1 :- FLR :- 19.6 km, FC :- 10.65 kA, M2:- FLR:- 19.5 km, FC :- 10.56 kA. Fault in Sriperumbdur TLM section.* SV Chitram end <-(>-&->R panels belongs to TANTRANSCO.
CKT	400KV PUDUCHERRY-SVCHATRAM(TANTRANSCO)-1	OSPD	29-08-2023	11:45:00	29-08-2023	17:34:00	0.24	0.00	0.00	0.00	5.82	100.00	* Shut down availed by TANTRANSCO for quarterly maintenance works vide SRLDC code no. CR-08/4558
CKT	400KV PAVAGADA-BELLARY(KPTCL)-1	OSPD	08-08-2023	11:11:00	08-08-2023	17:27:00	0.26	0.00	0.00	0.00	6.27	100.00	* Shut down availed by KPTCL for replacement of damaged spacers and Quarterly maintenance work vide SRLDC code no. CR-08/1176
CKT	400KV PAVAGADA-BELLARY(KPTCL)-2	OSPD	09-08-2023	11:15:00	09-08-2023	18:56:00	0.26	0.00	0.00	0.00	6.27	100.00	
CKT	400 KV PAVAGADA-DEVANAHALLI(KPTCL)-1			00:00:00		00:00:00	0.32	0.00	0.00	0.00	7.68	100.00	* Shut down availed by KPTCL for replacement of damaged spacers and quarterly maintenance works vide SRLDC code no. CR-08/1418.
CKT	400 KV PAVAGADA-DEVANAHALLI(KPTCL)-2			00:00:00		00:00:00	0.32	0.00	0.00	0.00	7.68	100.00	
CKT	400KV PAVAGADA-HIRIYUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV PAVAGADA-TUMKUR-1	LVRD	20-08-2023	20:25:00	21-08-2023	06:23:00	0.42	0.00	0.00	0.00	9.97	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/3108(428 -426 Kv).
CKT	400KV PAVAGADA-TUMKUR-1	LVRD	30-08-2023	20:43:00	31-08-2023	07:37:00	0.45	0.00	0.00	0.00	10.90	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/4498 (424-421 Kv).
CKT	400KV PAVAGADA-TUMKUR-1	LVRD	19-08-2023	20:35:00	20-08-2023	09:13:00	0.53	0.00	0.00	0.00	12.63	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/3041(421 -420 Kv).
CKT	400KV PAVAGADA-TUMKUR-1	LVRD	29-08-2023	20:43:00	30-08-2023	07:22:00	0.44	0.00	0.00	0.00	10.65	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/4647(418-418 Kv).
CKT	400KV PAVAGADA-TUMKUR-2	LVRD	12-08-2023	20:25:00	14-08-2023	06:29:00	1.42	0.00	0.00	0.00	34.07	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/2086(419 - 415Kv).
CKT	400KV PAVAGADA-TUMKUR-2	LVRD	01-08-2023	19:14:00	02-08-2023	08:32:00	0.55	0.00	0.00	0.00	13.30	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/ 133.
CKT	400KV PAVAGADA-TUMKUR-2	LVRD	03-08-2023	23:20:00	04-08-2023	06:33:00	0.30	0.00	0.00	0.00	7.22	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/472 (425-422 Kv).
CKT	400KV PAVAGADA-TUMKUR-2	LVRD	04-08-2023	23:29:00	07-08-2023	09:19:00	2.41	0.00	0.00	0.00	57.83	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/668 (424 - 423 Kv).
CKT	400KV PAVAGADA-TUMKUR-2	LVRD	22-08-2023	02:57:00	23-08-2023	09:59:00	1.29	0.00	0.00	0.00	31.03	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/3280 (422-420Kv).
CKT	400KV PAVAGADA-TUMKUR-2	LVRD	31-08-2023	20:19:00	31-08-2023	23:59:59	0.15	0.00	0.00	0.00	3.68	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/5096(430-429 Kv).
CKT	400KV PAVAGADA-TUMKUR-2	LVRD	27-08-2023	21:05:00	28-08-2023	07:24:00	0.43	0.00	0.00	0.00	10.32	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/4307 (418-418 Kv).
CKT	400KV PAVAGADA-TUMKUR-2	LVRD	30-08-2023	20:45:00	31-08-2023	07:22:00	0.44	0.00	0.00	0.00	10.62	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/4497 (420-419 Kv).
CKT	400KV PAVAGADA-TUMKUR-2	LVRD	19-08-2023	23:34:00	20-08-2023	09:51:00	0.43	0.00	0.00	0.00	10.28	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/3046 (427-426 Kv).
CKT	400KV PAVAGADA-TUMKUR-3	LVRD	01-08-2023	19:17:00	02-08-2023	08:58:00	0.57	0.00	0.00	0.00	13.68	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/134
CKT	400KV PAVAGADA-TUMKUR-3	LVRD	05-08-2023	22:45:00	07-08-2023	06:52:00	1.34	0.00	0.00	0.00	32.12	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/822 (422 - 422 Kv).
CKT	400KV PAVAGADA-TUMKUR-3	LVRD	01-08-2023	00:00:01	01-08-2023	08:21:00	0.35	0.00	0.00	0.00	8.35	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2755 (430-429 Kv).
CKT	400KV PAVAGADA-TUMKUR-4	LVRD	29-08-2023	20:45:00	30-08-2023	07:25:00	0.44	0.00	0.00	0.00	10.67	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/4648(418-416 Kv).
CKT	400KV PAVAGADA-TUMKUR-4	LVRD	22-08-2023	03:02:00	23-08-2023	09:57:00	1.29	0.00	0.00	0.00	30.92	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/3281 (420-420Kv).
CKT	400KV PAVAGADA-TUMKUR-4	LVRD	26-08-2023	18:32:00	27-08-2023	08:23:00	0.58	0.00	0.00	0.00	13.85	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/4194(419 -417 Kv).
CKT	400KV PAVAGADA-TUMKUR-4	LVRD	11-08-2023	20:24:00	12-08-2023	10:46:00	0.60	0.00	0.00	0.00	14.37	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/1935(429 -427 Kv).
CKT	400KV PAVAGADA-TUMKUR-4	LVRD	13-08-2023	21:10:00	16-08-2023	09:18:00	2.51	0.00	0.00	0.00	60.13	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 08/2189 (424 - 422Kv)

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							5.42	0.00	0.00	0.00	129.94	100.00	
CKT	400KV PAVAGADA-MYSORE	LVRD	01-08-2023	19:23:00	02-08-2023	08:35:00	0.55	0.00	0.00	0.00	13.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/131.
CKT	400KV PAVAGADA-MYSORE	LVRD	26-08-2023	18:29:00	27-08-2023	09:32:00	0.63	0.00	0.00	0.00	15.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/4193(419 - 419Kv).
CKT	400KV PAVAGADA-MYSORE	LVRD	27-08-2023	21:03:00	28-08-2023	06:56:00	0.41	0.00	0.00	0.00	9.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/4306 (420-418 Kv).
CKT	400KV PAVAGADA-MYSORE	LVRD	29-08-2023	20:53:00	30-08-2023	07:31:00	0.44	0.00	0.00	0.00	10.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/465(1 415- Kv).
CKT	400KV PAVAGADA-MYSORE	LVRD	20-08-2023	20:28:00	21-08-2023	06:24:00	0.41	0.00	0.00	0.00	9.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/3107(423-420 Kv).
CKT	400KV PAVAGADA-MYSORE	LVRD	03-08-2023	20:55:00	04-08-2023	06:37:00	0.40	0.00	0.00	0.00	9.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/467 (418-415 Kv).Line reactor is converted into Bus reactor.
CKT	400KV PAVAGADA-MYSORE	LVRD	05-08-2023	22:39:00	07-08-2023	07:20:00	1.36	0.00	0.00	0.00	32.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/823 (420 - 417 Kv). LR @ Mysore end converted to BR.
CKT	400KV PAVAGADA-MYSORE	LVRD	04-08-2023	21:35:00	05-08-2023	07:09:00	0.40	0.00	0.00	0.00	9.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/657 (419 -417 Kv).
CKT	400KV PAVAGADA-MYSORE	LVRD	30-08-2023	20:49:00	31-08-2023	07:34:00	0.45	0.00	0.00	0.00	10.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/4896 (418-415 Kv).
CKT	400KV PAVAGADA-MYSORE	LVRD	19-08-2023	20:32:00	20-08-2023	09:09:00	0.53	0.00	0.00	0.00	12.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/3042(421 -421 Kv).
CKT	400KV PAVAGADA-MYSORE	LVRD	13-08-2023	21:10:00	14-08-2023	06:47:00	0.40	0.00	0.00	0.00	9.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/2188 (415 - 412Kv) <-&-> converted LR in to BR.
CKT	400KV PAVAGADA-MYSORE	LVRD	11-08-2023	22:54:00	12-08-2023	07:22:00	0.35	0.00	0.00	0.00	8.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/1943(419 -417 Kv). L/R converted as B/R at Mysore
CKT	400KV PAVAGADA-MYSORE	LVRD	12-08-2023	20:31:00	13-08-2023	07:04:00	0.44	0.00	0.00	0.00	10.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system side SRLDC code no. CR- 08/2087(413 - 409Kv) <-&-> converted in to BR.
							6.77	0.00	0.00	0.00	162.65	100.00	
CKT	400KV SALEM-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400KV SALEM-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV SALEM-NNTPS(NLC)	OMSU	13-08-2023	18:32:00	13-08-2023	19:13:00	0.03	0.00	0.68	0.00	0.00		* Line tripped due to DT receipt at Salem end due to false pickup of gas pressure at NNTPS end.
							0.03	0.00	0.68	0.00	0.00	100.00	
CKT	400KV SALEM-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV SALEM-UDUMALPET-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV-SOMANHALLI-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV SOMANHALLI-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV SOMANHALLI-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV SOMANHALLI-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV SOMANHALLI-HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV-SOMANHALLI-MYLASANDRA-1	OSPT	07-08-2023	10:32:00	07-08-2023	17:57:00	0.31	7.42	0.00	0.00	0.00		* Shut down availed for AMP works vide SRLDC code no. CR-08/976
							0.31	7.42	0.00	0.00	0.00	99.00	
CKT	400KV SVCHATRM(TANTRANSCO)-SRIPERMBUDR-1	OSPD	01-08-2023	09:47:00	01-08-2023	17:06:00	0.31	0.00	0.00	0.00	7.32		* Shutdown availed by Tantransco for Monthly Maintainance work Vide SRLDC Code: 08/57. Opportunity Shutdown availed by SPDR SS.
							0.31	0.00	0.00	0.00	7.32	100.00	
CKT	400KV TRICHUR HVDC-KOCHI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV TRICHUR HVDC-KOCHI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV TRICHUR HVDC-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV TRICHUR HVDC-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV THIRUNELVELI-KOCHI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV THIRUNELVELI-KOTTAYAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV TIRUNELVELI-TRIVANDRUM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV TIRUNELVELI-TRIVANDRUM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV TIRUNELVELI-TUTICORIN PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV TIRUNELVELI-UDUMALPET-1	LART	31-08-2023	16:38:00	31-08-2023	16:38:00	0.00	0.00	0.00	0.00	0.00		* Auto reclosed successfully on B -G fault. Thirunelveli end details: M1: FLR: 265 KM, FC: 1.55 Kamps, M2: FLR: 242.6 KM, FC: 1.53 Kamps. Udumalpet end details:M1: FLR: 36.1 KM, FC: 9.6 Kamps, M2: FLR: 27 KM, FC: 9.4 Kamps* Fault is in Udumalpet TLM Jurisdiction.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TIRUNELVELI-UDUMALPET-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV TRICHY-KARAIKUDI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV TRICHY-MADURAI-1	LCSD	18-08-2023	08:18:00	20-08-2023	21:52:00	2.57	0.00	0.00	0.00	61.57		* Shutdown availed for LA replacement work at both Trichy <-&-> Madurai SS vide SRLDC Code: 08/2815. Trichy SS is also retrofitting Autoreclosure <-&-> LBB relay.
							0.01	0.23	0.00	0.00	0.00		
CKT	400KV TRICHY-MADURAI-1	LEFT	11-08-2023	18:19:00	11-08-2023	18:33:00	0.01	0.23	0.00	0.00	0.00		* Line tripped at Trichy End only and Autoreclosure successful at Madurai end on B -G fault. Madurai end details: M1: FLR: 60.86 KM, FC: 5 Kamps, M2: FLR: 60.85 KM, FC: 5.23 Kamps. Trichy end details:M1: FLR: NR, M2: FLR: 56.5 KM, FC: 4.5 Kamps* Fault is in Madurai Jurisdiction.
							2.58	0.23	0.00	0.00	61.57	99.97	
CKT	400KV TRICHY-NAGAPPATTANAM-1	LCSD	21-08-2023	07:45:00	22-08-2023	23:21:00	1.65	0.00	0.00	0.00	39.60		* Shut down availed for Construction works: Replacement of 06Nos old 390KV LA's with 336KV LA's and retrofitting of Auto Reclose and LBB protections under Add Cap Works at Trichy Substation vide SRLDC code no. CR-08/3123.
							1.65	0.00	0.00	0.00	39.60	100.00	
CKT	400KV TRICHY-NAGAPPATTANAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00		
CKT	400KV TIRUVALEM-CHITTOOR(APTRANSCO)-1	OSPT	17-08-2023	14:06:00	17-08-2023	18:52:00	0.20	4.77	0.00	0.00	0.00		* Shutdown availed by APTRANSCO vide SRLDC code: 08/2694 for Relay testing work aty Chittoor End. Opportunity shutdown availed by THIRUVALAM SS for Line Terminal AMP <-&-> by THIRUVALAM TLM for attending shutdown nature defect works.
							0.20	4.77	0.00	0.00	0.00	99.36	
CKT	400KV TIRUVALEM-CHITTOOR(APTRANSCO)-2	OSPT	18-08-2023	09:39:00	18-08-2023	17:32:00	0.33	7.88	0.00	0.00	0.00		* Shutdown availed by APTRANSCO for Relay testing work vide SRLDC Code: 08/2832. Opportunity shutdown availed by Thiruvalem SS for Relay Testing, Terminal Bay AMP work and to attend Shutdown nature defect work by Thiruvalem <-&-> SR-1 TLM.
							0.33	7.88	0.00	0.00	0.00	98.94	
CKT	400KV TIRUVALAM-KALVINDAPATTU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
								0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF HOSUR-2 AT SALEM	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59		31.00	0.00	0.00	0.00	744.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/283 (391 -392 Kv).
LNR	50MVAR,SWLR OF KOLAR AT SOMANHALLI			00:00:00		00:00:00		31.00	0.00	0.00	0.00	744.00	
LNR	50MVAR,SWLR OF CHITTOOR AT SRIPERUMBUDUR	SVRD	01-08-2023	00:00:01	08-08-2023	17:50:00		0.00	0.00	0.00	0.00	0.00	
LNR	50MVAR,SWLR OF SVCHATRAM AT SRIPERUMBUDUR	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59		7.74	0.00	0.00	0.00	185.83	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 02/4809 (399 - 400 Kv).
LNR	50MVAR,SWLR OF PALAKKAD-1 AT THRISSUR			00:00:00		00:00:00		31.00	0.00	0.00	0.00	744.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 04/2252 (391-391 Kv).
LNR	50MVAR,SWLR OF PALAKKAD-2 AT THRISSUR			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
LNR	63MVAR,SWLR OF UDUMALPT-1 AT TIRUNELVELI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
LNR	63MVAR,SWLR OF UDUMALPT-2 AT TIRUNELVELI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
LNR	63MVAR,SWLR OF NAGAPATTINAM-1 AT TRICHY	SVRD	01-08-2023	10:28:00	22-08-2023	23:21:00		21.54	0.00	0.00	0.00	518.88	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/67 (383- 386 Kv).
LNR	63MVAR,SWLR OF NAGAPATTINAM-1 AT TRICHY	SVRD	23-08-2023	09:40:00	31-08-2023	23:59:59		8.60	0.00	0.00	0.00	206.33	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 08/3546(397 - 397Kv).
LNR	50MVAR,SWLR OF NAGAPATTINAM-2 AT TRICHY	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59		30.14	0.00	0.00	0.00	723.21	
LNR	50MVAR,SWLR OF KADAPA-1 AT TUMKUR			00:00:00		00:00:00		31.00	0.00	0.00	0.00	744.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system wide SRLDC code no. CR- 03/5089(388 - 389Kv).
LNR	50MVAR,SWLR OF KADAPA-2 AT TUMKUR			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
LNR	50MVAR,SWLR OF NELLORE-1 AT TIRUVALAM			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
LNR	50MVAR,SWLR OF NELLORE-2 AT TIRUVALAM			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
LNR	63MVAR,SWLR OF SALEM-2 AT UDUMALPET			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
LNR	63MVAR,SWLR OF TIRUNELVELI-2 AT UDUMALPT			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
LNR	63MVAR,SWLR OF TIRUNELVELI-1 AT UDUMALPT			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
STATCOM	200+200 MVAR STATCOM AT TRICHY			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
STATCOM	200+200 MVAR STATCOM AT UDUMALPET			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
SVC	Trichy STATCOM-MSR-1 (-125 MVAR)			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-1	LART	28-08-2023	04:45:00	28-08-2023	04:45:00		0.00	0.00	0.00	0.00	0.00	* LFL and DC line fault recovery sequence operated <(>&< cleared in first attempt at 545.9 km from Kolar end (Tower no. 2208). Fault location comes under SR-1 TLM jurisdiction.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	LART	16-08-2023	03:39:00	16-08-2023	03:39:00		0.00	0.00	0.00	0.00	0.00	* HVDC Talcher - Kolar Pole-2 LFL with recovery sequence operated and cleared in 2nd attempt.* FLR: 603.7 km from kolar (Tower No: 2056).* Fault location comes under Vijayawada TLM, SR-1 jurisdiction.
VALVE_HALL	500kV HVDC TALCHAR-KOLAR POLE-2	LART	30-08-2023	03:09:00	30-08-2023	03:09:00		0.00	0.00	0.00	0.00	0.00	* LFL with recovery sequence operated <(>&< cleared in second attempt at 15.2km from Kolar end (Tower no. 3658). Fault location comes under Kolar TLM jurisdiction.
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-2	OSPT	08-08-2023	20:34:00	08-08-2023	22:37:00		0.09	2.05	0.00	0.00	0.00	* Shut down availed for attending hotspot in R-phase clamp of the BPI connected to AC PLC filter of Pole-2 vide SRLDC code no. CR-08/1= 289/705/619.
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-3			00:00:00		00:00:00		0.09	2.05	0.00	0.00	99.72	
VALVE_HALL	800kV HVDC RAIGARH-PUGALUR POLE-4			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-1	OMST	08-08-2023	20:20:00	08-08-2023	23:10:00		0.12	2.83	0.00	0.00	0.00	* VSC link-1 tripped on CWC PLC fault at Thirssur end and Pole is in decoupled mode at Pugalur end.
VALVE_HALL	320kV HVDC PUGALUR-THRISSUR POLE-2			00:00:00		00:00:00		0.12	2.83	0.00	0.00	99.62	
XMER	315MVA,400/220kV ICT-1 AT ARASUR			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
XMER	315MVA,400/220kV ICT-2 AT ARASUR			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
XMER	500MVA,400/220kV ICT-3 AT ARASUR			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
XMER	500MVA,400/220kV ICT-1 AT BIDADI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
XMER	500MVA,400/220kV ICT-2 AT BIDADI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
XMER	315MVA,400/220kV ICT-1 AT HASSAN			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
XMER	315MVA,400/220kV ICT-2 AT HASSAN			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
XMER	315MVA,400/220kV ICT-1 AT HIRIYUR			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	
XMER	315MVA,400/220kV ICT-2 AT HIRIYUR			00:00:00		00:00:00		0.00	0.00	0.00	0.00	0.00	

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
								0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT HIRIYUR			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT HOSUR			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT HOSUR	OSPT	23-08-2023	09:35:00	23-08-2023	17:52:00		0.35	8.28	0.00	0.00	98.89	* Shut down availed for AMP works vide SRLDC code no. CR-08/3538.
XMER	315MVA,400/220kV ICT-3 AT HOSUR			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KALIVANTHPATTU	OSPT	12-08-2023	09:17:00	12-08-2023	17:29:00		0.34	8.20	0.00	0.00	98.90	* Shut down availed for AMP works vide SRLDC code no. CR-08/2011.
XMER	315MVA,400/220kV ICT-2 AT KALIVANTHPATTU	OSPT	11-08-2023	09:37:00	11-08-2023	18:54:00		0.39	9.28	0.00	0.00	98.75	* Shut down availed for AMP works vide SRLDC code no. CR-08/1809
XMER	500MVA,400/220kV ICT-3 AT KALIVANTHPATTU			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KARAUKUDI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KARAUKUDI	OSPT	22-08-2023	07:08:00	22-08-2023	19:21:00		0.51	12.22	0.00	0.00	98.36	* shutdown availed vide SRLDC code: 08/3289 for AMP works and OLTC overhauling works
XMER	500MVA,400/220kV ICT-3 AT KARAUKUDI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KOCHI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KOCHI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KOCHI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT KOLAR			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT KOLAR	OSPT	30-08-2023	15:53:00	30-08-2023	16:16:00		0.02	0.38	0.00	0.00	99.95	* ICT Shut down availed for combination changing vide SRLDC code no. CR-08/4790.
XMER	315MVA,400/220kV ICT-1 AT KOZIKODE			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KOZIKODE			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KOZIKODE			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MADURAI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MADURAI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MADURAI			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MYSORE			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MYSORE			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MYSORE			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT NARENDRA			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT NARENDRA			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PALAKKAD			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PALAKKAD			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PUDUCHERRY	OSPT	17-08-2023	12:34:00	17-08-2023	21:25:00		0.37	8.85	0.00	0.00	98.81	* Shutdown availed for AMP works <(>&< WTI, OTI <(>&< PRV, OSR Scheme Modification Works vide SRLDC code no. CR- 08/2688.
XMER	315MVA,400/220kV ICT-2 AT PUDUCHERRY			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PUDUCHERRY	OSPT	19-08-2023	08:54:00	19-08-2023	18:38:00		0.41	9.73	0.00	0.00	98.69	* ICT Shut down availed for AMP works. WTI, OTI, PRV, OSR Scheme Modification Works vide SRLDC code no. CR-08/2963.
XMER	315MVA,400/220kV ICT-1 AT KARUR	SPRD	09-08-2023	19:23:00	10-08-2023	00:14:00		0.20	0.00	0.00	0.00	4.85	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/1523 (92, 93, 168 MW, TO - 0, 114,204 MW).
XMER	315MVA,400/220kV ICT-1 AT KARUR	SPRD	30-08-2023	18:49:00	30-08-2023	22:57:00		0.17	0.00	0.00	0.00	4.13	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/4868 (136,136,245 -> 0, 167, 290 MW).
XMER	315MVA,400/220kV ICT-1 AT KARUR	OSPT	17-08-2023	09:10:00	17-08-2023	19:09:00		0.42	9.98	0.00	0.00	0.00	* Shut down availed for AMP works vide SRLDC code no. CR-08/2635.
XMER	315MVA,400/220kV ICT-1 AT KARUR	SPRD	21-08-2023	19:13:00	22-08-2023	11:47:00		0.69	0.00	0.00	0.00	16.57	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/3247. ICT Loadings: ICT-1: 121/0, ICT-2: 122/151, ICT-3: 217/269.
XMER	315MVA,400/220kV ICT-1 AT KARUR	SPRD	08-08-2023	21:36:00	09-08-2023	01:45:00		0.17	0.00	0.00	0.00	4.15	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/1302(120, 120, 0-0, 165, 0 MW).
XMER	315MVA,400/220kV ICT-1 AT KARUR	SPRD	10-08-2023	21:45:00	11-08-2023	01:43:00		0.17	0.00	0.00	0.00	3.97	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/1729 (127,127,227 MW) to (0,159,282 MW).
XMER	315MVA,400/220kV ICT-2 AT KARUR	OSPT	18-08-2023	09:21:00	18-08-2023	17:53:00		0.36	8.53	0.00	0.00	98.66	* Shutdown availed for AMP work of ICT vide SRLDC code: 08/2827.
XMER	315MVA,400/220kV ICT-2 AT KARUR	SPRD	21-08-2023	19:14:00	22-08-2023	11:49:00		0.69	0.00	0.00	0.00	16.58	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/3248. ICT Loadings: ICT-1: 0/0, ICT-2: 151/0, ICT-3: 269/352.
XMER	315MVA,400/220kV ICT-2 AT KARUR	SPRD	08-08-2023	21:37:00	09-08-2023	01:43:00		0.17	0.00	0.00	0.00	4.10	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/1304(0, 165, 0-0, 0, 0 MW).
XMER	315MVA,400/220kV ICT-2 AT KARUR	SPRD	09-08-2023	19:23:00	10-08-2023	00:15:00		0.20	0.00	0.00	0.00	4.87	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/1524 (0, 114, 204MW TO - 0, 0, 264 MW).
XMER	315MVA,400/220kV ICT-2 AT KARUR	SPRD	10-08-2023	21:46:00	11-08-2023	01:42:00		0.16	0.00	0.00	0.00	3.93	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/1730 (0,159,282 MW) to (0,0,372 MW).
XMER	315MVA,400/220kV ICT-2 AT KARUR	SPRD	30-08-2023	18:50:00	30-08-2023	22:59:00		0.17	0.00	0.00	0.00	4.15	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/4868 (0,167,298 -> 0, 0, 386 MW).
XMER	500MVA,400/220kV ICT-3 AT KARUR	SPRD	09-08-2023	19:24:00	10-08-2023	00:17:00		0.20	0.00	0.00	0.00	4.88	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/1525 (0, 0, 264 MW TO 0, 0, 0MW)
XMER	500MVA,400/220kV ICT-3 AT KARUR	SPRD	08-08-2023	21:24:00	09-08-2023	01:11:00		0.16	0.00	0.00	0.00	3.78	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/1305(74, 74, 131 -107, 108, 0 MW).
XMER	500MVA,400/220kV ICT-3 AT KARUR	SPRD	10-08-2023	21:47:00	11-08-2023	01:41:00		0.16	0.00	0.00	0.00	3.90	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/1730 (0,0,372 MW) to (0,0,0 MW).
XMER	500MVA,400/220kV ICT-3 AT KARUR	SPRD	21-08-2023	19:14:00	22-08-2023	11:51:00		0.69	0.00	0.00	0.00	16.62	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/3249. ICT Loadings: ICT-1: 0/0, ICT-2: 0/0, ICT-3: 352/0.
XMER	500MVA,400/220kV ICT-3 AT KARUR	SPRD	30-08-2023	18:51:00	30-08-2023	23:00:00		0.17	0.00	0.00	0.00	4.15	* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 08/4868 (0,0,386 -> 0, 0, 0 MW).
XMER	500MVA,400/220kV ICT-1 AT PAVAGADA			00:00:00		00:00:00		0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Aug-2023

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT PAVAGADA	OSPT	10-08-2023	17:20:00	11-08-2023	01:21:00	0.33	8.02	0.00	0.00	0.00	98.92	* Shut down availed for AMP works vide SRLDC code no. CR-08/1677.
XMER	500MVA,400/220kV ICT-4 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT PAVAGADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOMANHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRICHUR HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT THIRUNELVELI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT TRICHY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	TuticorinGIS ICT3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	