

Standard of Performance data for the month of July-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	09-07-2024	08:44:00	09-07-2024	21:32:00	0.53	0.00	0.00	0.00	12.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1089(399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	10-07-2024	09:25:00	10-07-2024	16:54:00	0.31	0.00	0.00	0.00	7.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1238(398-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	24-07-2024	09:25:00	24-07-2024	18:55:00	0.40	0.00	0.00	0.00	9.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2902(395 - 395Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	25-07-2024	09:02:00	25-07-2024	21:24:00	0.52	0.00	0.00	0.00	12.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3029 (398 - 399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	08-07-2024	08:25:00	08-07-2024	18:42:00	0.43	0.00	0.00	0.00	10.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/947(401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	12-07-2024	08:05:00	12-07-2024	20:53:00	0.53	0.00	0.00	0.00	12.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1482 (401 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	04-07-2024	07:55:00	04-07-2024	22:58:00	0.63	0.00	0.00	0.00	15.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1443 (400-403Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	23-07-2024	08:50:00	23-07-2024	20:42:00	0.49	0.00	0.00	0.00	11.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2781(401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	21-07-2024	10:11:00	21-07-2024	15:28:00	0.22	0.00	0.00	0.00	5.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2561(397 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	17-07-2024	09:23:00	17-07-2024	16:24:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2065 (396 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	22-07-2024	09:57:00	22-07-2024	17:25:00	0.31	0.00	0.00	0.00	7.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2859 (395 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	18-07-2024	08:43:00	18-07-2024	16:47:00	0.34	0.00	0.00	0.00	8.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2165 (403 - 405Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	06-07-2024	09:28:00	06-07-2024	20:46:00	0.47	0.00	0.00	0.00	11.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/7737 (398 - 399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	13-07-2024	09:19:00	14-07-2024	17:18:00	1.33	0.00	0.00	0.00	31.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1642(399-402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	19-07-2024	07:59:00	19-07-2024	16:20:00	0.35	0.00	0.00	0.00	8.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2324 (404-406Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	01-07-2024	09:10:00	02-07-2024	18:10:00	1.38	0.00	0.00	0.00	33.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/43(394-396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	03-07-2024	08:07:00	03-07-2024	18:48:00	0.45	0.00	0.00	0.00	10.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/310 (402 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	05-07-2024	06:51:00	05-07-2024	18:13:00	0.47	0.00	0.00	0.00	11.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/578 (402 - 404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	30-07-2024	09:21:00	30-07-2024	16:58:00	0.32	0.00	0.00	0.00	7.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3696(396 - 397Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	29-07-2024	08:14:00	29-07-2024	18:37:00	0.43	0.00	0.00	0.00	10.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3546 (405 - 405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	27-07-2024	08:22:00	27-07-2024	17:17:00	0.37	0.00	0.00	0.00	8.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3338 (402-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	26-07-2024	08:26:00	26-07-2024	15:45:00	0.31	0.00	0.00	0.00	7.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3176 (399 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	31-07-2024	08:57:00	31-07-2024	16:52:00	0.33	0.00	0.00	0.00	7.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3851(397 - 397Kv).
BSR	63MVAR, BUS REACTOR-1 AT BIDADI	SVRD	11-07-2024	08:02:00	11-07-2024	17:14:00	0.38	0.00	0.00	0.00	9.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1339 (406 - 406 Kv).
							11.59	0.00	0.00	0.00	278.03	100.00	
BSR	125MVAR, BUS REACTOR AT DHARMAPURI	SVRD	30-07-2024	10:36:00	30-07-2024	20:34:00	0.42	0.00	0.00	0.00	9.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3724(393 -395 Kv).
							0.42	0.00	0.00	0.00	9.97	100.00	
BSR	80MVAR, BUS REACTOR-1 AT HASSAN	SVRD	26-07-2024	08:29:00	26-07-2024	21:34:00	0.55	0.00	0.00	0.00	13.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3177 (405 - 408Kv).
							0.55	0.00	0.00	0.00	13.08	100.00	
BSR	125MVAR, BUS REACTOR-2 AT HASSAN	SVRD	12-07-2024	09:50:00	12-07-2024	16:09:00	0.26	0.00	0.00	0.00	6.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1506 (399-402Kv).
							0.26	0.00	0.00	0.00	6.32	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	26-07-2024	08:32:00	26-07-2024	21:28:00	0.54	0.00	0.00	0.00	12.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3178 (400 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	24-07-2024	11:04:00	24-07-2024	18:56:00	0.33	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2918(397 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	25-07-2024	09:42:00	25-07-2024	21:25:00	0.49	0.00	0.00	0.00	11.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3049 (398 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	16-07-2024	10:01:00	16-07-2024	16:29:00	0.27	0.00	0.00	0.00	6.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1926(394 - 394Kv).
BSR	63MVAR, BUS REACTOR-1 AT HIRIYUR	SVRD	09-07-2024	08:37:00	11-07-2024	15:33:00	2.29	0.00	0.00	0.00	54.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1082(400-400 Kv).
							3.92	0.00	0.00	0.00	93.92	100.00	
BSR	125MVAR, BUS REACTOR-2 AT HIRIYUR	SVRD	25-07-2024	09:43:00	25-07-2024	21:26:00	0.49	0.00	0.00	0.00	11.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3050 (398 - 403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HIRIYUR	SVRD	24-07-2024	11:05:00	24-07-2024	18:58:00	0.33	0.00	0.00	0.00	7.88		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2919(399 - 402Kv).
BSR	125MVAR, BUS REACTOR-2 AT HIRIYUR	SVRD	16-07-2024	10:02:00	16-07-2024	16:27:00	0.27	0.00	0.00	0.00	6.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1927(394 - 398Kv).
BSR	125MVAR, BUS REACTOR-2 AT HIRIYUR	SVRD	11-07-2024	11:58:00	11-07-2024	15:34:00	0.15	0.00	0.00	0.00	3.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1377 (401-402Kv).
							1.24	0.00	0.00	0.00	29.62	100.00	
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	02-07-2024	09:30:00	18-07-2024	17:03:00	16.32	0.00	0.00	0.00	391.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/166(390-390 Kv).
BSR	63MVAR, BUS REACTOR-1 AT HOSUR	SVRD	23-07-2024	08:32:00	31-07-2024	23:59:59	8.64	0.00	0.00	0.00	207.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2771(390 - 390Kv).
							24.96	0.00	0.00	0.00	599.02	100.00	
BSR	125MVAR, BUS REACTOR-2 AT HOSUR	SVRD	02-07-2024	09:34:00	18-07-2024	17:05:00	16.31	0.00	0.00	0.00	391.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/167 (390-393 Kv).
BSR	125MVAR, BUS REACTOR-2 AT HOSUR	SVRD	22-07-2024	10:21:00	31-07-2024	23:59:59	9.57	0.00	0.00	0.00	229.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2663 (389 - 393 Kv).
							25.88	0.00	0.00	0.00	621.17	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KARAIKUDI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	13-07-2024	09:17:00	14-07-2024	17:22:00	1.34	0.00	0.00	0.00	32.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1641(402-404 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	07-07-2024	09:53:00	07-07-2024	16:23:00	0.27	0.00	0.00	0.00	6.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/838(395 - 397Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	19-07-2024	08:09:00	19-07-2024	16:24:00	0.34	0.00	0.00	0.00	8.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2322 (410-412Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	25-07-2024	09:11:00	25-07-2024	18:02:00	0.37	0.00	0.00	0.00	8.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3030 (399 - 401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	11-07-2024	07:58:00	11-07-2024	17:17:00	0.39	0.00	0.00	0.00	9.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1337 (403 - 405 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	22-07-2024	09:51:00	22-07-2024	17:28:00	0.32	0.00	0.00	0.00	7.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2656 (396 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	08-07-2024	09:09:00	08-07-2024	18:47:00	0.40	0.00	0.00	0.00	9.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/954(394 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	21-07-2024	09:56:00	21-07-2024	15:34:00	0.24	0.00	0.00	0.00	5.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2550(398 -400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	17-07-2024	09:24:00	17-07-2024	16:32:00	0.30	0.00	0.00	0.00	7.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2063 (400 - 402Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	20-07-2024	09:53:00	20-07-2024	22:53:00	0.54	0.00	0.00	0.00	13.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2466 (400-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	05-07-2024	07:01:00	05-07-2024	18:09:00	0.46	0.00	0.00	0.00	11.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/576 (399 - 401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	04-07-2024	08:00:00	04-07-2024	23:10:00	0.63	0.00	0.00	0.00	15.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1444 (400-402Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	12-07-2024	08:09:00	12-07-2024	16:05:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1484 (398 - 400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	23-07-2024	08:32:00	23-07-2024	20:47:00	0.51	0.00	0.00	0.00	12.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2772(398 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	09-07-2024	08:42:00	10-07-2024	17:42:00	1.38	0.00	0.00	0.00	33.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1085(395-397 Kv).

Standard of Performance data for the month of July-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	06-07-2024	09:31:00	06-07-2024	20:59:00	0.48	0.00	0.00	0.00	11.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/736 (398 - 400 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	18-07-2024	08:54:00	18-07-2024	16:50:00	0.33	0.00	0.00	0.00	7.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2163 (408 - 410Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	01-07-2024	09:09:00	02-07-2024	18:24:00	1.39	0.00	0.00	0.00	33.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/38(396-398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	03-07-2024	08:13:00	03-07-2024	18:28:00	0.43	0.00	0.00	0.00	10.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/306 (401 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	27-07-2024	08:30:00	27-07-2024	17:22:00	0.37	0.00	0.00	0.00	8.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3336 (407-408Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	30-07-2024	09:17:00	30-07-2024	17:02:00	0.32	0.00	0.00	0.00	7.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3694(391 -392 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	26-07-2024	08:31:00	26-07-2024	15:48:00	0.30	0.00	0.00	0.00	7.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3179 (401 - 403Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	29-07-2024	08:19:00	29-07-2024	18:43:00	0.43	0.00	0.00	0.00	10.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3547 (400 - 402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	31-07-2024	09:07:00	31-07-2024	16:55:00	0.33	0.00	0.00	0.00	7.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3849(399 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	16-07-2024	10:18:00	16-07-2024	19:01:00	0.36	0.00	0.00	0.00	8.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1930(398 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT KOLAR	SVRD	24-07-2024	09:27:00	24-07-2024	19:01:00	0.40	0.00	0.00	0.00	9.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2903(399 - 400Kv).
							12.96	0.00	0.00	0.00	310.78	100.00	
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	28-07-2024	10:48:00	30-07-2024	20:23:00	2.40	0.00	0.00	0.00	57.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3464 (390 -392 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	31-07-2024	10:28:00	31-07-2024	20:24:00	0.41	0.00	0.00	0.00	9.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3878(395 - 395Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	03-07-2024	08:13:00	03-07-2024	18:41:00	0.44	0.00	0.00	0.00	10.47		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/307(401 - 404 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	02-07-2024	09:57:00	02-07-2024	18:20:00	0.35	0.00	0.00	0.00	8.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/171 (390-392 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	06-07-2024	09:32:00	06-07-2024	20:47:00	0.47	0.00	0.00	0.00	11.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/738 (394 - 395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	09-07-2024	08:42:00	10-07-2024	16:52:00	1.34	0.00	0.00	0.00	32.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1084(401-403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	22-07-2024	11:46:00	26-07-2024	17:37:00	4.24	0.00	0.00	0.00	101.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1184 (384 - 393 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	21-07-2024	10:02:00	21-07-2024	17:48:00	0.32	0.00	0.00	0.00	7.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2551(393 -393 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	12-07-2024	08:09:00	12-07-2024	20:55:00	0.53	0.00	0.00	0.00	12.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1485 (408 - 410 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	07-07-2024	09:48:00	07-07-2024	20:17:00	0.44	0.00	0.00	0.00	10.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/945(397 - 397Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	11-07-2024	09:27:00	11-07-2024	15:38:00	0.26	0.00	0.00	0.00	6.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1357 (393 - 395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	14-07-2024	11:47:00	14-07-2024	17:24:00	0.23	0.00	0.00	0.00	5.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1718 (389 - 391 Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	16-07-2024	09:58:00	20-07-2024	22:50:00	4.54	0.00	0.00	0.00	108.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1924(390 - 392Kv).
BSR	125MVAR, BUS REACTOR-1 AT KUDGI	SVRD	27-07-2024	08:17:00	27-07-2024	17:12:00	0.37	0.00	0.00	0.00	8.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3341 (402-402Kv).
							16.34	0.00	0.00	0.00	392.24	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	11-07-2024	11:56:00	11-07-2024	15:42:00	0.16	0.00	0.00	0.00	3.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1379 (397-399Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	07-07-2024	10:46:00	07-07-2024	20:20:00	0.40	0.00	0.00	0.00	9.57		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/851(390 - 393Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	06-07-2024	09:36:00	06-07-2024	20:49:00	0.47	0.00	0.00	0.00	11.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/739 (395 - 395 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	28-07-2024	10:54:00	31-07-2024	23:59:59	3.55	0.00	0.00	0.00	85.10		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3465 (392 -396 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	27-07-2024	09:37:00	27-07-2024	17:16:00	0.32	0.00	0.00	0.00	7.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3361 (396-399Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	02-07-2024	10:01:00	02-07-2024	18:25:00	0.35	0.00	0.00	0.00	8.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/172 (392-395 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	03-07-2024	08:18:00	05-07-2024	18:15:00	2.42	0.00	0.00	0.00	57.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/308 (404 - 407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	14-07-2024	11:53:00	14-07-2024	20:33:00	0.36	0.00	0.00	0.00	8.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1719 (391 - 394 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	21-07-2024	12:02:00	21-07-2024	17:53:00	0.24	0.00	0.00	0.00	5.85		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2574(390 -396 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	22-07-2024	11:53:00	26-07-2024	17:45:00	4.24	0.00	0.00	0.00	101.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2680 (393 - 398 Kv).
BSR	125MVAR, BUS REACTOR-2 AT KUDGI	SVRD	16-07-2024	10:08:00	20-07-2024	22:53:00	4.53	0.00	0.00	0.00	108.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1925(392 - 395Kv).
							17.04	0.00	0.00	0.00	408.80	100.00	
BSR	50MVAR, BUS REACTOR-1 AT MYSORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT NAGAPATTINAM	SVRD	01-07-2024	00:00:01	31-07-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 02/5143 (402-402Kv).
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	03-07-2024	08:21:00	03-07-2024	16:22:00	0.33	0.00	0.00	0.00	8.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/309 (409 - 413Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	11-07-2024	11:53:00	11-07-2024	15:37:00	0.16	0.00	0.00	0.00	3.73		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1380 (399-401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	26-07-2024	12:31:00	26-07-2024	21:38:00	0.38	0.00	0.00	0.00	9.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3233 (393 - 398Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	16-07-2024	10:11:00	16-07-2024	16:40:00	0.27	0.00	0.00	0.00	6.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1935(399 - 403Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	07-07-2024	10:46:00	07-07-2024	16:27:00	0.24	0.00	0.00	0.00	5.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/852(393 - 396Kv).
BSR	125MVAR, BUS REACTOR-1 AT NARENDRA	SVRD	22-07-2024	11:44:00	22-07-2024	17:34:00	0.24	0.00	0.00	0.00	5.83		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2681 (392 - 398 Kv).
							1.62	0.00	0.00	0.00	38.86	100.00	
BSR	125MVAR, BUS REACTOR-1 AT PUGALUR HVDC	SVRD	05-07-2024	09:24:00	31-07-2024	23:59:59	26.61	0.00	0.00	0.00	638.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/602 (409 - 411 Kv).
							26.61	0.00	0.00	0.00	638.60	100.00	
BSR	125MVAR, BUS REACTOR-2 AT PUGALUR HVDC	SVRD	05-07-2024	09:27:00	31-07-2024	23:59:59	26.61	0.00	0.00	0.00	638.55		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/603 (411 - 413 Kv).
							26.61	0.00	0.00	0.00	638.55	100.00	
BSR	63MVAR, BUS REACTOR-1 AT PALAKKAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT PUGALUR	SVRD	25-07-2024	10:53:00	27-07-2024	18:53:00	2.33	0.00	0.00	0.00	56.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3065 (397 - 397 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PUGALUR	SVRD	21-07-2024	10:31:00	22-07-2024	20:38:00	1.42	0.00	0.00	0.00	34.12		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2569(397- 397Kv).
BSR	125MVAR, BUS REACTOR-1 AT PUGALUR	SVRD	28-07-2024	12:20:00	30-07-2024	20:24:00	2.34	0.00	0.00	0.00	56.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3473 (397- 399Kv).
							6.09	0.00	0.00	0.00	146.19	100.00	
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	13-07-2024	09:19:00	13-07-2024	16:38:00	0.31	0.00	0.00	0.00	7.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1643(408-410 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	21-07-2024	09:57:00	21-07-2024	15:34:00	0.23	0.00	0.00	0.00	5.62		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2553(399 -401 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	18-07-2024	12:08:00	18-07-2024	16:51:00	0.20	0.00	0.00	0.00	4.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2213 (391 - 395 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	25-07-2024	09:12:00	25-07-2024	18:23:00	0.38	0.00					

Standard of Performance data for the month of July-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE TO Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	07-07-2024	10:48:00	07-07-2024	16:19:00	0.23	0.00	0.00	0.00	5.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/853(399 - 399Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	30-07-2024	10:47:00	30-07-2024	17:01:00	0.26	0.00	0.00	0.00	6.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3726(401 - 403 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	29-07-2024	09:59:00	29-07-2024	17:39:00	0.32	0.00	0.00	0.00	7.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3575 (400 - 402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	31-07-2024	09:37:00	31-07-2024	16:53:00	0.30	0.00	0.00	0.00	7.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3864(401 - 401Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	26-07-2024	12:35:00	26-07-2024	15:48:00	0.13	0.00	0.00	0.00	3.22		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3234 (399 - 400Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	27-07-2024	10:53:00	27-07-2024	17:09:00	0.26	0.00	0.00	0.00	6.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3370 (400-401Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	03-07-2024	09:14:00	03-07-2024	16:00:00	0.28	0.00	0.00	0.00	6.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/331(405 - 406 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	02-07-2024	09:17:00	02-07-2024	18:12:00	0.37	0.00	0.00	0.00	8.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/160(401-402 Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	19-07-2024	10:35:00	19-07-2024	16:16:00	0.24	0.00	0.00	0.00	5.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2348 (398-401Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	12-07-2024	09:31:00	12-07-2024	16:12:00	0.28	0.00	0.00	0.00	6.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/1501 (401-402Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	16-07-2024	10:13:00	16-07-2024	16:25:00	0.26	0.00	0.00	0.00	6.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/1928(399 - 401Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	23-07-2024	08:34:00	23-07-2024	16:16:00	0.32	0.00	0.00	0.00	7.70		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2773(405 - 407Kv).
BSR	125MVAR, BUS REACTOR-1 AT PAVAGADA	SVRD	22-07-2024	11:27:00	22-07-2024	17:22:00	0.25	0.00	0.00	0.00	5.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2677 (398 - 399 Kv).
							5.41	0.00	0.00	0.00	129.72	100.00	
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	30-07-2024	10:48:00	30-07-2024	17:02:00	0.26	0.00	0.00	0.00	6.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3727(403 - 403 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	31-07-2024	09:38:00	31-07-2024	16:55:00	0.30	0.00	0.00	0.00	7.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3865(401 - 404Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	19-07-2024	10:37:00	19-07-2024	16:17:00	0.24	0.00	0.00	0.00	5.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3370 (400-401Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	23-07-2024	08:35:00	23-07-2024	16:11:00	0.32	0.00	0.00	0.00	7.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2774(407 - 407Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	24-07-2024	11:18:00	24-07-2024	17:32:00	0.26	0.00	0.00	0.00	6.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2921(408 - 410Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	25-07-2024	09:14:00	25-07-2024	18:24:00	0.38	0.00	0.00	0.00	9.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3032 (405 - 409 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	22-07-2024	11:28:00	22-07-2024	17:23:00	0.25	0.00	0.00	0.00	5.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/160(401-402Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	18-07-2024	12:09:00	18-07-2024	16:54:00	0.20	0.00	0.00	0.00	4.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2214 (395 - 397 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	16-07-2024	10:13:00	16-07-2024	16:24:00	0.26	0.00	0.00	0.00	6.18		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/1929(401 - 402Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	12-07-2024	09:33:00	12-07-2024	16:20:00	0.28	0.00	0.00	0.00	6.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/1502 (402-403Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	04-07-2024	08:02:00	04-07-2024	21:06:00	0.54	0.00	0.00	0.00	13.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/446 (410-410Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	05-07-2024	08:59:00	05-07-2024	16:09:00	0.30	0.00	0.00	0.00	7.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/593 (404 - 407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	11-07-2024	09:43:00	11-07-2024	17:10:00	0.31	0.00	0.00	0.00	7.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/1366 (402 - 405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	21-07-2024	09:57:00	21-07-2024	15:38:00	0.24	0.00	0.00	0.00	5.68		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2560(401 - 401 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	03-07-2024	09:16:00	03-07-2024	16:04:00	0.28	0.00	0.00	0.00	6.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2332 (406 - 408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	27-07-2024	10:55:00	27-07-2024	17:11:00	0.26	0.00	0.00	0.00	6.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3371 (402-402Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	29-07-2024	10:01:00	29-07-2024	17:41:00	0.32	0.00	0.00	0.00	7.67		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3576 (402 - 405 Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	26-07-2024	08:36:00	26-07-2024	15:51:00	0.30	0.00	0.00	0.00	7.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3180 (407 - 407Kv).
BSR	125MVAR, BUS REACTOR-2 AT PAVAGADA	SVRD	02-07-2024	09:19:00	02-07-2024	18:14:00	0.37	0.00	0.00	0.00	8.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/161(403-405 Kv).
							5.67	0.00	0.00	0.00	136.09	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SALEM	SVRD	25-07-2024	11:59:00	31-07-2024	23:59:59	6.50	0.00	0.00	0.00	156.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3073 (392 - 392 Kv).
							6.50	0.00	0.00	0.00	156.02	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	24-07-2024	09:29:00	24-07-2024	18:52:00	0.39	0.00	0.00	0.00	9.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2904(396 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	25-07-2024	09:01:00	25-07-2024	18:04:00	0.38	0.00	0.00	0.00	9.05		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3033 (397 - 397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	08-07-2024	08:33:00	08-07-2024	18:04:00	0.40	0.00	0.00	0.00	9.52		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/950(401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	23-07-2024	08:58:00	23-07-2024	20:53:00	0.50	0.00	0.00	0.00	11.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2782(401 - 406Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	18-07-2024	08:42:00	18-07-2024	17:00:00	0.35	0.00	0.00	0.00	8.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2164 (402 - 404Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	20-07-2024	09:57:00	20-07-2024	18:42:00	0.37	0.00	0.00	0.00	8.75		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2467 (400-401Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	17-07-2024	09:24:00	17-07-2024	16:45:00	0.31	0.00	0.00	0.00	7.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2064 (396 - 398Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	11-07-2024	08:06:00	11-07-2024	17:14:00	0.38	0.00	0.00	0.00	9.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/1338 (406 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	22-07-2024	10:00:00	22-07-2024	17:29:00	0.31	0.00	0.00	0.00	7.48		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2658 (395 - 398 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	05-07-2024	06:49:00	05-07-2024	18:25:00	0.48	0.00	0.00	0.00	11.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/577 (402 - 402 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	16-07-2024	10:19:00	16-07-2024	18:57:00	0.36	0.00	0.00	0.00	8.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/1931(398 - 400Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	04-07-2024	07:57:00	04-07-2024	23:15:00	0.64	0.00	0.00	0.00	15.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/445 (403-405Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	01-07-2024	09:09:00	01-07-2024	20:48:00	0.49	0.00	0.00	0.00	11.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/41(394-397 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	03-07-2024	08:31:00	03-07-2024	18:47:00	0.43	0.00	0.00	0.00	10.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/314 (402 - 404Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	09-07-2024	08:42:00	10-07-2024	16:50:00	1.34	0.00	0.00	0.00	32.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/1087 (399-399 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	27-07-2024	08:39:00	27-07-2024	17:28:00	0.37	0.00	0.00	0.00	8.82		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3337 (402-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	26-07-2024	08:33:00	26-07-2024	15:50:00	0.30	0.00	0.00	0.00	7.28		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3181 (398 - 399Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	29-07-2024	08:12:00	29-07-2024	17:37:00	0.39	0.00	0.00	0.00	9.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3548 (403 - 403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	31-07-2024	08:55:00	31-07-2024	17:03:00	0.34	0.00	0.00	0.00	8.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3850(396 - 396Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	30-07-2024	09:10:00	30-07-2024	17:10:00	0.33	0.00	0.00	0.00	8.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/3695(394 - 396 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	12-07-2024	08:02:00	12-07-2024	18:25:00	0.43	0.00	0.00	0.00	10.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/1483 (399 - 401 Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	19-07-2024	08:07:00	19-07-2024	16:43:00	0.36	0.00	0.00	0.00	8.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2323 (406-407Kv).
BSR	63MVAR, BUS REACTOR-1 AT SOMANHALLI	SVRD	21-07-2024	10:10:00	21-07-2024	18:02:00	0.33	0.00	0.00	0.00	7.87		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR-07/2562(396 - 398 Kv).
							9.98	0.00	0.00	0.00	238.96	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SRIPERUMBUDUR	SVRD	30-07-2024	11:13:00	31-07-2024</								

Standard of Performance data for the month of July-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT TRIVANDRUM	SVRD	25-07-2024	12:02:00	31-07-2024	23:59:59	6.50	0.00	0.00	0.00	155.97		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3074 (390 - 398 Kv).
BSR	125MVAR, BUS REACTOR-1 AT TRIVANDRUM	SVRD	01-07-2024	00:00:01	18-07-2024	23:38:00	17.99	0.00	0.00	0.00	431.63		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 06/2552(388 - 396Kv).
							24.49	0.00	0.00	0.00	587.60	100.00	
BSR	125MVAR, BUS REACTOR-1 AT TUTICORIN GIS	SVRD	08-07-2024	10:40:00	11-07-2024	20:23:00	3.41	0.00	0.00	0.00	81.72		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/974(398 - 398Kv).
BSR	125MVAR, BUS REACTOR-1 AT TUTICORIN GIS	SVRD	15-07-2024	12:12:00	31-07-2024	23:59:59	16.49	0.00	0.00	0.00	395.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1831(398 - 398Kv).
							19.90	0.00	0.00	0.00	477.52	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUTICORIN GIS	SVRD	16-07-2024	10:55:00	31-07-2024	23:59:59	15.55	0.00	0.00	0.00	373.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1944(395 - 398Kv).
							15.55	0.00	0.00	0.00	373.08	100.00	
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	26-07-2024	12:40:00	26-07-2024	15:55:00	0.14	0.00	0.00	0.00	3.25		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3235 (404 - 406Kv).
BSR	63MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	23-07-2024	08:38:00	30-07-2024	16:02:00	0.31	0.00	0.00	0.00	7.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2775(406 - 408Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	12-07-2024	09:35:00	12-07-2024	16:22:00	0.28	0.00	0.00	0.00	6.78		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1503 (402-404Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	10-07-2024	09:27:00	10-07-2024	16:57:00	0.31	0.00	0.00	0.00	7.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1240(405-408 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	25-07-2024	09:42:00	25-07-2024	18:04:00	0.35	0.00	0.00	0.00	8.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3051 (406 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	11-07-2024	09:48:00	11-07-2024	15:36:00	0.24	0.00	0.00	0.00	5.80		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1367 (404 - 406 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	02-07-2024	09:18:00	02-07-2024	18:17:00	0.37	0.00	0.00	0.00	8.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/162(403-403 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	03-07-2024	09:12:00	03-07-2024	16:09:00	0.29	0.00	0.00	0.00	6.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/333 (407 - 409 Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	31-07-2024	10:33:00	31-07-2024	17:00:00	0.27	0.00	0.00	0.00	6.45		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3875(401 - 401Kv).
BSR	63MVAR, BUS REACTOR-1 AT TUMKUR	SVRD	24-07-2024	11:21:00	24-07-2024	17:35:00	0.26	0.00	0.00	0.00	6.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2922(409 - 410Kv).
							2.82	0.00	0.00	0.00	67.71	100.00	
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	31-07-2024	10:34:00	31-07-2024	17:04:00	0.27	0.00	0.00	0.00	6.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3877(401 - 405Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	30-07-2024	10:56:00	30-07-2024	17:10:00	0.26	0.00	0.00	0.00	6.23		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2775(406 - 408Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	26-07-2024	12:42:00	26-07-2024	16:00:00	0.14	0.00	0.00	0.00	3.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3236 (406 - 408Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	12-07-2024	09:39:00	12-07-2024	16:43:00	0.29	0.00	0.00	0.00	7.07		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1504 (404-404Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	25-07-2024	09:44:00	25-07-2024	18:10:00	0.35	0.00	0.00	0.00	8.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3052 (406 - 408 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	16-07-2024	10:22:00	16-07-2024	16:47:00	0.27	0.00	0.00	0.00	6.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1934(406 - 408Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	23-07-2024	08:39:00	23-07-2024	15:58:00	0.31	0.00	0.00	0.00	7.32		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2776(408 - 410Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	11-07-2024	11:55:00	11-07-2024	15:34:00	0.15	0.00	0.00	0.00	3.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1378 (407-409Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	02-07-2024	09:19:00	02-07-2024	18:15:00	0.37	0.00	0.00	0.00	8.93		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/163(403-407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	03-07-2024	09:12:00	03-07-2024	16:13:00	0.29	0.00	0.00	0.00	7.02		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/334 (405 - 407 Kv).
BSR	125MVAR, BUS REACTOR-2 AT TUMKUR	SVRD	24-07-2024	11:22:00	24-07-2024	17:32:00	0.26	0.00	0.00	0.00	6.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2923(410- 412Kv).
							2.96	0.00	0.00	0.00	71.04	100.00	
BSR	63MVAR, BUS REACTOR AT TUTICORIN PS	SVRD	26-07-2024	09:36:00	31-07-2024	23:59:59	5.60	0.00	0.00	0.00	134.40		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3203 (396 - 397Kv).
							5.60	0.00	0.00	0.00	134.40	100.00	
BSR	PUGALUR-1 LINE REACTOR 63MVAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	03-07-2024	14:05:00	29-07-2024	20:27:00	26.27	0.00	0.00	0.00	630.37		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/361 (756 - 770 Kv).
BSR	240MVAR, BUS REACTOR-1 AT THIRUVALAM	SVRD	31-07-2024	09:38:00	31-07-2024	20:24:00	0.45	0.00	0.00	0.00	10.77		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3863(750 - 759Kv).
							26.72	0.00	0.00	0.00	641.14	100.00	
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	02-07-2024	15:06:00	30-07-2024	08:01:00	27.71	0.00	0.00	0.00	664.92		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/214 (765-773Kv).
BSR	240MVAR, BUS REACTOR-2 AT THIRUVALAM	SVRD	31-07-2024	10:24:00	31-07-2024	23:59:59	0.57	0.00	0.00	0.00	13.60		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3876(757 - 765Kv).
							28.28	0.00	0.00	0.00	678.52	100.00	
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	12-07-2024	08:04:00	12-07-2024	18:29:00	0.43	0.00	0.00	0.00	10.42		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1480 (403 - 404 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	16-07-2024	10:18:00	17-07-2024	23:57:00	1.57	0.00	0.00	0.00	37.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1933(397 - 398Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	24-07-2024	09:40:00	24-07-2024	17:34:00	0.33	0.00	0.00	0.00	7.90		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2906(396 - 396Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	05-07-2024	10:01:00	05-07-2024	20:31:00	0.44	0.00	0.00	0.00	10.50		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/607 (394 - 396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	31-07-2024	09:00:00	31-07-2024	16:57:00	0.33	0.00	0.00	0.00	7.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3854(396 - 398Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	30-07-2024	09:44:00	30-07-2024	17:07:00	0.31	0.00	0.00	0.00	7.38		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3698(395- 396Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	29-07-2024	08:13:00	29-07-2024	18:45:00	0.44	0.00	0.00	0.00	10.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3550 (403 - 404 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	27-07-2024	08:19:00	27-07-2024	17:19:00	0.38	0.00	0.00	0.00	9.00		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3340 (404-404Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	26-07-2024	08:33:00	26-07-2024	17:51:00	0.39	0.00	0.00	0.00	9.30		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3183 (400 - 400Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	10-07-2024	09:29:00	10-07-2024	16:55:00	0.31	0.00	0.00	0.00	7.43		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1237 (395-396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	18-07-2024	08:50:00	18-07-2024	16:59:00	0.34	0.00	0.00	0.00	8.15		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2167 (405 - 405Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	11-07-2024	08:01:00	11-07-2024	17:13:00	0.38	0.00	0.00	0.00	9.20		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1341 (406 - 406 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	23-07-2024	08:36:00	23-07-2024	20:46:00	0.51	0.00	0.00	0.00	12.17		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2778(399 - 399Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	22-07-2024	09:53:00	22-07-2024	17:28:00	0.32	0.00	0.00	0.00	7.58		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2648 (395 - 397 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	08-07-2024	08:38:00	08-07-2024	18:43:00	0.42	0.00	0.00	0.00	10.08		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/953(401 - 403Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	19-07-2024	08:16:00	20-07-2024	22:48:00	1.61	0.00	0.00	0.00	38.53		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2326 (409-409Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	25-07-2024	09:05:00	25-07-2024	21:21:00	0.51	0.00	0.00	0.00	12.27		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3035 (397 - 397 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	09-07-2024	08:39:00	09-07-2024	21:36:00	0.54	0.00	0.00	0.00	12.95		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1081(399-399 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	21-07-2024	09:54:00	21-07-2024	15:33:00	0.24	0.00	0.00	0.00	5.65		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2556(396 -397 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	02-07-2024	09:17:00	02-07-2024	18:16:00	0.37	0.00	0.00	0.00	8.98		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/158(394-396 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	14-07-2024	12:00:00	14-07-2024	17:21:00	0.22	0.00	0.00	0.00	5.35		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1724 (393 - 393 Kv).
BSR	63MVAR, BUS REACTOR-2 AT YELAHANKA	SVRD	01-07-2024	09:12:00	01-07-2024	20:44:00	0.48						

Standard of Performance data for the month of July-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	220kV KAYAMKULAM(KSEB)-PUNNAPRA(KSEB)-			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	230kV NEYVELI(NLC)-KARAIKAL(PED)-1	LPRD	24-07-2024	20:58:00	30-07-2024	08:56:00	5.50	0.00	0.00	0.00	131.97	100.00	* Line hand tripped at Neyveli end only as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 07/2999.
CKT	230kV NEYVELI(NLC)-VILLIANUR(PED)-1	LPRD	01-07-2024	00:00:01	31-07-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Line kept open as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 06/2082.Line kept idle cahrged from Villianur end.
CKT	220kV PUNNAPRA(KSEB)-POLLAM(KSEB)-1	OSPD	10-07-2024	08:05:00	10-07-2024	19:01:00	0.46	0.00	0.00	0.00	10.93	100.00	* Shut down availed by KSEB for relay testing and half yearly maintenance work at Punnapra SS vide SRLDC code no. CR-07/1223.
CKT	220kV TIRUNELVELI-EDAMON(KSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV TIRUNELVELI-EDAMON(KSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV ALMATY-TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV ALMATY-TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(NTECL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ALMTHY(TANTRANSCO)-VALLUR(NTECL)	OSPT	23-07-2024	09:50:00	23-07-2024	17:00:00	0.30	7.17	0.00	0.00	0.00	99.04	* Shut down availed TNEB for maintenance works vide SRLDC code no. CR-07/2787
CKT	400kV CHITTOOR(APTRANSCO)-SRIPERUMBUDU	LCS D	29-07-2024	10:16:00	31-07-2024	23:59:59	2.57	0.00	0.00	0.00	61.73	100.00	* Shut down availed for CVT replacement works under Add cap at Sriperumbudur SS vide SRLDC code no. CR-07/3569.
CKT	400kV GOOTY-SOMANAHALLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-MYSORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-MYSORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HASSAN-TALAGUPPA(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HOSUR-SALEM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV HOSUR-SALEM-2	LCS D	22-07-2024	10:11:00	24-07-2024	18:20:00	2.34	0.00	0.00	0.00	56.15	100.00	* Shut down availed for replacement of CVT at Salem SS under add cap works vide SRLDC code no. CR-07/2664.
CKT	400kV KAIGA(NPCIL)-NARENDRA-1	OSPD	19-07-2024	09:35:00	19-07-2024	15:21:00	0.24	0.00	0.00	0.00	5.77	100.00	* Emergency shutdown taken by NPCIL for attending isolator issue at Kaiga end.
CKT	400kV KAIGA(NPCIL)-NARENDRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	26-07-2024	10:40:00	26-07-2024	22:57:00	0.51	0.00	0.00	0.00	12.28	100.00	* Emergency shutdown availed by Guttur SS for attending arc observed in B phase Bus-1 isolator of 400kV Bus coupler at Guttur SS vide code CR-07/3212
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-1	OSPD	01-07-2024	07:18:00	06-07-2024	12:49:00	5.23	0.00	0.00	0.00	125.52	100.00	* Shut down availed by KPTCL for providing Double string arrangement to existing single suspension string for various road crossing locations vide SRLDC code no. CR-07/10.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OSPD	25-07-2024	09:54:00	25-07-2024	15:48:00	0.25	0.00	0.00	0.00	5.90	100.00	* Emergency shutdown availed by Kaiga for rectification of snapped vertical dropper of 400kV DS-15C at Kaiga end vide code CR-07/3044.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OMSU	24-07-2024	13:56:00	24-07-2024	15:08:00	0.05	0.00	1.20	0.00	0.00	100.00	* Line tripped on B -G fault. Kaiga end details: M1: FLR: 76 KM, FC: 3.095 Kamps, M2: FLR: 70.5 KM, FC: 3.012 Kamps. Guttur end details:M1: FLR: NR, FC: NR, M2: FLR: 116 KM, FC: 2.29 Kamps* Fault is in KPTCL Jurisdiction.
CKT	400kV KAIGA(NPCIL)-GUTTUR(KPTCL)-2	OSPD	06-07-2024	14:14:00	11-07-2024	15:20:00	5.05	0.00	0.00	0.00	121.10	100.00	* Shut down availed by KPTCLNHAI crossing works vide SRLDC code no. CR-07/768
CKT	400kV KARAIKUDI-MADURAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDAMKULAM(NPCIL)-TIRUNELVELI-3	OSPD	03-07-2024	07:32:00	04-07-2024	20:09:00	1.53	0.00	0.00	0.00	36.62	100.00	* Shut down availed by NPCIL for TL works vide SRLDC code no. CR-07/29
CKT	400kV-KOCHI-KOTTAYAM-1	OMSU	24-07-2024	09:46:00	24-07-2024	10:33:00	0.03	0.00	0.78	0.00	0.00	100.00	* Line tripped at Kochi end only on B-G, DEF protection operated.* Kochi: FC- 1.6 kA.
CKT	400kV-KOCHI-KOTTAYAM-2	OMSU	24-07-2024	09:46:00	24-07-2024	10:34:00	0.03	0.00	0.80	0.00	0.00	100.00	* Line tripped at Kochi end only on B-G, DEF protection operated.* Kochi: FC- 1.6 kA.
CKT	400kV KOLAR-HOODY(KPTCL)-1	OSPD	01-07-2024	00:00:01	12-07-2024	16:14:00	11.68	0.00	0.00	0.00	280.23	100.00	* Shutdown availed for dismantling and erection of new towers by NHAI for facilitation Bangalore-Chennai express highway works.
							11.68	0.00	0.00	0.00	280.23	100.00	

Standard of Performance data for the month of July-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV KOLAR-HOODY(KPTCL)-2	OSPD	01-07-2024	00:00:01	12-07-2024	16:17:00	11.68	0.00	0.00	0.00	280.28		* Shutdown availed for dismantling and erection of new towers by NHAI for facilitation Bangalore-Chennai express highway works.
							11.68	0.00	0.00	0.00	280.28	100.00	
CKT	400kV KOLAR-HOSUR-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-HOSUR-2			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-MYLASANDRA (KPTCL)			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLAR-THIRUVALAM-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDGI GIS-NARENDRA-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KUDGI GIS-NARENDRA-2	OSPT	26-07-2024	12:08:00	26-07-2024	13:58:00	0.08	1.83	0.00	0.00	0.00		* Emergency shutdown availed for attending hot spot in jumper at Loc.187 vide code CR-07/3220
							0.08	1.83	0.00	0.00	0.00	99.75	
CKT	400kV NP KUNTA-KOLAR			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-PUGALUR-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-PUGALUR-2			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TIRUNELVELI-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TIRUNELVELI-2			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TUTICORIN PS-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MADURAI-TUTICORIN PS-2	LPRD	24-07-2024	13:06:00	26-07-2024	17:46:00	2.19	0.00	0.00	0.00	52.67		* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 07/2940.
CKT	400kV MADURAI-TUTICORIN PS-2	LPRD	16-07-2024	11:21:00	18-07-2024	17:13:00	2.24	0.00	0.00	0.00	53.87		* Hand tripped as per SRLDC instruction for power regulation in the system vide SRLDC code no. CR- 07/1951(L1- 617/876, L2- 629/0 MW).
CKT	400kV MADURAI-TUTICORIN PS-2	LPRD	31-07-2024	15:11:00	31-07-2024	20:20:00	0.22	0.00	0.00	0.00	5.15		* Hand tripped as per SRLDC instruction for POWER regulation in the system vide SRLDC code no. CR- 07/3893
							4.65	0.00	0.00	0.00	111.69	100.00	
CKT	400kV UDUMALPET-MADURAI			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-HIRIYUR			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-KOZHIIKODE-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MYSORE-KOZHIIKODE-2			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELLI TS2-NEYVELLI TS1 EXP			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NEYVELI TS2(NLC)-KARUR-1	OSPD	23-07-2024	09:39:00	23-07-2024	19:25:00	0.41	0.00	0.00	0.00	9.77		* Shut down availed Neyveli TSII for maintenance works vide SRLDC code no. CR-07/2796
							0.41	0.00	0.00	0.00	9.77	100.00	
CKT	400kV NEYVELLI TS2 EXP(NLC) EXP-KARUR	OSPD	18-07-2024	12:43:00	19-07-2024	18:45:00	1.25	0.00	0.00	0.00	30.03		* Emergency shutdown availed by Neyveli TS-II for attending Oil Leakage in the "R" phase CVT.
							1.25	0.00	0.00	0.00	30.03	100.00	
CKT	400kV NEYVELI(NLC)-SALEM-2	LCSD	20-07-2024	20:35:00	20-07-2024	21:12:00	0.03	0.00	0.00	0.00	0.62		* Shutdown availed on 18.07.2024/09:54hrs for construction works(replacement of existing CVTs along with erection activities) vide SRLDC code no. CR- 07/2190.The said circuit normalised at 20:20hrs/20.07.2024.but hand tripped on emergency basis to check low voltage found in Core-2 of R-ph CVT.
CKT	400kV NEYVELI(NLC)-SALEM-2	LCSD	18-07-2024	09:54:00	20-07-2024	20:20:00	2.44	0.00	0.00	0.00	58.43		* Shutdown availed for construction works(replacement of existing CVTs along with erection activities)
							2.47	0.00	0.00	0.00	59.05	100.00	
CKT	400kV NAGAPATTINAM-NEYVELI TS1(NLC) EXP			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGAPATTINAM-NEYVELI TS2(NLC)			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-BIDADI-2			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-HASSAN-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NELAMANGALA(KPTCL)-MYSORE-2	LMAC	06-07-2024	13:05:00	06-07-2024	13:31:00	0.02	0.00	0.00	0.43	0.00		* Emergency shutdown taken for removal of kite thread hanging from line at Loc No.319 vide SRLDC code no. CR-07/761.
							0.02	0.00	0.00	0.43	0.00	100.00	
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of July-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV NNTPS(NLC)-ARIYALUR(TNEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NNTPS(NLC)-PUDUCHERRY-1	LNCC	20-07-2024	15:40:00	20-07-2024	16:34:00	0.04	0.00	0.00	0.90	0.00	100.00	* Line tripped on Y-G fault. Pondy end details: M1: FLR: 20 KM, FC: 4.26 Kamps, M2: FLR: 20.5 KM, FC: 4.22 Kamps. NNTPS end details:M1: FLR: 42.89 KM, FC:6.05 Kamps, M2: FLR: 43.6 KM, FC: 6.78 Kamps* Fault is in Pondy Jurisdiction.
CKT	400kV NARENDRA-GUTTUR(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.90	0.00	100.00	
CKT	400kV NARENDRA-GUTTUR(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-ARASUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-ARASUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-E.PALAYM(TANTRANSCO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR GIS-KARUR PS-1	OSPD	08-07-2024	14:29:00	08-07-2024	16:27:00	0.08	0.00	0.00	0.00	1.97	100.00	* Shut down availed by Karur PS for attending chattering sound problem in Wave Trap (Y-Phase) vide SRLDC code no. CR-07/991.
CKT	400kV PUGALUR GIS-KARUR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR-TIRUVALAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PALAKKAD-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PALAKKAD-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUDUCHERRY-SVCHATRAM(TANTRANSCO)	LART	11-07-2024	02:47:00	11-07-2024	02:47:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line auto reclosed successfully on B-G fault.* Puducherry end details: M1: FLR: 116.9 KM, FC: 2.27 Kamps, M2: FLR: 117.4 KM, FC: 2.12 Kamps.* SV Chatram end details: M1: FLR: 13.6 KM, FC: 13.325 Kamps, M2: FLR: 13.6 KM, FC: 13.325 Kamps* Fault is in Sripurumbadur TLM Jurisdiction.
CKT	400kV PUGALUR HVAC-KARUR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUGALUR HVAC-KARUR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-BELLARY(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV PAVAGADA-DEVANAHALLI(KPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 kV PAVAGADA-DEVANAHALLI(KPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PAVAGADA-HIRIYUR-1	OSPT	29-07-2024	09:12:00	29-07-2024	19:03:00	0.41	9.85	0.00	0.00	0.00	98.68	* Shut down availed for AMP works vide SRLDC code no. CR-07/3564.
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	06-07-2024	20:56:00	10-07-2024	08:08:00	3.47	0.00	0.00	0.00	83.20	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/811(420 - 420Kv).
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	14-07-2024	20:30:00	16-07-2024	11:01:00	1.61	0.00	0.00	0.00	38.52	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1782 (418 -416Kv).
CKT	400kV PAVAGADA-TUMKUR-1	LVRD	01-07-2024	00:00:01	01-07-2024	09:21:00	0.39	0.00	0.00	0.00	9.35	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 06/3314(421 - 420Kv).
CKT	400kV PAVAGADA-TUMKUR-2	LVRD	03-07-2024	18:21:00	04-07-2024	08:27:00	0.59	0.00	0.00	0.00	14.10	100.00	* Line kept open as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/408
CKT	400kV PAVAGADA-TUMKUR-2	OSPD	04-07-2024	08:27:00	04-07-2024	14:04:00	0.23	0.00	0.00	0.00	5.62	100.00	* Shutdown availed by KPTCL for fixing of open spacers, repair of damaged conductor and re-fixing of corona ring
CKT	400kV PAVAGADA-TUMKUR-2	LVRD	22-07-2024	21:23:00	23-07-2024	11:02:00	0.57	0.00	0.00	0.00	13.65	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2747 (416-415Kv).
CKT	400kV PAVAGADA-TUMKUR-2	LVRD	01-07-2024	00:00:01	02-07-2024	08:43:00	1.36	0.00	0.00	0.00	32.72	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 06/3519 (421 - 419 Kv).
CKT	400kV PAVAGADA-TUMKUR-2	OSPD	03-07-2024	08:25:00	03-07-2024	18:21:00	0.41	0.00	0.00	0.00	9.93	100.00	* Shut down availed by KPTCL for TL works vide SRLDC code no. CR-07/325
CKT	400kV PAVAGADA-TUMKUR-3	LVRD	14-07-2024	20:29:00	16-07-2024	11:08:00	1.61	0.00	0.00	0.00	38.65	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1783 (418-418Kv)
CKT	400kV PAVAGADA-TUMKUR-4	LVRD	22-07-2024	21:26:00	23-07-2024	09:36:00	0.51	0.00	0.00	0.00	12.17	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/2748 (415-414Kv).
CKT	400kV PAVAGADA-MYSORE	LVRD	13-07-2024	02:14:00	16-07-2024	11:27:00	3.38	0.00	0.00	0.00	81.22	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1617 (427-425 Kv).
CKT	400kV PAVAGADA-MYSORE	LVRD	07-07-2024	20:20:00	08-07-2024	10:45:00	0.60	0.00	0.00	0.00	14.42	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/906(422-419 Kv).
CKT	400kV PAVAGADA-MYSORE	OSFT	16-07-2024	11:27:00	16-07-2024	19:34:00	0.34	8.12	0.00	0.00	0.00	100.00	* Line kept out for insulator replacement works.
CKT	400kV PAVAGADA-MYSORE	LVRD	09-07-2024	00:23:00	10-07-2024	08:23:00	1.33	0.00	0.00	0.00	32.00	100.00	* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/1052 (420 - 417 Kv).
							5.65	8.12	0.00	0.00	127.64	98.91	

Standard of Performance data for the month of July-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV SALEM-DHARMAPURI-1	LART	17-07-2024	18:33:00	17-07-2024	18:33:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line Autoreclose successful on R phase to Ground fault. Salem end details: M1: FL: 5.2KM, FC: 17.11KA, M2: FL: 4.9KM, FC: 16.64, Dh= armapuri end details: M1: Not recorded, M2: FL: 51.22KM, FC: 4.69KA, Fault in Salem TLM jurisdiction.
CKT	400kV SALEM-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-NNTPS(NLC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SALEM-UDUMALPET-1	LCSD	25-07-2024	09:35:00	27-07-2024	19:34:00	2.42	0.00	0.00	0.00	0.00	57.98	* Shutdown availed for Construction works: Replacement of existing CVT's including pipe structures, Junction Box and Inter pole cabling under Add cap works.
CKT	400kV SALEM-UDUMALPET-2			00:00:00		00:00:00	2.42	0.00	0.00	0.00	0.00	57.98	
CKT	400kV-SOMANHALLI-BIDADI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANAHALLI-BIDADI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANAHALLI-DHARMAPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANAHALLI-DHARMAPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOMANAHALLI-HOSUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV-SOMANHALLI-MYLASANDRA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SVCHATRM(TANTRANSCO)-SRIPERMBUD	LCSD	20-07-2024	09:13:00	22-07-2024	20:26:00	2.47	0.00	0.00	0.00	0.00	59.22	* Shutdown availed for CVT Replacement work under addcap.
CKT	400kV TRICHUR HVDC-KOCHI-1			00:00:00		00:00:00	2.47	0.00	0.00	0.00	0.00	59.22	
CKT	400kV TRICHUR HVDC-KOCHI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-TRICHUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHUR HVDC-TRICHUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV THIRUNELVELI-KOTTAYAM-1	OMSU	24-07-2024	09:46:00	24-07-2024	10:43:00	0.04	0.00	0.95	0.00	0.00	100.00	* Line tripped on B-G fault at Tirunelveli end only.* Tirunelveli end details: M1: Z2, FLR: NR, FC: 1.6 Kamps, M2: Z-3 FLR: NR, FC: 1.6 Kkamps
CKT	400kV THIRUNELVELI-KOTTAYAM-2	OMSU	24-07-2024	09:46:00	24-07-2024	11:46:00	0.08	0.00	2.00	0.00	0.00	98.08	* Line tripped on B-G fault at Tirunelveli end only.* Tirunelveli end details: M1: FLR: 86.5 KM, FC: 3.2 Kamps, M2: FLR: 85.2 KM, FC: 3.4 Kamps.* Fault is in Trivendram TLM Jurisdiction.* Line test charged successfully at 11:46 hrs on 24/04/2024 vide SRLDC code no. CR- 07/2933 and subsequently hand tripped at 12:22 hrs on 24/04/2024 vide SRLDC code no. CR- 07/2936.
CKT	400kV THIRUNELVELI-KOTTAYAM-2	LEFT	14-07-2024	23:14:00	15-07-2024	13:25:00	0.59	14.18	0.00	0.00	0.00	98.61	* Line tripped on B -G fault (Fault Angle: 84 Degree, Top Phase). TIRUNELVELLI end details: M1: FLR: 154.2 KM, FC: 2.68 Kamps, M2: FLR: 152.2 KM, FC: 3.3 Kamps. KOTTAYAM end details:M1: FLR: 28.2 KM, FC: 6.4 Kamps, M2: FLR: 26.8 KM, FC: 6.3 Kamps* Fault is in KOCHI Jurisdiction.
CKT	400kV THIRUNELVELI-KOTTAYAM-2	OMSU	24-07-2024	11:46:00	24-07-2024	15:14:00	0.14	0.00	3.47	0.00	0.00	98.76	* Line kept out by KSEB for relay testing works at Kottayam SS.
CKT	400kV TIRUNELVELI-TRIVANDRUM-1	OSPT	29-07-2024	09:19:00	29-07-2024	19:40:00	0.43	10.35	0.00	0.00	0.00	98.61	* Shut down availed for AMP works and insulator replacement works vide SRLDC code no. CR-07/3565.
CKT	400kV TIRUNELVELI-TRIVANDRUM-2	OSPT	30-07-2024	09:33:00	30-07-2024	18:47:00	0.39	9.23	0.00	0.00	0.00	98.76	* Shutdown availed for AMP works vide SRLDC code CR/3706
CKT	400kV TIRUNELVELI-TUTICORIN PS			00:00:00		00:00:00	0.39	9.23	0.00	0.00	0.00	98.76	
CKT	400kV TIRUNELVELI-UDUMALPET-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUNELVELI-UDUMALPET-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-KARAIKUDI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-MADURAI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-NAGAPATTANAM-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TRICHY-NAGAPATTANAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALEM-CHITTOOR(APTRANSCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of July-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV TIRUVALAM-KALVINDAPATTU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-KALVINDAPATTU-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TIRUVALAM-SRIPERUMDUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN GIS -TUTICORIN PS- 4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-KUDAMKULAM(NPCL)-2	OSPD	10-07-2024	07:15:00	11-07-2024	20:13:00	1.54	0.00	0.00	0.00	36.97		* Shut down availed by Kudankulam for maintenance works vide SRLDC code no. CR-07/1209.
CKT	400kV TUTICORIN PS-TUTICORIN JV(NTPL)-1			00:00:00		00:00:00	1.54	0.00	0.00	0.00	36.97	100.00	
CKT	400kV TUTICORIN PS-TUTICORIN JV(NTPL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDMALPET-ARASUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDMALPET-ARASUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET-E.PALAYM(TANTRANSCO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET-E.PALAYM(TANTRANSCO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET -PALLAKAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV UDUMAPALET -PALLAKAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VALLUR(NTECL)-KALIVANTHAPATTU-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VALLUR(NTECL)-KALIVANTHAPATTU-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV YELHANKA GIS-DEVANAHALL(KPTCL)	OSPT	14-07-2024	11:44:00	14-07-2024	15:45:00	0.17	4.02	0.00	0.00	0.00		* Shutdown availed for replacement of suspected/defective insulator in multi circuit tower inside the Presidency university vide code CR-07/1721.
							0.17	4.02	0.00	0.00	0.00	99.46	
CKT	400kV YELHANKA-NELAMANGALA(KPTCL)-1	OSPT	14-07-2024	08:07:00	14-07-2024	11:22:00	0.14	3.25	0.00	0.00	0.00		* Shutdown availed for replacement of suspected/defective insulator in multi circuit tower inside the Presidency university vide code CR-07/1703.
CKT	400kV YELHANKA-NELAMANGALA(KPTCL)-1	OSPD	12-07-2024	10:00:00	12-07-2024	18:51:00	0.37	0.00	0.00	0.00	8.85		* Shutdown availed by KPTCL for annual relay testing and maintenance works.
							0.51	3.25	0.00	0.00	8.85	99.56	
CKT	400kV YELAHANKA GIS-TUMKUR-1	OSPT	14-07-2024	08:04:00	14-07-2024	15:57:00	0.33	7.88	0.00	0.00	0.00		* Shutdown availed for replacement of suspected/defective insulator in multi circuit tower inside the Presidency university vide code CR-07/1702.
							0.33	7.88	0.00	0.00	0.00	98.94	
CKT	400kV YELAHANKA GIS-TUMKUR-2	OSPT	14-07-2024	11:41:00	14-07-2024	16:06:00	0.18	4.42	0.00	0.00	0.00		* Shutdown availed for replacement of suspected/defective insulator in multi circuit tower inside the Presidency university vide code CR-07/1720.
							0.18	4.42	0.00	0.00	0.00	99.41	
CKT	400kV DHARAMPURI-TUMKUR-1	LEFT	24-07-2024	20:11:00	25-07-2024	03:40:00	0.31	7.48	0.00	0.00	0.00		* Line tripped on B -G fault. Tumkur end details: M1: FLR: 0.1 KM, FC: 25.26 Kamps, M2: FLR: 0.14 KM, FC: 27.24 Kamps. Dharmapuri end details: M1: FLR: 256.7 KM, FC: 1.24 Kamps, M2: FLR: 255 KM, FC: 2.107 Kamps. B-ph Pilot Insulator flashover observed at Tumkur SS switchyard entry deadend tower.
							0.31	7.48	0.00	0.00	0.00	98.99	
CKT	400kV KUDGI-KOLHAPUR GIS-1	OSPT	19-07-2024	05:59:00	19-07-2024	10:00:00	0.17	4.02	0.00	0.00	0.00		* Emergency Shut down availed for attending hot spot at Loc 454 vide SRLDC code no. CR-07/1347.
							0.17	4.02	0.00	0.00	0.00	99.46	
CKT	400kV KUDGI-KOLHAPUR GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-DHARAMPURI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV TUTICORIN PS-DHARAMPURI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF VALLUR-1 AT KALIVANTPATI	SVRD	30-07-2024	10:52:00	31-07-2024	23:59:59	1.55	0.00	0.00	0.00	37.13		* Hand tripped as per SRLDC instruction for voltage regulation in the system vide SRLDC code no. CR- 07/3725(392 -393 Kv).
							1.55	0.00	0.00	0.00	37.13	100.00	
LNR	63MVAR,SWLR OF TIRUNALVELLI-1 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF TIRUNALVELLI-2 AT KOCHI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of July-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., SOUTHERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-1 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT TRIVENDRAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	TuticorinGIS ICT3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-5 AT TUTICORIN GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT TUMKUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT TIRUVALAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT UDUMALPET			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT YELHANKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT YELHANKA	OSPT	28-07-2024	08:59:00	28-07-2024	18:16:00	0.39	9.28	0.00	0.00	0.00		* ICT Shut down availed for AMP vide SRLDC code no. CR-07/3448
							0.39	9.28	0.00	0.00	0.00	98.75	
							641.88	136.60	55.23	3.11	15,205.58	30,481.62	