

**Standard of Performance data for the month of OCTOBER - 2020**  
**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD.**  
**WESTERN REGION - I**

SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVar/MW/e tc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRDLC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
1	WR1_L_001	400kV KORBA-KORBA(WEST)	14	WRTS-I												
		<b>400kV KORBA-KORBA(WEST) Total</b>														<b>100.00%</b>
2	WR1_L_002	400kV KORBA-BHILAI I	197	WRTS-I												
		<b>400kV KORBA-BHILAI I Total</b>														<b>100.00%</b>
3	WR1_L_003	400kV KORBA-BHILAI II	192	WRTS-I												
		<b>400kV KORBA-BHILAI II Total</b>														<b>100.00%</b>
4	WR1_L_004	400kV BHILAI-KORADI	272	WRTS-I		28/10/20	11:20	28/10/20	18:57		7.616667	0	0	0	For AMP works.	
		<b>400kV BHILAI-KORADI Total</b>									7.616667					<b>98.98%</b>
5	WR1_L_005	400kV KORADI-SATPURA	149	WRTS-I												
		<b>400kV KORADI-SATPURA Total</b>														<b>100.00%</b>
6	WR1_L_006	400kV RAIPUR-BHILAI I	13	WRTS-I												
		<b>400kV RAIPUR-BHILAI I Total</b>														<b>100.00%</b>
7	WR1_L_007	400kV BHILAI-BHADRAVATI I	322	WRTS-I		28/10/20	00:12	28/10/20	00:12		0	0	0	0	Line A/R successfully at both end on Y phase to ground fault as per details: @Bhadravati - FC-16.97 KA, FD-13.15 Kms @Bhilai - FC-1.334 KA, FD-322 Kms Bhadravati TLM (Conductor Position: TOP)	
		<b>400kV BHILAI-BHADRAVATI I Total</b>									0					<b>100.00%</b>
8	WR1_L_008	400kV RAIPUR-BHADRAVATI I	333	WRTS-I		4-Oct-20	10:47	4-Oct-20	10:47		0	0	0	0	Line A/R Successfully from both ends on R-E/F. Raipur end :- Fd 150.9 km, FC 2.093 kAmp, Bhadravati end - Fd 195.12 km, Fc 1.46 kAmp	
						12-Oct-20	10:56	12-Oct-20	10:56		0	0	0	0	Line A/R successfully at both end on R phase-G Fault @Bhadravati : FC-2.2 KA, FD-187.58 Kms @Raipur : FC-1.97 KA, FD-144.4 Kms. Fault is in Brahmapuri TLM jurisdiction. Phase Position -Bottom	
						12-Oct-20	10:56	12-Oct-20	10:56		0	0	0	0	Line A/R successfully at both end on R phase-G Fault @Bhadravati : FC-2.2 KA, FD-187.58 Kms @Raipur : FC-1.97 KA, FD-144.4 Kms. Fault is in Brahmapuri TLM jurisdiction. Phase Position -Bottom	
		<b>400kV RAIPUR-BHADRAVATI I Total</b>									0					<b>100.00%</b>
9	WR1_L_009	400kV RAIPUR-BHADRAVATI II	345.55	WRTS-I		4-Oct-20	10:57	4-Oct-20	18:17		0	0	7.3333333	0	Line tripped on R-B fault. Fault details from Raipur: R-B, 160.47km and kA and from Bhadravati : R-B, 191.7km, FC-Ir 2.789kAmp, Ib 3.603kAmp. Farmers has burnt farm residual below the line leading to tripping of line.	
						6-Oct-20	09:10	6-Oct-20	10:38		0	0	1.4666667	0	Line tripped on R - B phase to phase fault, FC-4.113kA ,FD-158.409km from Raipur end and FC-3.610kA ,FD-189.224km from Bhadravati end. Farmers has burnt farm residual below the line leading to tripping of line.	
						9-Oct-20	13:04	9-Oct-20	19:30		6.4333333	0	0	0	Emergency outage availed to attend tree cutting work at Location No.417-418. (Availed by Bramhapuri TLM)	
						6-Oct-20	09:10	6-Oct-20	10:38		6.4333333	0	1.4666667	0	Line tripped on R - B phase to phase fault, FC-4.113kA ,FD-158.409km from Raipur end and FC-3.610kA ,FD-189.224km from Bhadravati end. Farmers has burnt farm residual below the line leading to tripping of line.	

SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVar/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRLDC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
						9-Oct-20	13:04	9-Oct-20	19:30		6.4333333	0	0	0	Emergency outage availed to attend tree cutting work at Location No.417-418. (Availed by Bramhapuri TLM)	
		<b>400kV RAIPUR-BHADRAVATI II Total</b>									12.866667					98.27%
10	WR1_L_010	400kV RAIPUR-BHADRAVATI III	345.55	WRTS-I		10-Oct-20	15:49	10-Oct-20	15:49		0	0	0	0	Line A/R successful at both end on Y-G fault, Fault details: @Bhadravati end Relay: M1-0.992 kA, 226.1 km. @Bhadravati end (AFAS): 1.972 kA, 243.53 km. @Raipur end (AFAS) - : M1-1.725 kA , FD- 171.02 km. AFAS (Double End): @Bhadrawati: 175.714km and 1.972kA & @Raipur: 169.286km and 1.729kA. Conductor position: Bottom. Fault is under Brahmapuri TLM jurisdiction.	
						11-Oct-20	10:44	11-Oct-20	19:23		8.65	0	0	0	Emergency outage of 400 kV Raipur-Bhadrawati-3 and ckt-2 AR off for emergency tree cutting works.	
						11-Oct-20	10:44	11-Oct-20	19:23		8.65	0	0	0	Emergency outage of 400 kV Raipur-Bhadrawati-3 and ckt-2 AR off for emergency tree cutting works.	
		<b>400kV RAIPUR-BHADRAVATI III Total</b>									8.65					98.84%
11	WR1_L_011	400kV BHADRAVATI-CHANDRAPUR I	20	WRTS-I												
		<b>400kV BHADRAVATI-CHANDRAPUR I Total</b>														100.00%
12	WR1_L_012	400kV BHADRAVATI-CHANDRAPUR II	20	WRTS-I												
		<b>400kV BHADRAVATI-CHANDRAPUR II Total</b>														100.00%
13	WR1_L_013	400kV BHADRAVATI-CHANDRAPUR III	22.42	WRTS-I		12-Oct-20	03:15	17-Oct-20	13:51		0	0	0	130.6	'Line H/T as per WRLDC instructions for Voltage Regulation	
						27/10/20	14:51	27/10/20	22:33		7.7	0	0	0	Emergency outage availed by BVT TLM for uprooting of vegetation in ROW of Line by JCB	
						27/10/20	14:51	27/10/20	22:33		7.7	0	0	0	Emergency outage availed by BVT TLM for uprooting of vegetation in ROW of Line by JCB	
		<b>400kV BHADRAVATI-CHANDRAPUR III Total</b>									7.7					98.97%
14	WR1_L_014	400kV BHADRAVATI-CHANDRAPUR IV	22.42	WRTS-I		9-Oct-20	11:51	9-Oct-20	16:55		5.066667	0	0	0	Line tripped on B-E fault, M1: FD-12.2km, FC-12.498kA & M2: FD-12.05km, FC-12.446kA from Bhadravati end.	
						10-Oct-20	09:59	10-Oct-20	18:30		8.516667	0	0	0	Line tripped on B-E fault, M1: FD-11.325km, FC-12.889kA & M2: FD-11.350km, FC-12.835kA from Bhadravati end. Fault is in Bhadravati-TLM Jurisdiction.	
						27/10/20	14:50	27/10/20	22:47		7.95	0	0	0	Emergency outage availed by BVT TLM for uprooting of vegetation in ROW of Line by JCB	
						10-Oct-20	09:59	10-Oct-20	18:30		21.53333	0	0	0	Line tripped on B-E fault, M1: FD-11.325km, FC-12.889kA & M2: FD-11.350km, FC-12.835kA from Bhadravati end. Fault is in Bhadravati-TLM Jurisdiction.	
						27/10/20	14:50	27/10/20	22:47		7.95	0	0	0	Emergency outage availed by BVT TLM for uprooting of vegetation in ROW of Line by JCB	
		<b>400kV BHADRAVATI-CHANDRAPUR IV Total</b>									29.483333					96.04%
15	WR1_L_015	400kV MAHAN-VINDHYACHAL	19	WRTS-I		3-Oct-20	23:40	4-Oct-20	00:24		0	0.7333333	0	0	line tripped only at Vindhyachal end due to unsuccessful Auto Reclosure on Y-G fault. However line Auto Reclosure successful and remains in service from Mahan end. Fault details from Vindhyachal: Y-G, 18.89km and 13.46kA and from Mahan: Y-G, 22.26km and 7.70kA. Line synchronized from Vindhyachal end at 00:24 Hrs. Fault is in WR-2 jurisdiction.	
		<b>400kV MAHAN-VINDHYACHAL Total</b>									0					100.00%

SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVar/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRDC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
16	WR1_L_016	400kV KORBA-MAHAN	196	WRTS-I		18-Oct-20	09:02	18-Oct-20	19:31		10.48333	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						20-Oct-20	07:42	20-Oct-20	20:07		12.41667	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						21-Oct-20	09:58	21-Oct-20	20:25		10.45	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						22/10/20	09:01	22/10/20	19:47		10.76667	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						23/10/20	08:29	23/10/20	19:21		10.86667	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						26/10/20	08:54	26/10/20	19:16		10.36667	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						27/10/20	07:45	27/10/20	19:27		11.7	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						28/10/20	08:18	28/10/20	19:17		10.98333	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						29/10/20	08:01	29/10/20	18:40		10.65	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						31/10/20	08:12	31/10/20	19:39		11.45	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						20-Oct-20	07:42	20-Oct-20	20:07		110.1333	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						21-Oct-20	09:58	21-Oct-20	20:25		10.45	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						22/10/20	09:01	22/10/20	19:47		10.76667	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						23/10/20	08:29	23/10/20	19:21		10.86667	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						26/10/20	08:54	26/10/20	19:16		10.36667	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						27/10/20	07:45	27/10/20	19:27		11.7	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						28/10/20	08:18	28/10/20	19:17		10.98333	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						29/10/20	08:01	29/10/20	18:40		10.65	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	
						31/10/20	08:12	31/10/20	19:39		11.45	0	0	0	For Replacement Of Conventional Porcelain Insulator with Composite Long Rod Insulator. For safety and system security	

SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRDC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
		<b>400kV KORBA-MAHAN Total</b>									197.36667					73.47%
17	WR1_L_017	400kV VINDHYACHAL-KORBA II	288.994	WRTS-I		7-Oct-20	12:18	7-Oct-20	18:02		5.7333333	0	0	0	Emergency outage availed by WR-2 .	
						20-Oct-20	12:43	20-Oct-20	17:30		0	0	4.7833333	0	Line tripped on R-G fault due to crops burnt by farmers below the line. Fault Details at Vindhyachal: R-G,FD-113.6km, FC-3.15KA & FD-202km, FC-1.2kA from Korba (NTPC) end. Photographs attached	
						21/10/20	12:24	21/10/20	20:03		0	0	7.65	0	Line tripped on R-G fault due to crops burnt by farmers below the line. Fault Details: FD-286.6km, FC-1.61kA from Korba end & FD-0.6km, FC-26.6kA from Vindhyachal end. Photographs attached	
						30/10/20	10:22	30/10/20	10:56		0.5666667	0	0	0	Emergency outage availed by WR-2 to attend Oil leakage in Line Reactor Bushing at Vindhyachal (NTPC) end	
						20-Oct-20	12:43	20-Oct-20	17:30		6.3	0	4.7833333	0	Line tripped on R-G fault due to crops burnt by farmers below the line. Fault Details at Vindhyachal: R-G,FD-113.6km, FC-3.15KA & FD-202km, FC-1.2kA from Korba (NTPC) end. Photographs attached	
						21/10/20	12:24	21/10/20	20:03		0	0	7.65	0	Line tripped on R-G fault due to crops burnt by farmers below the line. Fault Details: FD-286.6km, FC-1.61kA from Korba end & FD-0.6km, FC-26.6kA from Vindhyachal end. Photographs attached	
						30/10/20	10:22	30/10/20	10:56		0.5666667	0	0	0	Emergency outage availed by WR-2 to attend Oil leakage in Line Reactor Bushing at Vindhyachal (NTPC) end	
		<b>400kV VINDHYACHAL-KORBA II Total</b>									6.8666667					99.08%
18	WR1_L_018	400kV SATPURA-SEONI	1.507	WRTS-I		21-Oct-20	06:50	21-Oct-20	06:50		0	0	0	0	Line A/R successfully at both end on R phase to G fault, details : FC-3.42, FD-135.7 Kms from Seoni end.	
		<b>400kV SATPURA-SEONI Total</b>									0					100.00%
19	WR1_L_019	400kV BHILAI-SEONI	1.498	WRTS-I												
		<b>400kV BHILAI-SEONI Total</b>														100.00%
20	WR1_L_020	400kV BHILAI-BHATAPARA	90.453	WRTS-I		19-Oct-20	10:30	19-Oct-20	20:54		10.4	0	0	0	for AMP WORKS	
		<b>400kV BHILAI-BHATAPARA Total</b>									10.4					98.60%
21	WR1_L_021	400kV BHATAPARA-KORBA	123.73	WRTS-I		12-Oct-20	09:56	12-Oct-20	22:00		12.066667	0	0	0	Line tripped on R phase to ground fault as details: @Bhatapara : FC-2.99 KA, FD-114.229 Kms @Korba : FD-18.97 KA , FC-12.62 KA ( Insulator Decapped at Loc. No. 41 Rph) Phase Position - Right	
		<b>400kV BHATAPARA-KORBA Total</b>									12.066667					98.38%
22	WR1_L_022	400kV KORBA-SIPAT	68.653	WRTS-I												
		<b>400kV KORBA-SIPAT Total</b>														100.00%
23	WR1_L_023	400kV RAIPUR-SIPAT I	149.12	WRTS-I		17-Oct-20	09:09	17-Oct-20	21:39		12.5	0	0	0	For Line AMP works & 400KV-SIPAT-RAIPUR-2 A/R to be keep in non auto mode for safety precautions.	
						28/10/20	09:38	28/10/20	19:18		9.6666667	0	0	0	For Line AMP works & 400KV-SIPAT-RAIPUR-2 A/R to be keep in non auto mode for safety precautions.	
						28/10/20	09:38	28/10/20	19:18		22.166667	0	0	0	For Line AMP works & 400KV-SIPAT-RAIPUR-2 A/R to be keep in non auto mode for safety precautions.	
		<b>400kV RAIPUR-SIPAT I Total</b>									22.166667					97.02%



SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVar/MW/e tc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRDC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
39	WR1_L_039	400kV KORBA-RAIPUR III	212.83	WRTS-I		6-Oct-20	15:04	6-Oct-20	15:04		0	0	0	0	Line Auto Reclosure successful on R-G fault. Fault details from Raipur: FD: 203.1km and FC: 2.26kA and from Korba(NTPC): FD: 13.65km and FC: 5.68kA. Conductor position: Top. Fault is in Korba (TLM) jurisdiction.	
						15-Oct-20	10:13	15-Oct-20	21:14		11.016667	0	0	0	Emergency outage availed for replacement of flashover insulator string at Location No.42. (Availed by Korba TLM)	
						15-Oct-20	10:13	15-Oct-20	21:14		11.016667	0	0	0	Emergency outage availed for replacement of flashover insulator string at Location No.42. (Availed by Korba TLM)	
		<b>400kV KORBA-RAIPUR III Total</b>									11.016667					98.52%
40	WR1_L_040	400kV KORBA-RAIPUR IV	212.83	WRTS-I												
		<b>400kV KORBA-RAIPUR IV Total</b>														100.00%
41	WR1_L_041	400kV WARDHA-PARLI I	336.939	WRTS-I												
		<b>400kV WARDHA-PARLI I Total</b>														100.00%
42	WR1_L_042	400kV WARDHA-PARLI II	336.939	WRTS-I												
		<b>400kV WARDHA-PARLI II Total</b>														100.00%
43	WR1_L_043	400kV WARDHA-MAUDA II	123.45	WRTS-I												
		<b>400kV WARDHA-MAUDA II Total</b>														100.00%
44	WR1_L_044	400kV KORBA-VANDANA	14.768	WRTS-I												
		<b>400kV KORBA-VANDANA Total</b>														100.00%
45	WR1_L_045	400kV VANDANA-BIRSINGHPUR	211.874	WRTS-I												
		<b>400kV VANDANA-BIRSINGHPUR Total</b>														100.00%
46	WR1_L_046	400kV RAIPUR-WARDHA I	370.565	WRTS-I												
		<b>400kV RAIPUR-WARDHA I Total</b>														100.00%
47	WR1_L_047	400kV RAIPUR-WARDHA II	370.565	WRTS-I		7-Oct-20	14:12	8-Oct-20	05:00		0	0	14.8	0	Due to localized windstrom, Y phase Isolator connector got detached at Wardha SS. In view of heavy rains and lightning same could not be rectified during night hours . The works could be commenced only on date 08.10.2020 at 0500 hrs.	
						8-Oct-20	05:00	8-Oct-20	09:28		4.4666667	0	0	0	Due to localized windstrom, Y phase Isolator connector got detached at Wardha SS. In view of heavy rains and lightning same could not be rectified during night hours . The works could be commenced only on date 08.10.2020 at 0500 hrs.	
						19-Oct-20	19:27	19-Oct-20	23:25		15.966667	0	0	0	Line tripped due to LBB protection operated on 428 at Raipur & DT received at Wardha end.	
						26/10/20	12:32	26/10/20	20:19		7.7833333	0	0	0	Emergency outage availed to attend hot spot on Line Isolator at Raipur end	
						8-Oct-20	05:00	8-Oct-20	09:28		28.216667	0	0	0	Due to localized windstrom, Y phase Isolator connector got detached at Wardha SS. In view of heavy rains and lightning same could not be rectified during night hours . The works could be commenced only on date 08.10.2020 at 0500 hrs.	
						19-Oct-20	19:27	19-Oct-20	23:25		15.966667	0	0	0	Line tripped due to LBB protection operated on 428 at Raipur & DT received at Wardha end.	
						26/10/20	12:32	26/10/20	20:19		7.7833333	0	0	0	Emergency outage availed to attend hot spot on Line Isolator at Raipur end	
		<b>400kV RAIPUR-WARDHA II Total</b>									51.966667					93.02%
48	WR1_L_048	400kV RAIPUR-DURG I	21.43	WRTS-I												
		<b>400kV RAIPUR-DURG I Total</b>														100.00%
49	WR1_L_049	400kV RAIPUR-DURG II	21.43	WRTS-I												
		<b>400kV RAIPUR-DURG II Total</b>														100.00%
50	WR1_L_050	400kV RAIGARH-KOTRA PS I	6.288	WRTS-I		24/Oct/2020	18:00	31/10/20	23:59		0	0	0	173.99972	To control fault level at Kotra; Line idle charged from Raigarh end	



SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRLDC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
67	WR1_L_067	400Kv PUNE(GIS)-PUNE(TALEGOAN)_1	9.978	WRTS-I		6-Oct-20	12:06	6-Oct-20	18:17		6.183333	0	0	0	For Replacment of CVT at Pune (Talegaon) end & Line AMP works, 400KV-PUNE-GIS-PUNE-PG-2 A/R to be keep in non auto mode for safety precautions	
						22/10/20	15:11	22/10/20	15:11		0	0	0	0	Line A/R successfully at both ends on R phase to G fault, FC-4.8kA, FD- 50.5Kms from Pune-GIS end. Fault is in Adani portion. Line belong to Adani.	
						22/10/20	15:11	22/10/20	15:11		6.183333	0	0	0	Line A/R successfully at both ends on R phase to G fault, FC-4.8kA, FD- 50.5Kms from Pune-GIS end. Fault is in Adani portion. Line belong to Adani.	
		<b>400Kv PUNE(GIS)-PUNE(TALEGOAN)_1 Total</b>									6.1833333					99.17%
68	WR1_L_068	400Kv PUNE(GIS)-PUNE(TALEGOAN)_2	9.978	WRTS-I												
		<b>400Kv PUNE(GIS)-PUNE(TALEGOAN)_2 Total</b>														100.00%
69	WR1_L_069	765kv PUNE(GIS)-SOLAPUR	269.842	WRTS-I		1-Oct-20	00:00	10-Oct-20	11:39		0	0	0	227.65	Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at Solapur end at 20:46 hrs & Pune-GIS end at 20:51 hrs.	
						10-Oct-20	16:26	10-Oct-20	16:26		0	0	0	0	Line A/R successful at both end on R-G fault, Fault details: @Pune GIS end : M1-1.97 kA, 254.73 km, M2-1.96 kA, & 251 km @Solapur end - : M1-16.06 kA , FD-8.60 km , M2: Same as M1	
						10-Oct-20	21:19	31-Oct-20	23:59		0	0	0	506.66667	Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at Solapur end at 21:41 Hrs & Pune-GIS end at 21:47 Hrs.	
						10-Oct-20	16:26	10-Oct-20	16:26		0	0	0	0	Line A/R successful at both end on R-G fault, Fault details: @Pune GIS end : M1-1.97 kA, 254.73 km, M2-1.96 kA, & 251 km @Solapur end - : M1-16.06 kA , FD-8.60 km , M2: Same as M1	
						10-Oct-20	21:19	31-Oct-20	23:59		0	0	0	506.66667	Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at Solapur end at 21:41 Hrs & Pune-GIS end at 21:47 Hrs.	
		<b>765kv PUNE(GIS)-SOLAPUR Total</b>									0					100.00%
70	WR1_L_070	765kv WARDHA - AURANGABAD(PG) III	355	WRTS-I		1-Oct-20	00:00	6-Oct-20	07:06		0	0	0	127.1	Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at Wardha end at 01:37 hrs.	
						13-Oct-20	22:37	14-Oct-20	07:44		0	0	0	9.1166667	Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at Wardha end at 23:00 hrs.	
						15-Oct-20	00:05	31-Oct-20	23:59		0	0	0	407.9	Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at Wardha end at 00:38 hrs.	
						13-Oct-20	22:37	14-Oct-20	07:44		0	0	0	9.1166667	Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at Wardha end at 23:00 hrs.	
						15-Oct-20	00:05	31-Oct-20	23:59		0	0	0	407.9	Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at Wardha end at 00:38 hrs.	
		<b>765kv WARDHA - AURANGABAD(PG) III Total</b>									0					100.00%
71	WR1_L_071	765kv WARDHA - AURANGABAD(PG) IV	355	WRTS-I												
		<b>765kv WARDHA - AURANGABAD(PG) IV Total</b>														100.00%
72	WR1_L_072	400Kv SOLAPUR(NTPC)-SOLAPUR(PG)_1	11.2	WRTS-I												
		<b>400Kv SOLAPUR(NTPC)-SOLAPUR(PG)_1 Total</b>														100.00%
73	WR1_L_073	400Kv SOLAPUR(NTPC)-SOLAPUR(PG)_2	11.2	WRTS-I												
		<b>400Kv SOLAPUR(NTPC)-SOLAPUR(PG)_2 Total</b>														100.00%
74	WR1_L_074	765kv DURG PS- CHAMPA_1	149.15	WRTS-I		10-Oct-20	14:09	10-Oct-20	19:04		4.916667	0	0	0	Emergency outage availed for attending earthwire D-shackle nut bolt tightning work.	



SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVar/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRLDC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
						24/10/20	09:27	24/10/20	19:38		10.18333	0	0	0	Emergency outage availed by Bhatapara TLM for rectification / tightening of bolt in conductor suspension clamp & earth wire D shackle bolt to prevent falling / snapping of earth wire	
						24/10/20	09:27	24/10/20	19:38		15.1	0	0	0	Emergency outage availed by Bhatapara TLM for rectification / tightening of bolt in conductor suspension clamp & earth wire D shackle bolt to prevent falling / snapping of earth wire	
		<b>765kV DURG PS- CHAMPA_1 Total</b>									15.1					97.97%
75	WR1_L_075	765kV CHAMPA- KOTRA PS	96.33	WRTS-I												
		<b>765kV CHAMPA- KOTRA PS Total</b>														100.00%
76	WR1_L_076	765kV AURANGABAD(PG)-SOLAPUR I	279.57	WRTS-I		1-Oct-20	00:00	5-Oct-20	17:16		0	0	0	113.2667	Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at Aurangabad end at 15:28 hrs & at Solapur end at 15:40 hrs.	
						11-Oct-20	10:55	11-Oct-20	10:55		0	0	0	0	Line A/R successful at both ends on B-G fault, Fault details, @Aurangabad end: FC: 8.09KA, FD: 76 KMS @Solapur end: FC: 4.02KA, FD: 207 KMS Middle phase. Fault in Aurangabad TLM jurisdiction.	
						11-Oct-20	13:44	11-Oct-20	13:44		0	0	0	0	Line A/R successful at both ends on Y-G fault, Fault details, @ Aurangabad end: FC: 3.46KA, FD: 248.02 KMS @Solapur end: FC: 11.09, FD: 35.9 KMS. Middle phase. Fault in Solapur TLM jurisdiction.	
						14-Oct-20	21:06	31-Oct-20	23:59		0	0	0	410.8833	Line H/T as per WRLDC instructions for Voltage Regulation & SLR converted as BR at Aurangabad at 21:55 hrs & at Solapur at 21:37 hrs.	
						11-Oct-20	10:55	11-Oct-20	10:55		0	0	0	0	Line A/R successful at both ends on B-G fault, Fault details, @Aurangabad end: FC: 8.09KA, FD: 76 KMS @Solapur end: FC: 4.02KA, FD: 207 KMS Middle phase. Fault in Aurangabad TLM jurisdiction.	
						11-Oct-20	13:44	11-Oct-20	13:44		0	0	0	0	Line A/R successful at both ends on Y-G fault, Fault details, @ Aurangabad end: FC: 3.46KA, FD: 248.02 KMS @Solapur end: FC: 11.09, FD: 35.9 KMS. Middle phase. Fault in Solapur TLM jurisdiction.	
						14-Oct-20	21:06	31-Oct-20	23:59		0	0	0	410.8833	Line H/T as per WRLDC instructions for Voltage Regulation & SLR converted as BR at Aurangabad at 21:55 hrs & at Solapur at 21:37 hrs.	
		<b>765kV AURANGABAD(PG)-SOLAPUR I Total</b>									0					100.00%
77	WR1_L_077	765kV AURANGABAD(PG)-SOLAPUR II	279.57	WRTS-I		5-Oct-20	21:06	14-Oct-20	13:27		0	0	0	208.35	Line H/T as per WRLDC instructions for Voltage Regulation & SLR converted as BR at Aurangabad at 21:13 hrs & at Solapur at 21:16 hrs.	
		<b>765kV AURANGABAD(PG)-SOLAPUR II Total</b>									0					100.00%
78	WR1_L_078	220kV KORBA(EAST)-BUDDHIPADAR III	184	WRTS-I		26/10/20	12:31	26/10/20	18:30		5.983333	0	0	0	Emergency outage availed to attend hot spot at Loc 311 availed by Raigarh TLM	
		<b>220kV KORBA(EAST)-BUDDHIPADAR III Total</b>									5.983333					99.20%



SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRDLC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
91	WR1_L_091	400kV RAIGARH-JHARSUGUDA III	110.98	WRTS-I		3-Oct-20	15:45	3-Oct-20	15:45		0	0	0	0	Line autoreclose successful at both ends on R-Ph to G fault, FC:6.29KA; FD:60.5Kms from Raigarh end and FC:3.57KA, FD:103.7 Kms from Jharsuguda end.	
						5-Oct-20	07:36	5-Oct-20	15:09		7.55	0	0	0	Emergency outage availed for insulator replacement works by ER region.	
						5-Oct-20	07:36	5-Oct-20	15:09		7.55	0	0	0	Emergency outage availed for insulator replacement works by ER region.	
		<b>400kV RAIGARH-JHARSUGUDA III Total</b>									7.55					<b>98.99%</b>
92	WR1_L_092	400kV JHARSUGUDA-ROURKELA III	143.06	WRTS-I												
		<b>400kV JHARSUGUDA-ROURKELA III Total</b>														<b>100.00%</b>
91	WR1_L_093	400kV RAIGARH-JHARSUGUDA IV	145.5	WRTS-I												
		<b>400kV RAIGARH-SUNDERGARH IV Total</b>														<b>100.00%</b>
94	WR1_L_094	400kV STERLITE-ROURKELA IV	104.28	WRTS-I												
		<b>400kV STERLITE-ROURKELA IV Total</b>														<b>100.00%</b>
95	WR1_L_095	765kV D'JAIGARH-BILASPUR	90	WRTS-I												
		<b>765kV D'JAIGARH-BILASPUR Total</b>														<b>100.00%</b>
96	WR1_L_096	765kV D'JAIGARH-RANCHI I	303	WRTS-I		1-Oct-20	07:41	1-Oct-20	19:19		11.633333	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						2-Oct-20	07:55	2-Oct-20	19:53		11.966667	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						3-Oct-20	07:58	3-Oct-20	19:47		11.816667	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						4-Oct-20	09:37	4-Oct-20	19:38		10.016667	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						5-Oct-20	09:26	5-Oct-20	19:43		10.283333	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						6-Oct-20	08:07	6-Oct-20	19:44		11.616667	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						7-Oct-20	07:44	7-Oct-20	20:05		12.35	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						8-Oct-20	07:51	8-Oct-20	19:34		11.716667	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						9-Oct-20	08:19	9-Oct-20	20:13		11.9	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						10-Oct-20	07:40	10-Oct-20	19:48		12.133333	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	

SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVar/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRLDC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
						2-Oct-20	07:55	2-Oct-20	19:53		115.43333	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						3-Oct-20	07:58	3-Oct-20	19:47		11.816667	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						4-Oct-20	09:37	4-Oct-20	19:38		10.016667	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						5-Oct-20	09:26	5-Oct-20	19:43		10.283333	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						6-Oct-20	08:07	6-Oct-20	19:44		11.616667	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						7-Oct-20	07:44	7-Oct-20	20:05		12.35	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						8-Oct-20	07:51	8-Oct-20	19:34		11.716667	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						9-Oct-20	08:19	9-Oct-20	20:13		11.9	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						10-Oct-20	07:40	10-Oct-20	19:48		12.133333	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
		<b>765kV D'JAIGARH-RANCHI I Total</b>									207.26667					72.14%
97	WR1_L_097	765kV D'JAIGARH- JHARSUGUDA I	149.789	WRTS-I		29/10/20	09:38	29/10/20	20:15		0	0	0	10.616667	Line shutdown required for Tamnar Bay Extension Construction Works at Dharamajygarh end.	
		<b>765kV D'JAIGARH- JHARSUGUDA I Total</b>									0					100.00%
98	WR1_L_098	765kV D'JAIGARH- JHARSUGUDA II	149.789	WRTS-I		17-Oct-20	15:34	18-Oct-20	06:04		14.5	0	0	0	Emergency outage availed for replacement of R phase CVT at Jharsuguda end (Availed by ER)	
		<b>765kV D'JAIGARH- JHARSUGUDA II Total</b>									14.5					98.05%
99	WR1_L_099	400kV KOLHAPUR (MSETCL)- KOLHAPUR (GIS) I	39.383	WRTS-I												
		<b>400kV KOLHAPUR (MSETCL)- KOLHAPUR (GIS) I Total</b>														100.00%
100	WR1_L_100	400kV KOLHAPUR (MSETCL)- KOLHAPUR (GIS) II	39.383	WRTS-I		26/10/20	20:45	27/10/20	19:08		22.38333	0	0	0	Emergency hand tripped from Kolhapur(MSETCL) end due to spark observed on connector between CT and Isolator at Kolhapur(MSETCL) end.	
		<b>400kV KOLHAPUR (MSETCL)- KOLHAPUR (GIS) II Total</b>									22.383333					96.99%
	WR1_L_101	400kV KOLHAPUR (GIS)-MAPUSA I				6-Oct-20	08:40	6-Oct-20	20:22		11.7	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	

SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVar/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRDLC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
						8-Oct-20	08:19	8-Oct-20	19:31		11.2	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						10-Oct-20	10:58	10-Oct-20	18:42		7.7333333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						12-Oct-20	09:04	12-Oct-20	21:00		11.9333333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						14-Oct-20	09:18	14-Oct-20	20:09		10.85	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						18-Oct-20	09:01	18-Oct-20	19:34		10.55	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						28/10/20	10:11	28/10/20	19:21		9.1666667	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						29/10/20	14:40	29/10/20	19:25		4.75	0	0	0	Emergency outage availed to attend SF6 gas leakage at Kolhapur-GIS end	
						8-Oct-20	08:19	8-Oct-20	19:31		77.883333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						10-Oct-20	10:58	10-Oct-20	18:42		7.7333333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						12-Oct-20	09:04	12-Oct-20	21:00		11.933333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	

SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVAr/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRDLC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
						14-Oct-20	09:18	14-Oct-20	20:09		10.85	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						18-Oct-20	09:01	18-Oct-20	19:34		10.55	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						28/10/20	10:11	28/10/20	19:21		9.1666667	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						29/10/20	14:40	29/10/20	19:25		4.75	0	0	0	Emergency outage availed to attend SF6 gas leakage at Kolhapur-GIS end	
		<b>400kV KOLHAPUR (GIS)-MAPUSA I Total</b>									132.86667					82.14%
102	WR1_L_102	400kV KOLHAPUR (GIS)-MAPUSA II	156.039	WRTS-I		7-Oct-20	07:52	7-Oct-20	19:30		11.63333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						9-Oct-20	07:58	9-Oct-20	19:04		11.1	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						13-Oct-20	09:16	13-Oct-20	19:28		10.2	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						15-Oct-20	08:12	15-Oct-20	09:56		1.733333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						17-Oct-20	10:12	17-Oct-20	20:02		9.833333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	

SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVar/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRLDG
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
						19-Oct-20	09:18	19-Oct-20	19:53		10.58333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						23/10/20	09:28	23/10/20	20:26		10.96667	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						24/10/20	12:16	24/10/20	21:15		8.983333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						25/10/20	08:37	25/10/20	19:16		10.65	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						26/10/20	10:40	26/10/20	18:35		7.916667	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						27/10/20	10:33	27/10/20	17:55		7.366667	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						30/10/20	13:15	30/10/20	18:23		5.133333	0	0	0	Emergency outage availed to attend hot spot in jumper at Loc no. 322.	
						9-Oct-20	07:58	9-Oct-20	19:04		106.1	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						13-Oct-20	09:16	13-Oct-20	19:28		10.2	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						15-Oct-20	08:12	15-Oct-20	09:56		1.733333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	

SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVar/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRDC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
						17-Oct-20	10:12	17-Oct-20	20:02		9.833333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						19-Oct-20	09:18	19-Oct-20	19:53		10.583333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						23/10/20	09:28	23/10/20	20:26		10.96667	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						24/10/20	12:16	24/10/20	21:15		8.983333	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						25/10/20	08:37	25/10/20	19:16		10.65	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						26/10/20	10:40	26/10/20	18:35		7.916667	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						27/10/20	10:33	27/10/20	17:55		7.366667	0	0	0	To prevent tripping of line due to vegative deposition on insulators in Amboli Ghat section due to topography of region, polymer insulator are to be replaced by Glass Disc insulators to prevent tripping of line and for system security. Refer attached Photographs	
						30/10/20	13:15	30/10/20	18:23		5.133333	0	0	0	Emergency outage availed to attend hot spot in jumper at Loc no. 322.	
		<b>400kV KOLHAPUR (GIS)-MAPUSA II Total</b>									189.46667					74.53%
103	WR1_L_103	400kV WARDHA-MAUDA I	123.45	WRTS-I												
		<b>400kV WARDHA-MAUDA I Total</b>														100.00%
104	WR1_L_104	765kV D'JAI GARH-RANCHI II	354	WRTS-I		12-Oct-20	08:03	12-Oct-20	20:51		12.8	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	
						13-Oct-20	09:19	13-Oct-20	21:39		12.33333	0	0	0	For Tower Strengthening work to protect towers from extreme localized winds which exceeds design parameters. This is not a routine O& M works and the works are done for system security.	









SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVAR/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRLDC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
167	WR1_R_005	BUS REACTOR_400kV_63MVAR_SOLAPUR BUS REACTOR_400kV_63MVAR_SOLAPUR Total	63	WRTS-I		8-Oct-20	11:22	9-Oct-20	21:18		0	0	0	33.93333	H/T as per WRLDC instructions for Voltage Regulation	100.00%
168	WR1_R_006	BUS REACTOR_400kV_63MVAR_PARLI BUS REACTOR_400kV_63MVAR_PARLI Total	63	WRTS-I							0					
169	WR1_R_007	BUS REACTOR_400kV_50MVAR_PUNE BUS REACTOR_400kV_50MVAR_PUNE Total	50	WRTS-I												100.00%
170	WR1_R_008	BUS REACTOR_765kV_240MVAR_WARDHA BUS REACTOR_765kV_240MVAR_WARDHA Total	240	WRTS-I												100.00%
171	WR1_R_009	BUS REACTOR_765kV_240MVAR_BILASPUR BUS REACTOR_765kV_240MVAR_BILASPUR Total	240	WRTS-I												100.00%
172	WR1_R_010	SWITCHABLE LR_765kV_BINA_SEONI SWITCHABLE LR_765kV_BINA_SEONI Total	240	WRTS-I												100.00%
173	WR1_R_011	SWITCHABLE LR_765kV_SEONI 1_BILASPUR SWITCHABLE LR_765kV_SEONI 1_BILASPUR Total	240	WRTS-I												100.00%
174	WR1_R_012	SWITCHABLE LR_765kV_SEONI 2_BILASPUR SWITCHABLE LR_765kV_SEONI 2_BILASPUR Total	240	WRTS-I		7-Oct-20	10:24	7-Oct-20	21:00		10.6	0	0	0	For LR AMP works	98.58%
175	WR1_R_013	SWITCHABLE LR_765kV_D'GARH_BILASPUR SWITCHABLE LR_765kV_D'GARH_BILASPUR Total	240	WRTS-I												100.00%
176	WR1_R_014	BUS REACTOR_765kV_240MVAR_KOTRA PS BUS REACTOR_765kV_240MVAR_KOTRA PS Total	240	WRTS-I												100.00%
177	WR1_R_015	BUS REACTOR_400kV_80MVAR_KOTRA PS BUS REACTOR_400kV_80MVAR_KOTRA PS Total	80	WRTS-I												100.00%
178	WR1_R_016	SWITCHABLE LR_765kV_DURG 1_KOTRA PS SWITCHABLE LR_765kV_DURG 1_KOTRA PS Total	240	WRTS-I												100.00%
179	WR1_R_017	BUS REACTOR_400kV_50MVAR_BHADRAWATI BUS REACTOR_400kV_50MVAR_BHADRAWATI Total	50	WRTS-I												100.00%
180	WR1_R_018	BUS REACTOR_400kV_80MVAR_RAIPUR BUS REACTOR_400kV_80MVAR_RAIPUR Total	80	WRTS-I												100.00%
181	WR1_R_019	BUS REACTOR_400kV_50MVAR_MAPUSA	50	WRTS-I		7-Oct-20	09:50	7-Oct-20	19:45		0	0	0	9.9166667	H/T as per WRLDC instructions for Voltage Regulation	
						8-Oct-20	10:04	8-Oct-20	18:38		0	0	0	8.5666667	H/T as per WRLDC instructions for Voltage Regulation	
						9-Oct-20	11:41	9-Oct-20	21:23		0	0	0	9.7	H/T as per WRLDC instructions for Voltage Regulation	
						10-Oct-20	11:03	10-Oct-20	20:25		0	0	0	9.3666667	H/T as per WRLDC instructions for Voltage Regulation	
						12-Oct-20	09:25	12-Oct-20	20:41		0	0	0	11.266667	BR H/T as per WRLDC instructions for Voltage Regulation	
						27/10/20	11:15	27/10/20	21:22		0	0	0	10.116667	BR H/T as per WRLDC instructions for Voltage Regulation	
						27/10/20	11:15	27/10/20	21:22		0	0	0	10.116667	BR H/T as per WRLDC instructions for Voltage Regulation	
						28/10/20	10:26	28/10/20	22:12		0	0	0	11.766667	BR H/T as per WRLDC instructions for Voltage Regulation	
						8-Oct-20	10:04	8-Oct-20	18:38		0	0	0	8.5666667	H/T as per WRLDC instructions for Voltage Regulation	
						9-Oct-20	11:41	9-Oct-20	21:23		0	0	0	9.7	H/T as per WRLDC instructions for Voltage Regulation	
						10-Oct-20	11:03	10-Oct-20	20:25		0	0	0	9.3666667	H/T as per WRLDC instructions for Voltage Regulation	
						12-Oct-20	09:25	12-Oct-20	20:41		0	0	0	11.266667	BR H/T as per WRLDC instructions for Voltage Regulation	
						27/10/20	11:15	27/10/20	21:22		0	0	0	10.116667	BR H/T as per WRLDC instructions for Voltage Regulation	
						27/10/20	11:15	27/10/20	21:22		0	0	0	10.116667	BR H/T as per WRLDC instructions for Voltage Regulation	











SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVar/MW/e tc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRLDC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
		<b>ICT5_765/400kv_CHAMPA Total</b>														100.00%
237	WR1_L_113	400KV RAIGARH-JHARSUGUDA I	110.98	WRTS-I												100.00%
		<b>400KV RAIGARH-JHARSUGUDA I Total</b>														100.00%
238	WR1_L_114	400kv RAIPUR-RAIGARH III	217.02	WRTS-I		9-Oct-20	11:20	9-Oct-20	22:36		11.266667	0	0	0	For Line AMP works & 400KV-RAIGARH-RAIPUR-4 A/R to be keep in non auto mode for safety precautions.	
						12-Oct-20	17:42	12-Oct-20	17:42		0	0	0	0	Line A/R operated on Y-E fault, FD-202.05km, FC-1.816kA from Raipur end & FD-18.44km, FC-9.186kA from Raigarh end. Fault is in Raigarh-TLM jurisdiction. Phase Position -Middle	
						12-Oct-20	17:42	12-Oct-20	17:42		11.266667	0	0	0	Line A/R operated on Y-E fault, FD-202.05km, FC-1.816kA from Raipur end & FD-18.44km, FC-9.186kA from Raigarh end. Fault is in Raigarh-TLM jurisdiction. Phase Position -Middle	
		<b>400kv RAIPUR-RAIGARH III Total</b>									11.266667					98.49%
239	WR1_L_115	765kv DURG PS- CHAMPA_2	149.15	WRTS-I												100.00%
		<b>765kv DURG PS- CHAMPA_2 Total</b>														100.00%
240	WR1_L_116	765kv DURG PS -WARDHA_3	357.27	WRTS-I		2-Oct-20	15:49	31-Oct-20	07:43		0	0	0	687.9	Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at Durg PS end at 16:25 hrs.	
						31/10/20	08:27	31/10/20	18:05		0	0	9.633333	0	Line tripped on Y phase to E fault,FC-5.020KA,FD-150.084Km from Durg end and FC-3.408KA,FD-219.915Km from Wardha end. Fault is in Brahmपुरi TLM jurisdiction. Naxalite has burnt foreign material below the line. Leading to tripping of line.	
						31/10/20	08:27	31/10/20	18:05		0	0	9.633333	0	Line tripped on Y phase to E fault,FC-5.020KA,FD-150.084Km from Durg end and FC-3.408KA,FD-219.915Km from Wardha end. Fault is in Brahmपुरi TLM jurisdiction. Naxalite has burnt foreign material below the line. Leading to tripping of line.	
		<b>765kv DURG PS -WARDHA_3 Total</b>									0					100.00%
241	WR1_L_117	765kv DURG PS -WARDHA_4	357.27	WRTS-I												100.00%
		<b>765kv DURG PS -WARDHA_4 Total</b>														100.00%
242	WR1_T_052	ICT6_765/400kv_CHAMPA	1500	WRTS-I												100.00%
		<b>ICT6_765/400kv_CHAMPA Total</b>														100.00%
243	WR1_T_118	765KV D'JAIGARH- CHAMPA	56.48	WRTS-I												100.00%
		<b>765KV D'JAIGARH- CHAMPA TOTAL</b>														100.00%
244	WR1_T_053	ICT3_765/400kv_CHAMPA	1500	WRTS-I												100.00%
		<b>ICT3_765/400kv_CHAMPA Total</b>														100.00%
245	WR1_L_118	400KV KORBA-BIRSINGHPUR_1	226.642	WRTS-I		10-Oct-20	10:30	10-Oct-20	19:04		8.566667	0	0	0	Emergency outage availed for attending clearnce issues which is now 4.9m	
		<b>400KV KORBA-BIRSINGHPUR_2 Total</b>									8.566667					98.85%
246	WR1_T_053	ICT2_765/400kv_DURG PS	1500	WRTS-I												100.00%
		<b>ICT2_765/400kv_DURG PS Total</b>														100.00%
247	WR1_T_054	ICT4_765/400kv_TAMNAR PS	1500	WRTS-I												100.00%
		<b>ICT4_765/400kv_TAMNAR PS Total</b>														100.00%
248	WR1_R_072	SWITCHABLE LR_765kv_WARDHA 4_DURG PS	240	WRTS-I												100.00%
		<b>SWITCHABLE LR_765kv_WARDHA 4_DURG PS Total</b>														100.00%
249	WR1_L_118	400KV LARA(NTPC)-CHAMPA I	113.527	WRTS-I												100.00%
		<b>400KV LARA(NTPC)-CHAMPA I Total</b>														100.00%
250	WR1_L_119	400KV LARA(NTPC)-CHAMPA II	113.527	WRTS-I												100.00%
		<b>400KV LARA(NTPC)-CHAMPA II Total</b>														100.00%
251	WR1_L_120	400kv RAIPUR-RAIGARH IV	217.02	WRTS-I		13-Oct-20	08:20	13-Oct-20	20:54		12.566667	0	0	0	For Line AMP works & 400KV-RAIGARH-RAIPUR-3 A/R to be keep in non auto mode for safety precautions	

SN	Unique ID of transmission Element	NAME OF LINE/ICT	Description (Length/Nos./MVA/MVar/MW/etc.)	Region	Type of failure	OUTAGE		RESTORATION		Total outage in days (1)	DURATION OF OUTAGE ATTRIBUTABLE TO (in Hrs)				Detailed Reason(s) for Outage	% Availability as certified by WRLDC
						Date	Time	Date	Time		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available		
		<b>400kV RAIPUR-RAIGARH IV Total</b>									12.566667					98.31%
252	WR1_L_121	400kV SOLAPUR(NTPC)-SOLAPUR(PG)_3	11.2	WRTS-I												100.00%
		<b>400kV SOLAPUR(NTPC)-SOLAPUR(PG)_3 Total</b>														100.00%
253	WR1_L_122	400kV SOLAPUR(NTPC)-SOLAPUR(PG)_4	11.2	WRTS-I												100.00%
		<b>400kV SOLAPUR(NTPC)-SOLAPUR(PG)_4 Total</b>														100.00%
254	WR1_L_0123	400kV RAIGARH-JHARSUGUDA II	110.98	WRTS-I		31/10/20	09:20	31/10/20	21:42		12.366667	0	0	0	Outage availed by Odisha for Line AMP Works. Tree Cutting; Jumper Tightening etc;	98.34%
		<b>400kV RAIGARH-SUNDERGARH II Total</b>									12.366667					98.34%
255	WR1_T_124	765kV AURANGABAD(PG)-PADGHE(GIS) I	284.816	WRTS-I												100.00%
		<b>765kV AURANGABAD(PG)-PADGHE(GIS) I Total</b>														100.00%
256	WR1_T_125	765kV AURANGABAD(PG)-PADGHE(GIS) II	284.816	WRTS-I												100.00%
		<b>765kV AURANGABAD(PG)-PADGHE(GIS) II Total</b>														100.00%
257	WR1_T_055	ICT2_765/400kv_PADGHE(GIS)	1500	WRTS-I												100.00%
		<b>ICT2_765/400kv_PADGHE(GIS) Total</b>														100.00%
258	WR1_R_054	BUS REACTOR_765kV_240MVAR_PADGHE(GIS)	240	WRTS-I												100.00%
		<b>BUS REACTOR_765kV_240MVAR_PADGHE(GIS) TOTAL</b>														100.00%
259	WR1_R_055	SWITCHABLE LR_400kV_BWATI 2_RAIPUR	50	WRTS-I												100.00%
		<b>SWITCHABLE LR_400kV_BWATI 2_RAIPUR Total</b>														100.00%
260	WR1_T_125	400kV PADGHE(GIS)-KUDUS( PADGHE MSETCL) I	16.74	WRTS-I		9-Oct-20	15:19	9-Oct-20	19:55		4.6	0	0	0	Emergency outage availed to attend hot spot on ' B ph Wave Trap at Padghe SS	99.38%
		<b>400kV PADGHE(GIS)-KUDUS( PADGHE MSETCL) I TOTAL</b>									4.6					99.38%
261	WR1_T_125	400kV PADGHE(GIS)-KUDUS( PADGHE MSETCL) II	16.74	WRTS-I		26/10/20	14:58	26/10/20	19:18		4.3333333	0	0	0	Emergency outage availed to attend hot spot on CT connector at Kudus end.	99.42%
		<b>400kV PADGHE(GIS)-KUDUS( PADGHE MSETCL) II TOTAL</b>									4.3333333					99.42%
262	WR1_T_056	ICT1_765/400kv_PADGHE(GIS)	1500	WRTS-I												100.00%
		<b>ICT1_765/400kv_PADGHE(GIS) Total</b>														100.00%
263		400kV WARDHA-WARORA-1_LILOPOINT_PG	3.71	WRTS-I		11-Oct-20	06:02	11-Oct-20	06:02		0	0	0	0	Line A/R successful at both end on B-G fault, Fault details: @Warora end : FC-13.43 kA, 12.57 km (Double end) @Wardha end - : .FC- 11.668KA, 39.72KM (Double end) Fault is under Warora TLM jurisdiction.	100.00%
		<b>400kV WARDHA-WARORA-1_LILOPOINT_PG Total</b>									0					100.00%
264		400kV WARDHA-WARORA-2_LILOPOINT_PG	3.71	WRTS-I												100.00%
		<b>400kV WARDHA-WARORA-2_LILOPOINT_PG Total</b>														100.00%
265		400kV WARORA-PARLI-1_LILOPOINT_PG	333.23	WRTS-I		12-Oct-20	11:56	12-Oct-20	11:56		0	0	0	0	Line A/R successfully at both end on R phase-G Fault @Parli :M1: FC-1.79 KA, FD-213.4 Kms M2: 1.75 KA, 214.3Kms @Warora : M1: FC-2.74 KA, FD-150.0 Kms M2: 2.7 KA, 145.5 Kms. Fault is in Nanded TLM jurisdiction . Phase Position -Bottom	100.00%
						12-Oct-20	18:48	12-Oct-20	18:48		0	0	0	0	Line A/R operated on Y-E fault, FD-254.27km, FC-2.11kA from Warora end & FD-127.22km, FC-3.264kA from Parli end. Fault is in Nanded-TLM jurisdiction.Phase Position -Top	100.00%
						29/10/20	21:22	29/10/20	22:08		0	0	0.7666667	0	Line tripped on B phase to G fault, FC-5.279kA, FD-79.466Kms from Warora end.and FC-1.738kA, FD-302.033Kms from Parli end. Kite with thread hanging in conductor was observed.	100.00%
						29/10/20	22:08	30/10/20	05:59		0	0	0	7.85	Line is kept open for voltage regulation with WRLDC code: 10/3119.	100.00%
						30/10/20	13:39	30/10/20	17:08		0	0	3.4833333	0	Emergency outage availed to remove kite hanging in Top phase of Circuit I and thread from Ckt 2 location between span 210-211	100.00%



