

Standard of Performance data for the month of Jan-2024
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	03-01-2024	07:37:00	05-01-2024	20:26:00	2.53	0.00	0.00	0.00	60.82		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	06-01-2024	10:46:00	07-01-2024	20:11:00	1.39	0.00	0.00	0.00	33.42		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	13-01-2024	09:52:00	13-01-2024	21:52:00	0.50	0.00	0.00	0.00	12.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	01-01-2024	09:59:00	01-01-2024	22:05:00	0.50	0.00	0.00	0.00	12.10		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	08-01-2024	07:35:00	10-01-2024	20:14:00	2.53	0.00	0.00	0.00	60.65		* BR H/T as per WRLDC instructions for Voltage Regulation.
							7.45	0.00	0.00	0.00	178.99	100.00	
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	10-01-2024	08:47:00	10-01-2024	20:15:00	0.48	0.00	0.00	0.00	11.47		* BR H/T as per WRLDC instructions for Voltage Regulation
							0.48	0.00	0.00	0.00	11.47	100.00	
BSR	50MVAR, BUS REACTOR-1 AT BHADRAWATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	63MVAR, BUS REACTOR-2 AT BHADRAWATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	125MVAR, BUS REACTOR-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	80MVAR, BUS REACTOR-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	125MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	12-01-2024	09:44:00	26-01-2024	23:38:00	14.58	0.00	0.00	0.00	349.90		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	01-01-2024	09:46:00	01-01-2024	21:36:00	0.49	0.00	0.00	0.00	11.83		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	09-01-2024	09:47:00	10-01-2024	22:40:00	1.54	0.00	0.00	0.00	36.88		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	28-01-2024	10:23:00	31-01-2024	23:59:59	3.57	0.00	0.00	0.00	85.62		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	02-01-2024	10:23:00	07-01-2024	19:59:00	5.40	0.00	0.00	0.00	129.60		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation
							56.58	0.00	0.00	0.00	1,357.83	100.00	
BSR	125MVAR, BUS REACTOR-1 AT DHARAMJAYGARH	OSPT	12-01-2024	10:16:00	12-01-2024	13:57:00	0.15	3.68	0.00	0.00	0.00		* For CSD commissioning works in 426 bay
							0.15	3.68	0.00	0.00	0.00	99.50	
BSR	330MVAR, BUS REACTOR-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	330MVAR, BUS REACTOR-2 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	330MVAR, BUS REACTOR-3 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	06-01-2024	10:53:00	31-01-2024	23:59:59	25.55	0.00	0.00	0.00	613.12		* BR H/T as per WRLDC instructions for VR
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	28-01-2024	12:24:00	31-01-2024	23:59:59	3.48	0.00	0.00	0.00	83.60		* BR H/T as per WRLDC instructions for VR
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	20-01-2024	11:54:00	26-01-2024	21:56:00	6.42	0.00	0.00	0.00	154.03		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	27-01-2024	11:49:00	27-01-2024	21:52:00	0.42	0.00	0.00	0.00	10.05		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	12-01-2024	10:58:00	13-01-2024	19:38:00	1.36	0.00	0.00	0.00	32.67		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	15-01-2024	10:06:00	15-01-2024	23:07:00	0.54	0.00	0.00	0.00	13.02		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	16-01-2024	10:08:00	18-01-2024	00:35:00	1.60	0.00	0.00	0.00	38.45		* BR H/T as per WRLDC instructions for Voltage Regulation
							39.37	0.00	0.00	0.00	944.94	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	13-01-2024	09:51:00	13-01-2024	19:11:00	0.39	0.00	0.00	0.00	9.33		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	02-01-2024	11:54:00	02-01-2024	21:04:00	0.38	0.00	0.00	0.00	9.17		* BR H/T as per WRLDC instructions for Voltage Regulation .
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	10-01-2024	08:16:00	11-01-2024	23:57:00	1.65	0.00	0.00	0.00	39.68		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	18-01-2024	10:25:00	18-01-2024	20:33:00	0.42	0.00	0.00	0.00	10.13		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	19-01-2024	10:23:00	20-01-2024	21:50:00	1.48	0.00	0.00	0.00	35.45		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	31-01-2024	10:04:00	31-01-2024	19:34:00	0.40	0.00	0.00	0.00	9.50		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	30-01-2024	10:39:00	30-01-2024	20:01:00	0.39	0.00	0.00	0.00	9.37		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	27-01-2024	09:40:00	27-01-2024	21:28:00	0.49	0.00	0.00	0.00	11.80		* BR H/T as per WRLDC instructions for Vo
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	28-01-2024	10:15:00	28-01-2024	20:02:00	0.41	0.00	0.00	0.00	9.78		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	07-01-2024	10:35:00	31-01-2024	23:59:59	24.56	0.00	0.00	0.00	589.42		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	17-01-2024	09:50:00	31-01-2024	23:59:59	14.59	0.00	0.00	0.00	350.17		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	14-01-2024	10:14:00	14-01-2024	20:22:00	0.42	0.00	0.00	0.00	10.13		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	15-01-2024	09:24:00	15-01-2024	20:21:00	0.46	0.00	0.00	0.00	10.95		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	16-01-2024	09:38:00	17-01-2024	00:38:00	0.63	0.00	0.00	0.00	15.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	12-01-2024	10:52:00	12-01-2024	23:20:00	0.52	0.00	0.00	0.00	12.47		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	05-01-2024	09:52:00	06-01-2024	19:58:00	1.42	0.00	0.00	0.00	34.10		* BR H/T as per WRLDC instructions for Voltage Regulation

Standard of Performance data for the month of Jan-2024
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	03-01-2024	09:54:00	04-01-2024	23:26:00	1.56	0.00	0.00	0.00	37.53	100.00	* BR H/T as per WRLDC instructions for Voltage Regulation
							112.17	0.00	0.00	0.00	2,691.98		
BSR	80MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	125MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	10-01-2024	09:44:00	31-01-2024	23:59:59	21.59	0.00	0.00	0.00	518.27		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	27-01-2024	11:42:00	27-01-2024	21:48:00	0.42	0.00	0.00	0.00	10.10		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	30-01-2024	10:40:00	30-01-2024	20:27:00	0.41	0.00	0.00	0.00	9.78		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	17-01-2024	10:22:00	17-01-2024	21:33:00	0.47	0.00	0.00	0.00	11.18		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	08-01-2024	10:15:00	09-01-2024	00:49:00	0.61	0.00	0.00	0.00	14.57		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	15-01-2024	09:49:00	15-01-2024	23:14:00	0.56	0.00	0.00	0.00	13.42		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	09-01-2024	10:06:00	09-01-2024	22:00:00	0.50	0.00	0.00	0.00	11.90		* BR H/T as per WRLDC instructions for VR
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	16-01-2024	09:47:00	16-01-2024	20:55:00	0.46	0.00	0.00	0.00	11.13		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	14-01-2024	10:17:00	14-01-2024	21:13:00	0.46	0.00	0.00	0.00	10.93		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	05-01-2024	10:34:00	06-01-2024	21:44:00	1.47	0.00	0.00	0.00	35.17		* BR H/T as per WRLDC instructions for Voltage Regulation
							26.95	0.00	0.00	0.00	646.45	100.00	
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	24-01-2024	09:59:00	24-01-2024	19:28:00	0.40	0.00	0.00	0.00	9.48		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	27-01-2024	10:22:00	27-01-2024	18:39:00	0.35	0.00	0.00	0.00	8.28		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	20-01-2024	12:12:00	20-01-2024	19:37:00	0.31	0.00	0.00	0.00	7.42		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	17-01-2024	10:10:00	17-01-2024	20:22:00	0.43	0.00	0.00	0.00	10.20		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	19-01-2024	09:51:00	19-01-2024	17:53:00	0.34	0.00	0.00	0.00	8.03		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	04-01-2024	08:53:00	04-01-2024	18:56:00	0.42	0.00	0.00	0.00	10.05		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	03-01-2024	08:47:00	03-01-2024	22:28:00	0.57	0.00	0.00	0.00	13.68		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	10-01-2024	06:40:00	10-01-2024	20:28:00	0.58	0.00	0.00	0.00	13.80		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	08-01-2024	09:47:09	08-01-2024	20:09:00	0.43	0.00	0.00	0.00	10.36		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	07-01-2024	09:32:00	07-01-2024	20:16:00	0.45	0.00	0.00	0.00	10.73		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	15-01-2024	08:49:00	15-01-2024	18:20:00	0.40	0.00	0.00	0.00	9.52		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	13-01-2024	07:24:00	13-01-2024	19:06:00	0.49	0.00	0.00	0.00	11.70		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	11-01-2024	06:39:00	11-01-2024	20:39:00	0.58	0.00	0.00	0.00	14.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	06-01-2024	09:31:00	06-01-2024	21:15:00	0.49	0.00	0.00	0.00	11.73		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	14-01-2024	07:34:00	14-01-2024	13:09:00	0.23	0.00	0.00	0.00	5.58		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	16-01-2024	08:36:00	16-01-2024	20:03:00	0.48	0.00	0.00	0.00	11.45		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	12-01-2024	09:35:00	13-01-2024	04:09:00	0.77	0.00	0.00	0.00	18.57		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	09-01-2024	09:50:00	09-01-2024	21:41:00	0.49	0.00	0.00	0.00	11.85		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	10-01-2024	06:40:00	10-01-2024	20:28:00	0.58	0.00	0.00	0.00	13.80		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	05-01-2024	09:02:00	05-01-2024	20:31:00	0.48	0.00	0.00	0.00	11.48		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation
							40.27	0.00	0.00	0.00	965.71	100.00	
BSR	63MVAR, BUS REACTOR-1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	125MVAR, BUS REACTOR-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00		
BSR	50MVAR, BUS REACTOR-1 AT PUNE	SVRD	03-01-2024	10:23:00	31-01-2024	23:59:59	28.57	0.00	0.00	0.00	685.62		* BR H/T as per WRLDC instructions for Voltage Regulation
							28.57	0.00	0.00	0.00	685.62	100.00	
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	31-01-2024	09:57:00	31-01-2024	17:55:00	0.33	0.00	0.00	0.00	7.97		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	17-01-2024	10:19:00	17-01-2024	18:55:00	0.36	0.00	0.00	0.00	8.60		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	27-01-2024	11:46:00	27-01-2024	18:35:00	0.28	0.00	0.00	0.00	6.82		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	22-01-2024	10:53:00	22-01-2024	18:15:00	0.31	0.00	0.00	0.00	7.37		* Bus Reactor hand tripped for voltage regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	28-01-2024	09:18:00	28-01-2024	20:33:00	0.47	0.00	0.00	0.00	11.25		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	30-01-2024	09:25:00	30-01-2024	20:27:00	0.46	0.00	0.00	0.00	11.03		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	19-01-2024	09:56:00	19-01-2024	17:56:00	0.33	0.00	0.00	0.00	8.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	24-01-2024	09:57:00	24-01-2024	19:23:00	0.39	0.00	0.00	0.00	9.43		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	23-01-2024	10:23:00	23-01-2024	20:14:00	0.41	0.00	0.00	0.00	9.85		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	05-01-2024	10:03:00	05-01-2024	20:28:00	0.43	0.00	0.00	0.00	10.42		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	09-01-2024	09:43:00	09-01-2024	22:06:00	0.52	0.00	0.00	0.00	12.38		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	15-01-2024	09:23:00	15-01-2024	20:30:00	0.46	0.00	0.00	0.00	11.12		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-01-2024	11:23:00	01-01-2024	20:25:00	0.38	0.00	0.00	0.00	9.03		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	11-01-2024	08:27:00	11-01-2024	19:36:00	0.47	0.00	0.00	0.00	11.15		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	16-01-2024	08:35:00	16-01-2024	20:35:00	0.50	0.00	0.00	0.00	12.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	08-01-2024	09:43:00	09-01-2024	04:30:00	0.78	0.00	0.00	0.00	18.78		* BR H/T as per WRLDC instructions for Voltage Regulation

Standard of Performance data for the month of Jan-2024
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	03-01-2024	08:58:00	03-01-2024	22:29:00	0.56	0.00	0.00	0.00	13.52		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	12-01-2024	08:45:00	13-01-2024	22:26:00	1.57	0.00	0.00	0.00	37.68		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	07-01-2024	09:45:00	07-01-2024	18:40:00	0.37	0.00	0.00	0.00	8.92		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	02-01-2024	07:09:00	02-01-2024	19:54:00	0.53	0.00	0.00	0.00	12.75		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	04-01-2024	09:50:00	04-01-2024	22:26:00	0.53	0.00	0.00	0.00	12.60		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	06-01-2024	08:36:00	06-01-2024	19:55:00	0.47	0.00	0.00	0.00	11.32		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	10-01-2024	08:50:00	10-01-2024	20:31:00	0.49	0.00	0.00	0.00	11.68		* BR H/T as per WRLDC instructions for Voltage Regulation
							73.40	0.00	0.00	0.00	1,761.67	100.00	
BSR	63MVAR, BUS REACTOR-1 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for VR
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT WARDHA	OSPT	15-01-2024	10:10:00	15-01-2024	18:59:00	0.37	8.82	0.00	0.00	0.00		* For Amp of Bus Reactor
							0.37	8.82	0.00	0.00	0.00	98.81	
BSR	240MVAR, BUS REACTOR-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-2 AT WARDHA	SCSD	30-01-2024	14:49:00	30-01-2024	19:29:00	0.19	0.00	0.00	0.00	4.67		* CSD Fine tuning works.
							0.19	0.00	0.00	0.00	4.67	100.00	
BSR	330MVAR, BUS REACTOR-2 AT WARDHA	OSPT	17-01-2024	10:34:00	17-01-2024	21:24:00	0.45	10.83	0.00	0.00	0.00		* For Bus Reactor AMP works
							0.45	10.83	0.00	0.00	0.00	98.54	
BSR	63MVAR, BUS REACTOR-3 AT WARDHA	SCSD	30-01-2024	10:30:00	30-01-2024	13:03:00	0.11	0.00	0.00	0.00	2.55		* CSD Fine tuning works.
							0.11	0.00	0.00	0.00	2.55	100.00	
BSR	330MVAR, BUS REACTOR-3 AT WARDHA	OSPT	27-01-2024	13:17:00	27-01-2024	19:50:00	0.27	6.55	0.00	0.00	0.00		* Occ Sr. NO. 136 // for Spare Normalisation // Last Spare taken into service 13.07.2023// outage did not availed 02.01 or 12.01.2024/ RESCHEDULED/
BSR	330MVAR, BUS REACTOR-3 AT WARDHA	OSPT	27-01-2024	10:17:00	27-01-2024	13:17:00	0.13	3.00	0.00	0.00	0.00		* Occ Sr. NO. 136 // for Spare Normalisation // Last Spare taken into service 13.07.2023// outage did not availed 02.01 or 12.01.2024/ RESCHEDULED/* 22.02.2024 06:24:48 INDIA (60001973)* Beyond six months
							0.40	9.55	0.00	0.00	0.00	98.72	
CKT	220kV KORBA(CSEB)-BUDDHIPADAR(OPTCL)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AKOLA(MSETCL)-AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AKOLA(MSETCL)-AURANGABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-1	OSFT	03-01-2024	19:05:00	03-01-2024	21:44:00	0.11	2.65	0.00	0.00	0.00		* Emergency outage availed to attend Hot-spot on B-phase CT at Waluj ss. Bay at Waluj belongs to POWERGRID
							0.11	2.65	0.00	0.00	0.00	99.64	
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-1	OSFT	31-01-2024	08:11:00	31-01-2024	18:58:00	0.45	10.78	0.00	0.00	0.00		* E/S/D availed for replacement of Main-2 Realy at Bhadravati SS.
							0.45	10.78	0.00	0.00	0.00	98.55	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2024
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV MAUDA(NTPC)-WARDHA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MAUDA(NTPC)-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PADGHE GIS-KUDUS(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PADGHE GIS-KUDUS(MSETCL)-2	LART	15-01-2024	13:28:00	15-01-2024	13:28:00	0.00	0.00	0.00	0.00	0.00		* A/R successful on R-Ph to G fault through main bay only. Tie CB tripped on PD. FD:15.4KM , FC- 5.27 KA from Padghe end* 02.02.2024 12:56:00 INDIA (60031136)*** On Tower Top Patrolling carried out at Loc no 33 is Suspension tower with Long rod porcelain insulator. Bird drop was found in top surface of long rod insulator and insulator crack was found beneath the petticoat for this location for R - phase Bottom. loc 35 (Tension Tower) Bird drop was observed on Pilot long rod porcelain insulator (Bottom) , insulator chipping was found at bottom for R - phase Bottom
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PARLI(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PARLI(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PUNE GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PUNE GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE-PUNE GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE-PUNE GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LART	05-01-2024	00:13:00	05-01-2024	00:13:00	0.00	0.00	0.00	0.00	0.00		* Line Auto Reclosed successfully on B-G fault. Pune GIS end : 119.123Km (M1) <-> 121.041Km (M2), FC-2.845 KA. Waluj end : 96.8 KM , FC-3.61 KA. Fault is in Adani Jurisdiction.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for Power regulation
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* After completion of outage availed by M/s Adani, line is kept out for Power Regulation.
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	400kV PUNE GIS-PUNE-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE GIS-PUNE-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIGARH-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIGARH-KOTRA PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHADRAWATI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHADRAWATI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHADRAWATI-3	LEFT	23-01-2024	21:55:00	23-01-2024	23:49:00	0.08	1.90	0.00	0.00	0.00		* Line tripped on Y-E fault . Fault detail at Raipur End :-Main I- FD- 135.4 KM, FC- 2.56 KA , Main II- FD- 135.8 KM, FC- 2.6 KA. Fault detail at Bhadrawati End :-Main I- FD- 213 KM, FC- 1.66 KA , Main II- FD- 224.6 KM, FC- NA. Fault is in Brahmapuri TLM jurisdiction . Faulty phase position - Bottom . * 02.02.2024 14:07:58 INDIA (60031136)* Insulator of Double tention string towards Bhadrawati side on tower no. 370 decapped However , conductor came down and was holding by jumper and did not fall to ground . Since the conductor came down , burnt bush was observed in the span 370 - 371
CKT	400kV RAIPUR-BHADRAWATI-3	OSFT	24-01-2024	09:42:00	24-01-2024	19:47:00	0.42	10.08	0.00	0.00	0.00		* Emergency outage availed to attend broken insulator string at loc no: 370
							0.50	11.98	0.00	0.00	0.00	98.39	
CKT	400kV RAIPUR-BHILAI(CSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIPUR PS(DURG)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2024
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV RAIPUR-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-WARDHA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RANCHI-SIPAT(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RANCHI-SIPAT(NTPC)-2	LART	18-01-2024	02:25:00	18-01-2024	02:25:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line A/R successful on Y-G fault . Fault details at Ranchi end :- Main I- FD- 29.11 KM , FC- 8.13 KA , Main II- FD- 29.48 KM , FC- 8.13 KA . Fault is in ER-I jurisdiction . * 02.02.2024 21:14:16 INDIA (60001973)* Y PHASE(TOP PHASE) INSULATOR FLASHED OVER OBSERVED AT LOC-1045.
CKT	400kV ROURKELA-JHARSUGUDA-1	LCSD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Reconductoring works.
CKT	400kV ROURKELA-JHARSUGUDA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-3	LCSD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Reconductoring works
CKT	400kV ROURKELA-JHARSUGUDA-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SEONI-KIRNAPUR(MPPTCL)	OSPD	20-01-2024	10:55:00	20-01-2024	20:37:00	0.40	0.00	0.00	0.00	9.70	100.00	* Outage availed by MPPTCL for providing double fitting into single fitting <(>&<)> disc replacement work to be carried out at various location
CKT	400kV SEONI-KIRNAPUR(MPPTCL)	OSPD	19-01-2024	10:01:00	19-01-2024	18:46:00	0.37	0.00	0.00	0.00	8.75	100.00	* Outage availed by MPPTCL for providing double fitting into single fitting <(>&<)> disc replacement work to be carried out at various location
CKT	400kV SEONI-KIRNAPUR(MPPTCL)	OSPD	18-01-2024	09:54:00	18-01-2024	18:27:00	0.36	0.00	0.00	0.00	8.55	100.00	* Outage availed by MPPTCL for for providing double fitting into single fitting <(>&<)> disc replacement work to be carried out at various location
CKT	400kV SEONI-SATPURA(MPPTCL)			00:00:00		00:00:00	1.13	0.00	0.00	0.00	27.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-3	OSPT	30-01-2024	08:50:00	30-01-2024	20:16:00	0.48	11.43	0.00	0.00	0.00	98.46	* Line defect rectification and Line Terminal equipment AMP works.
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AKOLA(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AKOLA(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AURANGABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-WARORA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-WARORA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARORA-PARLI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARORA-PARLI-2	LART	17-01-2024	01:49:00	17-01-2024	01:49:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line Auto Reclosed successfully on Y-E fault. Fault details, AFAS(Parli), FD- 215.38 Kms, FC- 1.78KA, At Warora(Relay) M1: FD-134.3 K= ms, FC- 3.07KA, M2: FD-135.8 Kms, FC- 3.04 KA. Fault is in Warora TLM Jurisdiction.* 02.02.2024 13:10:47 INDIA (60031136)* bird dropping found at Loc.No. 411 <(>&<)> 414 and relavent photographs enclosed.
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2024
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	765kV AURANGABAD-PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV AURANGABAD-PUNE GIS	LVRD	01-01-2024	00:00:01	24-01-2024	18:58:00	23.79	0.00	0.00	0.00	570.97		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR converted to BR at hrs at Aurangabad end and hrs at Pune (GIS) end.
CKT	765kV AURANGABAD-PUNE GIS	LVRD	29-01-2024	19:41:00	31-01-2024	23:59:59	2.18	0.00	0.00	0.00	52.32		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR converted to BR at 20:04hrs at Aurangabad end and at 20:33hrs at Pune (GIS) end.
CKT	765kV AURANGABAD-PUNE GIS	LPRD	27-01-2024	11:34:00	29-01-2024	08:26:00	1.79	0.00	0.00	0.00	42.87		* Line H/T as per WRDLC instructions for Power Regulation
CKT	765kV BILASPUR-DHARAMJAYGARH			00:00:00		00:00:00	27.76	0.00	0.00	0.00	666.16	100.00	
CKT	765kV BILASPUR-SEONI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BILASPUR-SEONI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV CHAMPA-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV CHAMPA-RAIPUR PS(DURG)-1	LVRD	10-01-2024	00:26:00	10-01-2024	11:53:00	0.48	0.00	0.00	0.00	11.45		* Line H/T as per WRDLC instruction and converted SLR as B/R at Durg PS end at 00:47hrs for Voltage regulation.
CKT	765kV CHAMPA-RAIPUR PS(DURG)-2	LVRD	17-01-2024	00:42:00	31-01-2024	11:56:00	14.47	0.00	0.00	0.00	347.23		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR converted to BR at 02:08 hrs at Durg end.
CKT	765kV CHAMPA-RAIPUR PS(DURG)-2	LVRD	01-01-2024	00:00:01	04-01-2024	16:20:00	3.68	0.00	0.00	0.00	88.33		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR charged as BR at Durg end
CKT	765kV CHAMPA-DHARAMJAYGARH-1			00:00:00		00:00:00	18.15	0.00	0.00	0.00	435.56	100.00	
CKT	765kV RANCHI-DHARAMJAYGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RANCHI-DHARAMJAYGARH-2	OSFT	24-01-2024	08:23:00	24-01-2024	18:23:00	0.42	10.00	0.00	0.00	0.00		* Emergency outage availed to attend broken insulators were at location number 876 (Y phase pilot sting).
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-1	OMSU	19-01-2024	01:22:00	19-01-2024	19:39:00	0.76	0.00	18.28	0.00	0.00	98.66	* Line tripped on B-G fault due to fallen of OPGW rope on B-Ph at Tower Span No. 338-339. Fault detail at Dharamjagarh end: AFAS: B-G, 15.29KA, 22.737km. TWFL distance: 26.29km. Fault Phase Position :Top. TLM Jurisdiction: Korba, TLM.
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-1	LART	19-01-2024	01:19:00	19-01-2024	01:19:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on B-G fault. Fault detail at Dharamjagarh end: AFAS: B-G, 13.68KA, 22.797km. TWFL distance: 26.25km. SLR at Dh= aramjagarh end tripped during A/R operation due to implimented Ferro-Reasonance protection. Fault Phase Position :Top. TLM Jurisdiction: Korba, TLM.* 02.02.2024 14:34:49 INDIA (60031136)*** the cause of tripping was unpredicted bad weather condition (i. e. rain (>&<) dense fog) which increased the induction level and discharged induction through PP rope/hanging pullies to earth wire resulting melting of setting rope which was used during OPGW stringing work in between tower no. 338-339 thereby the said rope come nearer to top (B) phase conductor and said line got tripped.
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-2			00:00:00		00:00:00	0.76	0.00	18.28	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-4	OSPT	17-01-2024	09:11:00	17-01-2024	21:13:00	0.50	12.03	0.00	0.00	0.00		* For Line terminal equipment AMP works
CKT	765kV KOTRA PS-RAIPUR PS(DURG)-1			00:00:00		00:00:00	0.50	12.03	0.00	0.00	0.00	98.38	
CKT	765kV KOTRA PS-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-TAMNAR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-TAMNAR PS-2	OSPT	30-01-2024	08:03:00	30-01-2024	20:08:00	0.50	12.08	0.00	0.00	0.00		* Line defect rectification and Line Terminal equipment AMP works.
CKT	765kV-PUNE GIS-PADGHE GIS-1	OSFT	29-01-2024	09:47:00	29-01-2024	19:12:00	0.39	9.42	0.00	0.00	0.00		* Emergency outage availed for insulator replacement work
CKT	765kV RAIPUR PS(DURG)-WARDHA-1	LVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for voltage Regulation and SLR charged as BR at 17:13 Hrs at Durg end.
CKT	765kV RAIPUR PS(DURG)-WARDHA-2	OSPT	31-01-2024	09:11:00	31-01-2024	18:01:00	0.37	8.83	0.00	0.00	0.00		* For Amp of Line Bays.
CKT	765kV RAIPUR PS(DURG)-WARDHA-2	LVRD	31-01-2024	20:30:00	31-01-2024	23:59:59	0.15	0.00	0.00	0.00	3.50		* Line kept out on voltage regulation and convert SLR at Durg end as BR.
CKT	765kV RAIPUR PS(DURG)-WARDHA-3			00:00:00		00:00:00	0.52	8.83	0.00	0.00	3.50	98.81	

Standard of Performance data for the month of Jan-2024
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	765kV RAIPUR PS(DURG)-WARDHA-4	LVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	0.00	100.00	* Line H/T as per WRLDC instructions for Voltage Regulation and SLR charged as BR at Durg end on dt 30.11.2023 at 00:41Hrs.
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	765kV SEONI-WARDHA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SEONI-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SOLAPUR-AURANGABAD-1	LVRD	26-01-2024	21:41:00	27-01-2024	11:26:00	0.57	0.00	0.00	0.00	13.75		* Line H/T as per WRLDC instructions for Voltage Regulation and LR has been converted as BR at both end of substation.
CKT	765kV SOLAPUR-AURANGABAD-1	LVRD	22-01-2024	21:22:00	23-01-2024	04:17:00	0.29	0.00	0.00	0.00	6.92		* Line H/T as per WRLDC instruction and converted SLRs as B/R at Solapur end at 22:14 hrs and at Aurangabad end at 21:29hrs for Voltage regulation.* 22.01.2024 21:47:21 INDIA (60020910)* Line H/T as per WRLDC instruction and converted SLRs as B/R at Solapur end at 21:42hrs and at Aurangabad end at 21:29hrs for Voltage regulation.
							0.86	0.00	0.00	0.00	20.67	100.00	
CKT	765kV SOLAPUR-AURANGABAD-2	LVRD	07-01-2024	21:27:00	13-01-2024	11:22:00	5.58	0.00	0.00	0.00	133.92		* Line H/T as per WRLDC instruction and converted SLRs as B/R at Solapur end at 22:14 hrs and at Aurangabad end at 22:21hrs for Voltage regulation.
							5.58	0.00	0.00	0.00	133.92	100.00	
CKT	765kV SOLAPUR-PUNE GIS	GOMD	25-01-2024	19:55:00	27-01-2024	09:39:00	1.57	0.00	0.00	0.00	37.73		* To keep line out of service for Voltage Regulation and convert SLRs as BR at both ends for VR. SLR as BR converts at Pune GIS at 20:21 hrs. and at Solapur end at 20:16Hrs.
CKT	765kV SOLAPUR-PUNE GIS	LVRD	25-01-2024	00:34:00	25-01-2024	08:15:00	0.32	0.00	0.00	0.00	7.68		* Line H/T as per WRLDC instructions for Voltage Regulation and LR has been converted as BR at both end of substation.
CKT	765kV SOLAPUR-PUNE GIS	OSFT	25-01-2024	08:45:00	25-01-2024	19:55:00	0.47	11.17	0.00	0.00	0.00		* Emergency outage availed for rectification of detached jumper sub conductor at location number 163 (R phase)* 02.02.2024 14:23:25 INDIA (60031136)* Emergency outage availed for rectification of detached jumper sub conductor at Loc. No. 163 (R phase) . Line charging attempt taken at 19:28 hrs from Pune GIS end but line tripped due to O/V operated at Solapur end .
							2.36	11.17	0.00	0.00	45.41	98.50	
CKT	765kV SIPAT(NTPC)-BILASPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SIPAT(NTPC)-BILASPUR-2	OMSU	18-01-2024	06:21:00	18-01-2024	10:07:00	0.16	0.00	3.77	0.00	0.00		* Line tripped on Y-ph to Ground Fault due to DT received from Sipat(NTPC) during Auto reclosure dead time. AFAS Single end at Bilaspur: Y-G, FD-14.009km, FC-18.822KA.* 18.01.2024 10:16:52 INDIA (60020904)* Line test charging request mail sent to WRLDC at 06:43 hrs but line charging delayed by NTPC for protection checking at Sipat end.* 02.02.2024 14:40:32 INDIA (60031136)* During tower top patrolling of .loc. 24 heavy bird dropping found on porcelain insulator of Middle phase (Y - phase) Hole and flashover marks found on cc Ring.
CKT	765kV SIPAT(NTPC)-BILASPUR-2	OSFT	19-01-2024	11:29:00	19-01-2024	17:31:00	0.25	6.03	0.00	0.00	0.00		* Emergency outage availed for cleaning of heavy Bird Droppings on Insulator strings at Loc.No.24
							0.41	6.03	3.77	0.00	0.00	99.18	
CKT	765kV WARDHA-AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV WARDHA-AURANGABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV WARDHA-AURANGABAD-3	LVRD	01-01-2024	00:00:01	10-01-2024	12:41:00	9.53	0.00	0.00	0.00	228.68		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR charged as BR at Wardha end
							9.53	0.00	0.00	0.00	228.68	100.00	
CKT	765kV WARDHA-AURANGABAD-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF WARDHA-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF WARDHA-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-01-2024	07:43:00	01-01-2024	20:05:00	0.52	0.00	0.00	0.00	12.37		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	10-01-2024	06:49:00	10-01-2024	23:23:00	0.69	0.00	0.00	0.00	16.57		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	03-01-2024	10:26:00	03-01-2024	22:11:00	0.49	0.00	0.00	0.00	11.75		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	07-01-2024	09:28:00	31-01-2024	23:59:59	24.61	0.00	0.00	0.00	590.53		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	30-01-2024	09:24:00	30-01-2024	18:15:00	0.37	0.00	0.00	0.00	8.85		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	04-01-2024	15:17:00	05-01-2024	01:03:00	0.41	0.00	0.00	0.00	9.77		* SLR H/T as per WRLDC instructions for Voltage Regulation

Standard of Performance data for the month of Jan-2024
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	09-01-2024	07:14:00	09-01-2024	20:29:00	0.55	0.00	0.00	0.00	13.25		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	06-01-2024	08:34:00	06-01-2024	19:34:00	0.46	0.00	0.00	0.00	11.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	08-01-2024	07:34:00	08-01-2024	20:41:00	0.55	0.00	0.00	0.00	13.12		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	14-01-2024	09:53:00	14-01-2024	18:16:00	0.35	0.00	0.00	0.00	8.38		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	15-01-2024	08:41:00	15-01-2024	17:52:00	0.38	0.00	0.00	0.00	9.18		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	12-01-2024	09:29:00	12-01-2024	19:34:00	0.42	0.00	0.00	0.00	10.08		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	02-01-2024	07:40:00	02-01-2024	19:44:00	0.50	0.00	0.00	0.00	12.07		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	13-01-2024	06:51:00	13-01-2024	18:40:00	0.49	0.00	0.00	0.00	11.82		* SLR H/T as per WRLDC instructions for VR
							92.79	0.00	0.00	0.00	2,226.74	100.00	
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	09-01-2024	09:46:00	09-01-2024	23:16:00	0.56	0.00	0.00	0.00	13.50		* SLR H/T as per WRLDC instructions for Voltage Regulation.
							0.56	0.00	0.00	0.00	13.50	100.00	
LNR	240MVAR,SWLR OF SEONI-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF SEONI-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAJNANGAON-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAJNANGAON-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DHARAMJYGARH AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-2 AT KORBA PS	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-1 AT KORBA PS	SVRD	09-01-2024	08:33:00	09-01-2024	22:32:00	0.58	0.00	0.00	0.00	13.98		* SLR H/T as per WRLDC instructions for Voltage Regulation.
							0.58	0.00	0.00	0.00	13.98	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-2 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-1 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DURG-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DURG-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-1 AT PUNE	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for V.R.
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PUNE	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-3 AT PUNE	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-4 AT PUNE	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	50MVAR,SWLR OF PUNE GIS-4 AT PUNE	SVRD	01-01-2024	00:00:01	31-01-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
							62.00	0.00	0.00	0.00	1,488.00	100.00	
LNR	240MVAR,SWLR OF SHOLAPUR AT PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	03-01-2024	07:14:00	03-01-2024	19:22:00	0.51	0.00	0.00	0.00	12.13		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	06-01-2024	09:28:00	06-01-2024	20:56:00	0.48	0.00	0.00	0.00	11.47		* SLR H/T as per WRLDC instructions for VR
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-01-2024	07:40:00	01-01-2024	21:50:00	0.59	0.00	0.00	0.00	14.17		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	13-01-2024	07:19:00	13-01-2024	18:41:00	0.47	0.00	0.00	0.00	11.37		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	09-01-2024	07:12:00	09-01-2024	19:48:00	0.53	0.00	0.00	0.00	12.60		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	16-01-2024	08:32:00	16-01-2024	19:40:00	0.46	0.00	0.00	0.00	11.13		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	08-01-2024	07:10:00	08-01-2024	19:48:00	0.53	0.00	0.00	0.00	12.63		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	07-01-2024	08:55:00	07-01-2024	14:38:00	0.24	0.00	0.00	0.00	5.72		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	11-01-2024	09:57:00	11-01-2024	22:39:00	0.53	0.00	0.00	0.00	12.70		* SLR H/T as per WRLDC instructions for Voltage Regulation

Standard of Performance data for the month of Jan-2024
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	330MVAR_LR OF AURANGABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR_LR OF AURANGABAD-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR_LR OF AURANGABAD-4 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT SHOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE HALL	500MW_BHADRAWATI HVDC BTB POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE HALL	500MW_BHADRAWATI HVDC BTB POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE HALL	POLE1 VALVE HALL_RAIGARH_HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE HALL	POLE2_VALVE HALL_RAIGARH_HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHATAPARA	OSFT	12-01-2024	12:38:00	12-01-2024	17:34:00	0.21	4.93	0.00	0.00	0.00	99.34	* Emergency outage availed for attending hotspot in 210-89C isolator CT side contact
XMER	500MVA,400/220kV ICT-3 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-5 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-6 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2024
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-1 AT MAPUSA	OSPT	07-01-2024	07:52:00	08-01-2024	01:05:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.72	17.22	0.00	0.00	0.00		* AMP works
							0.72	17.22	0.00	0.00	0.00	97.69	
XMER	315MVA,400/220kV ICT-2 AT MAPUSA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT MAPUSA	OSFT	25-01-2024	09:12:00	25-01-2024	10:17:00	0.05	1.08	0.00	0.00	0.00		* During Transfer of ICT # 3, hotspot/sparking observed in Bay 201 (B ph). Considering the emergency ICT # 3 hand tripped.
							0.05	1.08	0.00	0.00	0.00	99.85	
XMER	1500MVA,765/400kV ICT-1 AT PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PUNE	OSPT	29-01-2024	10:51:00	29-01-2024	21:51:00	0.46	11.00	0.00	0.00	0.00		* For AMP work
							0.46	11.00	0.00	0.00	0.00	98.52	
XMER	315MVA,400/220kV ICT-2 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT RAIPUR	OSPT	11-01-2024	06:33:00	23-01-2024	16:58:00	12.43	298.42	0.00	0.00	0.00		* Overhauling work of ICT-1 at Raipur SS.
							12.43	298.42	0.00	0.00	0.00	59.89	
XMER	315MVA,400/220kV ICT-2 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT RAIPUR	OSFT	10-01-2024	11:03:00	10-01-2024	15:27:00	0.18	4.40	0.00	0.00	0.00		* ESD availed for attending hot Spot of R Phase 209 89 L Isolator (Male Female contact) <-&-> 209 52 B Phase Breaker pad
							0.18	4.40	0.00	0.00	0.00	99.41	
XMER	1500MVA,765/400kV ICT-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT SEONI	OSPT	16-01-2024	09:29:00	16-01-2024	19:23:00	0.41	9.90	0.00	0.00	0.00		* For ICT AMP works.
							0.41	9.90	0.00	0.00	0.00	98.67	
XMER	1500MVA,765/400kV ICT-3 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SEONI	OSPT	24-01-2024	09:24:00	24-01-2024	14:35:00	0.22	5.18	0.00	0.00	0.00		* ICT AMP Works
							0.22	5.18	0.00	0.00	0.00	99.30	
XMER	500MVA,400/220kV ICT-3 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT TAMNAR PS	OSPT	02-01-2024	10:24:00	02-01-2024	19:35:00	0.38	9.18	0.00	0.00	0.00		* AMP WROKS
							0.38	9.18	0.00	0.00	0.00	98.77	

Standard of Performance data for the month of Jan-2024
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	1500MVA,765/400kV ICT-3 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT WARDHA	SCSD	29-01-2024	10:42:00	29-01-2024	21:17:00	0.44	0.00	0.00	0.00	10.58		* CSD fine tuning (element shall be taken into/out of service various time)
							0.44	0.00	0.00	0.00	10.58	100.00	