

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifiyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	12-02-2025	09:34:00	12-02-2025	18:42:00	0.38	0.00	0.00	0.00	9.13		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	17-02-2025	07:46:00	17-02-2025	18:33:00	0.45	0.00	0.00	0.00	10.78		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	22-02-2025	08:59:00	22-02-2025	18:22:00	0.39	0.00	0.00	0.00	9.38		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	18-02-2025	07:08:00	18-02-2025	13:19:00	0.26	0.00	0.00	0.00	6.18		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	28-02-2025	09:45:00	28-02-2025	20:30:00	0.45	0.00	0.00	0.00	10.75		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	13-02-2025	08:47:00	13-02-2025	18:29:00	0.40	0.00	0.00	0.00	9.70		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	27-02-2025	07:45:00	27-02-2025	13:45:00	0.25	0.00	0.00	0.00	6.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	24-02-2025	07:07:00	24-02-2025	22:19:00	0.63	0.00	0.00	0.00	15.20		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	25-02-2025	08:47:00	25-02-2025	23:54:00	0.63	0.00	0.00	0.00	15.12		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	11-02-2025	07:25:00	12-02-2025	00:15:00	0.70	0.00	0.00	0.00	16.83		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	15-02-2025	10:07:00	16-02-2025	21:07:00	1.46	0.00	0.00	0.00	35.00		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	08-02-2025	09:37:00	08-02-2025	19:13:00	0.40	0.00	0.00	0.00	9.60		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	09-02-2025	07:25:00	09-02-2025	21:15:00	0.58	0.00	0.00	0.00	13.83		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	10-02-2025	05:39:00	10-02-2025	18:30:00	0.54	0.00	0.00	0.00	12.85		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	03-02-2025	09:21:00	03-02-2025	20:09:00	0.45	0.00	0.00	0.00	10.80		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	04-02-2025	09:09:00	04-02-2025	20:02:00	0.45	0.00	0.00	0.00	10.88		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	05-02-2025	09:17:00	05-02-2025	21:34:00	0.51	0.00	0.00	0.00	12.28		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	01-02-2025	10:37:00	01-02-2025	22:25:00	0.49	0.00	0.00	0.00	11.80		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	06-02-2025	08:39:00	07-02-2025	22:14:00	1.57	0.00	0.00	0.00	37.58		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	19-02-2025	07:40:00	19-02-2025	18:24:00	0.45	0.00	0.00	0.00	10.73		* BR H/T as per WRLDLC instructions for VR
							67.44	0.00	0.00	0.00	1,618.42	100.00	
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	20-02-2025	06:54:00	28-02-2025	23:59:59	8.71	0.00	0.00	0.00	209.10		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	10-02-2025	09:34:00	28-02-2025	23:59:59	18.60	0.00	0.00	0.00	446.43		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	22-02-2025	10:15:00	23-02-2025	22:12:00	1.50	0.00	0.00	0.00	35.95		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	19-02-2025	09:58:00	19-02-2025	18:16:00	0.35	0.00	0.00	0.00	8.30		* BR H/T as per WRLDLC instructions for Vo
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	20-02-2025	06:54:00	20-02-2025	18:26:00	0.48	0.00	0.00	0.00	11.53		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	01-02-2025	07:42:00	01-02-2025	21:59:00	0.60	0.00	0.00	0.00	14.28		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	07-02-2025	09:33:00	08-02-2025	20:26:00	1.45	0.00	0.00	0.00	34.88		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	13-02-2025	09:55:00	13-02-2025	19:57:00	0.42	0.00	0.00	0.00	10.03		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	12-02-2025	07:32:00	12-02-2025	20:47:00	0.55	0.00	0.00	0.00	13.25		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	03-02-2025	10:06:00	03-02-2025	20:46:00	0.44	0.00	0.00	0.00	10.67		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	17-02-2025	09:28:00	17-02-2025	21:33:00	0.50	0.00	0.00	0.00	12.08		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	14-02-2025	08:32:00	14-02-2025	18:35:00	0.42	0.00	0.00	0.00	10.05		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	21-02-2025	07:47:00	21-02-2025	19:05:00	0.47	0.00	0.00	0.00	11.30		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	27-02-2025	10:23:00	27-02-2025	20:23:00	0.42	0.00	0.00	0.00	10.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	26-02-2025	08:29:00	26-02-2025	18:57:00	0.44	0.00	0.00	0.00	10.47		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	18-02-2025	07:38:00	18-02-2025	20:45:00	0.55	0.00	0.00	0.00	13.12		* BR H/T as per WRLDLC instructions for Voltage Regulation.
							81.90	0.00	0.00	0.00	2,205.44	100.00	
BSR	50MVAR, BUS REACTOR-1 AT BHADRAWATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-2 AT BHADRAWATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT BHATAPARA	SVRD	20-02-2025	17:00:00	28-02-2025	23:59:59	8.29	0.00	0.00	0.00	199.00		* BR H/T as per WRLDLC instructions for VR
							8.29	0.00	0.00	0.00	199.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDLC instructions for Voltage Regulation
							56.00	0.00	0.00	0.00	1,344.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-2 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-3 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	15-02-2025	11:07:00	15-02-2025	17:10:00	0.25	0.00	0.00	0.00	6.05		* BR H/T as per WRLDLC instructions for VR
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	06-02-2025	10:07:00	09-02-2025	21:37:00	3.48	0.00	0.00	0.00	83.50		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-02-2025	09:48:00	02-02-2025	02:08:00	0.68	0.00	0.00	0.00	16.33		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	21-02-2025	10:19:00	23-02-2025	20:27:00	2.42	0.00	0.00	0.00	58.13		* BR H/T as per WRLDLC instructions for VR
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	19-02-2025	09:58:00	20-02-2025	22:18:00	1.51	0.00	0.00	0.00	36.33		* BR H/T as per WRLDLC instructions for Vo
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDLC instructions for VR
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDLC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDLC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
							120.34	0.00	0.00	0.00	2,888.34	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	12-02-2025	09:21:00	12-02-2025	20:46:00	0.48	0.00	0.00	0.00	11.42		* BR H/T as per WRLDLC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	08-02-2025	09:02:00	28-02-2025	23:59:59	20.62	0.00	0.00	0.00	494.97		* BR H/T as per WRLDLC instructions for Voltage Regulation.

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Vo
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-02-2025	09:59:00	07-02-2025	11:30:00	6.06	0.00	0.00	0.00	145.52		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	OSPT	07-02-2025	11:30:00	08-02-2025	01:49:00	0.60	14.32	0.00	0.00	0.00		* For Reactor AMP Works
							559.76	14.32	0.00	0.00	13,419.91	97.87	
BSR	80MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KOTRA PS	SCSD	01-02-2025	00:00:01	01-02-2025	15:49:00	0.66	0.00	0.00	0.00	15.82		* Outage. availed for ICT-5 Bay Constructions Works.
							0.66	0.00	0.00	0.00	15.82	100.00	
BSR	240MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	22-02-2025	10:16:00	28-02-2025	23:59:59	6.57	0.00	0.00	0.00	157.73		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-02-2025	10:01:00	01-02-2025	19:53:00	0.41	0.00	0.00	0.00	9.87		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	05-02-2025	09:10:00	05-02-2025	21:29:00	0.51	0.00	0.00	0.00	12.32		* BR H/T as per WRLDC instructions for Vo
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	11-02-2025	08:49:00	12-02-2025	19:59:00	1.47	0.00	0.00	0.00	35.17		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	06-02-2025	09:58:00	07-02-2025	17:24:00	1.31	0.00	0.00	0.00	31.43		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	13-02-2025	10:36:00	13-02-2025	20:00:00	0.39	0.00	0.00	0.00	9.40		* BR H/T as per WRLDC instructions for VR
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	03-02-2025	10:12:00	03-02-2025	20:41:00	0.44	0.00	0.00	0.00	10.48		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	18-02-2025	10:28:00	18-02-2025	22:26:00	0.50	0.00	0.00	0.00	11.97		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	19-02-2025	09:38:00	19-02-2025	23:07:00	0.56	0.00	0.00	0.00	13.48		* BR H/T as per WRLDC instructions for Vo
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	18-02-2025	10:28:00	18-02-2025	23:59:59	10.56	0.00	0.00	0.00	253.53		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Power Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	21-02-2025	10:26:00	21-02-2025	21:14:00	0.45	0.00	0.00	0.00	10.80		* BR H/T as per WRLDC instructions for VR
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	20-02-2025	10:51:00	20-02-2025	22:14:00	0.47	0.00	0.00	0.00	11.38		* BR H/T as per WRLDC instructions for Vo
							247.64	0.00	0.00	0.00	5,943.56	100.00	
BSR	63MVAR, BUS REACTOR-1 AT NAVI MUMBAI	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
							28.00	0.00	0.00	0.00	672.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	19-02-2025	08:54:00	19-02-2025	19:55:00	0.46	0.00	0.00	0.00	11.02		* BR H/T as per WRLDC instructions for Vo
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	09-02-2025	07:34:00	09-02-2025	20:32:00	0.54	0.00	0.00	0.00	12.97		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	08-02-2025	08:34:15	08-02-2025	21:35:00	0.54	0.00	0.00	0.00	13.01		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-02-2025	09:50:00	01-02-2025	18:07:00	0.35	0.00	0.00	0.00	8.28		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	13-02-2025	08:49:00	13-02-2025	19:53:00	0.46	0.00	0.00	0.00	11.07		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	12-02-2025	07:31:00	12-02-2025	18:16:00	0.45	0.00	0.00	0.00	10.75		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	04-02-2025	09:19:00	04-02-2025	19:46:00	0.44	0.00	0.00	0.00	10.45		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	02-02-2025	09:34:00	02-02-2025	15:15:00	0.24	0.00	0.00	0.00	5.68		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	10-02-2025	07:32:00	10-02-2025	20:10:00	0.53	0.00	0.00	0.00	12.63		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	07-02-2025	07:37:00	07-02-2025	18:11:00	0.44	0.00	0.00	0.00	10.57		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	03-02-2025	09:25:00	03-02-2025	19:43:00	0.43	0.00	0.00	0.00	10.30		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	05-02-2025	09:05:00	05-02-2025	20:11:00	0.46	0.00	0.00	0.00	11.10		* BR H/T as per WRLDC instructions for Vo

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	14-02-2025	08:35:00	14-02-2025	18:12:00	0.40	0.00	0.00	0.00	9.62		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	17-02-2025	07:37:00	17-02-2025	21:43:00	0.59	0.00	0.00	0.00	14.10		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	15-02-2025	08:45:00	15-02-2025	18:16:00	0.40	0.00	0.00	0.00	9.52		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	11-02-2025	07:30:00	11-02-2025	18:47:00	0.47	0.00	0.00	0.00	11.28		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	26-02-2025	08:26:00	26-02-2025	19:54:00	0.48	0.00	0.00	0.00	11.47		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	22-02-2025	08:56:00	22-02-2025	21:10:00	0.51	0.00	0.00	0.00	12.23		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	23-02-2025	09:57:00	23-02-2025	19:51:00	0.41	0.00	0.00	0.00	9.90		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	24-02-2025	08:03:00	24-02-2025	20:04:00	0.50	0.00	0.00	0.00	12.02		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	21-02-2025	09:22:00	21-02-2025	21:16:00	0.50	0.00	0.00	0.00	11.90		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	28-02-2025	07:38:00	28-02-2025	20:08:00	0.52	0.00	0.00	0.00	12.50		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	25-02-2025	09:51:00	25-02-2025	19:33:00	0.40	0.00	0.00	0.00	9.70		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	27-02-2025	07:57:00	27-02-2025	20:14:00	0.51	0.00	0.00	0.00	12.28		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	20-02-2025	06:52:00	20-02-2025	18:34:00	0.49	0.00	0.00	0.00	11.70		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	18-02-2025	09:55:00	18-02-2025	20:16:00	0.43	0.00	0.00	0.00	10.35		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	06-02-2025	08:46:00	28-02-2025	23:59:59	22.64	0.00	0.00	0.00	543.23		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	20-02-2025	06:52:00	28-02-2025	23:59:59	8.71	0.00	0.00	0.00	209.13		* BR H/T as per WRLDG instructions for Voltage Regulation.
							267.30	0.00	0.00	0.00	6,414.76	100.00	
BSR	63MVAR, BUS REACTOR-1 AT PARLI	SVRD	25-02-2025	10:24:00	28-02-2025	23:59:59	3.57	0.00	0.00	0.00	85.60		* BR H/T as per WRLDG instructions for Voltage Regulation.
							3.57	0.00	0.00	0.00	85.60	100.00	
BSR	125MVAR, BUS REACTOR-2 AT PARLI	SVRD	24-02-2025	10:48:00	28-02-2025	23:59:59	4.55	0.00	0.00	0.00	109.20		* BR H/T as per WRLDG instructions for Voltage Regulation.
							4.55	0.00	0.00	0.00	109.20	100.00	
BSR	50MVAR, BUS REACTOR-1 AT PUNE	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
							28.00	0.00	0.00	0.00	672.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	16-02-2025	09:06:04	16-02-2025	13:50:00	0.20	0.00	0.00	0.00	4.73		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	19-02-2025	09:24:00	19-02-2025	18:13:00	0.37	0.00	0.00	0.00	8.82		* BR H/T as per WRLDG instructions for Vo
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	20-02-2025	10:01:00	20-02-2025	18:17:00	0.34	0.00	0.00	0.00	8.27		* BR H/T as per WRLDG instructions for Vo
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	08-02-2025	08:39:00	08-02-2025	18:58:00	0.43	0.00	0.00	0.00	10.32		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	05-02-2025	08:57:00	05-02-2025	18:19:00	0.39	0.00	0.00	0.00	9.37		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-02-2025	10:11:00	01-02-2025	18:07:00	0.33	0.00	0.00	0.00	7.93		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	07-02-2025	08:51:00	07-02-2025	18:06:00	0.39	0.00	0.00	0.00	9.25		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	12-02-2025	09:15:00	12-02-2025	18:26:00	0.38	0.00	0.00	0.00	9.18		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	11-02-2025	08:53:00	11-02-2025	18:51:00	0.42	0.00	0.00	0.00	9.97		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	13-02-2025	08:45:00	13-02-2025	18:09:00	0.39	0.00	0.00	0.00	9.40		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	03-02-2025	09:16:00	05-02-2025	02:53:00	1.73	0.00	0.00	0.00	41.62		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	10-02-2025	08:28:00	10-02-2025	18:10:00	0.40	0.00	0.00	0.00	9.70		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	06-02-2025	08:37:00	06-02-2025	18:22:00	0.41	0.00	0.00	0.00	9.75		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	17-02-2025	07:40:00	17-02-2025	17:52:00	0.43	0.00	0.00	0.00	10.20		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	15-02-2025	08:48:00	15-02-2025	18:19:00	0.40	0.00	0.00	0.00	9.52		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	14-02-2025	08:30:00	14-02-2025	18:20:00	0.41	0.00	0.00	0.00	9.83		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	23-02-2025	08:58:00	23-02-2025	15:00:00	0.25	0.00	0.00	0.00	6.03		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	25-02-2025	09:44:00	25-02-2025	19:29:00	0.41	0.00	0.00	0.00	9.75		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	21-02-2025	09:14:00	21-02-2025	18:17:00	0.38	0.00	0.00	0.00	9.05		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	26-02-2025	10:42:00	26-02-2025	13:17:00	0.11	0.00	0.00	0.00	2.58		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	28-02-2025	09:38:00	28-02-2025	20:12:00	0.44	0.00	0.00	0.00	10.57		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	22-02-2025	09:32:00	22-02-2025	18:07:00	0.36	0.00	0.00	0.00	8.58		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	27-02-2025	07:44:00	27-02-2025	13:29:00	0.24	0.00	0.00	0.00	5.75		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	18-02-2025	08:25:00	18-02-2025	18:18:00	0.41	0.00	0.00	0.00	9.88		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
							234.02	0.00	0.00	0.00	5,616.05	100.00	
BSR	63MVAR, BUS REACTOR-1 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT RAIPUR	SVRD	22-02-2025	17:17:00	28-02-2025	23:59:59	6.28	0.00	0.00	0.00	150.72		* BR H/T as per WRLDG instructions for Voltage Regulation.
							6.28	0.00	0.00	0.00	150.72	100.00	
BSR	125MVAR, BUS REACTOR-2 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	05-02-2025	09:34:00	05-02-2025	18:37:00	0.38	0.00	0.00	0.00	9.05		* BR H/T as per WRLDG instructions for Vo
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	10-02-2025	10:53:00	10-02-2025	18:00:00	0.30	0.00	0.00	0.00	7.12		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	25-02-2025	10:10:00									

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifiyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	29.81	0.00	0.00	0.00	715.16	100.00	
							28.00	0.00	0.00	0.00	672.00	100.00	* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-2 AT SOLAPUR	LVRD	10-02-2025	09:30:00	10-02-2025	17:33:00	0.34	0.00	0.00	0.00	8.05		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT SOLAPUR	SVRD	21-02-2025	08:24:00	21-02-2025	19:06:00	0.45	0.00	0.00	0.00	10.70		* BR H/T as per WRLDC instructions for VR
							0.79	0.00	0.00	0.00	18.75	100.00	
BSR	240MVAR, BUS REACTOR-1 AT TAMNAR PS	OSPT	10-02-2025	12:55:00	10-02-2025	17:41:00	0.20	4.77	0.00	0.00	0.00		* for Spare rotation (normalization) works.
BSR	240MVAR, BUS REACTOR-1 AT TAMNAR PS	SCSD	10-02-2025	09:55:00	10-02-2025	12:55:00	0.13	0.00	0.00	0.00	3.00		Spare unit normalization (Spare unit will be taken out of service <-<->* B-ph unit will be taken back into service). Previous rotation* carried out on 28.12.2024. Outage Duration after 03hrs.
							0.33	4.77	0.00	0.00	3.00	99.29	* for Spare rotation (normalization) works.
BSR	50MVAR, BUS REACTOR-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-2 AT WARDHA	SVRD	20-02-2025	15:50:00	20-02-2025	19:24:00	0.15	0.00	0.00	0.00	3.57		* BR H/T as per WRLDC instructions for VR
BSR	63MVAR, BUS REACTOR-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KORBA(CSEB)-BUDDHIPADAR(OPTCL)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AKOLA(MSETCL)-AURANGABAD-1	OSFT	05-02-2025	14:43:00	05-02-2025	20:21:00	0.24	5.63	0.00	0.00	0.00		* Line outage taken to take Non SLR into service at Akola SS.c
CKT	400kV AKOLA(MSETCL)-AURANGABAD-2	OSFT	10-02-2025	15:12:00	10-02-2025	18:33:00	0.14	3.35	0.00	0.00	0.00		* ESD availed on 400kV Akola - Aurangabad#2 To attend the heavy oil leakages of line reactor from multiple points.
CKT	400kV AKOLA(MSETCL)-AURANGABAD-2	OSFT	24-02-2025	16:49:00	24-02-2025	22:02:00	0.22	5.22	0.00	0.00	0.00		* Line outage availed for taking Non-Switchable LR in to service at Akola(MSTCL) end.
							0.36	8.57	0.00	0.00	0.00	98.73	
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-2	LPRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for Power Regulation.
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-1	OMSU	10-02-2025	09:25:00	10-02-2025	23:47:00	0.60	0.00	14.37	0.00	0.00		* LBB ABB/RAICA Model relay will be upgraded to Numerical relay under under technology upgradation AT MSETCL END
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-2	OMSU	12-02-2025	11:22:00	12-02-2025	20:45:00	0.39	0.00	9.38	0.00	0.00		* LBB ABB/RAICA Model relay will be upgraded to Numerical relay under under technology upgradation AT MSETCL END.
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-3	OMSU	17-02-2025	10:42:00	17-02-2025	20:54:00	0.43	0.00	10.20	0.00	0.00		* LBB ABB/RAICA Model relay will be upgraded to Numerical relay under under technology upgradation AT MSETCL END
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-4	OMSU	21-02-2025	10:05:00	21-02-2025	21:01:00	0.46	0.00	10.93	0.00	0.00		* LBB ABB/RAICA Model relay will be upgraded to Numerical relay under under technology upgradation AT MSETCL END
CKT	400kV BHADRAWATI-DHARIWAL(CESC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-PARLI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHATAPARA-BHILA(CSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHILAI(CSEB)-BHADRAWATI-2	LCSD	20-02-2025	09:52:00	23-02-2025	21:55:00	3.50	0.00	0.00	0.00	84.05		* For Construction Work of 400 KV D/C (QUAD) RAIPUR POOL - DHAMTARI TRANSMISSION LINE
CKT	400kV BHILAI(CSEB)-KORADI(MSEB)-1	LCSD	20-02-2025	11:00:00	23-02-2025	22:06:00	3.46	0.00	0.00	0.00	83.10	100.00	* For Construction Work of 400 KV D/C (QUAD) RAIPUR POOL - DHAMTARI TRANSMISSION LINE
CKT	400kV DHARIWAL(CESC)-PARLI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHARSUGUDA-RAIGARH-1	OSPT	22-02-2025	08:00:00	22-02-2025	19:32:00	0.48	11.53	0.00	0.00	0.00		* Outage availed for Replacement of all defective 400kV 160KN porcelain insulator in 400KV-JHARSUGUDA-RAIGARH-1 Daily
CKT	400kV JHARSUGUDA-RAIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	98.28	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHARSUGUDA-RAIGARH-3	LCSD	20-02-2025	08:46:00	20-02-2025	22:04:00	0.55	0.00	0.00	0.00	13.30		* For Reconductoring work in 400KV JHARSUGUDA-ROURKELA CKT#4 availed by Odisha Region.
CKT	400kV JHARSUGUDA-RAIGARH-3	LCSD	18-02-2025	09:56:00	18-02-2025	20:13:00	0.43	0.00	0.00	0.00	10.28		* Reconductoring work in 400KV JHARSUGUDA-ROURKELA CKT#4 availed by Odisha Region.
CKT	400kV JHARSUGUDA-RAIGARH-3	LCSD	19-02-2025	08:19:00	19-02-2025	20:33:00	0.51	0.00	0.00	0.00	12.23		* Reconductoring work in 400KV JHARSUGUDA-ROURKELA CKT#4 availed by Odisha Region.
CKT	400kV JHARSUGUDA-RAIGARH-3	OMSU	24-02-2025	09:26:00	24-02-2025	17:13:00	0.32	0.00	7.78	0.00	0.00		* Outage availed for reconductoring work .
CKT	400kV JHARSUGUDA-RAIGARH-3	LCSD	21-02-2025	08:14:00	21-02-2025	21:28:00	0.55	0.00	0.00	0.00	13.23		* For Reconductoring work in 400KV JHARSUGUDA-ROURKELA CKT#4 availed by Odisha Region.
							2.36	0.00	7.78	0.00	49.04	100.00	
CKT	400kV JHARSUGUDA-RAIGARH-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLHAPUR GIS-MAPUSA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLHAPUR GIS-MAPUSA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLHAPUR(MSETCL)-KOLHAPUR GIS-1	LART	19-02-2025	06:06:00	19-02-2025	06:06:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on B ph to E fault. Fault details at Kolhapur GIS end :- Main1 : FD- 21.7km, FC-4.568kA, Main 2 :- FD- 19.5 KM , FC-4.55 KA . Fault details at Kolhapur MSETCL end :- Main 2 :- FD- 15.8 KM , FC- 9.4 KA. Fault is in Kolhapur TLM jurisdiction. Faulty phase position - Top* 27.02.2025 18:51:16 INDIA (60001973)* The Flashover marks found on top phase CC Ring and hardware fitting/arcing horn on cross arm at Loc No. 72.
CKT	400kV KOLHAPUR(MSETCL)-KOLHAPUR GIS-1	LART	19-02-2025	06:22:00	19-02-2025	06:22:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on B ph to E fault. Fault details at Kolhapur GIS end :- Main1 : FD- 20.8km, FC-4.67kA, Main 2 :- FD- 19.7 KM , FC-4.6 KA . Fault details at Kolhapur MSETCL end :- Main 2 :- FD- 16.5 KM , FC- 8.8 KA. Fault is in Kolhapur TLM jurisdiction. Faulty phase position - Top* 27.02.2025 18:54:54 INDIA (60001973)* The Flashover marks found on top phase CC Ring and hardware fitting/arcing horn on cross arm at Loc No. 72.* (Loc No-72)TFR in ohms Leg A-3.3,Leg B-3.5,Leg C-3.4,Leg D-3.0
CKT	400kV KOLHAPUR(MSETCL)-KOLHAPUR GIS-1	SCSD	12-02-2025	17:15:00	13-02-2025	06:42:00	0.56	0.00	0.00	0.00	13.45		* For LBB protection relay retrofitting works.
							0.56	0.00	0.00	0.00	13.45	100.00	
CKT	400kV KOLHAPUR(MSETCL)-KOLHAPUR GIS-2	LCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-M= S-KOLHAPUR GIS-1
CKT	400kV KOLHAPUR(MSETCL)-KOLHAPUR GIS-2	LART	19-02-2025	06:07:00	19-02-2025	06:07:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on R ph to E fault. Fault details at Kolhapur GIS end :- Main1 : FD- 21.4km, FC-4.3kA, Main 2 :- FD- 20.6 KM , FC-4.59 KA. Kolhapur MSETCL end :- Main 1 :- FD- 12.59 KM , FC- 9.24 KA ; Main 2 :- FD- 14.16 KM , FC- 9.23 KA. Fault is in Kolhapur TLM jurisdiction. Faulty phase position -Top* 27.02.2025 18:55:49 INDIA (60001973)* The Flashover marks found on top phase CC Ring and hardware fitting/arcing horn on cross arm at Loc No. 72.* t Loc No. 72.* (Loc No-72)TFR in ohms Leg A-3.3,Leg B-3.5,Leg C-3.4,Leg D-3.0

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV KOLHAPUR(MSETCL)-KOLHAPUR GIS-2	LART	19-02-2025	06:08:00	19-02-2025	06:08:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on Y ph to E fault. Fault details at Kolhapur GIS end :- Main1 : FD- 19.7km, FC-4.5kA, Main 2 :- FD- 19.8 KM , FC-4.52 KA at Kolhapur MSETCL end :- Main 1 :- FD- 14.18 KM , FC- 8.73 KA ; Main 2 :- FD- 11.06 KM , FC- 8.62 KA. Fault is in Kolhapur TLM jurisdiction. Faulty phase position-Middle* 25.02.2025 18:40:04 INDIA (60001973)* The fault for Auto reclosure of 400KV Kolhapur-Kolhapur ckt-02 has been found to be flash over mark on tower Location No. 068. The flash over mark found on top phase cc ring and hardware fittings/arcing horn on cross arm,due to foggy weather condition occurred in that area.* (Loc No-68)TFR in ohms Leg A-10.6,Leg B-9.9,Leg C-6.8,Leg D-6.7
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	400kV KORBA(NTPC)-BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KORBA(NTPC)-BHILAI(CSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KORBA(NTPC)-BHILAI(CSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KORBA(NTPC)-BIRSINGHPUR(MPGENCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KORBA(NTPC)-BIRSINGHPUR(MPGENCO)-2	OSPD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* For LILO Interconnection at BALCO Switchyard as per 2nd meeting of WRPC Dated: 04/09/2020. A/R in Non-Auto mode of 400kV Korba(NTPC)-Birsingpur Ckt-1 is required during the above line outage.
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	400kV KORBA(NTPC)-KORBA(CSEB)-1	OSPD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Outage availed By NTPC
CKT	400kV KORBA(NTPC)-KORBA(CSEB)-1	LPRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Opened to control fault level at NTPC Korba
							56.00	0.00	0.00	0.00	1,344.00	100.00	
CKT	400kV KORBA(NTPC)-RAIPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KORBA(NTPC)-RAIPUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KORBA(NTPC)-SIPAT(NTPC)	OSFD	07-02-2025	12:40:00	07-02-2025	19:30:00	0.29	0.00	0.00	0.00	6.83		* Emergency outage availed by Korba NTPC for cutting of tree below the tower as tree height is nearly 3 to 5 meter below sipat line.
							0.29	0.00	0.00	0.00	6.83	100.00	
CKT	400kV KORADI(MSEB)-SATPURA(MPPTCL)	OMSU	13-02-2025	21:10:00	13-02-2025	23:26:00	0.09	0.00	2.27	0.00	0.00		* For AMP of Line Bay, Line was charged from Koradi at 2110hrs (WRLDC code 02/1781) but not synchronised at Sami.
CKT	400kV KORADI(MSEB)-SATPURA(MPPTCL)	OSPT	12-02-2025	11:34:00	12-02-2025	21:10:00	0.40	9.60	0.00	0.00	0.00		* For AMP of Line Bay at Koradi End.
							0.49	9.60	2.27	0.00	0.00	98.57	
CKT	400kV LARA(NTPC)-CHAMPA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LARA(NTPC)-CHAMPA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LARA(NTPC)-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LARA(NTPC)-KOTRA PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MAUDA(NTPC)-WARDHA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MAUDA(NTPC)-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PADGHE GIS-KUDUS(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PADGHE GIS-KUDUS(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PARLI(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PARLI(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PUNE GIS-1	LCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Indigrid requested for outage of lines for connecting the LILO with Kallam substation
CKT	400kV PARLI-PUNE GIS-1	OSPT	27-02-2025	09:59:00	27-02-2025	21:22:00	0.47	11.38	0.00	0.00	0.00		* Outage of 400KV Pune GIS- Kallam-1 line (LILO of 400KV Parli - Pune GIS -1) for AMP of LR at Pune GIS.
							28.47	11.38	0.00	0.00	672.00	98.31	
CKT	400kV PARLI-PUNE GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE-PUNE GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE-PUNE GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for Power Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for Power regulation
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for Power Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for Power Regulation
							112.00	0.00	0.00	0.00	2,688.00	100.00	
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* "Line H/T as per WRLDC instructions for Power flow Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	SCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* For construction works of upcoming ICT-3.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	SCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* For Inter connection, Bus bar Stability test under construction project of For Extension of 765/400/220kV Pune (Shikrapur) GIS substation under Western Region Expansion Scheme – XXVI (WRES-XXVI).)
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for voltage Regulation only at Aurangabad (Waluj) end. Line is idle charge from Pune-GIS end. (PLCC at both ends are NIS)
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	OSFD	20-02-2025	20:52:00	20-02-2025	23:49:00	0.12	0.00	0.00	0.00	2.95		* Emergency outage availed by Adani for removing tarpaulin in span 11 ~ 112 and keep AR of Ckt-1 in NA mode.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	20-02-2025	23:49:00	28-02-2025	23:59:59	8.01	0.00	0.00	0.00	192.18		* Line kept out as per WRLDC instructions for Power Regulation only at Aurangabad (Waluj) end. Line is idle charge from Pune-GIS end. (PLCC at both ends are NIS)
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	28-02-2025	19:54:00	28-02-2025	23:59:59	0.17	0.00	0.00	0.00	4.10		* Line H/T per WRLDC instructions for Power Regulation.
							120.30	0.00	0.00	0.00	2,887.23	100.00	
CKT	400kV PUNE GIS-PUNE-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE GIS-PUNE-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIGARH-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIGARH-KOTRA PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHADRAWATI-1	LCSD	20-02-2025	10:16:00	23-02-2025	21:00:00	3.45	0.00	0.00	0.00	82.73		* For Construction Work of 400 KV D/C (QUAD) RAIPUR POOL - DHAMTARI TRANSMISSION LINE
							3.45	0.00	0.00	0.00	82.73	100.00	
CKT	400kV RAIPUR-BHADRAWATI-2	LCSD	28-02-2025	09:50:00	28-02-2025	23:59:59	0.59	0.00	0.00	0.00	14.17		* For Construction Work of 400 KV D/C (QUAD) RAIPUR POOL - DHAMTARI TRANSMISSION LINE

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV RAIPUR-BHADRAWATI-3	LCSD	28-02-2025	09:54:00	28-02-2025	23:59:59	0.59	0.00	0.00	0.00	14.17	100.00	* For Construction Work of 400 KV D/C (QUAD) RAIPUR POOL - DHAMTARI TRANSMISSION LINE
							0.59	0.00	0.00	0.00	14.10	100.00	
CKT	400kV RAIPUR-BHILAI(CSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-1	LPRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRDLC instructions for Power Regulation .
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	400kV RAIPUR-RAIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIPUR PS(DURG)-1	LCSD	10-02-2025	09:27:00	12-02-2025	19:51:00	2.43	0.00	0.00	0.00	58.40		* For Construction Work of 400 KV D/C (QUAD) RAIPUR POOL - DHAMTARI TRANSMISSION LINE
							2.43	0.00	0.00	0.00	58.40	100.00	
CKT	400kV RAIPUR-RAIPUR PS(DURG)-2	LCSD	10-02-2025	09:08:00	12-02-2025	19:50:00	2.45	0.00	0.00	0.00	58.70		* For Construction Work of 400 KV D/C (QUAD) RAIPUR POOL - DHAMTARI TRANSMISSION LINE
							2.45	0.00	0.00	0.00	58.70	100.00	
CKT	400kV RAIPUR-WARDHA-1	LCSD	17-02-2025	15:24:00	19-02-2025	17:34:00	2.09	0.00	0.00	0.00	50.17		* 400 kV Raipur Pool Dhamtari line stringing work (DIA to be closed after opening line isolator at Raipur end)
							2.09	0.00	0.00	0.00	50.17	100.00	
CKT	400kV RAIPUR-WARDHA-2	LCSD	17-02-2025	15:26:00	19-02-2025	17:01:00	2.07	0.00	0.00	0.00	49.58		* 400 kV Raipur Pool Dhamtari line stringing work (DIA to be closed after opening line isolator at Raipur end)
CKT	400kV RAIPUR-WARDHA-2	OMSU	03-02-2025	12:37:00	03-02-2025	14:28:00	0.08	0.00	1.85	0.00	0.00		* Line tripped on R-G fault. Fault details at Wardha: R-G, 5.11KA, 75.47km(AFAS). At Raipur: M1: R-G, 332km, 1.403KA, M2: R-G, 318km, 1.35KA.* 25.02.2025 18:30:58 INDIA (60001973)* Fire was observed below the line conductor of span no.801-802 due to crop waste burning and black marks found in bottom conductor.
							2.15	0.00	1.85	0.00	49.58	100.00	
CKT	400kV RANCHI-SIPAT(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RANCHI-SIPAT(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-1	LCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Reconductoring works.
							0.45	0.00	0.00	0.00	10.85		
CKT	400kV ROURKELA-JHARSUGUDA-1	LCSD	14-02-2025	09:03:00	14-02-2025	19:54:00	0.49	0.00	0.00	0.00	11.67		* for reconductoring work in 400KV Jharsuguda-Rourkela # 3 <(>&<)> 4
							28.94	0.00	0.00	0.00	694.52	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-2	LART	20-02-2025	17:04:00	20-02-2025	17:04:00	0.00	0.00	0.00	0.00	0.00		* AR successful occured at 17:04 hrs on 20.02.2025* The fault details are as follows* Jharsuguda End: YG,7.794KA,44.48kms* Rourkela End: YG,3.941 kA,100.819 kms
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-3	LCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Reconductoring works
							28.00	0.00	0.00	0.00	672.00		
CKT	400kV ROURKELA-JHARSUGUDA-3	LCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* for reconductoring work on continuous basis
							56.00	0.00	0.00	0.00	1,344.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-4	LCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* for reconductoring work on continuous basis
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	400kV SEONI-KIRNAPUR(MPTCL)	OSPD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* 400KV Seoni Kimapur Line approved outage availed by MPTCL.
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	400kV SEONI-SATPURA(MPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-1	LCSD	09-02-2025	10:39:00	28-02-2025	23:59:59	19.56	0.00	0.00	0.00	469.35		* For NHAI Diversion work under Bharatmala Pariyojana
							19.56	0.00	0.00	0.00	469.35	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-2	LCSD	09-02-2025	10:41:00	28-02-2025	23:59:59	19.56	0.00	0.00	0.00	469.32		* For NHAI Diversion work under Bharatmala Pariyojana
							19.56	0.00	0.00	0.00	469.32	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-3	OMSU	08-02-2025	13:06:00	28-02-2025	23:59:59	20.45	0.00	490.90	0.00	0.00		* Line H/T to facilitate to attend tie bay CB spring discharge lower alarm at Sipat end.
							20.45	0.00	490.90	0.00	0.00	100.00	
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AKOLA(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AKOLA(MSETCL)-2	OSFD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Emergency line outage availed by MSTCL for attending 412 89B (R Phase) Isolator operating mechanism <(>&<)> misalignment issue at 400 kV Akola SS.
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	400kV WARDHA-AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AURANGABAD-2	OSFT	18-02-2025	16:26:00	18-02-2025	19:30:00	0.13	3.07	0.00	0.00	0.00		* ESD for rectification of Gantry to BPI jumper drop burned and hanging in 400 kv Wardha Aurangabad ckt #2 Y-phase at Aurangabad SS.
							0.13	3.07	0.00	0.00	0.00	99.54	
CKT	400kV WARDHA-WARORA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-WARORA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARORA-PARLI-1	OSPT	10-02-2025	08:20:00	11-02-2025	07:51:00	0.98	23.52	0.00	0.00	0.00		* for AMP work and Cable replacement work of LR at Parli 400 substation
							0.98	23.52	0.00	0.00	0.00	96.50	
CKT	400kV WARORA-PARLI-2	OSPT	17-02-2025	08:15:00	17-02-2025	21:08:00	0.54	12.88	0.00	0.00	0.00		* For Line Equipments AMP Work
							0.54	12.88	0.00	0.00	0.00	98.08	
CKT	765kV AURANGABAD-PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV AURANGABAD-PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BILASPUR-DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BILASPUR-SEONI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	765KV BILASPUR-SEONI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV CHAMPA-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV CHAMPA-RAIPUR PS(DURG)-1	LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instruction and SLR at Durg PS is converted as BR at 04:02hrs for Voltage regulation.
CKT	765KV CHAMPA-RAIPUR PS(DURG)-1	LPRD	01-02-2025	00:00:01	05-02-2025	07:32:00	4.31	0.00	0.00	0.00	103.53		* Line H/T as per WRLDC instructions for Power Regulation.
CKT	765KV CHAMPA-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV CHAMPA-DHARAMJAYGARH-1	LART	12-02-2025	14:38:00	12-02-2025	14:38:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on R-G fault. Fault details at Dharamjaygarh end : Main I :- FD-56.471km, FC-11.138KA Main II :- FD-56.480km,FC-11.203KA. Fault details at Champa end :- Main I :- FD-4.539Km,FC-17.277KA , Main II :- FD-4.548Km, FC-17.418KA. Fault is in Champa TLM jurisdiction. Faulty phase position :- Left
CKT	765KV RANCHI-DHARAMJAYGARH-1	LART	20-02-2025	17:52:00	20-02-2025	17:52:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on R-G fault. Fault details at Dharamjaygarh end : Main I :- FD-12.246km, FC-14.426KA Main II :- FD-12.506km,FC-17.409KA. Fault details at Ranchi end :- Main I :- FD-301Km,FC-2.859KA , Main II :- FD-301Km, FC-2.866KA. Fault is in Korba TLM jurisdiction. Faulty phase position :- Bottom.* 28.02.2025 18:19:12 INDIA (60001973)* Flashover mark found in between CC ring,porcelain disc insulator and inTension plate.Also hole found in CC ring due to flashover at TN-793 (B+3).* (LOC No-793)TFR -(in ohm)* Leg A-10,Leg B-10.03,Leg C-10.26,Leg D-10.10
CKT	765KV RANCHI-DHARAMJAYGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV JHARSUGUDA-DHARAMJAYGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV JHARSUGUDA-DHARAMJAYGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV JHARSUGUDA-DHARAMJAYGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV JHARSUGUDA-DHARAMJAYGARH-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV KOTRA PS-RAIPUR PS(DURG)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV KOTRA PS-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV KOTRA PS-TAMNAR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV KOTRA PS-TAMNAR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV-PUNE GIS-PADGHE GIS-1	SCSD	09-02-2025	11:31:00	09-02-2025	20:36:00	0.38	0.00	0.00	0.00	9.08		* For Commissioning of ICT-3 Works - TIE bay LBB testing under Western Region Expansion Scheme WRES XXIX
CKT	765KV RAIPUR PS(DURG)-WARDHA-1	LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for voltage Regulation and SLR charged as BR at 17:13 Hrs at Durg end.
CKT	765KV RAIPUR PS(DURG)-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV RAIPUR PS(DURG)-WARDHA-3	LVRD	01-02-2025	19:28:00	12-02-2025	12:48:00	10.72	0.00	0.00	0.00	257.33		* Line H/T as per WRLDC instructions for V
CKT	765KV RAIPUR PS(DURG)-WARDHA-3	LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC code for V/R and SLR converted as BR at 19:04Hrs. at Durg SS for VR.
CKT	765KV RAIPUR PS(DURG)-WARDHA-3	SVRD	20-02-2025	22:49:00	28-02-2025	23:59:59	8.05	0.00	0.00	0.00	193.18		* Line H/T as per WRLDC instructions for Voltage Regulation.SLR converted as Bus Reator at Durg end at 23:04 hrs .
CKT	765KV RAIPUR PS(DURG)-WARDHA-4	LVRD	01-02-2025	00:00:01	01-02-2025	16:44:00	46.77	0.00	0.00	0.00	1,122.51	100.00	* Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at 18:13hrs.@ Durg end.
CKT	765KV RAIPUR PS(DURG)-WARDHA-4	LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR charged as BR at Durg end on dt 30.11.2023 at 00:41Hrs.
CKT	765KV SEONI-WARDHA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV SEONI-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV SOLAPUR-AURANGABAD-1	LVRD	10-02-2025	20:20:00	11-02-2025	10:21:00	0.58	0.00	0.00	0.00	14.02		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR Covered as BR at 20:36 hrs at Aurangabad SS and at 20:33 hrs at Solapur SS
CKT	765KV SOLAPUR-AURANGABAD-1	LVRD	01-02-2025	00:00:01	08-02-2025	10:57:00	7.46	0.00	0.00	0.00	178.95		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR Covered as BR at 21:46 hrs at Aurangabad SS and at hrs at Solapur SS
CKT	765KV SOLAPUR-AURANGABAD-1	LVRD	14-02-2025	21:59:00	17-02-2025	09:45:00	2.49	0.00	0.00	0.00	59.77		* Line H/T as per WRLDC instructions for Voltage Regulation. and Both Side Line Reactor convert as Bus Reactor, at aurangabad SLR convert as BR 22:25 HRS <(> at Solapur SLR convert as BR 22:23 hrs
CKT	765KV SOLAPUR-AURANGABAD-1	LVRD	22-02-2025	21:40:00	24-02-2025	08:00:00	1.43	0.00	0.00	0.00	34.33		* Line H/T as per WRLDC instructions for Voltage Regulation.SLR converted as Bus Reator at Solapur end at 21:51 hrs and SLR converted as Bus Reator at Aurangabad end at 21:49 hrs.
CKT	765KV SOLAPUR-AURANGABAD-1	SVRD	20-02-2025	22:27:00	21-02-2025	07:02:00	0.36	0.00	0.00	0.00	8.58		* Line H/T as per WRLDC instructions for Voltage Regulation.SLR converted as Bus Reator at Solapur end at 22:44 hrs and SLR converted as Bus Reator at Aurangabad end at 22:37 hrs.
CKT	765KV SOLAPUR-AURANGABAD-1	LVRD	17-02-2025	20:38:00	18-02-2025	09:10:00	0.52	0.00	0.00	0.00	12.53		* Line H/T as per WRLDC instructions for Voltage Regulation.Line LR converted as Bus Reator at both end.
CKT	765KV SOLAPUR-AURANGABAD-1	LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR Covered as BR at 21:38 hrs at Aurangabad SS and at hrs at Solapur SS
CKT	765KV SOLAPUR-AURANGABAD-2	SVRD	08-02-2025	19:19:00	10-02-2025	11:36:00	1.68	0.00	0.00	0.00	40.28		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR Covered as BR at 20:05 hrs at Aurangabad SS and at 19:36 hrs at Solapur SS.
CKT	765KV SOLAPUR-AURANGABAD-2	LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR Covered as BR at 23:13 hrs at Aurangabad SS and SLR Covered as BR at 23:01 hrs at Solapur SS
CKT	765KV SOLAPUR-PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV SIPAT(NTPC)-BILASPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV SIPAT(NTPC)-BILASPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV WARDHA-AURANGABAD-1	LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR Covered as BR at 00:41hrs at Wardha SS .
CKT	765KV WARDHA-AURANGABAD-2	LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for Voltage Regulation at 10:51 and SLR Covered as BR at 12:05 hrs at Wardha SS.
CKT	765KV WARDHA-AURANGABAD-3	LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Line H/T as per WRLDC instructions for Voltage Regulation .
CKT	765KV WARDHA-AURANGABAD-4	OSFT	15-02-2025	11:11:00	15-02-2025	18:01:00	0.29	6.83	0.00	0.00	0.00		* ESD for Rectification work in Line
LNR	80MVAR LR OF WARDHA-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	80MVAR,LR OF WARDHA-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRDLC instructions for Voltage Regulation
							84.00	0.00	0.00	0.00	2,016.00	100.00	
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	07-02-2025	07:32:00	07-02-2025	18:16:00	0.45	0.00	0.00	0.00	10.73		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	04-02-2025	07:44:00	04-02-2025	19:48:00	0.50	0.00	0.00	0.00	12.07		* SLR Charged as BR,H/T as per WRDLC instructions for VR
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	18-02-2025	07:33:00	18-02-2025	09:10:00	0.07	0.00	0.00	0.00	1.62		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	23-02-2025	08:52:00	24-02-2025	08:00:00	0.96	0.00	0.00	0.00	23.13		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	16-02-2025	09:06:00	16-02-2025	18:16:00	0.38	0.00	0.00	0.00	9.17		* SLR H/T as per WRDLC instructions for Voltage regulation
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	08-02-2025	07:12:00	08-02-2025	10:57:00	0.16	0.00	0.00	0.00	3.75		* SLR H/T as per WRDLC instructions for VR
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	03-02-2025	08:34:00	03-02-2025	18:11:00	0.40	0.00	0.00	0.00	9.62		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	05-02-2025	07:45:00	05-02-2025	20:13:00	0.52	0.00	0.00	0.00	12.47		* SLR Charged as BR, SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	02-02-2025	08:31:00	02-02-2025	20:01:00	0.48	0.00	0.00	0.00	11.50		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	06-02-2025	10:20:00	06-02-2025	21:51:00	0.48	0.00	0.00	0.00	11.52		* SLR H/T as per WRDLC instructions for Voltage Regulation.
							60.40	0.00	0.00	0.00	1,449.58	100.00	
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	10-02-2025	07:28:00	10-02-2025	11:36:00	0.17	0.00	0.00	0.00	4.13		* BR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	09-02-2025	10:16:00	09-02-2025	20:21:00	0.42	0.00	0.00	0.00	10.08		* BR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRDLC instructions for VR
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
							56.59	0.00	0.00	0.00	1,358.21	100.00	
LNR	240MVAR,SWLR OF SEONI-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF SEONI-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAJNANGAON-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAJNANGAON-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DHARAMJYGARH AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-2 AT KORBA PS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	330MVAR,SWLR OF JABALPUR-1 AT KORBA PS			00:00:00		00:00:00	28.00	0.00	0.00	0.00	672.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-2 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-1 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DURG-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DURG-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-1 AT PUNE	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
							28.00	0.00	0.00	0.00	672.00	100.00	

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	50MVAR.SWLR OF PUNE GIS-2 AT PUNE	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
							28.00	0.00	0.00	0.00	672.00	100.00	
LNR	50MVAR.SWLR OF PUNE GIS-3 AT PUNE	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
							28.00	0.00	0.00	0.00	672.00	100.00	
LNR	50MVAR.SWLR OF PUNE GIS-4 AT PUNE	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	50MVAR.SWLR OF PUNE GIS-4 AT PUNE	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
							56.00	0.00	0.00	0.00	1,344.00	100.00	
LNR	240MVAR.SWLR OF SHOLAPUR AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
							28.00	0.00	0.00	0.00	672.00	100.00	
LNR	240MVAR.SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
							280.00	0.00	0.00	0.00	6,720.00	100.00	
LNR	240MVAR.SWLR OF JARSUGUDA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF JARSUGUDA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF WARDHA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF CHAMPA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF WARDHA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF CHAMPA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF WARDHA-3 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF WARDHA-4 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR.SWLR OF KORBA-3 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF WARDHA-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF WARDHA-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF BINA-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80 MVAR, 765 KV SPARE COLD REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR.SWLR OF KARAD AT SHOLAPUR	OSPT	27-02-2025	08:29:00	27-02-2025	18:08:00	0.40	9.65	0.00	0.00	0.00		* Line Reactor and Recator CB AMP at 765kV Solapur Substation.
LNR	80MVAR.SWLR OF KARAD AT SHOLAPUR	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
							28.40	9.65	0.00	0.00	672.00	98.56	
LNR	240MVAR.SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	06-02-2025	10:31:00	06-02-2025	18:15:00	0.32	0.00	0.00	0.00	7.73		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	03-02-2025	10:57:00	03-02-2025	17:55:00	0.29	0.00	0.00	0.00	6.97		* BR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	01-02-2025	10:26:00	01-02-2025	18:12:00	0.32	0.00	0.00	0.00	7.77		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	07-02-2025	10:18:00	07-02-2025	21:55:00	0.48	0.00	0.00	0.00	11.62		* SLR H/T as per WRLDC instructions for Voltage Regulation.
							29.41	0.00	0.00	0.00	706.09	100.00	
LNR	240MVAR.SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR.SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	10-02-2025	08:00:00	10-02-2025	11:36:00	0.15	0.00	0.00	0.00	3.60		* BR H/T as per WRLDC instructions for Voltage Regulation.
							56.15	0.00	0.00	0.00	1,347.60	100.00	
LNR	240MVAR.SWLR OF PUNE AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF RAICHUR-2 AT SOLAPUR	OMSU	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	672.00	0.00	0.00		* SLR tripped due to implementation of Ferroresonance scheme at Solapur s/s as 765KV Solapur Raichur ckt#2 Auto Reclosed on R-E fault.
							28.00	0.00	672.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF RAICHUR-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR.LR OF AURANGABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR.LR OF AURANGABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF NIZAMABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR.SWLR OF NIZAMABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR.LR OF AURANGABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR.LR OF AURANGABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	330MVAR,LR OF AURANGABAD-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-4 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT SHOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	500MW.BHADRAWATI HVDC BTB POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	500MW.BHADRAWATI HVDC BTB POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	POLE1 VALVE HALL RAIGARH HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	POLE2 VALVE HALL RAIGARH HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHATAPARA	OSPT	05-02-2025	09:24:00	07-02-2025	16:28:00	2.29	55.07	0.00	0.00	0.00		* FOR REPLACEMENT OF GASKET TO ARREST OIL LEAKAGE
XMER	500MVA,400/220kV ICT-3 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-5 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-6 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	TBCB-500MVA,400/220kV ICT-4 AT DHARAMJAY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-6 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MAPUSA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MAPUSA	OSFT	10-02-2025	15:34:00	10-02-2025	21:10:00	0.23	5.60	0.00	0.00	0.00		* ESD availed on 400/220kV ICT#2 to attend broken conductor strands of B-ph <[>&<] R-ph Jack bus 220kV side at dropper side
XMER	315MVA,400/220kV ICT-3 AT MAPUSA	OSFT	03-02-2025	16:56:00	03-02-2025	21:08:00	0.18	4.20	0.00	0.00	0.00		* Emergency outage availed to attain melted ICT#3 R-ph Jack bus 220kV side melted conductor strands at dropper side.
XMER	315MVA,400/220kV ICT-1 AT NAVI MUMBAI	OSFT	10-02-2025	23:50:00	11-02-2025	02:50:00	0.13	3.00	0.00	0.00	0.00		* Emergency outage availed for Attending oil leakage at pressure relay on OLTC tank (R-Ph) of ICT-1 and Oil filling in OLTC conservator tank
XMER	315MVA,400/220kV ICT-2 AT NAVI MUMBAI	OSFT	06-02-2025	13:15:00	06-02-2025	17:13:00	0.17	3.97	0.00	0.00	0.00		* Emergency outage availed for attending oil leakage in 220 KV side (R-Ph) Cable Box Oil to Oil chambers joint of ICT#2 at Navi Mumbai-GIS
XMER	1500MVA,765/400kV ICT-1 AT PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT PADGHE GIS	SCSD	06-02-2025	10:40:00	07-02-2025	00:21:00	0.57	0.00	0.00	0.00	13.68		* For Spare Changover of ICT#3, Taking Yph IN service <[>&<] Spare OUT of Service <[>&<] Fine tuning of CSD of ICT
XMER	500MVA,400/220kV ICT-1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PUNE	OSPT	28-02-2025	12:25:00	28-02-2025	23:59:59	0.48	11.58	0.00	0.00	0.00		* Outage of ICT1 for AMP Works

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.48	11.58	0.00	0.00	0.00	98.28	
XMER	315MVA,400/220kV ICT-2 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT RAIGARH	OSPT	28-02-2025	09:06:00	28-02-2025	22:41:00	0.57	13.58	0.00	0.00	0.00		* Outage of ICT2 for AMP Works
							0.57	13.58	0.00	0.00	0.00	97.98	
XMER	500MVA,400/220kV ICT-3 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SEONI	OSPT	27-02-2025	10:56:00	27-02-2025	22:58:00	0.50	12.03	0.00	0.00	0.00		* AMP
							0.50	12.03	0.00	0.00	0.00	98.21	
XMER	1500MVA,765/400kV ICT-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT SOLAPUR	SCSD	14-02-2025	08:42:00	14-02-2025	13:54:00	0.22	0.00	0.00	0.00	5.20		* For Spare Change over Note Dia to be kept open Last Spare Change over done on 07.11.2023
							0.22	0.00	0.00	0.00	5.20	100.00	
XMER	315MVA,400/220kV ICT-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT TAMNAR PS	OSPT	25-02-2025	10:51:00	25-02-2025	20:16:00	0.39	9.42	0.00	0.00	0.00		* AMP WORKS
							0.39	9.42	0.00	0.00	0.00	98.60	
XMER	1500MVA,765/400kV ICT-3 AT TAMNAR PS	OSPT	15-02-2025	09:28:00	15-02-2025	20:03:00	0.44	10.58	0.00	0.00	0.00		* ICT-3 for AMP Works
							0.44	10.58	0.00	0.00	0.00	98.43	
XMER	1500MVA,765/400kV ICT-4 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT WARDHA	OSPT	24-02-2025	11:39:00	24-02-2025	19:57:00	0.35	8.30	0.00	0.00	0.00		* For Transformer AMP
							0.35	8.30	0.00	0.00	0.00	98.76	
XMER	315MVA,400/220kV ICT-2 AT WARDHA	OSPT	25-02-2025	09:35:00	25-02-2025	18:25:00	0.37	8.83	0.00	0.00	0.00		* For Transformer AMP
							0.37	8.83	0.00	0.00	0.00	98.69	
XMER	500MVA,400/220kV ICT-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	