

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	12-01-2025	08:44:00	12-01-2025	20:11:00	0.48	0.00	0.00	0.00	0.00	11.45	* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	06-01-2025	08:43:00	06-01-2025	20:04:00	0.47	0.00	0.00	0.00	0.00	11.35	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	21-01-2025	10:35:00	21-01-2025	20:37:00	0.42	0.00	0.00	0.00	0.00	10.03	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	25-01-2025	09:46:00	25-01-2025	20:51:00	0.46	0.00	0.00	0.00	0.00	11.08	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	16-01-2025	07:16:00	16-01-2025	21:26:00	0.59	0.00	0.00	0.00	0.00	14.17	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	18-01-2025	08:36:00	18-01-2025	20:10:00	0.48	0.00	0.00	0.00	0.00	11.57	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	08-01-2025	09:35:00	08-01-2025	23:06:00	0.56	0.00	0.00	0.00	0.00	13.52	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	17-01-2025	09:04:00	17-01-2025	19:23:00	0.43	0.00	0.00	0.00	0.00	10.32	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	10-01-2025	09:18:00	10-01-2025	22:02:00	0.53	0.00	0.00	0.00	0.00	12.73	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	23-01-2025	09:57:00	23-01-2025	13:05:00	0.13	0.00	0.00	0.00	0.00	3.13	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	19-01-2025	08:41:00	19-01-2025	20:02:00	0.47	0.00	0.00	0.00	0.00	11.35	* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	01-01-2025	08:54:00	01-01-2025	21:46:00	0.54	0.00	0.00	0.00	0.00	12.87	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	02-01-2025	07:02:00	02-01-2025	21:58:00	0.62	0.00	0.00	0.00	0.00	14.93	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	04-01-2025	08:55:00	04-01-2025	22:33:00	0.57	0.00	0.00	0.00	0.00	13.63	* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	05-01-2025	08:57:00	05-01-2025	20:18:00	0.47	0.00	0.00	0.00	0.00	11.35	* BR H/T as per WRLDc instructions for Vo
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	03-01-2025	09:36:00	03-01-2025	20:09:00	0.44	0.00	0.00	0.00	0.00	10.55	* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	27-01-2025	08:21:00	27-01-2025	20:24:00	0.50	0.00	0.00	0.00	0.00	12.05	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	13-01-2025	09:50:00	14-01-2025	20:38:00	1.45	0.00	0.00	0.00	0.00	34.80	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	09-01-2025	09:14:00	09-01-2025	21:35:00	0.52	0.00	0.00	0.00	0.00	12.35	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	31-01-2025	09:30:00	31-01-2025	22:25:00	0.54	0.00	0.00	0.00	0.00	12.92	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	0.00	744.00	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	24-01-2025	08:44:00	31-01-2025	23:59:59	7.64	0.00	0.00	0.00	0.00	183.27	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	28-01-2025	07:46:00	28-01-2025	21:00:00	0.55	0.00	0.00	0.00	0.00	13.23	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	20-01-2025	08:36:00	20-01-2025	18:32:00	0.41	0.00	0.00	0.00	0.00	9.93	* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	22-01-2025	08:28:00	22-01-2025	20:10:00	0.49	0.00	0.00	0.00	0.00	11.70	* 765KV BR HT For VR as per WRLDc instruction
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	30-01-2025	08:25:00	30-01-2025	21:55:00	0.56	0.00	0.00	0.00	0.00	13.50	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	11-01-2025	09:45:00	11-01-2025	21:18:00	0.48	0.00	0.00	0.00	0.00	11.55	* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	07-01-2025	06:30:00	07-01-2025	19:54:00	0.56	0.00	0.00	0.00	0.00	13.40	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	29-01-2025	09:16:00	29-01-2025	19:43:00	0.44	0.00	0.00	0.00	0.00	10.45	* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	15-01-2025	06:41:00	15-01-2025	22:11:00	0.65	0.00	0.00	0.00	0.00	15.50	* BR H/T as per WRLDc instructions for VR
							53.45	0.00	0.00	0.00	1,282.68	100.00	
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	20-01-2025	11:12:00	20-01-2025	19:49:00	0.36	0.00	0.00	0.00	0.00	8.62	* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	22-01-2025	09:38:00	22-01-2025	20:38:00	0.46	0.00	0.00	0.00	0.00	11.00	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	14-01-2025	09:58:00	14-01-2025	18:33:00	0.36	0.00	0.00	0.00	0.00	8.58	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	29-01-2025	09:24:00	29-01-2025	20:27:00	0.46	0.00	0.00	0.00	0.00	11.05	* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	30-01-2025	09:10:00	30-01-2025	22:04:00	0.54	0.00	0.00	0.00	0.00	12.90	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	15-01-2025	08:25:00	15-01-2025	22:32:00	0.59	0.00	0.00	0.00	0.00	14.12	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	28-01-2025	08:47:00	28-01-2025	21:08:00	0.52	0.00	0.00	0.00	0.00	12.35	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	0.00	744.00	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	0.00	744.00	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	01-01-2025	09:20:00	01-01-2025	13:57:00	0.19	0.00	0.00	0.00	0.00	4.62	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	04-01-2025	10:15:00	05-01-2025	20:38:00	1.43	0.00	0.00	0.00	0.00	34.38	* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	02-01-2025	09:38:00	03-01-2025	20:18:00	1.44	0.00	0.00	0.00	0.00	34.67	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	13-01-2025	09:52:00	13-01-2025	23:05:00	0.55	0.00	0.00	0.00	0.00	13.22	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	18-01-2025	09:58:00	18-01-2025	21:39:00	0.49	0.00	0.00	0.00	0.00	11.68	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	09-01-2025	10:27:00	09-01-2025	21:58:00	0.48	0.00	0.00	0.00	0.00	11.52	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	16-01-2025	08:00:00	16-01-2025	21:30:00	0.56	0.00	0.00	0.00	0.00	13.50	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	27-01-2025	09:23:00	27-01-2025	20:43:00	0.47	0.00	0.00	0.00	0.00	11.33	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	25-01-2025	10:20:00	25-01-2025	21:02:00	0.45	0.00	0.00	0.00	0.00	10.70	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	10-01-2025	09:13:00	11-01-2025	21:53:00	1.53	0.00	0.00	0.00	0.00	36.67	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	08-01-2025	09:37:00	08-01-2025	23:16:00	0.57	0.00	0.00	0.00	0.00	13.65	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	21-01-2025	09:54:00	21-01-2025	21:32:00	0.49	0.00	0.00	0.00	0.00	11.63	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	17-01-2025	10:43:00	17-01-2025	21:27:00	0.45	0.00	0.00	0.00	0.00	10.73	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	06-01-2025	10:00:00	06-01-2025	20:13:00	0.43	0.00	0.00	0.00	0.00	10.22	* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	07-01-2025	10:34:00	07-01-2025	20:30:00	0.41	0.00	0.00	0.00	0.00	9.93	* BR H/T as per WRLDc instructions for Voltage Regulation.
							75.23	0.00	0.00	0.00	1,805.07	100.00	
BSR	50MVAR, BUS REACTOR-1 AT BHADRAWATI	OSPT	03-01-2025	09:32:00	03-01-2025	21:26:00	0.50	11.90	0.00	0.00	0.00		* Overhauling of Bus reactor-1 (3 nos Single phase unit)<-&-> LBB EASUN/2DAB Model relay will be upgraded to Numerical relay under ADD CAP/additional element.
							0.50	11.90	0.00	0.00	0.00	98.40	
BSR	63MVAR, BUS REACTOR-2 AT BHADRAWATI	OMSU	15-01-2025	09:46:00	15-01-2025	19:48:00	0.42	0.00	10.03	0.00	0.00		* For LBB EASUN/2DAB Model relay will be upgraded to Numerical relay under ADD CAP/additional element
BSR	63MVAR, BUS REACTOR-2 AT BHADRAWATI	SBBT	06-01-2025	19:17:00	06-01-2025	22:24:00	0.13	3.12	0.00	0.00	0.00		* BR tripped due to BB protection operated at Bhadrawati end* 01.02.2025 20:44:32 INDIA (60001973)* Due to not Changing in DT wiring fututure bay extension works
							0.55	3.12	10.03	0.00	0.00	99.58	
BSR	125MVAR, BUS REACTOR-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	0.00	744.00	* BR H/T as per WRLDc instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	0.00	744.00	* BR H/T as per WRLDc instructions for Voltage Regulation.
							62.00	0.0					

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifiyin	Detailed Reasons for Outage
BSR	330MVAR, BUS REACTOR-3 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	22-01-2025	09:18:00	24-01-2025	21:16:00	2.50	0.00	0.00	0.00	59.97		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	25-01-2025	10:33:00	25-01-2025	21:08:00	0.44	0.00	0.00	0.00	10.58		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	17-01-2025	10:22:00	17-01-2025	21:09:00	0.45	0.00	0.00	0.00	10.78		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	15-01-2025	09:30:00	17-01-2025	01:12:00	1.65	0.00	0.00	0.00	39.70		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	30-01-2025	08:30:00	30-01-2025	22:05:00	0.57	0.00	0.00	0.00	13.58		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	20-01-2025	11:03:00	20-01-2025	19:28:00	0.35	0.00	0.00	0.00	8.42		* BR H/T as per WRLDC instructions for VR
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	31-01-2025	08:59:00	31-01-2025	23:23:00	0.60	0.00	0.00	0.00	14.40		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for VR
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
							130.56	0.00	0.00	0.00	3,133.43	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	21-01-2025	10:15:00	31-01-2025	23:59:59	10.57	0.00	0.00	0.00	253.75		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	13-01-2025	09:20:00	16-01-2025	18:07:00	3.37	0.00	0.00	0.00	80.78		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	07-01-2025	09:53:00	31-01-2025	23:59:59	24.59	0.00	0.00	0.00	590.12		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	25-01-2025	09:45:00	31-01-2025	23:59:59	6.59	0.00	0.00	0.00	158.25		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	05-01-2025	10:15:00	31-01-2025	23:59:59	26.57	0.00	0.00	0.00	637.75		* BR H/T as per WRLDC instructions for Vo
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	02-01-2025	09:46:00	04-01-2025	21:18:00	2.48	0.00	0.00	0.00	59.53		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	18-01-2025	09:12:00	18-01-2025	20:03:00	0.45	0.00	0.00	0.00	10.85		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	12-01-2025	10:09:00	12-01-2025	21:10:00	0.46	0.00	0.00	0.00	11.02		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	20-01-2025	09:14:00	20-01-2025	18:10:00	0.37	0.00	0.00	0.00	8.93		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	06-01-2025	09:48:00	06-01-2025	19:58:00	0.42	0.00	0.00	0.00	10.17		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	10-01-2025	09:21:00	10-01-2025	21:50:00	0.52	0.00	0.00	0.00	12.48		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	19-01-2025	10:26:00	19-01-2025	22:08:00	0.49	0.00	0.00	0.00	11.70		* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	27-01-2025	09:00:00	27-01-2025	20:45:00	0.49	0.00	0.00	0.00	11.75		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	28-01-2025	08:40:00	31-01-2025	23:24:00	3.61	0.00	0.00	0.00	86.73		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDC instructions for Voltage Regulation
							545.98	0.00	0.00	0.00	13,103.81	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KOTRA PS	SCSD	29-01-2025	11:24:00	31-01-2025	23:59:59	2.53	0.00	0.00	0.00	60.60		* Outage availed for ICT-5 Bay Constructions Works.
BSR	125MVAR, BUS REACTOR-2 AT KOTRA PS	SCSD	06-01-2025	10:00:00	07-01-2025	16:15:00	1.26	0.00	0.00	0.00	30.25		* For ICT 5 Bay Construction works
							3.79	0.00	0.00	0.00	90.85	100.00	
BSR	240MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	02-01-2025	08:55:00	02-01-2025	21:41:00	0.53	0.00	0.00	0.00	12.77		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	13-01-2025	10:17:00	13-01-2025	22:39:00	0.52	0.00	0.00	0.00	12.37		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	08-01-2025	09:03:00	08-01-2025	22:46:00	0.57	0.00	0.00	0.00	13.72		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	21-01-2025	09:55:09	22-01-2025	19:09:00	1.39	0.00	0.00	0.00	33.23		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	10-01-2025	09:21:00	10-01-2025	21:59:00	0.53	0.00	0.00	0.00	12.63		* BR H/T as per WRLDC instructions for Voltage Regulation.

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	12-01-2025	08:00:00	12-01-2025	19:56:00	0.50	0.00	0.00	0.00	11.93		* BR H/T as per WRLDc instructions for VR
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	16-01-2025	10:48:00	16-01-2025	21:23:00	0.44	0.00	0.00	0.00	10.58		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	28-01-2025	08:47:00	28-01-2025	19:32:00	0.45	0.00	0.00	0.00	10.75		* BR H/T as per WRLDc instructions for Voltage regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	20-01-2025	10:54:00	20-01-2025	19:27:00	0.36	0.00	0.00	0.00	8.55		* BR H/T as per WRLDc instructions for VR
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	27-01-2025	09:18:00	27-01-2025	20:45:00	0.48	0.00	0.00	0.00	11.45		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	06-01-2025	09:52:00	07-01-2025	21:03:00	1.47	0.00	0.00	0.00	35.18		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	14-01-2025	10:40:00	14-01-2025	21:16:00	0.44	0.00	0.00	0.00	10.60		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	15-01-2025	09:27:00	15-01-2025	18:05:00	0.36	0.00	0.00	0.00	8.63		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	29-01-2025	11:28:00	31-01-2025	23:23:00	2.50	0.00	0.00	0.00	59.92		* BR H/T as per WRLDc instructions for VR
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
							258.54	0.00	0.00	0.00	6,204.31	100.00	
BSR	63MVAR, BUS REACTOR-1 AT NAVI MUMBAI	SVRD	01-01-2025	00:00:01	07-01-2025	13:09:00	6.55	0.00	0.00	0.00	157.15		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	63MVAR, BUS REACTOR-1 AT NAVI MUMBAI	SCSD	07-01-2025	13:09:00	07-01-2025	18:44:00	0.23	0.00	0.00	0.00	5.58		* Outage availed for Onload Commissioning works of 63MVAR Bus Reactor at Navi Mumbai GIS SS
BSR	63MVAR, BUS REACTOR-1 AT NAVI MUMBAI	SVRD	16-01-2025	10:24:00	31-01-2025	23:59:59	15.57	0.00	0.00	0.00	373.60		* BR H/T as per WRLDc instructions for Voltage Regulation.
							22.35	0.00	0.00	0.00	536.33	100.00	
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	30-01-2025	08:21:00	30-01-2025	18:21:00	0.42	0.00	0.00	0.00	10.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	13-01-2025	09:13:00	13-01-2025	19:36:00	0.43	0.00	0.00	0.00	10.38		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	31-01-2025	08:59:00	31-01-2025	20:07:00	0.46	0.00	0.00	0.00	11.13		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	02-01-2025	08:55:00	02-01-2025	20:28:00	0.48	0.00	0.00	0.00	11.55		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	03-01-2025	06:57:00	03-01-2025	19:46:00	0.53	0.00	0.00	0.00	12.82		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	12-01-2025	09:28:00	12-01-2025	19:16:00	0.41	0.00	0.00	0.00	9.80		* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	20-01-2025	09:18:00	20-01-2025	18:14:00	0.37	0.00	0.00	0.00	8.93		* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	17-01-2025	08:30:00	17-01-2025	19:15:00	0.45	0.00	0.00	0.00	10.75		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	06-01-2025	08:49:00	06-01-2025	19:39:00	0.45	0.00	0.00	0.00	10.83		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	19-01-2025	08:35:00	19-01-2025	19:38:00	0.46	0.00	0.00	0.00	11.05		* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	23-01-2025	08:36:00	23-01-2025	18:09:00	0.40	0.00	0.00	0.00	9.55		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	24-01-2025	07:31:00	24-01-2025	20:27:00	0.54	0.00	0.00	0.00	12.93		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	18-01-2025	08:18:00	18-01-2025	19:59:00	0.49	0.00	0.00	0.00	11.28		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	08-01-2025	09:08:00	08-01-2025	18:34:00	0.44	0.00	0.00	0.00	10.43		* BR H/T as per WRLDc instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	27-01-2025	07:58:00	27-01-2025	17:13:00	0.39	0.00	0.00	0.00	9.25		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	16-01-2025	07:16:00	16-01-2025	20:02:00	0.53	0.00	0.00	0.00	12.77		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	14-01-2025	08:58:00	14-01-2025	18:05:00	0.38	0.00	0.00	0.00	9.12		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	28-01-2025	08:22:00	28-01-2025	19:27:00	0.46	0.00	0.00	0.00	11.08		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	07-01-2025	07:46:00	07-01-2025	19:52:00	0.50	0.00	0.00	0.00	12.10		
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	11-01-2025	09:50:00	11-01-2025	19:28:00	0.40	0.00	0.00	0.00	9.63		* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	09-01-2025	08:48:00	09-01-2025	19:53:00	0.46	0.00	0.00	0.00	11.08		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	25-01-2025	09:07:00	25-01-2025	20:42:00	0.48	0.00	0.00	0.00	11.58		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	29-01-2025	09:20:00	29-01-2025	19:06:00	0.41	0.00	0.00	0.00	9.77		* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	21-01-2025	08:40:00	21-01-2025	17:55:00	0.39	0.00	0.00	0.00	9.25		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	15-01-2025	08:39:00	15-01-2025	21:49:00	0.55	0.00	0.00	0.00	13.17		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	22-01-2025	06:47:00	22-01-2025	18:20:00	0.48	0.00	0.00	0.00	11.55		* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	10-01-2025	09:07:00	10-01-2025	19:29:00	0.43	0.00	0.00	0.00	10.37		* BR H/T as per WRLDc instructions for V
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	05-01-2025	08:45:00	05-01-2025	19:27:00	0.45	0.00	0.00	0.00	10.70		* BR H/T as per WRLDc instructions for V
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	04-01-2025	08:54:00	04-01-2025	20:34:00	0.49	0.00	0.00	0.00	11.67		* BR H/T as per WRLDc instructions for VR
							261.13	0.00	0.00	0.00	6,266.92	100.00	
BSR	63MVAR, BUS REACTOR-1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT PUNE	SVRD	01-01-2025	00:00:01	02-01-2025	03:43:00	1.16	0.00	0.00	0.00	27.72		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT PUNE	SVRD	06-01-2025	10:05:00	14-01-2025	21:35:00	8.48	0.00	0.00	0.00	203.50		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT PUNE	SVRD	16-01-2025	10:33:00	31-01-2025	23:59:59	15.56	0.00	0.00	0.00	373.45		* BR H/T as per WRLDc instructions for Voltage Regulation.
							25.20	0.00	0.00	0.00	604.67	100.00	
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	15-01-2025	08:53:00	15-01-2025	18:05:00	0.38	0.00	0.00	0.00	9.20		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	08-01-2025	09:19:00	08-01-2025	19:37:00	0.43	0.00	0.00	0.00	10.30		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	29-01-2025	09:16:00	29-01-2025	19:02:00	0.41	0.00	0.00	0.00	9.77		* BR H/T as per WRLDc instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	16-01-2025	08:51:00	16-01-2025	13:14:00	0.18	0.00	0.00	0.00	4.38		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	09-01-2025	10:25:00	09-01-2025	20:01:00	0.40	0.00	0.00	0.00	9.60		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	25-01-2025	08:34:00	25-01-2025	19:24:00	0.45	0.00	0.00	0.00	10.83		* BR H/T as per WRLDc instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	30-01-2025	08:21:00	30-01-2025	18:16:00	0.41	0.00	0.00	0.0			

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	18-01-2025	08:24:00	18-01-2025	19:59:00	0.48	0.00	0.00	0.00	11.58		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	23-01-2025	08:24:00	23-01-2025	13:06:00	0.20	0.00	0.00	0.00	4.70		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	17-01-2025	08:33:00	17-01-2025	19:09:00	0.44	0.00	0.00	0.00	10.60		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	12-01-2025	11:04:00	12-01-2025	18:06:00	0.29	0.00	0.00	0.00	7.03		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	05-01-2025	09:09:00	05-01-2025	16:08:00	0.29	0.00	0.00	0.00	6.98		* BR H/T as per WRLDG instructions for Vo
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	03-01-2025	09:31:00	03-01-2025	19:46:00	0.43	0.00	0.00	0.00	10.25		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	04-01-2025	09:20:00	04-01-2025	19:02:00	0.40	0.00	0.00	0.00	9.70		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	02-01-2025	09:18:00	02-01-2025	20:20:00	0.46	0.00	0.00	0.00	11.03		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	24-01-2025	08:37:00	24-01-2025	18:22:00	0.41	0.00	0.00	0.00	9.75		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	20-01-2025	09:18:00	20-01-2025	19:38:00	0.43	0.00	0.00	0.00	10.33		
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	11-01-2025	09:46:00	11-01-2025	19:25:00	0.40	0.00	0.00	0.00	9.65		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	13-01-2025	08:57:00	13-01-2025	17:57:00	0.36	0.00	0.00	0.00	8.67		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	06-01-2025	08:49:00	06-01-2025	19:33:00	0.45	0.00	0.00	0.00	10.73		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	21-01-2025	09:02:00	21-01-2025	17:49:00	0.37	0.00	0.00	0.00	8.78		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	10-01-2025	10:14:00	10-01-2025	19:51:00	0.40	0.00	0.00	0.00	9.62		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	27-01-2025	09:11:00	27-01-2025	19:53:00	0.45	0.00	0.00	0.00	10.70		* BR H/T as per WRLDG instructions for Voltage Regulation.
							259.00	0.00	0.00	0.00	6,215.91	100.00	
BSR	63MVAR, BUS REACTOR-1 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	24-01-2025	10:07:00	24-01-2025	18:38:00	0.36	0.00	0.00	0.00	8.52		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	16-01-2025	10:22:00	16-01-2025	21:51:00	0.48	0.00	0.00	0.00	11.48		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	22-01-2025	09:56:00	22-01-2025	22:16:00	0.51	0.00	0.00	0.00	12.33		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	15-01-2025	10:01:00	15-01-2025	22:11:00	0.51	0.00	0.00	0.00	12.17		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	06-01-2025	10:01:00	31-01-2025	23:59:59	25.58	0.00	0.00	0.00	613.98		* BR H/T as per WRLDG instructions for Voltage Regulation.
							27.44	0.00	0.00	0.00	658.48	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	15-01-2025	10:30:00	15-01-2025	21:28:00	0.46	0.00	0.00	0.00	10.97		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	63MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* BR H/T as per WRLDG instructions for VR
							31.46	0.00	0.00	0.00	754.97	100.00	
BSR	240MVAR, BUS REACTOR-2 AT SOLAPUR	SVRD	15-01-2025	10:35:00	15-01-2025	19:11:00	0.36	0.00	0.00	0.00	8.60		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT SOLAPUR	OSFT	18-01-2025	11:11:00	18-01-2025	13:58:00	0.12	2.78	0.00	0.00	0.00		* to attend the oil leakage from Prismatic Oil level gauge of B.Ph Unit/ spare changeover.
							0.48	2.78	0.00	0.00	8.60	99.63	
BSR	240MVAR, BUS REACTOR-1 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT WARDHA	SVRD	02-01-2025	08:08:00	17-01-2025	01:39:00	14.73	0.00	0.00	0.00	353.52		* BR H/T as per WRLDG instructions for Voltage Regulation.
							14.73	0.00	0.00	0.00	353.52	100.00	
BSR	63MVAR, BUS REACTOR-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KORBA(CSEB)-BUDDHIPADAR(OPTCL)-3	OSFT	17-01-2025	16:01:00	18-01-2025	01:06:00	0.38	9.08	0.00	0.00	0.00		* Emergency shut down is required on 220 kV Korba – Budipadar #3 ckt for attending the hot spot on bus gantry inside the CSPCTL SS.
							0.38	9.08	0.00	0.00	0.00	98.78	
CKT	400kV AKOLA(MSETCL)-AURANGABAD-1	OSPT	22-01-2025	12:05:00	22-01-2025	18:48:00	0.28	6.72	0.00	0.00	0.00		* For Replacement of Old BHEL Insulators on gantries of element and AMP Work.Planned shutdown for maintenance work of POWERGRID elements
							0.28	6.72	0.00	0.00	0.00	99.10	
CKT	400kV AKOLA(MSETCL)-AURANGABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-1	OSFT	22-01-2025	16:34:00	22-01-2025	20:05:00	0.15	3.52	0.00	0.00	0.00		* Emergency outage availed to attend hot spot in isolator 89C at Aurangabad MSETCL SS
							0.15	3.52	0.00	0.00	0.00	99.53	
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-2	LPRD	11-01-2025	13:17:00	31-01-2025	23:59:59	20.45	0.00	0.00	0.00	490.72		* Line H/T as per WRLDG instructions for Power Regulation.
							20.45	0.00	0.00	0.00	490.72	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-1	OMSU	17-01-2025	09:55:00	17-01-2025	20:31:00	0.44	0.00	10.60	0.00	0.00		* LBB EASUN/2DAB Model relay will be upgraded to Numerical relay under Technology upgradation
							0.44	0.00	10.60	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-2	OMSU	03-01-2025	09:37:00	04-01-2025	00:00:01	0.60	0.00	14.38	0.00	0.00		* Tie Bay-LBB EASUN/2DAB Model relay will be upgraded to Numerical relay under ADD CAP/additional element
							0.60	0.00	14.38	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-3	OMSU	14-01-2025	09:19:00	14-01-2025	19:51:00	0.44	0.00	10.53	0.00	0.00		* FOR LBB EASUN/2DAB Model relay will be upgraded to Numerical relay under ADD CAP <>&<> AMP works/additional elements
							0.44	0.00	10.53	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-4	OMSU	13-01-2025	09:47:00	13-01-2025	20:01:00	0.43	0.00	10.23	0.00	0.00		* For LBB ABB/RAICA Model relay will be upgraded to Numerical relay under ADD CAP/additional elements
							0.43	0.00	10.23	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-DHARWAL(CESC)-2	OSPD	10-01-2025	09:44:00	10-01-2025	17:02:00	0.30	0.00	0.00	0.00	7.30		* Transmission line routine maintenance work outage availed by M/s Dhariwal
CKT	400kV BHADRAWATI-DHARWAL(CESC)-2	OMSU	16-01-2025	11:52:00	16-01-2025	19:40:00	0.33	0.00	7.80	0.00	0.00		* LBB EASUN/2DAB Model relay will be upgraded to Numerical relay under Technology upgradation/
CKT	400kV BHADRAWATI-DHARWAL(CESC)-2	OSFT	21-01-2025	13:27:00	21-01-2025	19:57:00	0.27	6.50	0.00	0.00	0.00		* Emergency outage availed to replace Faulty M-1 Distance relay at Bhadrawati SS
							0.90	6.50	7.80	0.00	7.30	99.12	
CKT	400kV BHADRAWATI-PARLI-1	OMSU	14-01-2025	09:14:00	14-01-2025	20:04:00	0.45	0.00	10.83	0.00	0.00		* FOR LBB EASUN/2DAB Model relay will be upgraded to Numerical relay under ADD CAP/additional elements
							0.45	0.00	10.83	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifiyin	Detailed Reasons for Outage
CKT	400kV BHATAPARA-BHILAI(CSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV BHILAI(CSEB)-BHADRAWATI-2	OMSU	06-01-2025	11:11:00	07-01-2025	00:31:00	0.56	0.00	13.33	0.00	0.00	100.00	* For LBB EASUN/2DAB Model relay will be upgraded to Numerical relay under ADD CAP <{>&<> AMP works/additional elements
CKT	400kV BHILAI(CSEB)-KORADI(MSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV DHARIWAL(CESC)-PARLI-2	OSFT	15-01-2025	08:18:00	15-01-2025	20:26:00	0.51	12.13	0.00	0.00	0.00		* Emergency outage availed for replacement of broken insulator string on the R ph jumper at Loc No. 172.
CKT	400kV JHARSUGUDA-RAIGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV JHARSUGUDA-RAIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV JHARSUGUDA-RAIGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV JHARSUGUDA-RAIGARH-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV KOLHAPUR GIS-MAPUSA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV KOLHAPUR GIS-MAPUSA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV KOLHAPUR(MSETCL)-KOLHAPUR GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV KOLHAPUR(MSETCL)-KOLHAPUR GIS-2	LCSD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-M= S-KOLHAPUR GIS-1
CKT	400kV KORBA(NTPC)-BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV KORBA(NTPC)-BHILAI(CSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV KORBA(NTPC)-BHILAI(CSEB)-2	OMSU	17-01-2025	10:02:00	17-01-2025	16:49:00	0.28	0.00	6.78	0.00	0.00		* Emergency outage availed by Korba, TLM for removal of Kites and its threads at Loc No. TN-42 <{>&<> TN-43.
CKT	400kV KORBA(NTPC)-BHILAI(CSEB)-2	OMSU	16-01-2025	15:30:00	16-01-2025	18:14:00	0.11	0.00	2.73	0.00	0.00		* Emergency outage availed by Korba, TLM for removal of Kites and its threads at Loc No. TN-43 <{>&<> TN-44.
CKT	400kV KORBA(NTPC)-BIRSINGHPUR(MPGENCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV KORBA(NTPC)-BIRSINGHPUR(MPGENCO)-2	OSPD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* For LILO Interconnection at BALCO Switchyard as per 2nd meeting of WRPC Dated: 04/09/2020. A/R in Non-Auto mode of 400kV Korba(NTPC)-Birsingpur Ckt-1 is required during the above line outage.
CKT	400kV KORBA(NTPC)-KORBA(CSEB)-1	LPRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Opened to control fault level at NTPC Korba
CKT	400kV KORBA(NTPC)-KORBA(CSEB)-1	OSPD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Outage availed By NTPC
CKT	400kV KORBA(NTPC)-RAIPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV KORBA(NTPC)-RAIPUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV KORBA(NTPC)-SIPAT(NTPC)	OSFT	14-01-2025	12:17:00	14-01-2025	19:06:00	0.28	6.82	0.00	0.00	0.00		* Emergency outage availed for attending hot spot on the R ph line jumper at Loc No # 5
CKT	400kV KORADI(MSEB)-SATPURA(MPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV LARA(NTPC)-CHAMPA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV LARA(NTPC)-CHAMPA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV LARA(NTPC)-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV LARA(NTPC)-KOTRA PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV MAUDA(NTPC)-WARDHA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV MAUDA(NTPC)-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV PADGHE GIS-KUDUS(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV PADGHE GIS-KUDUS(MSETCL)-2	OSPT	25-01-2025	11:10:00	25-01-2025	18:37:00	0.31	7.45	0.00	0.00	0.00		* AMP of Line Equipment
CKT	400kV PARLI-PARLI(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV PARLI-PARLI(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV PARLI-PUNE GIS-1	LCSD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Indigrid requested for outage of lines for connecting the LILO with Kallam substation
CKT	400kV PARLI-PUNE GIS-2	OMSU	24-01-2025	16:38:00	24-01-2025	18:44:00	0.09	0.00	2.10	0.00	0.00		* Line tripped on receving DT: 01.02.2025 20:10:24 INDIA (60001973)* Line name shall be updated in SAP. ** As Parli is not terminating station- LILO at Kallam SS (Indigrid)** Hence Now line is Pune-Kallam #2 Line (Which has been tripped due to receipt of DT from Kallam end)
CKT	400kV PUNE-PUNE GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV PUNE-PUNE GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	14-01-2025	10:30:00	31-01-2025	23:59:59	17.56	0.00	0.00	0.00	421.50		* Line H/T as per WRLDC instructions for Power Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	07-01-2025	10:25:00	12-01-2025	17:02:00	5.28	0.00	0.00	0.00	126.62		* Line H/T as per WRLDC instructions for Power Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRLDC instructions for Power regulation
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRLDC instructions for Power Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRLDC instructions for Power Regulation
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	01-01-2025	00:00:01	03-01-2025	12:41:00	2.53	0.00	0.00	0.00	60.68		* Line H/T as per WRLDC instructions for Power Regulation.

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifiyin	Detailed Reasons for Outage
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AKOLA(MSETCL)-1	OSFT	08-01-2025	12:18:00	08-01-2025	20:41:00	0.35	8.38	0.00	0.00	0.00		* Emergency outage availed to attend hot spot in T-section of 419Main bay and 420 Tie bay
							0.35	8.38	0.00	0.00	0.00	98.87	
CKT	400kV WARDHA-AKOLA(MSETCL)-2	OSFT	09-01-2025	09:37:00	09-01-2025	23:15:00	0.57	13.63	0.00	0.00	0.00		* Emergency outage availed to attend open jumper in B-phase at location no. 254 (Tension tower) .
CKT	400kV WARDHA-AKOLA(MSETCL)-2	OSFD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Emergency line outage availed by MSTCL for attending 412 89B (R Phase) Isolator operating mechanism <(>&<)> misalignment issue at 400 kV Akola SS.
							31.57	13.63	0.00	0.00	744.00	98.17	
CKT	400kV WARDHA-AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AURANGABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-WARORA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-WARORA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARORA-PARLI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARORA-PARLI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV AURANGABAD-PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV AURANGABAD-PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BILASPUR-DHARAMJAYGARH	LMAC	21-01-2025	12:11:00	21-01-2025	13:08:00	0.04	0.00	0.00	0.95	0.00		* Emergency outage availed for safely descending a person climbed on 765kV D/C D'garh - Champa # 1 <(>&<)> 765KV D'garh - Bilaspur line at tower no. .4) peak which is hazardous condition for humen safety and grid security.
							0.04	0.00	0.00	0.95	0.00	100.00	
CKT	765kV BILASPUR-SEONI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BILASPUR-SEONI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV CHAMPA-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV CHAMPA-RAIPUR PS(DURG)-1	LVRD	01-01-2025	00:00:01	04-01-2025	09:05:00	3.38	0.00	0.00	0.00	81.08		* Line H/T as per WRLCD instructions for Voltage Regulation and SLR converted as BR at 23:46 hrs.@ Durg end.
CKT	765kV CHAMPA-RAIPUR PS(DURG)-1	LPRD	15-01-2025	00:59:00	31-01-2025	23:59:59	16.96	0.00	0.00	0.00	407.02		* Line H/T as per WRLCD instructions for Power Regulation.
CKT	765kV CHAMPA-RAIPUR PS(DURG)-1	LVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRLCD instruction and SLR at Durg PS is converted as BR at 04:02hrs for Voltage regulation.
							51.34	0.00	0.00	0.00	1,232.10	100.00	
CKT	765kV CHAMPA-RAIPUR PS(DURG)-2	LMAC	04-01-2025	11:19:00	04-01-2025	19:19:00	0.33	0.00	0.00	8.00	0.00		* Emergency outage availed by Champa TLM to remove Foreign material stuck to earth wire between loc 23-24
							0.33	0.00	0.00	8.00	0.00	100.00	
CKT	765kV CHAMPA-DHARAMJAYGARH-1	LMAC	21-01-2025	12:12:00	21-01-2025	13:22:00	0.05	0.00	0.00	1.17	0.00		* Emergency outage availed for safely descending a person climbed on 765kV D/C D'garh - Champa # 1 <(>&<)> 765KV D'garh - Bilaspur line at tower no. .4) peak which is hazardous condition for humen safety and grid security.
							0.05	0.00	0.00	1.17	0.00	100.00	
CKT	765kV RANCHI-DHARAMJAYGARH-1	OSPT	31-01-2025	10:25:00	31-01-2025	19:15:00	0.37	8.83	0.00	0.00	0.00		* Outage availed by ER I for Broken Disc Insulator Replacement at Loc No-370, Tightening of Jumper N<(>&<)>B, Hardwire fittings, CC Rings <(>&<)> other shutdown nature defects rectification works
							0.37	8.83	0.00	0.00	0.00	98.81	
CKT	765kV RANCHI-DHARAMJAYGARH-2	OSPT	30-01-2025	08:55:00	30-01-2025	21:20:00	0.52	12.42	0.00	0.00	0.00		* Outage availed by ER for Broken Disc Insulator Replacement at Loc No-370, Tightening of Jumper N<(>&<)>B, Hardwire fittings, CC Rings <(>&<)> other shutdown nature defects rectification works
							0.52	12.42	0.00	0.00	0.00	98.33	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-RAIPUR PS(DURG)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-TAMNAR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-TAMNAR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV-PUNE GIS-PADGHE GIS-1	OMSU	08-01-2025	14:39:00	08-01-2025	15:55:00	0.05	0.00	1.27	0.00	0.00		* Line tripped on R-G fault. Fault details at Padghe GIS: R-G, 4.9km, 8.76KA, At Pune GIS: R-G, 4.328KA, 196.8km. Fault is in Padghe TLM Jurisdiction. Fault is due to burning of crop wastage at Loc. No. 758.* 27.01.2025 19:34:44 INDIA (60001973)* Line tripped on R-G fault. Fault details at Padghe GIS: R-G, 4.9km, 8.76KA, At Pune GIS: R-G, 4.328KA, 196.8km. Fault is in Padghe TLM Jurisdiction. Fault is due to burning of crop wastage under the line at Loc. No. 758.* Fire was observed the line coridor of tower no.758 due to crop waste burning.
							0.05	0.00	1.27	0.00	0.00	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-1	LVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRLCD instructions for voltage Regulation and SLR charged as BR at 17:13 Hrs at Durg end.
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-3	LVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRLCD code for V/R and SLR converted as BR at 19:04Hrs. at Durg SS for VR.
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-4	LVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRLCD instructions for Voltage Regulation and SLR converted as BR at 18:13hrs.@ Durg end.
CKT	765kV RAIPUR PS(DURG)-WARDHA-4	LVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRLCD instructions for Voltage Regulation and SLR charged as BR at Durg end on dt 30.11.2023 at 00:41Hrs.
							62.00	0.00	0.00	0.00	1,488.00	100.00	
CKT	765kV SEONI-WARDHA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SEONI-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SOLAPUR-AURANGABAD-1	LVRD	29-01-2025	21:41:00	31-01-2025	23:59:59	2.10	0.00	0.00	0.00	50.32		* Line H/T as per WRLCD instructions for Voltage Regulation and SLR Covered as BR at 21:46 hrs at Aurangabad SS and at hrs at Solapur SS
CKT	765kV SOLAPUR-AURANGABAD-1	SVRD	20-01-2025	21:41:00	23-01-2025	13:25:00	2.66	0.00	0.00	0.00	63.73		* Line H/T as per WRLCD instructions for voltage Regulation and Convert SLR at both ends as BR.
CKT	765kV SOLAPUR-AURANGABAD-1	LVRD	28-01-2025	21:34:00	31-01-2025	23:59:59	3.10	0.00	0.00	0.00	74.43		* Line H/T as per WRLCD instructions for Voltage Regulation and SLR Covered as BR at 21:38 hrs at Aurangabad SS and at hrs at Solapur SS
							7.86	0.00	0.00	0.00	188.48	100.00	

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	765kV SOLAPUR-AURANGABAD-2	LVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR Covered as BR at 23:13 hrs at Aurangabad SS and SLR Covered as BR at 23:01 hrs at Solapur SS.
CKT	765kV SOLAPUR-AURANGABAD-2	GOVC	29-01-2025	10:31:00	29-01-2025	17:09:00	0.28	0.00	0.00	6.63	0.00		* Line tripped on Over Voltage protection at Aurangabad SS.
CKT	765kV SOLAPUR-AURANGABAD-2	LVRD	23-01-2025	20:18:00	27-01-2025	09:53:00	3.57	0.00	0.00	0.00	85.58		* Line H/T as per WRDLC instructions for voltage Regulation and Converted SLR to BR at both ends * 27.01.2025 12:23:15 INDIA (60070159)* Both side SLR Charged with 765KV Aurangabad- Solapur 2 Line @0953 hrs
CKT	765kV SOLAPUR-AURANGABAD-2	LVRD	01-01-2025	00:00:01	20-01-2025	06:53:00	19.29	0.00	0.00	0.00	462.88		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR Covered as BR at hrs at Aurangabad SS and at hrs at Solapur SS
							54.14	0.00	0.00	6.63	1,292.46	100.00	
CKT	765kV SOLAPUR-PUNE GIS			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SIPAT(NTPC)-BILASPUR-1			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SIPAT(NTPC)-BILASPUR-2			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV WARDHA-AURANGABAD-1	LVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR Covered as BR at 00:41hrs at Wardha SS .
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	765kV WARDHA-AURANGABAD-2	LVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for Voltage Regulation at 10:51 and SLR Covered as BR at 12:05 hrs at Wardha SS.
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	765kV WARDHA-AURANGABAD-3	OSFT	29-01-2025	12:41:00	29-01-2025	20:50:00	0.34	8.15	0.00	0.00	0.00		* Emergency outage availed for attending problem in main bay isolator (89B) at Aurangabad SS.
CKT	765kV WARDHA-AURANGABAD-3	LVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for Voltage Regulation .
							31.34	8.15	0.00	0.00	744.00	98.90	
CKT	765kV WARDHA-AURANGABAD-4	LVRD	01-01-2025	00:00:01	16-01-2025	10:17:00	15.43	0.00	0.00	0.00	370.28		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR Covered as BR at 02:08hs at Wardha SS .
							15.43	0.00	0.00	0.00	370.28	100.00	
LNR	80MVAR,LR OF WARDHA-2 AT AURANGABAD			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF WARDHA-1 AT AURANGABAD			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-2 AT AURANGABAD			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-1 AT AURANGABAD			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-2 AT AURANGABAD			00:00:00		00:00:00		0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRDLC instructions for Voltage Regulation
							93.00	0.00	0.00	0.00	2,232.00	100.00	
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	21-01-2025	07:43:00	21-01-2025	21:35:00	0.58	0.00	0.00	0.00	13.87		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	22-01-2025	06:47:00	22-01-2025	18:10:00	0.47	0.00	0.00	0.00	11.38		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	30-01-2025	07:40:00	30-01-2025	18:15:00	0.44	0.00	0.00	0.00	10.58		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	23-01-2025	08:30:00	23-01-2025	13:25:00	0.21	0.00	0.00	0.00	4.92		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
							63.70	0.00	0.00	0.00	1,528.75	100.00	
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	10-01-2025	07:20:00	10-01-2025	20:22:00	0.54	0.00	0.00	0.00	13.03		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	09-01-2025	08:43:00	09-01-2025	20:06:00	0.47	0.00	0.00	0.00	11.38		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	02-01-2025	08:43:00	02-01-2025	20:26:00	0.49	0.00	0.00	0.00	11.72		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	03-01-2025	06:58:00	03-01-2025	21:30:00	0.61	0.00	0.00	0.00	14.53		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	04-01-2025	07:04:00	04-01-2025	21:19:00	0.59	0.00	0.00	0.00	14.25		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	01-01-2025	07:06:00	01-01-2025	13:36:00	0.27	0.00	0.00	0.00	6.50		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	12-01-2025	07:34:00	12-01-2025	20:36:00	0.54	0.00	0.00	0.00	13.03		* SLR H/T as per WRDLC instructions for VR
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	06-01-2025	07:00:00	06-01-2025	13:12:00	0.26	0.00	0.00	0.00	6.20		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	19-01-2025	07:35:00	19-01-2025	20:41:00	0.55	0.00	0.00	0.00	13.10		* SLR H/T as per WRDLC instructions for VR
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	13-01-2025	06:55:00	13-01-2025	21:19:00	0.60	0.00	0.00	0.00	14.40		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	18-01-2025	08:08:00	18-01-2025	21:26:00	0.55	0.00	0.00	0.00	13.30		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	27-01-2025	06:38:00	27-01-2025	09:53:00	0.14	0.00	0.00	0.00	3.25		* SLR H/T as per WRDLC instructions for VR* 27.01.2025 12:10:40 INDIA (60070159)* SLR Charged with 765KV Aurangabad- Solapur 2 Line @0953 hrs
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	26-01-2025	07:58:00	26-01-2025	13:11:00	0.22	0.00	0.00	0.00	5.22		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	25-01-2025	08:31:00	25-01-2025	19:17:00	0.45	0.00	0.00	0.00	10.77		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	08-01-2025	07:41:00	08-01-2025	20:15:00	0.52	0.00	0.00	0.00	12.57		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	14-01-2025	08:27:00	14-01-2025	19:36:00	0.47	0.00	0.00	0.00	11.15		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	16-01-2025	08:56:00	16-01-2025	13:16:00	0.18	0.00	0.00	0.00	4.33		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	15-01-2025	08:45:00	15-01-2025	22:36:00	0.58	0.00	0.00	0.00	13.85		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	11-01-2025	08:32:00	11-01-2025	19:29:00	0.46	0.00	0.00	0.00	10.95		* SLR H/T as per WRDLC instructions for VR

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	24-01-2025	09:21:00	31-01-2025	23:59:59	7.61	0.00	0.00	0.00	182.65		* SLR H/T as per WRLDC instructions for VR
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	24-01-2025	09:21:00	31-01-2025	23:59:59	7.61	0.00	0.00	0.00	182.65		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SEONI-1 AT BILASPUR			00:00:00		00:00:00	23.71	0.00	0.00	0.00	568.83	100.00	
LNR	240MVAR,SWLR OF SEONI-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAJNANGAON-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAJNANGAON-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DHARAMJYGARH AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-2 AT KORBA PS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	330MVAR,SWLR OF JABALPUR-1 AT KORBA PS			00:00:00		00:00:00	31.00	0.00	0.00	0.00	744.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-2 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-1 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DURG-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DURG-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-1 AT PUNE	SVRD	27-01-2025	10:42:00	31-01-2025	23:59:59	4.55	0.00	0.00	0.00	109.30	100.00	* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PUNE	SVRD	27-01-2025	10:43:00	31-01-2025	23:59:59	4.55	0.00	0.00	0.00	109.28	100.00	* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	50MVAR,SWLR OF PUNE GIS-3 AT PUNE	SVRD	28-01-2025	10:57:00	31-01-2025	23:59:59	3.54	0.00	0.00	0.00	85.05	100.00	* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	50MVAR,SWLR OF PUNE GIS-4 AT PUNE	SVRD	28-01-2025	10:58:00	31-01-2025	23:59:59	3.54	0.00	0.00	0.00	85.03		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	50MVAR,SWLR OF PUNE GIS-4 AT PUNE	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF SHOLAPUR AT PUNE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for V
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF JARSUGUDA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF JARSUGUDA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF CHAMPA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF CHAMPA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-3 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-4 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KORBA-3 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTA BLE TO ISTS Licensee	OUTAGE ATTRIBUTA BLE To Others	OUTAGE ATTRIBUTA BLE To System Constraint	OUTAGE ATTRIBUTA BLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	240MVAR,SWLR OF WARDHA-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80 MVAR 765 KV SPARE COLD REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF KARAD AT SHOLAPUR	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	21-01-2025	10:59:00	21-01-2025	17:57:00	0.29	0.00	0.00	0.00	6.97		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	22-01-2025	09:33:00	22-01-2025	19:52:00	0.43	0.00	0.00	0.00	10.32		* SLR Charged as BR H/T as per WRLDC instructions for Voltage Regulation.
							31.72	0.00	0.00	0.00	761.29	100.00	
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	24-01-2025	09:20:00	24-01-2025	19:03:00	0.41	0.00	0.00	0.00	9.72		* BR H/T as per WRLDC instructions for VR
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	16-01-2025	08:58:00	16-01-2025	13:20:00	0.18	0.00	0.00	0.00	4.37		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	15-01-2025	09:22:00	15-01-2025	18:03:00	0.36	0.00	0.00	0.00	8.68		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	13-01-2025	09:31:00	13-01-2025	19:45:00	0.43	0.00	0.00	0.00	10.23		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	25-01-2025	09:45:00	25-01-2025	19:24:00	0.40	0.00	0.00	0.00	9.65		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	24-01-2025	09:20:00	24-01-2025	20:23:00	0.46	0.00	0.00	0.00	11.05		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	10-01-2025	10:18:00	11-01-2025	21:43:00	1.48	0.00	0.00	0.00	35.42		* SLR H/T as per WRLDC instructions for V
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	14-01-2025	11:50:00	14-01-2025	17:58:00	0.26	0.00	0.00	0.00	6.13		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	08-01-2025	10:17:00	08-01-2025	20:14:00	0.42	0.00	0.00	0.00	9.95		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	04-01-2025	09:57:00	04-01-2025	21:28:00	0.48	0.00	0.00	0.00	11.52		* SLR H/T as per WRLDC instructions VR
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	27-01-2025	09:15:00	27-01-2025	09:53:00	0.03	0.00	0.00	0.00	0.63		* SLR H/T as per WRLDC instructions for Voltage Regulation.* 27.01.2025 12:09:25 INDIA (60070159)* SLR Charged with 765KV Aurangabad- Solapur 2 Line @0953 hrs
							66.91	0.00	0.00	0.00	1,605.35	100.00	
LNR	240MVAR,SWLR OF PUNE AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAICHUR-2 AT SOLAPUR	OMSU	01-01-2025	00:00:01	31-01-2025	23:59:59	31.00	0.00	744.00	0.00	0.00		* SLR tripped due to implementation of Ferroresonance scheme at Solapur s/s as 765KV Solapur Raichur ckt#2 Auto Reclosed on R-E fault.
							31.00	0.00	744.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAICHUR-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF AURANGABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF AURANGABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF NIZAMABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF NIZAMABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-4 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT SHOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	500MW,BHADRAWATI HVDC BTB POLE-1	OSFT	23-01-2025	11:28:00	25-01-2025	19:08:00	2.32	55.67	0.00	0.00	0.00		* Emergency outage availed to attend thyristor redundancy lost alarm
							2.32	55.67	0.00	0.00	0.00	92.52	
VALVE_HALL	500MW,BHADRAWATI HVDC BTB POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	POLE1 VALVE HALL, RAIGARH HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	POLE2 VALVE HALL, RAIGARH HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT AURANGABAD	OSPT	10-01-2025	10:32:00	10-01-2025	18:28:00	0.33	7.93	0.00	0.00	0.00		* ICT outage for AMP works.
							0.33	7.93	0.00	0.00	0.00	98.93	
XMER	315MVA,400/220kV ICT-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Jan-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-2 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-5 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-6 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	TBCB-500MVA,400/220kV ICT-4 AT DHARAMJAY			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-6 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MAPUSA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MAPUSA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT MAPUSA	OSFT	07-01-2025	08:25:00	07-01-2025	20:59:00	0.52	12.57	0.00	0.00	0.00		* Emergency outage availed to attend Y phase CT oil leakage in 209 bay .
							0.52	12.57	0.00	0.00	0.00	98.31	
XMER	315MVA,400/220kV ICT-1 AT NAVI MUMBAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT NAVI MUMBAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT PADGHE GIS	OSFT	27-01-2025	17:25:00	27-01-2025	19:17:00	0.08	1.87	0.00	0.00	0.00		* ESD of 765/400KV ICT#2 at Padghe GIS for removal of Kite thread (Manjha) in ICT#2 Rph
							0.08	1.87	0.00	0.00	0.00	99.75	
XMER	1500MVA,765/400kV ICT-3 AT PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT PARLI	OSFT	11-01-2025	11:58:00	11-01-2025	16:43:00	0.20	4.75	0.00	0.00	0.00		* ESD availed by PARLI for rectification of Isolator 419-89B B-Ph alignment issue (towards ICT-1 side)
							0.20	4.75	0.00	0.00	0.00	99.36	
XMER	500MVA,400/220kV ICT-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	1500MVA,765/400kV ICT-1 AT SEONI	OMST	24-01-2025	11:09:00	24-01-2025	11:40:00	0.02	0.52	0.00	0.00	0.00		* Tripped during Tie LBB retrofitting works** While removing wire from terminal 20, mistakenly screw drive slip and touched with positive terminal 19, which extend tripping operation of Group-B Relay (765KV side AT#1). Tripped at 11:09Hrs after that regularised by obtain WRDLC Outage Code at 11:40Hrs for Tie bay LBB retrofitting work.** As outage of 765KV AT#1 was already planned in this month for testing of same Tie LBB relay hence after tripping complete testing were performed and actual operation of CB tripping's are tested successfully for back trip command through LBB relay. AT#1 charged at 18:30 hrs
							0.02	0.52	0.00	0.00	0.00	99.93	
XMER	1500MVA,765/400kV ICT-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SEONI	OMSU	24-01-2025	10:54:00	24-01-2025	20:33:00	0.40	0.00	9.65	0.00	0.00		* Tie LBB Relay retrofitting and testing work @ Seoni S/S
							0.40	0.00	9.65	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SEONI	OMSU	31-01-2025	10:40:00	31-01-2025	18:05:00	0.31	0.00	7.42	0.00	0.00		* Tie LBB Relay retrofitting and testing work @ Seoni S/S
							0.31	0.00	7.42	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT SOLAPUR	SCSD	20-01-2025	08:52:00	20-01-2025	20:17:00	0.48	0.00	0.00	0.00	11.42		* For Spare Change over Note : Dia to be kept open. Last Spare Change over done on 07.11.2023
							0.48	0.00	0.00	0.00	11.42	100.00	
XMER	315MVA,400/220kV ICT-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT TAMNAR PS	OSPT	29-01-2025	09:00:00	29-01-2025	22:41:00	0.57	13.68	0.00	0.00	0.00		* For AMP Works
							0.57	13.68	0.00	0.00	0.00	98.16	
XMER	1500MVA,765/400kV ICT-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	</