

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifiyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	23-11-2024	09:25:00	30-11-2024	23:59:59	7.61	0.00	0.00	0.00	182.58		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	27-11-2024	09:46:00	27-11-2024	21:54:00	0.51	0.00	0.00	0.00	12.13		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	25-11-2024	09:23:00	25-11-2024	20:22:00	0.46	0.00	0.00	0.00	10.98		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	30-11-2024	10:09:00	30-11-2024	23:08:00	0.54	0.00	0.00	0.00	12.98		* B/R H/T for V/R.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	18-11-2024	07:50:00	18-11-2024	21:53:00	0.59	0.00	0.00	0.00	14.05		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	19-11-2024	08:56:00	19-11-2024	22:02:00	0.55	0.00	0.00	0.00	13.10		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	21-11-2024	07:11:00	21-11-2024	23:34:00	0.68	0.00	0.00	0.00	16.38		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	05-11-2024	07:03:00	21-11-2024	21:56:00	12.62	0.00	0.00	0.00	302.88		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	22-11-2024	10:02:00	22-11-2024	21:55:00	0.50	0.00	0.00	0.00	11.88		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	26-11-2024	09:17:00	26-11-2024	17:02:00	0.32	0.00	0.00	0.00	7.75		* BR H/T as per WRLDLC instructions for Voltage Regulation.
							24.38	0.00	0.00	0.00	584.71	100.00	
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	06-11-2024	07:28:00	17-11-2024	21:43:00	11.59	0.00	0.00	0.00	273.25		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	19-11-2024	10:39:00	20-11-2024	19:50:00	1.39	0.00	0.00	0.00	33.18		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	25-11-2024	15:55:00	25-11-2024	20:47:00	0.20	0.00	0.00	0.00	4.87		* BR H/T as per WRLDLC instructions for VR
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
							73.17	0.00	0.00	0.00	1,756.30	100.00	
BSR	50MVAR, BUS REACTOR-1 AT BHADRAWATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-2 AT BHADRAWATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation
							60.00	0.00	0.00	0.00	1,440.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-2 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-3 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for VR
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	16-11-2024	09:02:00	16-11-2024	21:32:00	0.52	0.00	0.00	0.00	12.50		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	27-11-2024	07:52:00	27-11-2024	20:35:00	0.53	0.00	0.00	0.00	12.72		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	05-11-2024	14:27:00	07-11-2024	04:09:00	1.57	0.00	0.00	0.00	37.70		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	08-11-2024	10:33:00	11-11-2024	22:18:00	3.49	0.00	0.00	0.00	83.75		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	23-11-2024	08:52:00	23-11-2024	20:50:00	0.50	0.00	0.00	0.00	11.97		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	19-11-2024	15:02:00	20-11-2024	02:12:00	0.47	0.00	0.00	0.00	11.17		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	24-11-2024	09:47:00	24-11-2024	19:53:00	0.42	0.00	0.00	0.00	10.10		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	15-11-2024	09:51:00	16-11-2024	04:54:00	0.79	0.00	0.00	0.00	19.05		* BR H/T as per WRLDLC instructions for Voltage Regulation.
							128.29	0.00	0.00	0.00	3,078.96	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	09-11-2024	10:11:00	30-11-2024	23:59:59	21.58	0.00	0.00	0.00	517.82		* BR H/T as per WRLDLC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	07-11-2024	09:19:00	30-11-2024	23:59:59	23.61	0.00	0.00	0.00	566.68		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	18-11-2024	10:00:00	30-11-2024	23:59:59	12.58	0.00	0.00	0.00	302.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDLC instructions for Voltage Regulation

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	05-11-2024	08:47:00	13-11-2024	17:59:00	8.38	0.00	0.00	0.00	201.20		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	17-11-2024	09:53:00	18-11-2024	00:08:00	0.59	0.00	0.00	0.00	14.25		
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	15-11-2024	09:06:00	15-11-2024	20:45:00	0.49	0.00	0.00	0.00	11.65		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	24-11-2024	09:21:00	24-11-2024	19:47:00	0.44	0.00	0.00	0.00	10.43		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	16-11-2024	09:16:00	16-11-2024	20:13:00	0.46	0.00	0.00	0.00	10.95		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	19-11-2024	08:48:00	19-11-2024	23:08:00	0.60	0.00	0.00	0.00	14.33		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	11-11-2024	09:38:00	13-11-2024	17:59:00	2.35	0.00	0.00	0.00	56.35		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	14-11-2024	09:41:00	15-11-2024	23:34:00	1.58	0.00	0.00	0.00	37.88		* BR H/T as per WRLDC instructions for Voltage Regulation.
							372.66	0.00	0.00	0.00	8,943.54	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	06-11-2024	09:26:00	07-11-2024	03:19:00	0.75	0.00	0.00	0.00	17.88		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	30-11-2024	10:14:00	30-11-2024	22:35:00	0.52	0.00	0.00	0.00	12.35		* B/R H/T for V/R.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	28-11-2024	09:03:00	28-11-2024	18:31:00	0.39	0.00	0.00	0.00	9.47		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	05-11-2024	09:38:00	05-11-2024	20:56:00	0.47	0.00	0.00	0.00	11.30		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	16-11-2024	09:11:00	16-11-2024	20:36:00	0.48	0.00	0.00	0.00	11.42		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	15-11-2024	09:47:00	15-11-2024	22:03:00	0.51	0.00	0.00	0.00	12.27		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	18-11-2024	10:21:00	18-11-2024	20:20:00	0.42	0.00	0.00	0.00	9.98		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	19-11-2024	10:19:00	19-11-2024	20:21:00	0.42	0.00	0.00	0.00	10.03		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	23-11-2024	08:38:00	23-11-2024	19:50:00	0.47	0.00	0.00	0.00	11.20		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	13-11-2024	10:06:00	13-11-2024	20:51:00	0.45	0.00	0.00	0.00	10.75		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	08-11-2024	08:58:00	08-11-2024	18:01:00	0.38	0.00	0.00	0.00	9.05		* BR H/T as per WRLDC instructions for VR. RLDC Code: 11691
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Power Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	10-11-2024	07:04:00	10-11-2024	18:31:00	0.48	0.00	0.00	0.00	11.45		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	07-11-2024	09:35:00	07-11-2024	18:40:00	0.38	0.00	0.00	0.00	9.08		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	09-11-2024	09:31:00	09-11-2024	18:56:00	0.39	0.00	0.00	0.00	9.42		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	04-11-2024	09:26:00	04-11-2024	20:00:00	0.44	0.00	0.00	0.00	10.57		* BR H/T as per WRLDC instructions for Voltage Regulation.
							246.95	0.00	0.00	0.00	5,926.22	100.00	
BSR	63MVAR, BUS REACTOR-1 AT NAVI MUMBAI	SVRD	01-11-2024	00:00:01	01-11-2024	02:39:00	0.11	0.00	0.00	0.00	2.65		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	63MVAR, BUS REACTOR-1 AT NAVI MUMBAI	SVRD	06-11-2024	09:50:00	25-11-2024	01:02:00	18.63	0.00	0.00	0.00	447.20		* BR H/T as per WRLDC instructions for Voltage Regulation.
							18.74	0.00	0.00	0.00	449.85	100.00	
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	08-11-2024	07:22:34	08-11-2024	20:15:00	0.54	0.00	0.00	0.00	12.87		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	14-11-2024	07:26:00	14-11-2024	21:46:00	0.60	0.00	0.00	0.00	14.33		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	30-11-2024	07:17:00	30-11-2024	20:32:00	0.55	0.00	0.00	0.00	13.25		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	05-11-2024	09:33:00	05-11-2024	21:18:00	0.49	0.00	0.00	0.00	11.75		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	24-11-2024	09:44:00	24-11-2024	19:47:00	0.42	0.00	0.00	0.00	10.05		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	23-11-2024	07:27:00	23-11-2024	20:19:00	0.54	0.00	0.00	0.00	12.87		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	21-11-2024	07:02:00	21-11-2024	21:33:00	0.61	0.00	0.00	0.00	14.52		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	15-11-2024	06:36:00	15-11-2024	20:17:00	0.57	0.00	0.00	0.00	13.68		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	19-11-2024	09:56:00	19-11-2024	20:28:00	0.44	0.00	0.00	0.00	10.53		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	18-11-2024	07:56:00	18-11-2024	21:08:00	0.55	0.00	0.00	0.00	13.20		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	16-11-2024	08:37:00	16-11-2024	20:14:00	0.48	0.00	0.00	0.00	11.62		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	22-11-2024	07:36:00	22-11-2024	20:25:00	0.53	0.00	0.00	0.00	12.82		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	13-11-2024	09:38:00	13-11-2024	21:37:00	0.50	0.00	0.00	0.00	11.98		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	17-11-2024	09:33:00	17-11-2024	19:20:00	0.41	0.00	0.00	0.00	9.78		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	26-11-2024	09:11:00	26-11-2024	19:48:00	0.44	0.00	0.00	0.00	10.62		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	29-11-2024	07:40:00	29-11-2024	19:49:00	0.51	0.00	0.00	0.00	12.15		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	25-11-2024	08:01:00	25-11-2024	20:10:00	0.47	0.00	0.00	0.00	11.15		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	27-11-2024	08:25:00	27-11-2024	20:34:00	0.51	0.00	0.00	0.00	12.15		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	28-11-2024	09:16:00	28-11-2024	20:21:00	0.46	0.00	0.00	0.00	11.08		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	11-11-2024	07:22:00	11-11-2024	19:18:00	0.50	0.00	0.00	0.00	11.93		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	06-11-2024	07:15:00	07-11-2024	03:22:00	0.84	0.00	0.00	0.00	20.12		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	12-11-2024	09:08:00	12-11-2024	21:26:00	0.51	0.00	0.00	0.00	12.30		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	09-11-2024	09:18:00	09-11-2024	21:21:00	0.50	0.00	0.00	0.00	12.05		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	04-11-2024	10:44:00	05-11-2024	04:29:00	0.74	0.00	0.00	0.00	17.75		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	07-11-2024	09:33:00	07-11-2024	23:41:00	0.59	0.00	0.00	0.00	14.13		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	01-11-2024	00:00:01	30-11-2024								

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifiyin	Detailed Reasons for Outage
BSR	63MVAR, BUS REACTOR-1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT PUNE	SVRD	05-11-2024	10:34:00		02:26:00	14.66	0.00	0.00	0.00	351.87		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	50MVAR, BUS REACTOR-1 AT PUNE	SVRD	01-11-2024	00:00:01	01-11-2024	02:54:00	0.12	0.00	0.00	0.00	2.90		* BR H/T as per WRLDG instructions for Voltage Regulation.
							14.78	0.00	0.00	0.00	354.77	100.00	
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	17-11-2024	10:18:00	17-11-2024	20:17:00	0.42	0.00	0.00	0.00	9.98		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	30-11-2024	09:00:00	30-11-2024	20:02:00	0.46	0.00	0.00	0.00	11.03		* Br H/T for V/R.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	25-11-2024	08:52:00	25-11-2024	13:20:00	0.19	0.00	0.00	0.00	4.47		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	26-11-2024	09:21:00	26-11-2024	18:50:00	0.40	0.00	0.00	0.00	9.48		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	29-11-2024	09:39:00	29-11-2024	19:49:00	0.42	0.00	0.00	0.00	10.17		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	27-11-2024	08:49:00	27-11-2024	20:31:00	0.49	0.00	0.00	0.00	11.70		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	09-11-2024	09:20:00	09-11-2024	21:22:00	0.50	0.00	0.00	0.00	12.03		* BR H/T as per WRLDG instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	13-11-2024	09:37:00	13-11-2024	20:36:00	0.46	0.00	0.00	0.00	10.98		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	07-11-2024	09:18:00	07-11-2024	20:29:00	0.47	0.00	0.00	0.00	11.18		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	08-11-2024	09:19:00	09-11-2024	02:06:00	0.70	0.00	0.00	0.00	16.78		* BR H/T as per WRLDG instructions for VR RLDC Code:11/695 <?&<?> NL-11/588
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	16-11-2024	08:31:00	16-11-2024	21:21:00	0.54	0.00	0.00	0.00	12.83		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	14-11-2024	08:37:00	30-11-2024	23:59:59	16.64	0.00	0.00	0.00	399.38		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	19-11-2024	08:32:00	19-11-2024	20:12:00	0.49	0.00	0.00	0.00	11.67		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	12-11-2024	09:38:00	12-11-2024	21:29:00	0.49	0.00	0.00	0.00	11.85		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	05-11-2024	09:38:00	06-11-2024	21:39:00	1.50	0.00	0.00	0.00	36.02		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	18-11-2024	07:48:00	18-11-2024	20:15:00	0.52	0.00	0.00	0.00	12.45		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	21-11-2024	06:57:00	21-11-2024	19:43:00	0.53	0.00	0.00	0.00	12.77		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	22-11-2024	08:33:00	22-11-2024	20:33:00	0.50	0.00	0.00	0.00	12.00		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	24-11-2024	09:46:00	24-11-2024	19:52:00	0.42	0.00	0.00	0.00	10.10		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	11-11-2024	08:50:00	11-11-2024	21:34:00	0.53	0.00	0.00	0.00	12.73		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	15-11-2024	08:45:00	15-11-2024	20:18:00	0.48	0.00	0.00	0.00	11.55		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	04-11-2024	16:57:00	05-11-2024	00:46:00	0.33	0.00	0.00	0.00	7.82		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	28-11-2024	09:20:00	28-11-2024	20:19:00	0.46	0.00	0.00	0.00	10.98		* BR H/T as per WRLDG instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	23-11-2024	08:39:00	23-11-2024	20:13:00	0.48	0.00	0.00	0.00	11.57		* BR H/T as per WRLDG instructions for Voltage Regulation.
							238.42	0.00	0.00	0.00	5,721.52	100.00	
BSR	63MVAR, BUS REACTOR-1 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* BR H/T as per WRLDG instructions for VR
							30.00	0.00	0.00	0.00	720.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KORBA(CSEB)-BUDDHIPADAR(OPTCL)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AKOLA(MSETCL)-AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AKOLA(MSETCL)-AURANGABAD-2	OSFT	14-11-2024	09:57:00	14-11-2024	16:11:00	0.26	6.23	0.00	0.00	0.00		* Emergency outage availed for attending Hot spot in Middle phase Jumper on Multi Circuit Tower No 768 of 400 KV Akola -Aurangabad Ckt 2.
							0.26	6.23	0.00	0.00	0.00	99.13	
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-DHARIWAL(CESC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-PARLI-1	OSFT	04-11-2024	17:30:00	04-11-2024	22:53:00	0.22	5.38	0.00	0.00	0.00		* Emergency outage availed to attend hot spot in Line Isolator at Parli end.
							0.22	5.38	0.00	0.00	0.00	99.25	
CKT	400kV BHATAPARA-BHILAI(CSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHILAI(CSEB)-BHADRAWATI-2	LPPT	14-11-2024	19:37:00	15-11-2024	00:35:00	0.21	4.97	0.00	0.00	0.00		* Line tripped on R-Y fault.* Fault details at Bhadrawati end :-* A)M1- FD:227km FC: 2.6KA B)M2- FD:228km FC: 2.6KA* Fault details at Bhilai end :-* A)M1- FD:93.18km FC: 5.9KA B)M2- FD:93.65km FC: 5.8KA* Fault is in Durg TLM Jurisdiction. Faulty Phase position : Bottom and Middle (Twin Moose ACSR)* 04.12.2024 15:40:08 INDIA (60001973)* Foreign material (Advertising Parachute Balloon) found hanging on tower Earth x-arm of both circuit to Top, Middle & Bottom Conductor at Loc. No. 258.*
							0.21	4.97	0.00	0.00	0.00	99.31	
CKT	400kV BHILAI(CSEB)-KORADI(MSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DHARIWAL(CESC)-PARLI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHARSUGUDA-RAIGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHARSUGUDA-RAIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHARSUGUDA-RAIGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHARSUGUDA-RAIGARH-4	LCSD	14-11-2024	07:37:00	19-11-2024	16:30:00	5.37	0.00	0.00	0.00	128.88		* For Reconductoring work in 400KV Rourkela -Sundargarh line #4 between T No-258 to T No-267 due to Multi Circuit Towers.
							5.37	0.00	0.00	0.00	128.88	100.00	
CKT	400kV KOLHAPUR GIS-MAPUSA-1	OSPT	09-11-2024	06:56:00	09-11-2024	18:30:00	0.48	11.57	0.00	0.00	0.00		* Line Bay AMP work. AR OF CKT 2 IN NON AUTO IS REQUIRED
							0.48	11.57	0.00	0.00	0.00	98.39	
CKT	400kV KOLHAPUR GIS-MAPUSA-2	OSPT	10-11-2024	06:57:00	10-11-2024	18:19:00	0.47	11.37	0.00	0.00	0.00		* Line Bay AMP work. AR OF CKT 1 IN NON AUTO IS REQUIRED
							0.47	11.37	0.00	0.00	0.00	98.42	
CKT	400kV KOLHAPUR(MSETCL)-KOLHAPUR GIS-1	OSFT	30-11-2024	20:29:00	30-11-2024	23:59:59	0.15	3.52	0.00	0.00	0.00		* Emergency Shutdown of 400KV Kolhapur(MS)-Kolhapur(PG) ckt#1 to attend Hotspot in Y-phase Wave trap dropper clamp at Kolhap

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV PARLI-PUNE GIS-1	LCSD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* Indigrid requested for outage of lines for connecting the LiLO with Kallam substation
							30.37	0.00	0.00	0.00	728.82	100.00	
CKT	400kV PARLI-PUNE GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE-PUNE GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE-PUNE GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-11-2024	00:00:01	25-11-2024	09:18:00	24.39	0.00	0.00	0.00	585.30		* Line kept out as per WRDLC instruction for Power regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	26-11-2024	07:36:00	28-11-2024	09:42:00	2.09	0.00	0.00	0.00	50.10		* Line H/T as per WRDLC instruction for Power regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LVRD	28-11-2024	22:00:12	30-11-2024	23:59:59	2.08	0.00	0.00	0.00	50.00		* Line H/T as per WRDLC instructions for Voltage Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* Line H/T as per WRDLC instructions for Power regulation
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* Line H/T as per WRDLC instructions for Power Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* Line H/T as per WRDLC instructions for Power Regulation
							118.56	0.00	0.00	0.00	2,845.40	100.00	
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	26-11-2024	10:08:00	30-11-2024	23:59:59	4.58	0.00	0.00	0.00	109.87		* Line H/T as per WRDLC instruction for Power regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	08-11-2024	16:09:00	25-11-2024	09:26:00	16.72	0.00	0.00	0.00	401.28		* Line H/T as per WRDLC instruction for Power regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* Line H/T as per WRDLC instructions for Power flow Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	SCSD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* For construction works of upcoming ICT-3.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	SCSD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* For Inter connection, Bus bar Stability test under construction project of For Extension of 765/400/220kV Pune (Shikrapur) GIS substation under Western Region Expansion Scheme – XXVI (WRES-XXVI).)
							111.30	0.00	0.00	0.00	2,671.15	100.00	
CKT	400kV PUNE GIS-PUNE-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE GIS-PUNE-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIGARH-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIGARH-KOTRA PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHADRAWATI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHADRAWATI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHADRAWATI-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHILAI(CSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-1	LMAC	14-11-2024	12:35:00	14-11-2024	14:47:00	0.09	0.00	0.00	2.20	0.00		* Emergency outage availed for removing foreign material (Tarpolin) found at Loc No 66 of Middle(Y) phase.
							0.09	0.00	0.00	2.20	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIPUR PS(DURG)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-WARDHA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-WARDHA-2	OSFT	02-11-2024	10:27:00	02-11-2024	14:44:00	0.18	4.28	0.00	0.00	0.00		* Emergency outage availed for removing foreign material from Wardha 2 Line Y-Ph conductor at Raipur End.
							0.18	4.28	0.00	0.00	0.00	99.41	
CKT	400kV RANCHI-SIPAT(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RANCHI-SIPAT(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-1	LCSD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* Reconductoring works.
							30.00	0.00	0.00	0.00	720.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-3	LCSD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* for reconductoring work on continuous basis
CKT	400kV ROURKELA-JHARSUGUDA-3	LCSD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* Reconductoring works
							60.00	0.00	0.00	0.00	1,440.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-4	LCSD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* for reconductoring work on continuous basis
							30.00	0.00	0.00	0.00	720.00	100.00	
CKT	400kV SEONI-KIRNAPUR(MPTCL)	OSPD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* 400KV Seoni Kirnapur Line approved outage availed by MPTCL.
							30.00	0.00	0.00	0.00	720.00	100.00	
CKT	400kV SEONI-SATPURA(MPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-1	OSPD	12-11-2024	10:41:00	15-11-2024	18:51:00	3.34	0.00	0.00	0.00	80.17		* Outage availed by NTPC for Annual Maintenance: Annual testing-IR, CT testing, isolator testing, breaker testing, isolator alignment
							3.34	0.00	0.00	0.00	80.17	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-3	OSPD	27-11-2024	10:03:00	30-11-2024	17:39:00	3.32	0.00	0.00	0.00	79.60		* Outage availed by NTPC for Annual Maintenance: Annual testing-IR, CT testing, isolator testing, breaker testing, isolator alignment.
							3.32	0.00	0.00	0.00	79.60	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifiyin	Detailed Reasons for Outage
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AKOLA(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AKOLA(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AURANGABAD-2	OMSU	23-11-2024	13:35:00	23-11-2024	18:11:00	0.19	0.00	4.60	0.00	0.00	100.00	* Line tripped on Y-B phase fault on 23.11.2024@13:35Hrs* Aurangabad End* Main-1: FC: ly-1.382 KA , lb-1.804kA ,FD: 370 Km* Main 2: FC: ly-1.316 KA , lb-1.801kA ,FD: 370km* Wardha End* Main-1: FC: ly-39.6 KA , lb-39kA, FD: 0 Km* Main 2: FC: ly-37.7 KA , lb-37.1kA ,FD: 0km* Due to Foreign Material* Faulty Phase position : Top and Middle (QUADS-MOOSE)* TWFL: Not Installed* Double End: NA
CKT	400kV WARDHA-WARORA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-WARORA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARORA-PARLI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARORA-PARLI-2	LEFT	02-11-2024	01:39:00	02-11-2024	02:51:00	0.05	1.20	0.00	0.00	0.00	99.83	* Line tripped on R-G fault. Fault details at Warora end :- M1) FC-4.76KA, FD-79.9km and Fault details at Parli end :- M1) FC-1.52KA , FD-269.6km. Fault is in Warora TLM Jurisdiction. Faulty Phase position : Top.* 04.12.2024 15:44:06 INDIA (60001973)* Fault is under Warora TLM.* Flashover mark observed on D-Shackle Bolt and a hole on CC Ring with bird droppings on insulator string and CC Ring at Loc No.234.
CKT	765kV AURANGABAD-PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV AURANGABAD-PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BILASPUR-DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BILASPUR-SEONI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BILASPUR-SEONI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV CHAMPA-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV CHAMPA-RAIPUR PS(DURG)-1	LVRD	18-11-2024	13:18:00	20-11-2024	09:51:00	1.86	0.00	0.00	0.00	44.55		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR Covered as BR at hrs at Durg PS.
CKT	765kV CHAMPA-RAIPUR PS(DURG)-1	LVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* Line H/T as per WRLDC instruction and SLR at Durg PS is converted as BR at 04:02hrs for Voltage regulation.
CKT	765kV CHAMPA-RAIPUR PS(DURG)-2	LVRD	01-11-2024	00:00:01	07-11-2024	11:56:00	31.86	0.00	0.00	0.00	764.55	100.00	* Line H/T as per WRLDC instructions for Voltage Regulation.
CKT	765kV CHAMPA-DHARAMJAYGARH-1			00:00:00		00:00:00	8.50	0.00	0.00	0.00	155.93	100.00	
CKT	765kV RANCHI-DHARAMJAYGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RANCHI-DHARAMJAYGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-3	OSPT	12-11-2024	07:17:00	12-11-2024	19:19:00	0.50	12.03	0.00	0.00	0.00	98.33	* Outage availed by Odissa for Rectification of SD nature defect for Punch point of CC AM cross Patrolling and Line Bay AMP
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-4	OSPT	16-11-2024	08:33:00	16-11-2024	20:06:00	0.48	11.55	0.00	0.00	0.00	98.40	* Rectification of SD nature defect for Punch point of CC AM cross Patrolling availed by ER
CKT	765kV KOTRA PS-RAIPUR PS(DURG)-1	OMST	09-11-2024	10:57:00	09-11-2024	11:34:00	0.03	0.62	0.00	0.00	0.00		* 765KV Raipur- Raigarh Kotara Ckt 1 Line Tripped at 09-11-2024 @ 10:57 Hrs at Durg End Only and Holding From Kotara End* 09.11.2024 19:35:17 INDIA (60020591)* Line tripped at Durg end only due to DT send from Kotra end during DC changer over.
CKT	765kV KOTRA PS-RAIPUR PS(DURG)-1	OSPT	20-11-2024	10:34:00	20-11-2024	18:56:00	0.35	8.37	0.00	0.00	0.00		* RECTIFICATION OF SHUTDOWN NATURE DEFECT
CKT	765kV KOTRA PS-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-TAMNAR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-TAMNAR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765KV-PUNE GIS-PADGHE GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-1	LVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* Line H/T as per WRLDC instructions for voltage Regulation and SLR charged as BR at 17:13 Hrs at Durg end.
CKT	765kV RAIPUR PS(DURG)-WARDHA-1	LVRD	01-11-2024	00:00:01	06-11-2024	09:41:00	5.40	0.00	0.00	0.00	129.68	100.00	* Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at 16:26hrs.@ Durg end.
CKT	765kV RAIPUR PS(DURG)-WARDHA-2	LVRD	29-11-2024	02:54:00	30-11-2024	23:59:59	35.40	0.00	0.00	0.00	849.68	100.00	* Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at hrs.@ Durg end.
CKT	765kV RAIPUR PS(DURG)-WARDHA-3	LVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	1.88	0.00	0.00	0.00	45.10	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-4	LVRD	06-11-2024	11:38:00	22-11-2024	10:18:00	15.94	0.00	0.00	0.00	382.67		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR converted as BR at hrs.@ Durg end.
CKT	765kV RAIPUR PS(DURG)-WARDHA-4	LVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR charged as BR at Durg end on dt 30.11.2023 at 00:41Hrs.
CKT	765kV SEONI-WARDHA-1			00:00:00		00:00:00	45.94	0.00	0.00	0.00	1,102.67	100.00	
CKT	765kV SEONI-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SOLAPUR-AURANGABAD-1	LVRD	06-11-2024	21:59:00	15-11-2024	10:50:00	8.54	0.00	0.00	0.00	204.85		* Line H/T as per WRLDC instructions for Voltage Regulation at 21:59/06-11-2024 and SLR Covered as BR at 21:22 hrs at Aurangabad SS and SLR Covered as BR at 21:23 hrs at Solapur SS.
CKT	765kV SOLAPUR-AURANGABAD-1	LVRD	25-11-2024	21:14:00	30-11-2024	23:59:59	5.12	0.00	0.00	0.00	122.77		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR Covered as BR at 21:19 hrs at Aurangabad SS and at hrs at Solapur SS .
CKT	765kV SOLAPUR-AURANGABAD-2	LVRD	01-11-2024	00:00:01	06-11-2024	12:47:00	13.66	0.00	0.00	0.00	327.62	100.00	
CKT	765kV SOLAPUR-AURANGABAD-2	LVRD	01-11-2024	00:00:01	06-11-2024	12:47:00	5.53	0.00	0.00	0.00	132.78		* Line H/T as per WRLDC instructions for Voltage Regulation and SLR Covered as BR at 01:58 hrs at Aurangabad SS and SLR Covered as BR at 00:47 hrs at Solapur SS .

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	765kV SOLAPUR-AURANGABAD-2	LVRD	16-11-2024	22:10:00	25-11-2024	08:13:00	8.42	0.00	0.00	0.00	202.05		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR Covered as BR at 23:09hrs at Aurangabad SS and at 22:29 hrs at Solapur SS .
CKT	765kV SOLAPUR-AURANGABAD-2	LVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR Covered as BR at 23:13 hrs at Aurangabad SS and SLR Covered as BR at 23:01 hrs at Solapur SS .
CKT	765kV SOLAPUR-PUNE GIS	OSFT	25-11-2024	10:20:00	25-11-2024	20:35:00	43.95	0.00	0.00	0.00	1,054.83	100.00	
CKT	765kV SIPAT(NTPC)-BILASPUR-1	OSPD	28-11-2024	10:21:00	30-11-2024	20:09:00	0.43	10.25	0.00	0.00	0.00	98.58	* ESD of 765kV Pune Solapur Line for rectification of Hotspot
CKT	765kV SIPAT(NTPC)-BILASPUR-2			00:00:00		00:00:00	2.41	0.00	0.00	0.00	57.80	100.00	* Outage availed by NTPC For Surge arrestor replacement and line equipments testing.
CKT	765kV WARDHA-AURANGABAD-1	LVRD	01-11-2024	00:00:01	18-11-2024	09:41:00	17.40	0.00	0.00	0.00	417.68	100.00	* Line H/T as per WRDLC instructions for Voltage Regulation and SLR Covered as BR at 12:22 hrs at Wardha SS .
CKT	765kV WARDHA-AURANGABAD-1	LVRD	30-11-2024	00:24:00	30-11-2024	23:59:59	0.98	0.00	0.00	0.00	23.60		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR Covered as BR at 00:41hrs at Wardha SS .
CKT	765kV WARDHA-AURANGABAD-2	LVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00	100.00	* Line H/T as per WRDLC instructions for Voltage Regulation at 10:51 and SLR Covered as BR at 12:05 hrs at Wardha SS.
CKT	765kV WARDHA-AURANGABAD-3	LVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00	100.00	* Line H/T as per WRDLC instructions for Voltage Regulation .
CKT	765kV WARDHA-AURANGABAD-4			00:00:00		00:00:00	30.00	0.00	0.00	0.00	720.00	100.00	
LNR	80MVAR,LR OF WARDHA-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF WARDHA-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	28-11-2024	09:04:00	28-11-2024	21:01:00	0.50	0.00	0.00	0.00	11.95		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	27-11-2024	08:38:00	27-11-2024	19:00:00	0.43	0.00	0.00	0.00	10.37		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	13-11-2024	08:38:00	13-11-2024	22:43:00	0.59	0.00	0.00	0.00	14.08		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	15-11-2024	06:38:00	30-11-2024	23:59:59	15.72	0.00	0.00	0.00	377.37		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	30-11-2024	07:14:00	30-11-2024	22:49:00	0.65	0.00	0.00	0.00	15.58		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	07-11-2024	15:07:00	07-11-2024	21:40:00	0.27	0.00	0.00	0.00	6.55		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	08-11-2024	09:29:00	10-11-2024	21:09:00	2.49	0.00	0.00	0.00	59.67		* SLR H/T as per WRDLC instructions for Voltage Regulation. RLDC code: *11/696 and NL-11/589
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	14-11-2024	07:22:00	14-11-2024	21:30:00	0.59	0.00	0.00	0.00	14.13		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	11-11-2024	07:25:00	12-11-2024	04:23:00	0.87	0.00	0.00	0.00	20.97		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	12-11-2024	09:11:00	13-11-2024	04:26:00	0.80	0.00	0.00	0.00	19.25		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	29-11-2024	08:30:00	29-11-2024	20:37:00	0.51	0.00	0.00	0.00	12.12		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	04-11-2024	07:22:00	06-11-2024	12:47:00	2.23	0.00	0.00	0.00	53.42		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	18-11-2024	09:51:00	18-11-2024	13:14:00	0.14	0.00	0.00	0.00	3.38		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	21-11-2024	09:51:00	21-11-2024	21:31:00	0.49	0.00	0.00	0.00	11.67		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	23-11-2024	06:59:00	23-11-2024	20:54:00	0.58	0.00	0.00	0.00	13.92		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	19-11-2024	08:50:00	19-11-2024	23:03:00	0.59	0.00	0.00	0.00	14.22		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD	SVRD	22-11-2024	06:45:00	22-11-2024	21:08:00	0.60	0.00	0.00	0.00	14.38		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SEONI-1 AT BILASPUR			00:00:00		00:00:00	4.63	0.00	0.00	0.00	110.99	100.00	
LNR	240MVAR,SWLR OF SEONI-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAJNANGAON-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAJNANGAON-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DHARAMJYGARH AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-2 AT KORBA PS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRDLC instructions for Voltage Regulation

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifiyin	Detailed Reasons for Outage
LNR	330MVAR,SWLR OF JABALPUR-1 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-2 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-1 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DURG-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DURG-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-1 AT PUNE	SVRD	08-11-2024	10:25:00	28-11-2024	23:17:00	20.54	0.00	0.00	0.00	492.87		* SLR H/T as per WRLDC instructions for Voltage Regulation. RLDC: 11/710
							20.54	0.00	0.00	0.00	492.87	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PUNE	SVRD	09-11-2024	09:27:00	28-11-2024	23:18:00	19.58	0.00	0.00	0.00	469.85		* SLR-H/T WRLDC instructions for VR
							19.58	0.00	0.00	0.00	469.85	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-3 AT PUNE	SVRD	01-11-2024	00:00:01	01-11-2024	02:42:00	0.11	0.00	0.00	0.00	2.70		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	50MVAR,SWLR OF PUNE GIS-3 AT PUNE	SVRD	15-11-2024	09:40:00	30-11-2024	23:59:59	15.60	0.00	0.00	0.00	374.33		* SLR H/T as per WRLDC instructions for Voltage Regulation.
							15.71	0.00	0.00	0.00	377.03	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-4 AT PUNE	SVRD	01-11-2024	00:00:01	01-11-2024	02:43:00	0.11	0.00	0.00	0.00	2.72		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	50MVAR,SWLR OF PUNE GIS-4 AT PUNE	SVRD	15-11-2024	09:43:00	30-11-2024	23:59:59	15.60	0.00	0.00	0.00	374.28		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	50MVAR,SWLR OF PUNE GIS-4 AT PUNE	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
							45.71	0.00	0.00	0.00	1,097.00	100.00	
LNR	240MVAR,SWLR OF SHOLAPUR AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
							30.00	0.00	0.00	0.00	720.00	100.00	
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation.
							300.36	0.00	0.00	0.00	7,208.60	100.00	
LNR	240MVAR,SWLR OF JARSUGUDA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF JARSUGUDA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF CHAMPA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF CHAMPA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-3 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-4 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KORBA-3 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80 MVAR 765 KV SPARE COLD REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF KARAD AT SHOLAPUR	SCSD	21-11-2024	10:26:00	23-11-2024	14:14:00	2.16	0.00	0.00	0.00	51.80		* 400 Kv Solapur Karad line Outage availed by Adani to restore the original configuration, we need to terminate the 220kV Solapur-Jeur Line from Jeur SS to 400kV Karad SS. This 400kV line, intended for load supply from 400kV Solapur to 400kV Karad, was temporarily charged at 200kV from Solapur to Jeur.
LNR	80MVAR,SWLR OF KARAD AT SHOLAPUR	SCSD	11-11-2024	07:32:00	12-11-2024	09:16:00	1.07	0.00	0.00	0.00	25.73		* 400kV Solapur-Karad line out since 2017 as diverted by MSETCL for their loading conditions. As per letter ref no.1494 dt 04.11.2024, 400kV Solapur (PG)-Karad line is planned for Charging on 13.11.24. In order to ensure protection healthiness Line Reactor (Charged as Bus Reactor) outage at Solapur end is required. Dia CB to be open at Solapur end.
LNR	80MVAR,SWLR OF KARAD AT SHOLAPUR	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
							33.23	0.00	0.00	0.00	797.53	100.00	
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	30-11-2024	10:12:00	30-11-2024	19:56:00	0.41	0.00	0.00	0.00	9.73		* SLR H/T for V/R.

Standard of Performance data for the month of Nov-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	29-11-2024	09:57:00	29-11-2024	20:16:00	0.43	0.00	0.00	0.00	10.32		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	13-11-2024	08:40:00	13-11-2024	20:37:00	0.50	0.00	0.00	0.00	11.95		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	15-11-2024	09:29:00	15-11-2024	10:50:00	0.06	0.00	0.00	0.00	1.35		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	09-11-2024	15:22:00	09-11-2024	21:59:00	0.28	0.00	0.00	0.00	6.62		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	14-11-2024	09:55:00	14-11-2024	19:17:00	0.39	0.00	0.00	0.00	9.37		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	11-11-2024	09:46:00	11-11-2024	21:43:00	0.50	0.00	0.00	0.00	11.95		* SLR H/T as per WRDLC instructions for Voltage Regulation.
							32.57	0.00	0.00	0.00	781.29	100.00	
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	21-11-2024	09:34:00	21-11-2024	19:38:00	0.42	0.00	0.00	0.00	10.07		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	0.00	0.00	720.00		* SLR H/T as per WRDLC instructions for Voltage Regulation.
							60.42	0.00	0.00	0.00	1,450.07	100.00	
LNR	240MVAR,SWLR OF PUNE AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAICHUR-2 AT SOLAPUR	OMSU	01-11-2024	00:00:01	30-11-2024	23:59:59	30.00	0.00	720.00	0.00	0.00		* SLR tripped due to implementation of Ferroresonance scheme at Solapur s/s as 765KV Solapur Raichur ckt#2 Auto Reclosed on R-E fault.
							30.00	0.00	720.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAICHUR-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF AURANGABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF AURANGABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF NIZAMABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF NIZAMABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-4 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT AURANGABAD	OSFT	26-11-2024	16:15:00	26-11-2024	20:54:00	0.19	4.65	0.00	0.00	0.00		* Emergency outage availed to attend hot spot in Statcom Coupling Xmer isolator 6-89T- Y1 Xmer side at Aurangabad S/s
							0.19	4.65	0.00	0.00	0.00	99.35	
STATCOM	-300/+300 MVAR STATCOM AT SHOLAPUR	OSPT	19-11-2024	09:28:00	19-11-2024	21:00:00	0.48	11.53	0.00	0.00	0.00		* 400KV/38.5KV ICT AMP and PRV trip logic modification work
							0.48	11.53	0.00	0.00	0.00	98.40	
VALVE_HALL	500MW,BHADRAWATI HVDC BTB POLE-1	GOMD	18-11-2024	22:19:00	19-11-2024	11:05:00	0.53	0.00	0.00	0.00	12.77		* Pole kept out as per WRDLC instructions for Voltage Regulation
VALVE_HALL	500MW,BHADRAWATI HVDC BTB POLE-1	OSPT	17-11-2024	08:15:00	18-11-2024	22:19:00	1.59	38.07	0.00	0.00	0.00		* Pole and West <(>&<)> South side converter transformer AMP works, instalation of cable tray, Connected Bay AMP works, WTI <(>&<)> OTI installation
							2.12	38.07	0.00	0.00	12.77	94.71	
VALVE_HALL	500MW,BHADRAWATI HVDC BTB POLE-2	OMSU	18-11-2024	19:04:00	19-11-2024	01:00:00	0.25	0.00	5.93	0.00	0.00		* Pole blocked on undervoltage protection operated (South side bus voltage was zero due to tripping of both Ramagundam 1 and 2 lines on O/V).
VALVE_HALL	500MW,BHADRAWATI HVDC BTB POLE-2	OSFT	08-11-2024	19:40:00	08-11-2024	22:10:00	0.10	2.50	0.00	0.00	0.00		* "Emergency outage availed to replace 2 Nos. of thyristor/gate card in" 1. Pole-2 South "B" Phase in valve YDLV T2-L14 and T-3 L-14."
							0.35	2.50	5.93	0.00	0.00	99.65	
VALVE_HALL	POLE1 VALVE HALL RAIGARH HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
VALVE_HALL	POLE2 VALVE HALL RAIGARH HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT BILASPUR	OSPT	22-11-2024	09:08:00	23-11-2024	00:16:00	0.63	15.13	0.00	0.00	0.00		* PRD, Buchholz Modification
							0.63	15.13	0.00	0.00	0.00	97.90	
XMER	1500MVA,765/400kV ICT-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

[illegible]