

**Standard of Performance data for the month of Aug-2023**  
**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	23-08-2023	08:42:00	23-08-2023	21:48:00	0.55	0.00	0.00	0.00	13.10		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	09-08-2023	09:34:00	11-08-2023	20:42:00	2.46	0.00	0.00	0.00	59.13		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	19-08-2023	10:20:00	19-08-2023	22:03:00	0.49	0.00	0.00	0.00	11.72		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	29-08-2023	10:37:00	29-08-2023	20:30:00	0.41	0.00	0.00	0.00	9.88		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	31-08-2023	12:13:00	31-08-2023	18:30:00	0.26	0.00	0.00	0.00	6.28		* BR H/T as per WRLDC instructions for Voltage Regulation
							4.17	0.00	0.00	0.00	100.11	100.00	
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT BHADRAWATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-2 AT BHADRAWATI	OSPT	22-08-2023	08:07:00	22-08-2023	18:56:00	0.45	10.82	0.00	0.00	0.00	98.55	* AMP works
BSR	125MVAR, BUS REACTOR-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT CHAMPA	OSPT	29-08-2023	09:49:00	29-08-2023	20:01:00	0.43	10.20	0.00	0.00	0.00	98.63	* For AMP works. Dia to be kept open.
BSR	125MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	25-08-2023	11:41:00	28-08-2023	20:10:00	3.35	0.00	0.00	0.00	80.48		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	29-08-2023	10:48:00	29-08-2023	19:54:00	0.38	0.00	0.00	0.00	9.10		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-2 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-3 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	30-08-2023	09:28:00	30-08-2023	19:09:00	0.40	0.00	0.00	0.00	9.68		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	31-08-2023	11:19:00	31-08-2023	23:59:59	0.53	0.00	0.00	0.00	12.68		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	05-08-2023	09:40:00	15-08-2023	19:25:00	10.41	0.00	0.00	0.00	249.75		* BR H/T as per WRLDC instructions for VR
							11.34	0.00	0.00	0.00	272.11	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	29-08-2023	10:25:00	31-08-2023	23:59:59	2.57	0.00	0.00	0.00	61.58		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	16-08-2023	10:15:00	28-08-2023	20:09:00	12.41	0.00	0.00	0.00	297.90		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	12-08-2023	10:38:00	12-08-2023	22:03:00	0.48	0.00	0.00	0.00	11.42		* BR H/T as per WRLDC instructions for Voltage Regulation
							15.46	0.00	0.00	0.00	370.90	100.00	
BSR	80MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	22-08-2023	10:11:00	31-08-2023	23:59:59	9.58	0.00	0.00	0.00	229.82		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	05-08-2023	08:27:00	06-08-2023	17:13:00	1.37	0.00	0.00	0.00	32.77		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	13-08-2023	10:24:00	13-08-2023	18:15:00	0.33	0.00	0.00	0.00	7.85		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	16-08-2023	10:31:00	17-08-2023	22:20:00	1.49	0.00	0.00	0.00	35.82		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	14-08-2023	10:59:00	15-08-2023	19:17:00	1.35	0.00	0.00	0.00	32.30		* BR H/T as per WRLDC instructions for Voltage Regulation
							14.12	0.00	0.00	0.00	338.56	100.00	

**Standard of Performance data for the month of Aug-2023**  
**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	24-08-2023	09:23:00	24-08-2023	18:36:00	0.38	0.00	0.00	0.00	9.22		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	14-08-2023	10:56:00	14-08-2023	20:41:00	0.41	0.00	0.00	0.00	9.75		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	10-08-2023	09:21:00	10-08-2023	17:59:00	0.36	0.00	0.00	0.00	8.63		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	07-08-2023	09:46:00	07-08-2023	21:42:00	0.50	0.00	0.00	0.00	11.93		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	09-08-2023	09:27:00	09-08-2023	20:43:00	0.47	0.00	0.00	0.00	11.27		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	18-08-2023	11:07:00	18-08-2023	17:29:00	0.27	0.00	0.00	0.00	6.37		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	21-08-2023	09:22:00	21-08-2023	20:34:00	0.47	0.00	0.00	0.00	11.20		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	25-08-2023	09:26:00	25-08-2023	21:07:00	0.49	0.00	0.00	0.00	11.68		* BR H/T as per WRLDC instructions for Voltage RegulationEnter text here...
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	11-08-2023	09:15:00	11-08-2023	18:21:00	0.38	0.00	0.00	0.00	9.10		* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	23-08-2023	08:33:00	23-08-2023	19:03:00	0.44	0.00	0.00	0.00	10.50		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	26-08-2023	09:21:00	26-08-2023	19:42:00	0.43	0.00	0.00	0.00	10.35		* BR H/T as per WRLDC instructions for Voltage RegulationEnter text here...
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	28-08-2023	09:10:00	28-08-2023	20:27:00	0.47	0.00	0.00	0.00	11.28		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	29-08-2023	09:10:00	29-08-2023	19:14:00	0.42	0.00	0.00	0.00	10.07		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	17-08-2023	09:41:00	17-08-2023	18:46:00	0.38	0.00	0.00	0.00	9.08		* BR H/T as per WRLDC instructions for Voltage RegulationEnter text here...
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	31-08-2023	09:33:00	31-08-2023	17:34:00	0.33	0.00	0.00	0.00	8.02		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	19-08-2023	08:36:00	19-08-2023	18:08:00	0.40	0.00	0.00	0.00	9.53		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	16-08-2023	09:01:00	16-08-2023	19:07:00	0.42	0.00	0.00	0.00	10.10		* BR H/T as per WRLDC instructions for Voltage Regulation
							7.02	0.00	0.00	0.00	168.08	100.00	
BSR	63MVAR, BUS REACTOR-1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT PARLI	OSFT	21-08-2023	12:40:00	23-08-2023	00:32:00	1.49	35.87	0.00	0.00	0.00		* Emergency outage availed to attend oil leakage from PRD
BSR	125MVAR, BUS REACTOR-2 AT PARLI	OSPT	12-08-2023	09:43:00	12-08-2023	22:29:00	0.53	12.77	0.00	0.00	0.00		* FOR SCHEME MODIFICATION WORKS* *
							2.02	48.64	0.00	0.00	0.00	93.46	
BSR	50MVAR, BUS REACTOR-1 AT PUNE	SVRD	16-08-2023	10:27:00	17-08-2023	23:30:00	1.54	0.00	0.00	0.00	37.05		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	50MVAR, BUS REACTOR-1 AT PUNE	SVRD	21-08-2023	09:52:00	31-08-2023	23:59:59	10.59	0.00	0.00	0.00	254.13		* BR H/T as per WRLDC instructions for Voltage Regulation
							12.13	0.00	0.00	0.00	291.18	100.00	
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	23-08-2023	08:32:00	23-08-2023	19:52:00	0.47	0.00	0.00	0.00	11.33		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	16-08-2023	10:27:00	16-08-2023	20:30:00	0.42	0.00	0.00	0.00	10.05		* SLR H/T as per WRLDC instructions for Voltage Regulation* 16.08.2023 20:38:17 INDIA Mohd Faisudin (60031122)* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	22-08-2023	10:27:00	22-08-2023	19:29:00	0.38	0.00	0.00	0.00	9.03		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	25-08-2023	07:52:00	26-08-2023	00:00:01	0.67	0.00	0.00	0.00	16.13		* BR H/T as per WRLDC instructions for Voltage RegulationEnter text here...
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	17-08-2023	09:36:00	17-08-2023	18:40:00	0.38	0.00	0.00	0.00	9.07		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	26-08-2023	10:01:00	26-08-2023	21:47:00	0.49	0.00	0.00	0.00	11.77		* BR H/T as per WRLDC instructions for Voltage RegulationEnter text here...
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	19-08-2023	08:41:00	19-08-2023	21:32:00	0.54	0.00	0.00	0.00	12.85		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	21-08-2023	09:19:00	21-08-2023	19:09:00	0.41	0.00	0.00	0.00	9.83		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	30-08-2023	09:27:00	30-08-2023	19:37:00	0.42	0.00	0.00	0.00	10.17		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	24-08-2023	08:57:00	24-08-2023	22:12:00	0.55	0.00	0.00	0.00	13.25		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	29-08-2023	10:01:00	29-08-2023	19:21:00	0.39	0.00	0.00	0.00	9.33		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	18-08-2023	08:22:00	18-08-2023	17:32:00	0.38	0.00	0.00	0.00	9.17		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	05-08-2023	10:15:00	07-08-2023	21:38:00	2.47	0.00	0.00	0.00	59.38		* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	10-08-2023	11:04:00	10-08-2023	18:03:00	0.29	0.00	0.00	0.00	6.98		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	12-08-2023	09:49:00	15-08-2023	18:47:00	3.37	0.00	0.00	0.00	80.97		* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	11-08-2023	09:30:00	11-08-2023	20:50:00	0.47	0.00	0.00	0.00	11.33		* BR H/T as per WRLDC instructions for Voltage Regulation

**Standard of Performance data for the month of Aug-2023**  
**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE TO Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	08-08-2023	09:16:00	08-08-2023	21:18:00	0.50	0.00	0.00	0.00	12.03		* BR H/T as per WRLDC instructions for Voltage RegulationEnter text here...
BSR	240MVAR, BUS REACTOR-1 AT PUNE GIS	SVRD	09-08-2023	09:27:00	09-08-2023	20:24:00	0.46	0.00	0.00	0.00	10.95		* BR H/T as per WRLDC instructions for Voltage Regulation.
							13.06	0.00	0.00	0.00	313.62	100.00	
BSR	63MVAR, BUS REACTOR-1 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT WARDHA	OSPT	23-08-2023	12:39:00	23-08-2023	20:45:00	0.34	8.10	0.00	0.00	0.00		* FOR SPARE CHANGEOVER WORK
BSR	240MVAR, BUS REACTOR-1 AT WARDHA	SCSD	23-08-2023	09:39:00	23-08-2023	12:39:00	0.13	0.00	0.00	0.00	3.00		* For taking Spare into Service
							0.47	8.10	0.00	0.00	3.00	98.91	
BSR	63MVAR, BUS REACTOR-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KORBA(CSEB)-BUDDHIPADAR(OPTCL)-3	OMS U	02-08-2023	23:46:00	03-08-2023	08:06:00	0.35	0.00	8.33	0.00	0.00		* Line tripped at buddipadar end only on CB PD operated.
							0.35	0.00	8.33	0.00	0.00	100.00	
CKT	400kV AKOLA(MSETCL)-AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AKOLA(MSETCL)-AURANGABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-DHARIWAL(CESC)-2	OSPD	07-08-2023	09:59:00	07-08-2023	17:57:00	0.33	0.00	0.00	0.00	7.97		* Outage availed by Dhariwal for faulty energy meter replacement at Dhariwal end.
							0.33	0.00	0.00	0.00	7.97	100.00	
CKT	400kV BHADRAWATI-PARLI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHATAPARA-BHILAI(CSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHILAI(CSEB)-BHADRAWATI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHILAI(CSEB)-KORADI(MSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DHARIWAL(CESC)-PARLI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHARSUGUDA-RAIGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	



**Standard of Performance data for the month of Aug-2023**  
**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE TO Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV PADGHE GIS-KUDUS(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PARLI(MSETCL)-1	LCSD	19-08-2023	22:49:00	31-08-2023	23:59:59	12.05	0.00	0.00	0.00	289.18	100.00	* Outage availed for reconductoring work
CKT	400kV PARLI-PARLI(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PUNE GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PUNE GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE-PUNE GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE-PUNE GIS-2	SEFU	10-08-2023	22:29:00	11-08-2023	00:15:00	0.07	0.00	1.77	0.00	0.00	99.12	* Line tripped on B-G fault due to Reactor B-ph LA failure at Pune Talegaon end. Line Charged without SLR.
CKT	400kV PUNE-PUNE GIS-2	OSFT	10-08-2023	15:55:00	10-08-2023	22:29:00	0.27	6.57	0.00	0.00	0.00	100.00	* Emergency outage availed for attending hotspot in line isolator R ph and conductor unwinding in R Ph at Wavetrap Dropper at Pune (Talegaon) end.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	05-08-2023	10:07:00	31-08-2023	23:59:59	26.58	0.00	0.00	0.00	637.88	100.00	* Line H/T as per WRDLC instructions for Power regulation
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	24-08-2023	06:20:00	31-08-2023	23:59:59	7.74	0.00	0.00	0.00	185.67	100.00	* Line H/T as per WRDLC instructions for Power Regulation
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	OSPT	23-08-2023	10:32:00	23-08-2023	18:06:00	0.32	7.57	0.00	0.00	0.00	100.00	* Line Bay AMP Work. AR in non auto mode of 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	OSFT	23-08-2023	20:42:00	23-08-2023	23:44:00	0.13	3.03	0.00	0.00	0.00	100.00	* Emergency lineoutage availed to attend hot spot on Main Bay B-ph CT Clamp at Aurangabad(Waluj) end.
CKT	400kV PUNE GIS-PUNE-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE GIS-PUNE-4	OSPD	27-08-2023	11:50:00	27-08-2023	20:15:00	0.35	0.00	0.00	0.00	8.42	100.00	* Outage availed by M/s Adani for insulators replacement works.
CKT	400kV RAIGARH-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIGARH-KOTRA PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHADRAWATI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHADRAWATI-2	OSPD	25-08-2023	10:38:00	25-08-2023	19:02:00	0.35	0.00	0.00	0.00	8.40	100.00	* Line H/T and LT converted as BR at 10:58hrs. at Bhadravati end for Mock drill testing.
CKT	400kV RAIPUR-BHADRAWATI-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHILAI(CSEB)-1	OSFT	22-08-2023	22:47:00	23-08-2023	05:55:00	0.30	7.13	0.00	0.00	0.00	99.04	* Emergency outage availed to attend hot spot in Y-Ph Line Isolator (Male Female Contact) at Raipur end.
CKT	400kV RAIPUR-RAIGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-2	OSFT	14-08-2023	10:50:00	14-08-2023	17:36:00	0.28	6.77	0.00	0.00	0.00	100.00	* Emergency outage availed to take Line reactor in service after attending oil leakage in LR at Raipur end.
CKT	400kV RAIPUR-RAIGARH-2	LART	18-08-2023	19:28:00	18-08-2023	19:28:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line A/R successfully operated on B-E fault. Fault distance is 54.5km from Raipur. Suspected fault tower location is 152. Suspected fault tower section 147-157. Patrolling may be done from 142-162. Fault is in Bhatapara TLM jurisdiction.* 02.09.2023 11:51:46 INDIA Nakka Nataraj (60031136)* Flashover mark observed in porcelain disc insulator at location no. 161 (top phase).
CKT	400kV RAIPUR-RAIGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIPUR PS(DURG)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-WARDHA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-WARDHA-2	LEFT	11-08-2023	13:53:00	11-08-2023	14:37:00	0.03	0.73	0.00	0.00	0.00	99.90	* line tripped on R-G fault, Rph- G fault, At Raipur end, FL-245.562Km, Fc-1.99KA and At Wardha end FL-87.225Km, Fc-4.378KA.* 11.08.2023 14:34:49 INDIA Mohd Faisudin (60031122)* Updated details.line tripped on R-G fault, Rph- G fault, At Raipur end, FL-297.932Km, Fc-1.99KA and At Wardha end FL-77.067Km, Fc-4.378KA.* 02.09.2023 11:25:40 INDIA Nakka Nataraj (60031136)** Flashover Observed on the conductor in Span at Loc No.756-757.Some miscreant Person has cut the teak tree between 756-757.
CKT	400kV RAIPUR-WARDHA-2	LART	11-08-2023	13:43:00	11-08-2023	13:43:00	0.00	0.00	0.00	0.00	0.00	100.00	* AR successful on Rph- G fault, At Raipur end, FL-296.43Km, Fc-2KA and At Wardha end FL-78.5Km, Fc-4.23KA.* 02.09.2023 11:30:24 INDIA Nakka Nataraj (60031136)** Flashover Observed on the conductor in Span at Loc No.756-757.Some miscreant Person has cut the teak tree between 756-757.
CKT	400kV RANCHI-SIPAT(NTPC)-1			00:00:00		00:00:00	0.03	0.73	0.00	0.00	0.00	99.90	
CKT	400kV RANCHI-SIPAT(NTPC)-2	OSPT	31-08-2023	09:18:00	31-08-2023	23:59:59	0.61	14.70	0.00	0.00	0.00	98.02	* Line outage for CT REPLACEMENT WORKS AT SIPAT END.* 31.08.2023 13:56:04 INDIA N Vinod Babu (60016790)* Sipat(NTPC) is not ready to issue NBFC on above line.
CKT	400kV ROURKELA-JHARSUGUDA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

**Standard of Performance data for the month of Aug-2023**  
**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV ROURKELA-JHARSUGUDA-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SEONI-KIRNAPUR(MPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SEONI-SATPURA(MPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-1	OMS U	08-08-2023	12:12:00	09-08-2023	14:35:00	1.10	0.00	26.38	0.00	0.00	100.00	* Line outage availed by M/s NTPC for relay replacement works at NTPC end.Solapur-Solapur ckt-2.
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-4	OSPT	29-08-2023	10:22:00	29-08-2023	21:28:00	0.46	11.10	0.00	0.00	0.00	98.51	* For Line terminal equipments AMP at 765kV Solapur Substation. 400kV Solapur (PG) - Solapur (NTPC) # 3 line AR to be kept in Non-Auto mode.
CKT	400kV SIPAT(NTPC)-RAIPUR-1	OSPT	24-08-2023	10:39:00	24-08-2023	19:42:00	0.38	9.05	0.00	0.00	0.00	98.78	* AMP at Raipur SS. AR to be kept in non Auto mode for 400kV Sipat-Raipur-2
CKT	400kV SIPAT(NTPC)-RAIPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-3	OSPT	26-08-2023	10:25:00	26-08-2023	19:15:00	0.37	8.83	0.00	0.00	0.00	98.81	* For line and Line Bay AMP works.Enter text here...
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-1	OMS U	03-08-2023	11:04:00	03-08-2023	18:13:00	0.30	0.00	7.15	0.00	0.00	100.00	* Line tripped due to reactor protection operated at korba end.
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-2	OSFD	10-08-2023	13:28:00	10-08-2023	20:08:00	0.28	0.00	0.00	0.00	6.67	98.76	* Emergency outage availed by NTPC Korba due to transfer bus R-phase Isolator not closing fully during transfer the line on TBC.
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-2	OMS U	31-08-2023	20:25:00	31-08-2023	23:59:59	0.15	0.00	3.58	0.00	0.00	100.00	* Line charging readiness Email from POWERGRID was sent to WRLDC at 20:25 Hrs. Line charging delayed by Vindychal NTPC due to non receipt of charging clearance .
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-2	OMS U	06-08-2023	21:12:00	06-08-2023	22:35:00	0.06	0.00	1.38	0.00	0.00	100.00	* Line tripped at Korba (NTPC) end only due to LBB protection operated during tripping of U-7 shutdown..
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-2	LART	22-08-2023	13:42:00	22-08-2023	13:42:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line autoreclose successfully operated on Y ph to Ground fault. Indication from Korba end : FD: 211.7 FC:1.82 KA, Vindychal end:- FD: 81 Km, FC: 4.45 KA* 04.09.2023 08:10:42 INDIA Krishnanjaneyulu Machha (60001973)* And informed by WR-2, Villager Birbal in Village Kuliha that lightning <-> sound is heard in line near loc no 226 .* Patrolling of Line done from loc no 210-239 .It was found that heavy rain and lightning took place at time of fault in fault area .
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-2	OSPT	31-08-2023	11:13:00	31-08-2023	20:25:00	0.38	9.20	0.00	0.00	0.00	98.76	* Outage availed by WR-2 for REF Relay Retrofitting work at Vindhyachal NTPC end.
CKT	400kV WARDHA-AKOLA(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AKOLA(MSETCL)-2	GOV C	24-08-2023	19:45:00	24-08-2023	22:52:00	0.13	0.00	0.00	3.12	0.00	100.00	* DT received from Akola end* 24.08.2023 23:21:42 INDIA Manoj N Moudekar (60020591)* Line tripped on receipt of DT due to operation of Overvoltage protection at Akola end.
CKT	400kV WARDHA-AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AURANGABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-WARORA-1	OSPT	11-08-2023	10:38:00	11-08-2023	17:53:00	0.30	7.25	0.00	0.00	0.00	99.03	* Line Bay AMP works
CKT	400kV WARDHA-WARORA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARORA-PARLI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARORA-PARLI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV AURANGABAD-PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV AURANGABAD-PUNE GIS	LVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Line H/T as per WRLDC instruction amd SLR converted as BR at 00:45hrs at Pune GIS end at Aurangabad SS SLR converted as BR at 00:38hrs for Voltage regulation.
CKT	765kV BILASPUR-DHARAMJAYGARH	OSPT	18-08-2023	09:05:00	18-08-2023	21:20:00	0.51	12.25	0.00	0.00	0.00	98.35	* Line equipments tightness <-> LR Amp works
CKT	765kV BILASPUR-SEONI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BILASPUR-SEONI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV CHAMPA-KOTRA PS-1	OSPT	28-08-2023	11:41:00	28-08-2023	22:59:00	0.47	11.30	0.00	0.00	0.00	98.48	* For AMP of LTE at Champa end. Dia to be kept open.
CKT	765kV CHAMPA-RAIPUR PS(DURG)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV CHAMPA-RAIPUR PS(DURG)-2	OSPT	10-08-2023	13:37:00	10-08-2023	16:53:00	0.14	3.27	0.00	0.00	0.00	100.00	* Line reactor Spare change over at Durg end.
CKT	765kV CHAMPA-RAIPUR PS(DURG)-2	OSPT	10-08-2023	10:37:00	10-08-2023	13:37:00	0.13	3.00	0.00	0.00	0.00	100.00	* Line reactor Spare change over at Durg end.
CKT	765kV CHAMPA-RAIPUR PS(DURG)-2	GOM b	10-08-2023	16:53:00	28-08-2023	10:57:00	17.75	0.00	0.00	0.00	426.07	100.00	* Line kept out as per WRLDC instructions for Voltage Regulation
CKT	765kV CHAMPA-RAIPUR PS(DURG)-2	LVRD	01-08-2023	00:00:01	10-08-2023	10:37:00	9.44	0.00	0.00	0.00	226.62	100.00	* Line H/T as per WRLDC instructions for Voltage Regulation
							27.46	6.27	0.00	0.00	652.69	99.16	

**Standard of Performance data for the month of Aug-2023**

**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE TO Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	765kV CHAMPA-DHARAMJAYGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RANCHI-DHARAMJAYGARH-1	LCSD	29-08-2023	07:34:00	29-08-2023	21:08:00	0.57	0.00	0.00	0.00	13.57	100.00	* FOR REPLACEMENT OF EXISTING E/W WITH OPGW UNDER Western Region communication strengthening scheme.
CKT	765kV RANCHI-DHARAMJAYGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-RAIPUR PS(DURG)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-TAMNAR PS-1	LART	18-08-2023	21:36:00	18-08-2023	21:36:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line A/R successfully operated on Y-E fault. Fault details at Tamnar PS end :- FD-9.308Km, FC-22.671KA and Fault details at Kotra PS end :- FD-38.651Km, FC-12.685KA (Double end).* 02.09.2023 11:47:46 INDIA Nakka Nataraj (60031136)** Flashover marks found on insulator at Loc. 109
CKT	765kV KOTRA PS-TAMNAR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV-PUNE GIS-PADGHE GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-1	LVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* Line H/T as per WRDLC instructions for voltage Regulation and SLR charged as BR at 17:13 Hrs at Durg end.
CKT	765kV RAIPUR PS(DURG)-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SEONI-WARDHA-1	OSPT	25-08-2023	10:18:00	25-08-2023	20:59:00	0.45	10.68	0.00	0.00	0.00	98.56	* Line Bay AMP works.
CKT	765kV SEONI-WARDHA-2	LCSD	22-08-2023	09:19:00	22-08-2023	22:11:00	0.54	0.00	0.00	0.00	12.87	100.00	* Spare Reactor changeover at Seoni end. (Spare reactor OUT and R-phase unit IN)
CKT	765kV SOLAPUR-AURANGABAD-1	OSFT	10-08-2023	10:15:00	10-08-2023	22:12:00	0.50	11.95	0.00	0.00	0.00	98.39	* Emergency outage availed by Solapur TLM for attending damaged Bph Conductor strands at Loc No: 364 by providing mid span compression joint
CKT	765kV SOLAPUR-AURANGABAD-1	GOMD	10-08-2023	22:12:00	11-08-2023	10:14:00	0.50	0.00	0.00	0.00	12.03	98.39	* After completion of emergency outage, Line kept out as per WRDLC instructions for Voltage Regulation and SLRs converted as BRs at 23:38hrs @ Aurangabad <-&-> at 23:14hrs @ Solapur end for Voltage Regulation.
CKT	765kV SOLAPUR-AURANGABAD-2	LVRD	01-08-2023	00:00:01	10-08-2023	10:02:00	9.42	0.00	0.00	0.00	226.03	100.00	* Line H/T and SLR is converted to BR at both end for Voltage Regulation as per instructions of WRDLC.
CKT	765kV SOLAPUR-PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SIPAT(NTPC)-BILASPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SIPAT(NTPC)-BILASPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV WARDHA-AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV WARDHA-AURANGABAD-2	LVRD	01-08-2023	00:00:01	24-08-2023	07:20:00	23.31	0.00	0.00	0.00	559.33	100.00	* Line H/T as per WRDLC instructions for Voltage Regulation
CKT	765kV WARDHA-AURANGABAD-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV WARDHA-AURANGABAD-4	LVRD	24-08-2023	22:55:00	31-08-2023	23:59:59	7.05	0.00	0.00	0.00	169.08	100.00	* Line H/T as per WRDLC instructions for Voltage Regulation and SLR converted as BR at hrs at Wardha end.* 07.10.2023 21:55:03 INDIA P. Pandharikar (60021315) Phone 8554993381* Line charging attempt taken on dt 07.10.2023 at 17:32 Hrs from Aurangabad end but Line tripped on Over Voltage protection at Wardha end.
LNR	80MVAR,LR OF WARDHA-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF WARDHA-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	25-08-2023	09:51:00	25-08-2023	20:13:00	0.43	0.00	0.00	0.00	10.37	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

**Standard of Performance data for the month of Aug-2023**  
**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF SEONI-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF SEONI-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAJNANGAON-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAJNANGAON-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DHARAMJYGARH AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-2 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-1 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-2 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-1 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DURG-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DURG-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-1 AT PUNE	SVRD	01-08-2023	00:00:01	31-08-2023	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRDLC instructions for VR
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PUNE	SEFU	10-08-2023	23:04:00	12-08-2023	16:42:00	1.74	0.00	41.63	0.00	0.00		* SLR is out along with line tripping due to failure of B-ph Reactor LA at Pune Talegaon end.
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PUNE	SVRD	16-08-2023	10:52:00	31-08-2023	23:59:59	15.55	0.00	0.00	0.00	373.13		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PUNE	SVRD	01-08-2023	00:00:01	10-08-2023	22:31:00	9.94	0.00	0.00	0.00	238.52		* SLR H/T as per WRDLC instructions for VR
							27.23	0.00	41.63	0.00	611.65	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-3 AT PUNE	SVRD	16-08-2023	10:52:00	31-08-2023	23:59:59	15.55	0.00	0.00	0.00	373.13		* SLR H/T as per WRDLC instructions for Voltage Regulation
							15.55	0.00	0.00	0.00	373.13	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-4 AT PUNE	SVRD	16-08-2023	10:53:00	31-08-2023	23:59:59	15.55	0.00	0.00	0.00	373.12		* SLR H/T as per WRDLC instructions for Voltage Regulation
							15.55	0.00	0.00	0.00	373.12	100.00	
LNR	240MVAR,SWLR OF SHOLAPUR AT PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	26-08-2023	09:12:00	26-08-2023	19:20:00	0.42	0.00	0.00	0.00	10.13		* SLR H/T as per WRDLC instructions for Voltage RegulationEnter text here...
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	16-08-2023	09:06:00	16-08-2023	18:48:00	0.40	0.00	0.00	0.00	9.70		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	28-08-2023	09:07:00	28-08-2023	21:03:00	0.50	0.00	0.00	0.00	11.93		* SLR H/T as per WRDLC instructions for VR
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	23-08-2023	08:34:00	23-08-2023	18:39:00	0.42	0.00	0.00	0.00	10.08		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	25-08-2023	09:24:00	25-08-2023	20:10:00	0.45	0.00	0.00	0.00	10.77		* SLR H/T as per WRDLC instructions for Voltage RegulationEnter text here...
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	27-08-2023	08:07:00	27-08-2023	19:53:00	0.49	0.00	0.00	0.00	11.77		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	07-08-2023	09:47:00	07-08-2023	22:39:00	0.54	0.00	0.00	0.00	12.87		* SLR H/T as per WRDLC instructions for Voltage RegulationEnter text here...
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	14-08-2023	09:09:00	14-08-2023	20:15:00	0.46	0.00	0.00	0.00	11.10		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	05-08-2023	08:34:00	05-08-2023	20:29:00	0.50	0.00	0.00	0.00	11.92		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	08-08-2023	09:04:00	11-08-2023	18:00:00	3.37	0.00	0.00	0.00	80.93		* SLR H/T as per WRDLC instructions for Voltage RegulationEnter text here...
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	21-08-2023	10:48:00	21-08-2023	18:51:00	0.34	0.00	0.00	0.00	8.05		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	19-08-2023	09:57:00	19-08-2023	17:47:00	0.33	0.00	0.00	0.00	7.83		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	18-08-2023	10:53:00	18-08-2023	22:24:00	0.48	0.00	0.00	0.00	11.52		* SLR H/T as per WRDLC instructions for Voltage Regulation



**Standard of Performance data for the month of Aug-2023**  
**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
VALVE HALL	POLE2_VALVE HALL_RAIGARH_HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BILASPUR	OSFT	02-08-2023	12:37:00	02-08-2023	15:18:00	0.11	2.68	0.00	0.00	0.00	99.64	* Emergency outage on 765/400kV ICT#1 to attend the hot spot of 401-89T Rph isolator of 765/400kV ICT#1.
							0.11	2.68	0.00	0.00	0.00	99.64	
XMER	1500MVA,765/400kV ICT-2 AT BILASPUR	OSPT	02-08-2023	20:57:00	03-08-2023	00:40:00	0.16	3.72	0.00	0.00	0.00		* "For spare ICT change over" *
XMER	1500MVA,765/400kV ICT-2 AT BILASPUR	SCSD	02-08-2023	15:57:00	02-08-2023	20:57:00	0.21	0.00	0.00	0.00	5.00		* For spare ICT change over
							0.37	3.72	0.00	0.00	5.00	99.50	
XMER	1500MVA,765/400kV ICT-3 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-5 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-6 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MAPUSA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MAPUSA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT MAPUSA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT PARLI	OSPT	26-08-2023	08:51:00	26-08-2023	23:51:00	0.63	15.00	0.00	0.00	0.00	97.98	* AMP as per Maintenance schedule.Enter text here...
							0.63	15.00	0.00	0.00	0.00	97.98	
XMER	315MVA,400/220kV ICT-1 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

**Standard of Performance data for the month of Aug-2023**  
**Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1**

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	1500MVA,765/400kV ICT-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT SOLAPUR	OSPT	16-08-2023	09:02:00	16-08-2023	18:48:00	0.41	9.77	0.00	0.00	0.00	98.69	* ICT#2 AMP Works
							0.41	9.77	0.00	0.00	0.00	98.69	
XMER	315MVA,400/220kV ICT-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT WARDHA	OSPT	30-08-2023	10:20:00	30-08-2023	20:40:00	0.43	10.33	0.00	0.00	0.00	98.61	* For AMP works.
							0.43	10.33	0.00	0.00	0.00	98.61	
XMER	1500MVA,765/400kV ICT-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT WARDHA	SCSD	28-08-2023	10:48:00	28-08-2023	15:48:00	0.21	0.00	0.00	0.00	5.00		* For Taking Spare out of service
							0.21	0.00	0.00	0.00	5.00		
XMER	1500MVA,765/400kV ICT-3 AT WARDHA	OSPT	28-08-2023	15:48:00	28-08-2023	19:14:00	0.14	3.43	0.00	0.00	0.00	99.54	* For Taking Spare out of service
							0.35	3.43	0.00	0.00	5.00	99.54	
XMER	315MVA,400/220kV ICT-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	