

Standard of Performance data for the month of May-2023
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD	SVRD	08-05-2023	11:20:00	20-05-2023	18:51:00	12.31	0.00	0.00	0.00	0.00	100.00	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD	SVRD	20-05-2023	14:39:00	24-05-2023	21:56:00	4.30	0.00	0.00	0.00	0.00	103.28	* BR H/T as per WRLDC instructions for VR
BSR	50MVAR, BUS REACTOR-1 AT BHADRAWATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	63MVAR, BUS REACTOR-2 AT BHADRAWATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	80MVAR, BUS REACTOR-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-1 AT CHAMPA	SCSD	31-05-2023	10:10:00	31-05-2023	13:54:00	0.16	0.00	0.00	0.00	0.00	3.73	* For Spare Change Over.
BSR	125MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	09-05-2023	11:34:00	31-05-2023	23:59:59	22.52	0.00	0.00	0.00	0.00	540.43	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	330MVAR, BUS REACTOR-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	330MVAR, BUS REACTOR-2 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	330MVAR, BUS REACTOR-3 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	25-05-2023	10:31:00	31-05-2023	23:59:59	6.56	0.00	0.00	0.00	0.00	157.48	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-05-2023	00:00:01	24-05-2023	22:59:00	23.96	0.00	0.00	0.00	0.00	574.98	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	02-05-2023	09:54:00	04-05-2023	19:56:00	2.42	0.00	0.00	0.00	0.00	58.03	* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	21-05-2023	09:00:00	22-05-2023	18:04:00	1.38	0.00	0.00	0.00	0.00	33.07	* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	01-05-2023	00:00:01	01-05-2023	18:19:00	0.76	0.00	0.00	0.00	0.00	18.32	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	08-05-2023	08:25:00	08-05-2023	19:55:00	0.48	0.00	0.00	0.00	0.00	11.50	* BR H/T as per WRLDC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	05-05-2023	10:00:00	08-05-2023	03:10:00	2.72	0.00	0.00	0.00	0.00	65.17	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	09-05-2023	09:10:00	09-05-2023	21:05:00	0.50	0.00	0.00	0.00	0.00	11.92	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSETCL	SVRD	10-05-2023	09:05:00	20-05-2023	20:55:00	10.49	0.00	0.00	0.00	0.00	251.83	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	125MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	240MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	22-05-2023	10:22:00	31-05-2023	23:59:59	9.57	0.00	0.00	0.00	0.00	229.63	* BR H/T as per WRLDC instructions for VR
BSR	50MVAR, BUS REACTOR-1 AT MAPUSA	SVRD	01-05-2023	00:00:01	21-05-2023	17:58:00	20.75	0.00	0.00	0.00	0.00	497.97	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	27-05-2023	11:22:00	28-05-2023	05:23:00	0.75	0.00	0.00	0.00	0.00	18.02	* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	22-05-2023	10:02:00	22-05-2023	19:03:00	0.38	0.00	0.00	0.00	0.00	9.02	* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	17-05-2023	10:17:00	17-05-2023	19:23:00	0.38	0.00	0.00	0.00	0.00	9.10	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	18-05-2023	09:47:00	18-05-2023	20:14:00	0.44	0.00	0.00	0.00	0.00	10.45	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	08-05-2023	09:27:00	08-05-2023	20:13:00	0.45	0.00	0.00	0.00	0.00	10.77	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	13-05-2023	15:21:00	15-05-2023	02:47:00	1.48	0.00	0.00	0.00	0.00	35.43	* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	10-05-2023	09:51:00	10-05-2023	20:49:00	0.46	0.00	0.00	0.00	0.00	10.97	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	09-05-2023	10:04:00	09-05-2023	19:21:00	0.39	0.00	0.00	0.00	0.00	9.28	* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	15-05-2023	09:51:00	15-05-2023	21:10:00	0.47	0.00	0.00	0.00	0.00	11.32	* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	03-05-2023	10:16:00	03-05-2023	18:48:00	0.36	0.00	0.00	0.00	0.00	8.53	* SLR H/T as per WRLDC instructions for Voltage Regulation* 03.05.2023 14:19:38 INDIA Prasanna Anil Pandharikar (60021315)* B/R H/T
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	19-05-2023	11:02:00	19-05-2023	19:32:00	0.35	0.00	0.00	0.00	0.00	8.50	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	20-05-2023	10:31:00	20-05-2023	21:15:00	0.45	0.00	0.00	0.00	0.00	10.73	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	30-05-2023	09:01:00	30-05-2023	22:10:00	0.55	0.00	0.00	0.00	0.00	13.15	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	23-05-2023	09:16:00	24-05-2023	20:27:00	1.47	0.00	0.00	0.00	0.00	35.18	* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	25-05-2023	08:37:00	25-05-2023	18:44:00	0.42	0.00	0.00	0.00	0.00	10.12	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	29-05-2023	09:34:00	29-05-2023	19:55:00	0.43	0.00	0.00	0.00	0.00	10.35	* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-1 AT PADGHE GIS	SVRD	31-05-2023	08:56:00	31-05-2023	22:05:00	0.55	0.00	0.00	0.00	0.00	13.15	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR	63MVAR, BUS REACTOR-1 AT PARLI	SVRD	01-05-2023	00:00:01	31-05-2023	23:59:59	31.00	0.00	0.00	0.00	0.00	744.00	* BR H/T as per WRLDC instructions for VR
BSR	125MVAR, BUS REACTOR-2 AT PARLI	SVRD	01-05-2023	00:00:01	24-05-2023	23:22:00	23.97	0.00	0.00	0.00	0.00	575.37	* BR H/T as per WRLDC instructions for Voltage Regulation
BSR							23.97	0.00	0.00	0.00	0.00	575.37	100.00

Standard of Performance data for the month of May-2023
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
							24.59	0.00	0.00	0.00	590.22	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	765kV SEONI-WARDHA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SEONI-WARDHA-2	LART	28-05-2023	16:06:00	28-05-2023	16:06:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successfully operated on Y-E fault. Fault distance is 105Km from Seoni. Suspected fault tower location is 288. Suspected Fault t
CKT	765kV SEONI-WARDHA-2	LCSD	04-05-2023	09:08:00	04-05-2023	23:36:00	0.60	0.00	0.00	0.00	14.47	100.00	* For spare changeover work @Seoni SS* 04.05.2023 23:42:31 INDIA Prasanna Anil Pandharikar (60021315)* R PHASE UNIT OUT SPARE
CKT	765kV SOLAPUR-AURANGABAD-1	OMSU	20-05-2023	12:07:00	20-05-2023	20:21:00	0.34	0.00	8.23	0.00	0.00	100.00	* Emergency S/D of Line alongwith SLR For attending oil leakage from PRD of Y phase unit the and spare LR unit changeover in place of
CKT	765kV SOLAPUR-AURANGABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SOLAPUR-PUNE GIS	LMAC	19-05-2023	17:11:00	19-05-2023	19:37:00	0.10	0.00	0.00	2.43	0.00		* Emergency outage availed for removing of foreign material (Plastic Polythene) from tower nearby jumper at tower no.T0406, B-phase.
CKT	765kV SOLAPUR-PUNE GIS	OSFT	24-05-2023	16:52:00	24-05-2023	22:26:00	0.23	5.57	0.00	0.00	0.00		* Emergency line outage availed by Solapur(TLM) to attend open sub conductor jumper at Location No. 253.
CKT	765kV SIPAT(NTPC)-BILASPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.25	
CKT	765kV SIPAT(NTPC)-BILASPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV WARDHA-AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV WARDHA-AURANGABAD-2	OMSU	23-05-2023	13:32:00	23-05-2023	15:10:00	0.07	0.00	1.63	0.00	0.00		* ESD availed to take LR into service.
CKT	765kV WARDHA-AURANGABAD-2	LVRD	01-05-2023	00:00:01	09-05-2023	12:45:00	8.53	0.00	0.00	0.00	204.75	100.00	* Line H/T as per WRLDC instructions for Voltage Regulation and SLr converted as BR at 11:17 Hrs at Wardha end.
CKT	765kV WARDHA-AURANGABAD-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV WARDHA-AURANGABAD-4	OSPT	09-05-2023	16:12:00	10-05-2023	02:31:00	0.43	10.32	0.00	0.00	0.00		* for Spare L/R Changeover work(for taking spare unit out of service) at AURANGABAD S/S. Last spare changer over on 16.03.2023
CKT	765kV WARDHA-AURANGABAD-4	LVRD	10-05-2023	02:31:00	15-05-2023	11:58:00	5.39	0.00	0.00	0.00	129.45		* Line kept out by WRLDC For VR
CKT	765kV WARDHA-AURANGABAD-4	SCSD	09-05-2023	13:12:00	09-05-2023	16:12:00	0.13	0.00	0.00	0.00	3.00		* for Spare L/R Changeover work(for taking spare unit out of service) at AURANGABAD S/S. Last spare changer over on 16.03.2023
LNR	80MVAR_LR OF WARDHA-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR_LR OF WARDHA-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR_LR OF BOISAR-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR_LR OF BOISAR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR_SWLR OF PADGHE-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR_SWLR OF PADGHE-1 AT AURANGABAD	SVRD	03-05-2023	11:09:00	09-05-2023	21:43:00	6.44	0.00	0.00	0.00	154.57		* SLR H/T as per WRLDC instructions for VR
LNR	240MVAR_SWLR OF PADGHE-1 AT AURANGABAD	SVRD	20-05-2023	11:53:00	20-05-2023	19:26:00	0.32	0.00	0.00	0.00	7.55		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR_SWLR OF PADGHE-1 AT AURANGABAD	SVRD	10-05-2023	09:49:00	12-05-2023	14:43:00	2.20	0.00	0.00	0.00	52.90		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR_SWLR OF PADGHE-1 AT AURANGABAD	SVRD	12-05-2023	22:10:00	16-05-2023	19:52:00	3.90	0.00	0.00	0.00	93.70		* SLR kept open as per WRLDC instructions after H/T of 765kV AURANGABAD(PG)-PUNE(GIS) for Power Regulation.
LNR	240MVAR_SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-05-2023	00:00:01	31-05-2023	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRLDC instructions for Voltage Regulation
LNR	240MVAR_SWLR OF SOLAPUR-1 AT AURANGABAD	OSFT	20-05-2023	12:07:00	20-05-2023	20:25:00	0.35	8.30	0.00	0.00	0.00	100.00	* Emergency S/D of Line alongwith SLR For attending oil leakage from PRD of Y phase unit and spare LR unit changeover in place of Y p
LNR	240MVAR_SWLR OF SOLAPUR-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	98.88	
LNR	240MVAR_SWLR OF SEONI-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR_SWLR OF SEONI-2 AT BILASPUR	OSPT	26-05-2023	12:27:00	26-05-2023	16:11:00	0.16	3.73	0.00	0.00	0.00		* SWITCHABLE LR 765kV SEONI 2 BILASPUR
LNR	240MVAR_SWLR OF SEONI-2 AT BILASPUR	SCSD	26-05-2023	09:27:00	26-05-2023	12:27:00	0.13	0.00	0.00	0.00	3.00		* Spare LR change over works
LNR	240MVAR_SWLR OF RAJNANGAON-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.50	
LNR	240MVAR_SWLR OF RAJNANGAON-2 AT BILASPUR	OSFT	09-05-2023	12:33:00	09-05-2023	16:12:00	0.15	3.65	0.00	0.00	0.00		* SLR H/t in emergency to attend sparking and chattering sound in R-phase isolator.
LNR	240MVAR_SWLR OF DHARAMJYGARH AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR_SWLR OF JABALPUR-2 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR_SWLR OF JABALPUR-1 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR_SWLR OF JARSUGUDA-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR_SWLR OF JARSUGUDA-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR_SWLR OF JABALPUR-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR_SWLR OF JABALPUR-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR_SWLR OF JARSUGUDA-2 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR_SWLR OF JARSUGUDA-1 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of May-2023
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availabiity as certified by certifyin	Detailed Reasons for Outage
LNR	330MVAR,LR OF AURANGABAD-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-4 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATC	-300/+300 MVAR STATCOM AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATC	-300/+300 MVAR STATCOM AT SHOLAPUR	SCSD	19-05-2023	12:30:00	19-05-2023	18:55:00	0.27	0.00	0.00	0.00	6.42	100.00	* For Spare Change over as per CEA norms. Last Spare changeover 02.01.2023.
VALVE	500MW,BHADRAWATI HVDC BTB POLE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE	500MW,BHADRAWATI HVDC BTB POLE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE	POLE1 VALVE HALL RAIGARH HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
VALVE	POLE2 VALVE HALL RAIGARH HVDC			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT AURANGABAD	OSPT	10-05-2023	15:11:00	10-05-2023	23:19:00	0.34	8.13	0.00	0.00	0.00	98.91	* For taking Spare Unit out of service
XMER	1500MVA,765/400kV ICT-1 AT AURANGABAD	SCSD	10-05-2023	10:11:00	10-05-2023	15:11:00	0.21	0.00	0.00	0.00	5.00	100.00	* For taking Spare Unit out of service
XMER	1500MVA,765/400kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT CHAMPA	SCSD	30-05-2023	10:33:00	30-05-2023	17:27:00	0.29	0.00	0.00	0.00	6.90	100.00	* For Spare Change Over.
XMER	1500MVA,765/400kV ICT-5 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-6 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT KOTRA PS	SCSD	24-05-2023	08:34:00	24-05-2023	13:34:00	0.21	0.00	0.00	0.00	5.00	100.00	* For Spare Switching, Spare to be taken out of service. Last Spare changeover 25.03.2023
XMER	1500MVA,765/400kV ICT-3 AT KOTRA PS	OSPT	24-05-2023	13:34:00	24-05-2023	14:51:00	0.05	1.28	0.00	0.00	0.00	99.83	* For Spare Switching, Spare to be taken out of service. Last Spare changeover 25.03.2023
XMER	1500MVA,765/400kV ICT-4 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MAPUSA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MAPUSA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT MAPUSA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT PADGHE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of May-2023
Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-1

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBU TABLE TO ISTS Licensee	OUTAGE ATTRIBU TABLE To Others	OUTAGE ATTRIBU TABLE To System Constraint	OUTAGE ATTRIBU TABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	315MVA,400/220kV ICT-2 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT PUNE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT PUNE GIS	OSPT	23-05-2023	11:40:00	23-05-2023	17:07:00	0.23	5.45	0.00	0.00	0.00	99.27	* Spare ICT Changeover with Y-Phase of ICT#1
XMER	1500MVA,765/400kV ICT-1 AT PUNE GIS	SCSD	23-05-2023	06:40:00	23-05-2023	11:40:00	0.21	0.00	0.00	0.00	5.00	99.27	* Spare ICT Changeover with Y-Phase of ICT#1
XMER	1500MVA,765/400kV ICT-2 AT PUNE GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT RAIGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT RAIGARH	OSFT	29-05-2023	10:45:00	29-05-2023	13:57:00	0.13	3.20	0.00	0.00	0.00	99.57	* ESD to attend Broken Conductor in Bushing Dropper of R Phase at 400KV Raigarh SS.
XMER	1500MVA,765/400kV ICT-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT RAIPUR	SCSD	01-05-2023	17:14:00	01-05-2023	17:49:00	0.02	0.00	0.00	0.00	0.58	100.00	* Emergency outage availed for crossing the trailer vehicle safely carrying new 50 MVAR reactor for replacement of old 50 MVAR reactor for
XMER	1500MVA,765/400kV ICT-1 AT SEONI	OSPT	16-05-2023	09:44:00	16-05-2023	18:54:00	0.38	9.17	0.00	0.00	0.00	98.77	* For AMP Works @ Seoni SS
XMER	1500MVA,765/400kV ICT-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT TAMNAR PS	OSFT	20-05-2023	23:05:00	21-05-2023	00:59:00	0.08	1.90	0.00	0.00	0.00	99.74	* Emergency outage availed to attend Hotspot on 409-89T isolator Y-ph.
XMER	1500MVA,765/400kV ICT-2 AT TAMNAR PS	OSFT	21-05-2023	02:07:00	21-05-2023	04:19:00	0.09	2.20	0.00	0.00	0.00	99.70	* Emergency outage availed to attend Hotspot on 412 89T isolator B-ph
XMER	1500MVA,765/400kV ICT-3 AT TAMNAR PS	OSPT	27-05-2023	08:53:00	27-05-2023	15:50:00	0.29	6.95	0.00	0.00	0.00	99.07	* To Attend Oil Leakege on Neutral CT
XMER	1500MVA,765/400kV ICT-4 AT TAMNAR PS	SCSD	06-05-2023	08:48:00	06-05-2023	13:48:00	0.21	0.00	0.00	0.00	5.00	99.82	* Spare Change Over. Spare to be taken out of service.
XMER	1500MVA,765/400kV ICT-4 AT TAMNAR PS	OSPT	06-05-2023	13:48:00	06-05-2023	15:07:00	0.06	1.32	0.00	0.00	0.00	99.82	* For Spare Change Over. Spare to be taken out of service. Last Spare Changeover date 04.04.2023
XMER	1500MVA,765/400kV ICT-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	