

Standard of Performance data for the Month of Aug-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifier	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT BHADRAWATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-2 AT BHADRAWATI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-1 AT BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT CHAMPA	OSPT	09-08-2024	11:05:00	09-08-2024	16:31:00	0.23	5.43	0.00	0.00	0.00	99.27	* To attend minor oil seepage from Bucholz valve of Rph unit. Dia to be kept open. Spare unit will be taken into service in place of Rph unit.
BSR	125MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT CHAMPA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR, BUS REACTOR-1 AT DHULE	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-1 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-2 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-3 AT DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-08-2024	00:00:01	01-08-2024	23:32:00	0.98	0.00	0.00	0.00	23.53	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	03-08-2024	10:03:00	03-08-2024	23:58:00	0.58	0.00	0.00	0.00	13.92	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	12-08-2024	10:41:00	12-08-2024	21:26:00	0.45	0.00	0.00	0.00	10.75	100.00	* BR H/T as per WRDLC instructions for VR
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	19-08-2024	08:26:00	19-08-2024	19:13:00	0.45	0.00	0.00	0.00	10.78	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	14-08-2024	10:45:00	15-08-2024	17:11:00	1.27	0.00	0.00	0.00	30.43	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	20-08-2024	10:24:00	20-08-2024	20:08:00	0.41	0.00	0.00	0.00	9.73	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	28-08-2024	11:21:00	28-08-2024	21:28:00	0.42	0.00	0.00	0.00	10.12	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation.
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* BR H/T as per WRDLC instructions for VR
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation
BSR	125MVAR, BUS REACTOR-2 AT KOLHAPUR	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSET	SVRD	01-08-2024	09:44:00	01-08-2024	21:05:00	0.47	0.00	0.00	0.00	11.35	100.00	* BR H/T as per WRDLC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSET	SVRD	17-08-2024	09:30:00	19-08-2024	18:57:00	2.39	0.00	0.00	0.00	57.45	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSET	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSET	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSET	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSET	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSET	SVRD	04-08-2024	10:11:00	31-08-2024	23:59:59	27.58	0.00	0.00	0.00	661.82	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSET	SVRD	27-08-2024	09:42:00	31-08-2024	23:59:59	4.60	0.00	0.00	0.00	110.30	100.00	* BR H/T as per WRDLC instructions for Voltage Regulation.
BSR	80MVAR, BUS REACTOR-1 AT KOLHAPUR MSET	SVRD	24-08-2024	10:20:00	31-08-2024	23:59:59	7.57	0.00	0.00	0.00	181.67	100.00	* BR H/T as per WRDLC instructions for VR
BSR	80MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of Aug-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	14-08-2024	11:15:00	14-08-2024	21:46:00	0.44	0.00	0.00	0.00	10.52	100.00	* BR H/T as per WRLDC instructions for Voltage Regulation.
BSR	63MVAR, BUS REACTOR-1 AT SOLAPUR	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* BR H/T as per WRLDC instructions for VR
BSR	240MVAR, BUS REACTOR-2 AT SOLAPUR	OSFT	05-08-2024	11:16:00	05-08-2024	18:48:00	0.31	7.53	0.00	0.00	0.00	98.99	* Emergency out of 765KV Bus Reactor-2 at Solapur 765KV is required to attend the oil leakage from Prismatic Oil level gauge of R.Ph Unit.
BSR	240MVAR, BUS REACTOR-1 AT TAMNAR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR, BUS REACTOR-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR, BUS REACTOR-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR, BUS REACTOR-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR, BUS REACTOR-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KORBA(CSEB)-BUDDHIPADAR(OPTCL)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AKOLA(MSETCL)-AURANGABAD-1	OMST	19-08-2024	16:36:00	19-08-2024	17:10:00	0.02	0.57	0.00	0.00	0.00	99.92	* Line Auto reclosed successful on R ph to ground fault at Aurangabad end but tripped at Akola end on R-G fault.Fault Details at Aurangabad end: FD:-259.953 KM, FC:-2.085, Fault is in Akola TLM jurisdiction.* 29.08.2024 09:18:32 INDIA (60001973)* Flash ov
CKT	400kV AKOLA(MSETCL)-AURANGABAD-1	LART	01-08-2024	16:56:00	01-08-2024	16:56:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line A/R successful on Y-G fault. Fault Details at Aurangabad end : FD-38.636 km, FC: 10.166 KA, Fault Details at Akola end :- FD:-239.60 KM ,FC:- 1.67 KA. Fault is in Aurangabad TLM jurisdiction . Faulty phase position - Middle . * 28.08.2024 21:03
CKT	400kV AKOLA(MSETCL)-AURANGABAD-2	LNCC	20-08-2024	15:16:00	20-08-2024	15:59:00	0.03	0.00	0.00	0.72	0.00	100.00	* Line tripped on B ph to Ground fault. Fault details at Aurangabad end : M1-FD-134.9km,FC-2.5kA <->&<-> M2-FD-137.1km,FC-2.5kA and Fault details at Akola (MSETCL) end : M1-FD-137.7km,FC-2.48kA<->&<-> M2-FD-197.3km,FC-1.83kA. Fault is in Aurangabad T
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-2	OSFT	24-08-2024	10:19:00	24-08-2024	16:20:00	0.25	6.02	0.00	0.00	0.00	97.98	* Emergency outage availed by MSETCL to attend hot spot in Line isolator at Aurangabad (MSETCL) end.
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-2	LCS	02-08-2024	10:08:00	04-08-2024	23:59:00	2.58	0.00	0.00	0.00	61.85	100.00	* for GIS Module interconnection as part of 400/220 KV ICT 1 <->&<-> 2 Commissioning under Western Region Expansion Scheme – XXVI (WRES-XXVI) at Pune GIS.
CKT	400kV AURANGABAD-AURANGABAD(MSETCL)-2	OSFT	04-08-2024	05:44:00	04-08-2024	14:46:00	0.38	9.03	0.00	0.00	0.00	97.98	* Emergency outage availed to attend suspected Y ph CT secondary open (Y ph current was showing zero) at Aurangabad MSETCL end.
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-CHANDRAPUR(MSEB)-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-DHARIWAL(CESC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHADRAWATI-PARLI-1	OSPT	12-08-2024	07:50:00	12-08-2024	23:29:00	0.65	15.65	0.00	0.00	0.00	97.90	* For LR Cable replacement work and AMP of LR
CKT	400kV BHATAPARA-BHILAI(CSEB)-1	OMSU	21-08-2024	15:26:00	22-08-2024	12:25:00	0.87	0.00	20.98	0.00	0.00	100.00	* Line tripped on Y-B ph to ph fault. Fault details at Bhilai end : M1-FD-22.89km,FC-Y-15.18kA <->&<-> B-15.06kA and Fault details at Bhatapara end : M1-FD-62.5km,FC-Y-3.824kA <->&<-> B-3.911kA. Fault is in Raipur TLM jurisdiction. Faulty phase positi
							0.87	0.00	20.98	0.00	0.00	100.00	

Standard of Performance data for the Month of Aug-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifier	Detailed Reasons for Outage
CKT	400kV BHILAI(CSEB)-BHADRAWATI-2	SEFT	16-08-2024	14:29:00	16-08-2024	16:42:00	0.09	2.22	0.00	0.00	0.00		* During tripping of 400KV Bhilai - Bhdrawati on Rph - Earth fault , Main CB - R ph at Bhadrawati did not OPEN <->&-> Main CB LBB got Operated. This resulted into 400 KV BUS 1 tripping at Bhadrawati and 3Ph Line Tripping at both ends. Fault Detail
							0.09	2.22	0.00	0.00	0.00	99.70	
CKT	400kV BHILAI(CSEB)-KORADI(MSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV DHARIWAL(CESC)-PARLI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHARSUGUDA-RAIGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHARSUGUDA-RAIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JHARSUGUDA-RAIGARH-3	LHWT	07-08-2024	08:45:00	08-08-2024	16:01:00	1.30	31.27	0.00	0.00	0.00		* Line tripped on Yph to ground fault. Double end Detail: Raigarh end- FD: 132.87Km, FC- 3.417KA; Jharsuguda end- FD:21.62Km, 14.84KA. Fault is in Odisha jurisdiction. Charging attempt taken from Raigarh end at 09:46Hrs however line tripped at on persi
							1.30	31.27	0.00	0.00	0.00	95.80	
CKT	400kV JHARSUGUDA-RAIGARH-4	LART	23-08-2024	22:46:00	23-08-2024	22:46:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on B ph to Ground fault . Fault details at Raigarh (AFAS DE) :- FC- 3.16 kA,FD- 123.095 Km . Fault details at Jharsuguda (AFAS DE) :- FC-13.40 kA,FD- 22.405 km . Fault is in Odisha jurisdiction.* 31.08.2024 22:40:10 INDIA (60
CKT	400kV JHARSUGUDA-RAIGARH-4	LART	23-08-2024	20:07:00	23-08-2024	20:07:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on B ph to Ground fault . Fault details at Raigarh (AFAS DE) :- FC- 3.66 kA,FD- 129.65 Km . Fault details at Jharsuguda (AFAS DE) :- FC-17.07 kA,FD- 15.84 km . Fault is in Odisha jurisdiction.* 31.08.2024 22:33:59 INDIA (6000
CKT	400kV KOLHAPUR GIS-MAPUSA-1	OSFT	19-08-2024	06:09:00	19-08-2024	12:20:00	0.26	6.18	0.00	0.00	0.00	100.00	* Line H/T in emergency due to heavy spark observed in Y ph CVT at Kolhapur GIS end.
							0.26	6.18	0.00	0.00	0.00	99.17	
CKT	400kV KOLHAPUR GIS-MAPUSA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLHAPUR(MSETCL)-KOLHAPUR GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KOLHAPUR(MSETCL)-KOLHAPUR GIS-2	LCSD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-M= S-KOLHAPUR GIS-1
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	400kV KORBA(NTPC)-BHATAPARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KORBA(NTPC)-BHILAI(CSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KORBA(NTPC)-BHILAI(CSEB)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KORBA(NTPC)-BIRSINGHPUR(MPGENCO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KORBA(NTPC)-BIRSINGHPUR(MPGENCO)	OSPD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* For LILO Interconnection at BALCO Switchyard as per 2nd meeting of WRPC Dated: 04/09/2020. A/R in Non-Auto mode of 400kV Korba(NTPC)-Birsingpur Ckt-1 is required during the above line outage.
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	400kV KORBA(NTPC)-KORBA(CSEB)-1	LPRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Opened to control fault level at NTPC Korba
CKT	400kV KORBA(NTPC)-KORBA(CSEB)-1	OSPD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Outage availed By NTPC
							62.00	0.00	0.00	0.00	1,488.00	100.00	
CKT	400kV KORBA(NTPC)-RAIPUR-3	OSPT	17-08-2024	09:18:00	17-08-2024	18:44:00	0.39	9.43	0.00	0.00	0.00		* For AMP works. Also AR of 400KV-KORBA-NTPC-RAIPUR-4 is required on NON AUTO Mode.
							0.39	9.43	0.00	0.00	0.00	98.73	
CKT	400kV KORBA(NTPC)-RAIPUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KORBA(NTPC)-SIPAT(NTPC)	OSPD	06-08-2024	10:32:00	07-08-2024	19:38:00	1.38	0.00	0.00	0.00	33.10		* Outage availed by NTPC for line side equipment testing and CT oil sample collection
							1.38	0.00	0.00	0.00	33.10	100.00	
CKT	400kV KORADI(MSEB)-SATPURA(MPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LARA(NTPC)-CHAMPA-1	LART	22-08-2024	02:32:00	22-08-2024	02:32:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on R-ph to Ground fault . Fault details at Champa (AFAS) :- FC-4.75kA,FD-74.808km and Fault details at LARA NTPC end :- FD-28.05km. Fault is in Raigarh TLM jurisdiction. Faulty phase position - Top.* 30.08.2024 12:27:52 INDIA (
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LARA(NTPC)-CHAMPA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LARA(NTPC)-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV LARA(NTPC)-KOTRA PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of Aug-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifier	Detailed Reasons for Outage
CKT	400kV MAUDA(NTPC)-WARDHA-1	OSPD	24-08-2024	11:42:00	24-08-2024	13:59:00	0.10	0.00	0.00	0.00	2.28		* Outage availed by NTPC for implementation of revised relay settings as per the recommendations of Protection Audit
							0.10	0.00	0.00	0.00	2.28	100.00	
CKT	400kV MAUDA(NTPC)-WARDHA-2	OSPD	24-08-2024	15:36:00	24-08-2024	18:27:00	0.12	0.00	0.00	0.00	2.85		* Outage availed by NTPC for implementation of revised relay settings as per the recommendations of Protection Audit
							0.12	0.00	0.00	0.00	2.85	100.00	
CKT	400kV PADGHE GIS-KUDUS(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PADGHE GIS-KUDUS(MSETCL)-2	OSFT	29-08-2024	15:32:00	29-08-2024	20:57:00	0.23	5.42	0.00	0.00	0.00		* Emergency outage availed for attending hot spot in B-ph line CT at Kudus(MSTCL) end.
							0.23	5.42	0.00	0.00	0.00	99.27	
CKT	400kV PARLI-PARLI(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PARLI(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PARLI-PUNE GIS-1	LCSD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Indgrid requested for outage of lines for connecting the LILO with Kallam substation
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	400kV PARLI-PUNE GIS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE-PUNE GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE-PUNE GIS-2	OSPT	01-08-2024	00:00:01	01-08-2024	04:03:00	0.17	4.05	0.00	0.00	0.00		* Emergency outage availed for attending critical hot spots at Pune (Talegaon) end
							0.17	4.05	0.00	0.00	0.00	99.46	
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LART	25-08-2024	23:38:00	25-08-2024	23:38:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on R ph to Ground fault . Fault details at Pune-GIS end :- FC- 8.5kA,FD-29.5Km. Fault details at Aurangabad (Waluj) end :- FC-2.11kA,FD-183.3km . Fault is in M/s. Adani jurisdiction.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for Power regulation
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	31-08-2024	07:54:00	31-08-2024	23:59:59	0.67	0.00	0.00	0.00	16.10		* Line H/T as per WRDLC instructions for Power Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-1	LPRD	08-08-2024	07:23:00	13-08-2024	10:09:00	5.12	0.00	0.00	0.00	122.77		* Line H/T as per WRDLC instructions for Power Regulation.
							36.79	0.00	0.00	0.00	882.87	100.00	
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	05-08-2024	00:00:01	06-08-2024	09:30:00	1.40	0.00	0.00	0.00	33.50		* Line kept out under power regulation after completion of outage for construction works.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LCSD	06-08-2024	09:30:00	07-08-2024	18:46:00	1.39	0.00	0.00	0.00	33.27		* For GIS Module interconnection as part of 400 /220 KV ICT 1 <-&> 2 Commissioning under Western Region Expansion Scheme – XXVI (WRES-XXVI) at Pune GIS.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	01-08-2024	00:00:01	02-08-2024	10:08:00	1.42	0.00	0.00	0.00	34.13		* Line H/T as per WRDLC instructions for Power Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LCSD	13-08-2024	10:18:00	14-08-2024	22:36:00	1.51	0.00	0.00	0.00	36.30		* POST OCC: For completion of integration works of the project for Extension of 765/400/220kV Pune (Shikrapur) GIS substation under Western Region Expansion Scheme – XXVI (WRES-XXVI).
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	14-08-2024	22:36:00	23-08-2024	08:25:00	8.41	0.00	0.00	0.00	201.82		* Line kept out under Power Regulation
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	LPRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for Power flow Regulation.
CKT	400kV PUNE GIS-AURANGABAD(MSETCL)-2	SCSD	23-08-2024	08:25:00	31-08-2024	23:59:59	8.65	0.00	0.00	0.00	207.58		* For construction works of upcoming ICT-3.
							53.78	0.00	0.00	0.00	1,290.60	100.00	
CKT	400kV PUNE GIS-PUNE-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV PUNE GIS-PUNE-4	OSFT	11-08-2024	18:58:00	12-08-2024	04:26:00	0.39	9.47	0.00	0.00	0.00		* Emergency outage of 400KV Talegaon GIS Line # 4 is availed for replacement of 'Y' phase CVT due to violation in CVT Secondary voltage.
							0.39	9.47	0.00	0.00	0.00	98.73	
CKT	400kV RAIGARH-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIGARH-KOTRA PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHADRAWATI-1	LCSD	20-08-2024	09:18:00	20-08-2024	18:54:00	0.40	0.00	0.00	0.00	9.60		* For erection of new T<-&>R make 50 MVAR line reactor- Replacement of BHEL make Line reactor under ADDCAP
							0.40	0.00	0.00	0.00	9.60	100.00	
CKT	400kV RAIPUR-BHADRAWATI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHADRAWATI-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-BHILAI(CSEB)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of Aug-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifier	Detailed Reasons for Outage
CKT	400kV RAIPUR-RAIGARH-4	OMSU	13-08-2024	11:39:00	13-08-2024	15:18:00	0.15	0.00	3.65	0.00	0.00		* Line tripped on B-G fault. Fault Details at Raigarh end(DE) : FD-69.807 km, FC: 3.818 KA, Fault Details at Raipur end :- FD:-150.693 KM ,FC:- 2.276KA. Fault is in Raigarh TLM jurisdiction . Faulty phase position - Top * 30.08.2024 12:48:50 INDIA (6
							0.15	0.00	3.65	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIPUR PS(DURG)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-WARDHA-1	LART	21-08-2024	19:31:00	21-08-2024	19:31:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on Y ph to Ground fault . Fault details at Raipur (AFAS) :- FC-4.855kA,FD-71.044km and Fault details at Wardha end :- FC-1.35kA,FD-308.8km Fault is in Durg TLM jurisdiction. Faulty phase position - Top* 29.08.2024 13:55:17 INDIA
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAIPUR-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RANCHI-SIPAT(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RANCHI-SIPAT(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-1	LCSD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Reconductoring works.
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ROURKELA-JHARSUGUDA-3	LCSD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* for reconductoring work on continuous basis
							31.00	0.00	0.00	0.00	744.00		* Reconductoring works
CKT	400kV ROURKELA-JHARSUGUDA-3	LCSD	01-08-2024	00:00:01	31-08-2024	23:59:59	62.00	0.00	0.00	0.00	1,488.00	100.00	
							31.00	0.00	0.00	0.00	744.00		* for reconductoring work on continuous basis
CKT	400kV ROURKELA-JHARSUGUDA-4	LCSD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	
							31.00	0.00	0.00	0.00	744.00	100.00	
CKT	400kV SEONI-KIRNAPUR(MPPTCL)	GOVC	03-08-2024	12:59:00	03-08-2024	19:39:00	0.28	0.00	0.00	6.67	0.00		* Tripped on over voltage protection
							0.28	0.00	0.00	6.67	0.00		
CKT	400kV SEONI-KIRNAPUR(MPPTCL)	OSPD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* 400KV Seoni Kirnapur Line approved outage availed by MPPTCL.
							31.00	0.00	0.00	0.00	744.00		* Line A/R successful on Y-G fault. Fault details at Seoni end(AFAS) M1: Y-G, 5.74KA, 61.57km. at Kirnapur: Y-G, 2.4KA, 61.5km. Fault is in MPPTCL jurisdiction.
CKT	400kV SEONI-KIRNAPUR(MPPTCL)	LART	27-08-2024	11:03:00	27-08-2024	11:03:00	0.00	0.00	0.00	0.00	0.00		* Line H/T as per WRLDC instructions for Voltage Regulation.
							0.33	0.00	0.00	0.00	7.83		
CKT	400kV SEONI-KIRNAPUR(MPPTCL)	LVRD	04-08-2024	13:48:00	04-08-2024	21:38:00	0.33	0.00	0.00	0.00	7.83		
							31.61	0.00	0.00	6.67	751.83	100.00	
CKT	400kV SEONI-SATPURA(MPPTCL)	OMSU	28-08-2024	13:41:00	28-08-2024	17:48:00	0.17	0.00	4.12	0.00	0.00		* Line tripped on DT receipt at Seoni end.
							0.17	0.00	4.12	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SOLAPUR(NTPC)-SOLAPUR-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SIPAT(NTPC)-RAIPUR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV VINDHYACHAL(NTPC)-KORBA(NTPC)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AKOLA(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-AKOLA(MSETCL)-2	LART	22-08-2024	19:27:00	22-08-2024	19:27:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on R ph to Ground fault . Fault details at Wardha (AFAS) :- Main I :- FC- 3.79 kA,FD-102.9 Km ; Main II :- FC- 3.75 kA= ,FD-143.5 Km and Fault details at Akola end :- Main I- FC-5.89kA,FD- 52 km ; Main II- FC-NA,FD- 52 km. Fault i
							0.43	10.30	0.00	0.00	0.00		* For BHEL insulator replacement work and Line AMP work at Wardha Substation.
CKT	400kV WARDHA-AKOLA(MSETCL)-2	OSPT	24-08-2024	09:10:00	24-08-2024	19:28:00	0.43	10.30	0.00	0.00	0.00	98.62	
							0.43	10.30	0.00	0.00	0.00	98.62	
CKT	400kV WARDHA-AURANGABAD-1	LART	31-08-2024	22:29:00	31-08-2024	22:29:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on B ph to Ground fault . Fault details at Wardha end :- Main 1 - FC- 15.874 kA,FD-18.245 KM . Fault details at Aurangabad Main 1 - FC- 1.831 kA,FD-357.0 KM . Fault is in Wardha TLM Jurisdiction.* 04.09.2024 17:41:01 INDIA (600

Standard of Performance data for the Month of Aug-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifier	Detailed Reasons for Outage
CKT	400kV WARDHA-AURANGABAD-1	LART	22-08-2024	20:56:00	22-08-2024	20:56:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on R ph to Ground fault . Fault details at Wardha (AFAS DE) :- FC- 10.48 kA,FD- 35.9 Km . Fault details at Aurangabad (AFAS DE) :- FC-1.91 kA,FD- 321 km . Fault is in Wardha TLM jurisdiction. Faulty phase position - Right* 30.0
CKT	400kV WARDHA-AURANGABAD-1	LART	22-08-2024	21:16:00	22-08-2024	21:16:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on R ph to Ground fault . Fault details at Wardha (AFAS DE) :- FC- 11.28 kA,FD- 31.48 Km . Fault details at Aurangabad (AFAS DE) :- FC-1.89kA,FD- 325.52 km . Fault is in Wardha TLM jurisdiction. Faulty phase position - Right* 3
CKT	400kV WARDHA-AURANGABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-WARORA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARDHA-WARORA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARORA-PARLI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV WARORA-PARLI-2	OSPT	05-08-2024	09:15:00	06-08-2024	04:07:00	0.79	18.87	0.00	0.00	0.00		* For LR Cable replacement work. AR of CKT#1 to be kept in non auto mode
CKT	765kV AURANGABAD-PADGHE GIS	LART	26-08-2024	07:43:00	26-08-2024	07:43:00	0.00	0.00	0.00	0.00	0.00	100.00	* Line A/R successful on R ph to Ground fault . Fault details at Padghe-GIS end(DE) :- FC- 4.793kA,FD-47.953Km. Fault details at Aurangabad end(DE) :- FC-3.793kA,FD-241.987km . Fault is in Aurangabad TLM.* 03.09.2024 20:50:05 INDIA (60001973)* *On Towe
CKT	765kV AURANGABAD-PUNE GIS	LVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T along with SLR at both ends as per WRDLC instructions for Voltage Regulation.
CKT	765kV BILASPUR-DHARAMJAYGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BILASPUR-SEONI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BILASPUR-SEONI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV CHAMPA-KOTRA PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV CHAMPA-RAIPUR PS(DURG)-1	LVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instruction and SLR at Durg PS is converted as BR at 04:02hrs for Voltage regulation.
CKT	765kV CHAMPA-RAIPUR PS(DURG)-1	LVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR Converted as BR at Durg SS
CKT	765kV CHAMPA-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV CHAMPA-DHARAMJAYGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RANCHI-DHARAMJAYGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RANCHI-DHARAMJAYGARH-2	LART	21-08-2024	19:00:00	21-08-2024	19:00:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on Y ph to Ground fault . Fault details at Dharamjaygarh (AFAS - DE) :- FC-8.64kA,FD- 57.449km,TWFL- 44.53km. Fault is in Korba TLM jurisdiction. Faulty phase position - Right* 29.08.2024 13:28:32 INDIA (60001973)* Flashover marks fou
CKT	765kV RANCHI-DHARAMJAYGARH-2	LMAC	24-08-2024	12:28:00	24-08-2024	13:52:00	0.06	0.00	0.00	1.40	0.00		* Line H/T in emergency by ER I to rescue the mentally disabled person who climbed on the tower.
CKT	765kV RANCHI-DHARAMJAYGARH-2	LART	14-08-2024	15:04:00	14-08-2024	15:04:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on B-G fault. Fault Details at Dharamjaygarh end(DE) : FD-243.1 km, FC: 2.89 KA, Fault Details at Ranchi end (DE):- FD:-107.8 KM ,FC:- 4.36KA. Fault is in Tamnar TLM jurisdiction . Faulty phase position - Left .
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-1	LART	20-08-2024	04:48:00	20-08-2024	04:48:00	0.00	0.00	0.00	0.00	0.00		* Line Auto reclosed successful on R ph to ground fault . Fault details at Dharamjaygarh (AFAS - DE) R-G, FC- 5.67 KA, FD- 125.64 KM and Fault details at Jharsuguda (AFAS - DE) R-G, FC- 16.62 KA, FD- 25.85 KM, Fault is in Odissa jurisdiction. Faulty pha
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JHARSUGUDA-DHARAMJAYGARH-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-RAIPUR PS(DURG)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-RAIPUR PS(DURG)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV KOTRA PS-TAMNAR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of Aug-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifier	Detailed Reasons for Outage
CKT	765kV KOTRA PS-TAMNAR PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	765KV-PUNE GIS-PADGHE GIS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-1	LVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for voltage Regulation and SLR charged as BR at 17:13 Hrs at Durg end.
CKT	765kV RAIPUR PS(DURG)-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV RAIPUR PS(DURG)-WARDHA-3	LVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC code for V/R and SLR converted as BR at 19:04Hrs. at Durg SS for VR.
CKT	765kV RAIPUR PS(DURG)-WARDHA-4	LVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR charged as BR at Durg end on dt 30.11.2023 at 00:41Hrs.
CKT	765kV SEONI-WARDHA-1	OSPT	30-08-2024	09:36:00	30-08-2024	21:13:00	0.48	11.62	0.00	0.00	0.00		* FOR AMP WORK@SEONI S/S
CKT	765kV SEONI-WARDHA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	98.44	
CKT	765kV SOLAPUR-AURANGABAD-1	LVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR converted as BR at 3:17hrs. @ Aurangabad end <(>&< at hrs. 03:21@ Solapur end.
CKT	765kV SOLAPUR-AURANGABAD-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SOLAPUR-PUNE GIS	LART	10-08-2024	04:58:00	10-08-2024	04:58:00	0.00	0.00	0.00	0.00	0.00		* Line A/R successful on B-G fault. Fault details at Pune-GIS end : Main-1 FD-130km,FC-3.44KA <(>&< Main-2 FD-129.6km,FC-3.44KA and Fault details at Solapur end : Main-1 FD-114.7km,FC-5.603KA <(>&< Main-2 FD-114.7km= ,FC-5.62KA . Fault is in Solapur
CKT	765kV SIPAT(NTPC)-BILASPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SIPAT(NTPC)-BILASPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV WARDHA-AURANGABAD-1	OSFT	31-08-2024	09:45:00	31-08-2024	19:42:00	0.42	9.95	0.00	0.00	0.00		* Emergency outage availed for attending open <(>&< hanging jumper at Loc no 784.
CKT	765kV WARDHA-AURANGABAD-2	LVRD	04-08-2024	00:28:00	27-08-2024	08:02:00	23.32	0.00	0.00	0.00	559.57		* Line H/T as per WRDLC instructions for Voltage Regulation and SLR converted as BR at 00:40 hrs. @ Wardha end.
CKT	765kV WARDHA-AURANGABAD-3	LVRD	28-08-2024	00:32:00	31-08-2024	23:59:59	3.98	0.00	0.00	0.00	95.47		* Line H/T as per WRDLC instructions for Voltage Regulation .
CKT	765kV WARDHA-AURANGABAD-4	OSFT	27-08-2024	09:13:00	27-08-2024	19:46:00	0.44	10.55	0.00	0.00	0.00		* Emergency outage availed for attending for attending broken polymer insulator at loc no. 704.
LNR	80MVAR,LR OF WARDHA-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF WARDHA-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF BOISAR-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	05-08-2024	06:51:00	05-08-2024	20:11:00	0.56	0.00	0.00	0.00	13.33		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	12-08-2024	07:39:00	12-08-2024	20:16:00	0.53	0.00	0.00	0.00	12.62		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	13-08-2024	07:47:00	13-08-2024	23:44:00	0.67	0.00	0.00	0.00	15.95		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF PADGHE-1 AT AURANGABAD	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	240MVAR,SWLR OF SOLAPUR-1 AT AURANGABAD	SVRD	05-08-2024	06:55:00	05-08-2024	20:10:00	0.55	0.00	0.00	0.00	13.25		* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SOLAPUR-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF SEONI-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF SEONI-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAJNANGAON-1 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of Aug-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifier	Detailed Reasons for Outage
LNR	240MVAR,SWLR OF RAJNANGAON-2 AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DHARAMJYGARH AT BILASPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-2 AT KORBA PS	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation
LNR	330MVAR,SWLR OF JABALPUR-1 AT KORBA PS	OSFT	01-08-2024	11:52:00	01-08-2024	16:15:00	0.18	4.38	0.00	0.00	0.00	99.41	* Emergency outage availed to attend SF6 low alarm
LNR	330MVAR,SWLR OF JARSUGUDA-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-3 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JABALPUR-4 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-2 AT KORBA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF JARSUGUDA-1 AT KORBA PS	OMSU	20-08-2024	04:48:00	20-08-2024	05:23:00	0.02	0.00	0.58	0.00	0.00	100.00	* SLR at Dharamjygarh end tripped on implemented Ferro Resonance scheme
LNR	240MVAR,SWLR OF DURG-2 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF DURG-1 AT KOTRA PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS1 AT PARLI	OSPT	09-08-2024	08:30:00	10-08-2024	01:02:00	0.69	16.53	0.00	0.00	0.00	97.78	* For LR Cable replacement work
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PARLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF PUNE GIS-1 AT PUNE	GOMD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR kept open as per WRDLC instructions for Voltage Regulation.
LNR	50MVAR,SWLR OF PUNE GIS-2 AT PUNE	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	50MVAR,SWLR OF PUNE GIS-3 AT PUNE	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	50MVAR,SWLR OF PUNE GIS-4 AT PUNE	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	50MVAR,SWLR OF PUNE GIS-4 AT PUNE	SVRD	14-08-2024	11:22:00	31-08-2024	23:59:59	17.53	0.00	0.00	0.00	420.63	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF SHOLAPUR AT PUNE GIS	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	07-08-2024	10:16:00	07-08-2024	21:39:00	0.47	0.00	0.00	0.00	11.38	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-08-2024	08:25:00	01-08-2024	21:07:00	0.53	0.00	0.00	0.00	12.70	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	12-08-2024	06:46:00	12-08-2024	20:15:00	0.56	0.00	0.00	0.00	13.48	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	02-08-2024	11:45:00	02-08-2024	23:48:00	0.50	0.00	0.00	0.00	12.05	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	13-08-2024	06:38:00	13-08-2024	21:40:00	0.63	0.00	0.00	0.00	15.03	100.00	* SLR H/T as per WRDLC instructions for VR.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	08-08-2024	07:20:00	09-08-2024	05:04:00	0.91	0.00	0.00	0.00	21.73	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	06-08-2024	09:41:00	06-08-2024	21:57:00	0.51	0.00	0.00	0.00	12.27	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	05-08-2024	06:41:00	05-08-2024	20:22:00	0.57	0.00	0.00	0.00	13.68	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	24-08-2024	10:24:00	24-08-2024	22:31:00	0.51	0.00	0.00	0.00	12.12	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	30-08-2024	08:37:00	31-08-2024	23:59:59	1.64	0.00	0.00	0.00	39.38	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	23-08-2024	08:55:00	31-08-2024	23:59:59	8.63	0.00	0.00	0.00	207.08	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRDLC instructions for V
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	26-08-2024	10:41:00	27-08-2024	00:33:00	0.58	0.00	0.00	0.00	13.87	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	28-08-2024	09:01:00	28-08-2024	20:33:00	0.48	0.00	0.00	0.00	11.53	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	18-08-2024	08:51:00	18-08-2024	19:16:00	0.43	0.00	0.00	0.00	10.42	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	16-08-2024	06:53:00	16-08-2024	20:20:00	0.56	0.00	0.00	0.00	13.45	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	17-08-2024	08:09:00	17-08-2024	18:06:00	0.42	0.00	0.00	0.00	9.95	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	19-08-2024	10:06:00	19-08-2024	18:47:00	0.36	0.00	0.00	0.00	8.68	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	20-08-2024	07:41:00	20-08-2024	20:02:00	0.52	0.00	0.00	0.00	12.35	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	21-08-2024	08:33:00	21-08-2024	22:09:00	0.57	0.00	0.00	0.00	13.60	100.00	* SLR H/T as per WRDLC instructions for Voltage Regulation.

Standard of Performance data for the Month of Aug-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-I

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifier	Detailed Reasons for Outage
LNR	240MVAR,SWLR OF AURANGABAD AT PUNE GIS	SVRD	14-08-2024	11:24:00	14-08-2024	21:29:00	0.42	0.00	0.00	0.00	10.08		* SLR H/T as per WRDLC instructions for Voltage Regulation.
							174.80	0.00	0.00	0.00	4,194.83	100.00	
LNR	240MVAR,SWLR OF JARSUGUDA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF JARSUGUDA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF CHAMPA-1 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF CHAMPA-2 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-3 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-4 AT RAIPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KORBA-3 AT RAIPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF WARDHA-2 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-1 AT SEONI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80 MVAR,765 KV SPARE COLD REACTOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF KARAD AT SHOLAPUR	SVRD	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* SLR H/T as per WRDLC instructions for Voltage Regulation
							31.00	0.00	0.00	0.00	744.00	100.00	
LNR	240MVAR,SWLR OF AURANGABAD-1 AT SHOLAPUR	SVRD	13-08-2024	07:42:00	13-08-2024	21:43:00	0.58	0.00	0.00	0.00	14.02		* SLR H/T as per WRDLC instructions for Voltage Regulation.
							0.58	0.00	0.00	0.00	14.02	100.00	
LNR	240MVAR,SWLR OF AURANGABAD-2 AT SHOLAPUR	SVRD	12-08-2024	07:42:00	31-08-2024	23:59:59	19.68	0.00	0.00	0.00	472.30		* SLR H/T as per WRDLC instructions for Voltage Regulation.
							19.68	0.00	0.00	0.00	472.30	100.00	
LNR	240MVAR,SWLR OF PUNE AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAICHUR-2 AT SOLAPUR	OMSU	01-08-2024	00:00:01	31-08-2024	23:59:59	31.00	0.00	744.00	0.00	0.00		* SLR tripped due to implementation of Ferroresonance scheme at Solapur s/s as 765KV Solapur Raichur ckt#2 Auto Reclosed on R-E fault.
							31.00	0.00	744.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF RAICHUR-1 AT SOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF AURANGABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,LR OF AURANGABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF NIZAMABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF NIZAMABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-2 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-1 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-3 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,LR OF AURANGABAD-4 AT WARDHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT SHOLAPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT AURANGABAD			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

