

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-1 AT BANASKANTHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-1 AT BANASKANTHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT BETUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT BHACHAU	OSPT	27-02-2025	10:30:00	27-02-2025	18:12:00	0.32	7.70	0.00	0.00	0.00		* H/T for replacement of PRD switch and cable
							0.32	7.70	0.00	0.00	0.00	98.85	
BSR	125MVAR,BUS REACTOR-2 AT BHACHAU	SVRD	10-02-2025	09:38:00	10-02-2025	21:50:00	0.51	0.00	0.00	0.00	12.20		* h/t on v/r
BSR	125MVAR,BUS REACTOR-2 AT BHACHAU	SVRD	09-02-2025	09:32:00	09-02-2025	21:30:00	0.50	0.00	0.00	0.00	11.97		* H/T on V/R as per WRLDC instruction
							1.01	0.00	0.00	0.00	24.17	100.00	
BSR	125MVAR,BUS REACTOR-1 AT BHUJ	SVRD	09-02-2025	09:51:00	09-02-2025	21:47:00	0.50	0.00	0.00	0.00	11.93		* H/T on V/R as per WRLDC instruction
							0.50	0.00	0.00	0.00	11.93	100.00	
BSR	330MVAR,BUS REACTOR-1 AT BHUJ	SVRD	21-02-2025	09:31:00	21-02-2025	20:14:00	0.45	0.00	0.00	0.00	10.72		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
							0.45	0.00	0.00	0.00	10.72	100.00	
BSR	125MVAR,BUS REACTOR-1 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT DAMOH	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
							28.00	0.00	0.00	0.00	672.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT DAMOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT DEHGAM			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT DEHGAM	SVRD	08-02-2025	10:26:00	09-02-2025	21:25:00	1.46	0.00	0.00	0.00	34.98		* h/t on v/r
BSR	125MVAR,BUS REACTOR-2 AT DEHGAM	SVRD	19-02-2025	09:33:00	28-02-2025	23:59:59	9.60	0.00	0.00	0.00	230.45		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
							11.06	0.00	0.00	0.00	265.43	100.00	
BSR	125MVAR,BUS REACTOR-1 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	21-02-2025	09:29:00	21-02-2025	18:34:00	0.38	0.00	0.00	0.00	9.08		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	22-02-2025	06:38:00	22-02-2025	21:41:00	0.63	0.00	0.00	0.00	15.05		* H/T ON VOLTAGE REGULATION VIDE WRLDC CODE ON SYSTEM CONSTRAINTS
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	18-02-2025	07:22:00	18-02-2025	21:45:00	0.60	0.00	0.00	0.00	14.38		* H/T on V/R as per WRLDC instruction
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	20-02-2025	08:24:00	20-02-2025	18:59:00	0.44	0.00	0.00	0.00	10.58		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	19-02-2025	07:56:00	19-02-2025	20:17:00	0.52	0.00	0.00	0.00	12.35		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	27-02-2025	09:15:00	28-02-2025	23:59:59	1.62	0.00	0.00	0.00	38.75		* H/T on V/R
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	15-02-2025	10:58:00	17-02-2025	21:53:00	2.46	0.00	0.00	0.00	58.92		* H/T on Voltage regulation
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	03-02-2025	07:26:00	04-02-2025	20:48:00	1.56	0.00	0.00	0.00	37.37		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	14-02-2025	08:41:00	14-02-2025	20:01:00	0.47	0.00	0.00	0.00	11.33		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	09-02-2025	07:19:00	09-02-2025	21:21:00	0.59	0.00	0.00	0.00	14.03		* H/T on V/R as per WRLDC instruction
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	10-02-2025	09:24:00	10-02-2025	21:45:00	0.52	0.00	0.00	0.00	12.35		* h/t on v/r
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	01-02-2025	07:42:00	01-02-2025	21:32:00	0.58	0.00	0.00	0.00	13.83		* h/t on v/r
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	07-02-2025	07:27:00	08-02-2025	20:23:00	1.54	0.00	0.00	0.00	36.93		* h/t on v/r
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	06-02-2025	07:03:00	06-02-2025	16:30:00	0.39	0.00	0.00	0.00	9.45		* HT on VR
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	05-02-2025	08:53:00	05-02-2025	20:22:00	0.48	0.00	0.00	0.00	11.48		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	02-02-2025	09:31:00	02-02-2025	21:34:00	0.50	0.00	0.00	0.00	12.05		* h/t on v/r
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	13-02-2025	08:53:00	13-02-2025	20:12:00	0.47	0.00	0.00	0.00	11.32		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	11-02-2025	08:47:00	12-02-2025	20:38:00	1.49	0.00	0.00	0.00	35.85		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
							15.24	0.00	0.00	0.00	365.10	100.00	
BSR	125MVAR,BUS REACTOR-2 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT INDORE	SVRD	01-02-2025	00:00:01	02-02-2025	21:44:00	1.91	0.00	0.00	0.00	45.73		* H/T on Voltage regulation
BSR	240MVAR,BUS REACTOR-2 AT INDORE	SVRD	16-02-2025	08:59:00	18-02-2025	22:30:00	2.56	0.00	0.00	0.00	61.52		* H/T on Voltage regulation
BSR	240MVAR,BUS REACTOR-2 AT INDORE	SVRD	03-02-2025	09:18:00	03-02-2025	19:57:00	0.44	0.00	0.00	0.00	10.65		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-2 AT INDORE	SVRD	12-02-2025	08:44:00	14-02-2025	21:42:00	2.54	0.00	0.00	0.00	60.97		* 08.02.2025 08:54:57 INDIA (60001696)* h/t on v/r
BSR	240MVAR,BUS REACTOR-2 AT INDORE	SVRD	08-02-2025	07:53:00	11-02-2025	18:45:00	3.45	0.00	0.00	0.00	82.87		* h/t on v/r
BSR	240MVAR,BUS REACTOR-2 AT INDORE	SVRD	24-02-2025	07:30:00	24-02-2025	07:30:00	0.00	0.00	0.00	0.00	0.00		* H/T on Voltage regulation
BSR	240MVAR,BUS REACTOR-2 AT INDORE	SVRD	19-02-2025	08:54:00	21-02-2025	21:21:00	2.52	0.00	0.00	0.00	60.45		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-2 AT INDORE	SVRD	23-02-2025	07:41:00	23-02-2025	21:53:00	0.59	0.00	0.00	0.00	14.20		* H/T on Voltage regulation
BSR	240MVAR,BUS REACTOR-2 AT INDORE	SVRD	28-02-2025	08:47:00	28-02-2025	08:47:00	0.00	0.00	0.00	0.00	0.00		* H/T on VR
BSR	240MVAR,BUS REACTOR-2 AT INDORE	SVRD	22-02-2025	09:38:00	27-02-2025	20:33:00	5.46	0.00	0.00	0.00	130.92		* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
							19.47	0.00	0.00	0.00	467.31	100.00	
BSR	125MVAR,BUS REACTOR-1 AT ITARSI	SCSD	20-02-2025	10:48:00	20-02-2025	17:53:00	0.30	0.00	0.00	0.00	7.08		* H/T 400kv B/R 1 at Itarsi SS at 10:48 hrs./20.02.2025 to connect main bay jumper of isolator (416-89A) after isolator replacement works under add cap.
BSR	125MVAR,BUS REACTOR-1 AT ITARSI	SCSD	17-02-2025	09:25:00	28-02-2025	23:59:59	11.61	0.00	0.00	0.00	278.58		* H/T ITARSI - 400KV B/R 1 at 09:25 hrs./17.02.2025 to drop down the Main Bay Jumper of Isolator (416-89A) for Main Bay Isolator replacement works under ADD CAP.
							11.91	0.00	0.00	0.00	285.66	100.00	
BSR	125MVAR,BUS REACTOR-2 AT ITARSI	SVRD	01-02-2025	10:41:00	28-02-2025	23:59:59	27.56	0.00	0.00	0.00	661.32		* h/t on v/r

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

						27.56	0.00	0.00	0.00	661.32	100.00	
BSR	50MVAR,BUS REACTOR-3 AT ITARSI			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT JABALPUR PS			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT JABALPUR PS			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT JABALPUR PS			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT JABALPUR PS			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT JABALPUR			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT JABALPUR			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	25MVAR,33kV BUS REACTOR-1 AT JABALPUR			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	25MVAR,33kV BUS REACTOR-2 AT JABALPUR			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT KALA	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00	* H/T on Voltage regulation
BSR	80MVAR,BUS REACTOR-1 AT KALA	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00	* H/T on Voltage regulation vide WRLDC code on system constraints
						56.00	0.00	0.00	0.00	1,344.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT KHANDWA			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT KHANDWA			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT KHANDWA			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT MAGARWADA	SVRD	22-02-2025	10:59:00	28-02-2025	23:59:59	6.54	0.00	0.00	0.00	157.02	* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
BSR	80MVAR,BUS REACTOR-1 AT MAGARWADA	SVRD	04-02-2025	10:55:00	09-02-2025	21:31:00	5.44	0.00	0.00	0.00	130.60	* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
						11.98	0.00	0.00	0.00	287.62	100.00	
BSR	63MVAR,BUS REACTOR-1 AT NAVSARI	SVRD	08-02-2025	15:37:00	09-02-2025	21:25:00	1.24	0.00	0.00	0.00	29.80	* H/T on V/R as per WRLDC instruction
						1.24	0.00	0.00	0.00	29.80	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PIRANA			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT RAJGARH			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT RAJGARH			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT REWA			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT SATNA			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT SATNA			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR,BUS REACTOR-1 AT SATNA			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-2 AT SATNA			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT SHUJALPUR			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT SHUJALPUR			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT VADODARA	SVRD	13-02-2025	08:31:00	14-02-2025	20:57:00	1.52	0.00	0.00	0.00	36.43	* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
						1.52	0.00	0.00	0.00	36.43	100.00	
BSR	240MVAR,BUS REACTOR-1 AT VADODARA	SVRD	01-02-2025	09:50:00	01-02-2025	20:46:00	0.46	0.00	0.00	0.00	10.93	* h/t on v/r
BSR	240MVAR,BUS REACTOR-1 AT VADODARA	SVRD	08-02-2025	09:51:00	08-02-2025	18:46:00	0.37	0.00	0.00	0.00	8.92	* h/t on v/r
BSR	240MVAR,BUS REACTOR-1 AT VADODARA	SVRD	10-02-2025	11:06:00	10-02-2025	17:03:00	0.25	0.00	0.00	0.00	5.95	* h/t on v/r
BSR	240MVAR,BUS REACTOR-1 AT VADODARA	SVRD	09-02-2025	09:27:00	09-02-2025	16:46:00	0.31	0.00	0.00	0.00	7.32	* H/T on V/R as per WRLDC instruction
BSR	240MVAR,BUS REACTOR-1 AT VADODARA	SVRD	11-02-2025	10:31:00	11-02-2025	18:45:00	0.34	0.00	0.00	0.00	8.23	* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
BSR	240MVAR,BUS REACTOR-1 AT VADODARA	SVRD	17-02-2025	07:44:00	17-02-2025	17:42:00	0.42	0.00	0.00	0.00	8.97	* H/T on V/R as per WRLDC instruction
BSR	240MVAR,BUS REACTOR-1 AT VADODARA	SVRD	19-02-2025	09:35:00	19-02-2025	18:35:00	0.38	0.00	0.00	0.00	9.00	* H/T UNDER V/R AS PER WRLDC INSTRUCTION.
						2.53	0.00	0.00	0.00	60.32	100.00	
BSR	125MVAR,BUS REACTOR-1 AT VAV GIS			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT VINDHYACHAL PS			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT VINDHYACHAL PS			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV BHILOSA(DNH)-KHARADPARA(DNH)			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV GANDHAR(NTPC)-HALDARWA(GETCO)-1			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV GANDHAR(NTPC)-HALDARWA(GETCO)-2			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAKRAPAR(NPCIL)-HALDARWA(GETCO)-1			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAKRAPAR(NPCIL)-HALDARWA(GETCO)-2			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAKRAPAR(NPCIL)-VAPI(GETCO)-1			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAKRAPAR(NPCIL)-VAPI(GETCO)-2			00:00:00	00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAKRAPAR(NPCIL)-VAV(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAKRAPAR(NPCIL)-VAV(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAWAS(NTPC)-HALDARWA(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAWAS(NTPC)-HALDARWA(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAWAS(NTPC)-NAVSARI-1	LMAC	13-02-2025	08:56:00	13-02-2025	10:41:00	0.07	0.00	0.00	1.75	0.00		* A/T 220kV KAWAS(NTPC)-NAVSARI-1 at 08:56Hrs/13.02.2025 on R- Y Ph to Ph fault.* Indications:* Kawas end details:* M1: 5.7KM, Ir- 17.93KA, Iy- 17.82KA* Navsari end details:* M1- 50.37km, Ir- 3.57KA, Iy- 3.56KA* M2- 50.37km, Ir- 3.57KA, Iy- 3.56KA* Line test charged successfully at 10:41Hrs /13.02.2025.* 22.02.2025 00:45:17 INDIA (60003402)* Kite thread entangled at R Ph (top Ph) at location 39
CKT	220kV KAWAS(NTPC)-NAVSARI-1	LMAC	09-02-2025	17:17:00	09-02-2025	18:13:00	0.04	0.00	0.00	0.93	0.00		* A/T 220kV KAWAS(NTPC)-NAVSARI-1 at 17:17Hrs/09.02.2025 on R- Y Ph to Ph fault.* Indications:* Kawas end details:* 30.4km, Ir- 5.56KA, Iy- 5.62KA* Navsari end details:* M1- 22.1km, Ir- 8.3KA, Iy- 8.2KA* M2- 22.24km, Ir- 8.4KA, Iy- 8.36KA* Line test charged successfully at 18:13Hrs /09.02.2025.* suspected due to kite* 22.02.2025 02:00:01 INDIA (60002986)* Kite thread entangled at location 115
CKT	220kV KAWAS(NTPC)-NAVSARI-1	LMAC	15-02-2025	11:49:00	15-02-2025	19:41:00	0.33	0.00	0.00	7.87	0.00		* H/T 220KV Kawas-Navsari 1 line at 11:49Hrs/ 15.02.2025 on emergency basis to remove Kite thread at Various locations in Line.
							0.44	0.00	0.00	10.55	0.00	100.00	
CKT	220kV KAWAS(NTPC)-NAVSARI-2	LMAC	16-02-2025	11:27:00	16-02-2025	18:35:00	0.30	0.00	0.00	7.13	0.00		* H/T 220KV Kawas-Navsari 2 Line at 11:27Hrs/ 16.02.2025 on emergency basis to remove Kite thread at Various locations in Line
							0.30	0.00	0.00	7.13	0.00	100.00	
CKT	220kV KAWAS(NTPC)-VAV(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAWAS(NTPC)-VAV(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KHADOLI(DNH)-VAGCHIPA(DNH)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220KV NAVSARI GIS-BHESTAN#1	LMAC	04-02-2025	18:41:00	04-02-2025	19:52:00	0.05	0.00	0.00	1.18	0.00		* A/T of 220KV Navsari - Basthan #1 on R-Y Ph fault at 18:41hrs/04.02.2025* Navsari:-* M1- AFAS 18.35KM/10.64KA* Basthan:-* M1- 2.43KM/Ir- 14.95KM, Iy-15.3KA* M2-2.5KM/Ir-14.95KM, Iy-15.3KA* 22.02.2025 01:02:21 INDIA (60003402)* Kite thrads entangled in R Ph and Y Ph Insulators and Hardwares at location 69
							0.05	0.00	0.00	1.18	0.00	100.00	
CKT	220KV NAVSARI GIS-BHESTAN#2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV NAVSARI-NAVSARI (GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV NAVSARI-NAVSARI (GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SAYALI(DNH)-KHADOLI(DNH)	OSFD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* heavy spark was produced on Y-phase 89B (Bus isolator) of 220kV Khadoli-Sayli circuit for which emergency shutdown of 220kV Khadoli= -Sayli circuit was taken at 220kV Sayli switching Substation at 18:44 hrs./24.08.2024 taken by DNH BAY BELONGS TO DNH
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	220kV SAYALI(DNH)-VAGCHIPA(DNH)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV TARAPUR(NPCIL)-BOISAR-1	SCSD	11-02-2025	23:48:00	12-02-2025	07:38:00	0.33	0.00	0.00	0.00	7.83		* H/T 220kV TARAPUR-BOISAR line at 23:48 hrs./11.02.2025 for Bus-bar relay retrofitting <-> testing work at Boisar.Regards
CKT	220kV TARAPUR(NPCIL)-BOISAR-1	LCSD	05-02-2025	19:16:00	06-02-2025	03:54:00	0.36	0.00	0.00	0.00	8.63		* for Busbar/LBB retrofitting works
CKT	220kV TARAPUR(NPCIL)-BOISAR-1	LCSD	21-02-2025	22:34:00	22-02-2025	04:46:00	0.26	0.00	0.00	0.00	6.20		* H/T 220kV Tarapur 3<->4-Boisar -1 at 22:34hrs/21.02.2025 for busbar relay retrofitting and testing work.
							0.95	0.00	0.00	0.00	22.66	100.00	
CKT	220kV VAPI-BHILOSA(DNH)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV VAPI-KHARADPADA(DNH)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV VAPI-MAGARWADA(DAMAN)-1	OMSU	21-02-2025	16:42:00	21-02-2025	17:43:00	0.04	0.00	1.02	0.00	0.00		* A/R Successful at Vapi PG end and A/T at Magarwada DD end of 220KV Vapi-Magarwada 1 line on B-E fault at 16:42Hrs/ 21.02.2025.* Vapi end : * M1: 13.86KM, 7.44KA* M2: 14.8KM, 7.45KA** Magarwada DD end: 10.26KM, 3.06KA* Line Synchronized at Magarwada DD end at 17:43Hrs/ 21.02.2025* 27.02.2025 18:53:21 INDIA (60002986)* Infringement of Optical Cable during installation by Local Internet service provider at span 52-53. Flashover marks found on Bottom B Ph conductor.
CKT	220kV VAPI-MAGARWADA(DAMAN)-1	OSPD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* H/T 220KV-VAPI-MAGARWADA-1at 10:06 hrs./30.05.2024 for 220KV CVT REPLACEMENT, RELAY AND 220KV EQUIPMENTS TESTING AT MAGARWADA(DD) E= ND.(S/D requested by SLDC DD).
							28.04	0.00	1.02	0.00	672.00	100.00	
CKT	220kV VAPI-MAGARWADA(DAMAN)-2	OSPT	14-02-2025	11:31:00	14-02-2025	18:46:00	0.30	7.25	0.00	0.00	0.00		* H/T of 220KV-Vapi-Magarwada-2 at 11:31Hrs/14.02.2025 for attending Shutdown Nature Defects.
							0.30	7.25	0.00	0.00	0.00	98.92	
CKT	220kV VAPI -VAGCHIPA(DNH)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV VAPI -VAGCHIPA(DNH)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ANUPPUR(MB POWER)-JABALPUR PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ANUPPUR(MB POWER)-JABALPUR PS-2	OSFT	02-02-2025	09:02:00	02-02-2025	18:40:00	0.40	9.63	0.00	0.00	0.00		* H/T 400KV ANUPPUR-JABALPUR(Pooling) # 2 at 09:02 hrs./02.02.2025 on emergency basis to attend hot spot is observed at Loc No. 570.
							0.40	9.63	0.00	0.00	0.00	98.57	
CKT	400kV BANASKANTHA-SANKHARI(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANASKANTHA-SANKHARI(GETCO)-2	LART	16-02-2025	07:06:00	16-02-2025	07:06:00	0.00	0.00	0.00	0.00	0.00		* A/R Successful of 400KV Banaskantha - Sankhari #2 line at 07:06Hrs/16.02.2025 on B-E fault.* Banaskantha end:* M1: 13.8KM/11.9KA* M2: Not available* Sankhari end:* M1: 4.7KM/15.0KA* M2: -/16.62KA* 22.02.2025 02:10:25 INDIA (60002986)* Kite thrad entangled at middle ph and cross Arm at location 44
CKT	400kV BANASKANTHA-SANKHARI(GETCO)-2	LART	16-02-2025	06:07:00	16-02-2025	06:07:00	0.00	0.00	0.00	0.00	0.00		* A/R Successful of 400KV Banaskantha - Sankhari #2 line at 06:07Hrs/16.02.2025 on B-E fault.* Banaskantha end: AFAS* M1: 15.72KM/10.32KA* M2: 15.42KM/10.33KA* Sankhari end:* M1: 4.7KM/15.2KA, M2: 4.7KM/18.7KA* 22.02.2025 02:07:37 INDIA (60002986)* Kite thrad entangled at middle ph and cross Arm at location 44
CKT	400kV BANASKANTHA-SANKHARI(GETCO)-2	LMAC	16-02-2025	18:52:00	17-02-2025	01:46:00	0.29	0.00	0.00	6.90	0.00		* H/T 400KV BANASKANTHA-SANKHARI 2 at 18:52 hrs./16.02.2025 on emergency basis to remove kite thread at Loc. No 44.
							0.29	0.00	0.00	6.90	0.00	100.00	
CKT	400kV BANASKANTHA-VAV(RADHANESDA)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANASKANTHA-VAV(RADHANESDA)-2	LCSD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* H/T 400KV-VAV(RADHANESDA)-BANASKANTHA-2 at 22:09 hrs./24.06.2024 for Balance Diversion Work in CKT-1
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	400kV BETUL-KHANDWA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BETUL-KHANDWA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

						0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU-HALVAD(GETCO)			00:00:00		0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU-LIMBDI(GETCO)			00:00:00		0.00	0.00	0.00	0.00	0.00		
						0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV BHACHAU(PG)-LAKADIA(ADANI)-1	OSPT	05-02-2025	10:34:00	05-02-2025	21:50:00	0.47	11.27	0.00	0.00	0.00	
							0.47	11.27	0.00	0.00	0.00	98.32
CKT	400KV BHACHAU(PG)-LAKADIA(ADANI)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU-RANCHHODPURA(GETCO)-1	OSPT	19-02-2025	10:40:00	19-02-2025	20:03:00	0.39	9.38	0.00	0.00	0.00	
							0.39	9.38	0.00	0.00	0.00	98.60
CKT	400kV BHACHAU-RANCHHODPURA(GETCO)-2	LART	12-02-2025	04:47:00	12-02-2025	04:47:00	0.00	0.00	0.00	0.00	0.00	
CKT	400kV BHACHAU-RANCHHODPURA(GETCO)-2	LART	12-02-2025	06:38:00	12-02-2025	06:38:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV BHACHAU-VARSANA(GETCO)-1	OSPT	28-02-2025	10:45:00	28-02-2025	23:59:59	0.55	13.25	0.00	0.00	0.00	
							0.55	13.25	0.00	0.00	0.00	98.03
CKT	400kV BHACHAU-VARSANA(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV BINA-BINA(MPPTCL)-1	LEFT	04-02-2025	07:37:00	04-02-2025	08:14:00	0.03	0.62	0.00	0.00	0.00	
CKT	400kV BINA-BINA(MPPTCL)-1	OSFT	17-02-2025	11:43:00	18-02-2025	01:26:00	0.57	13.72	0.00	0.00	0.00	
							0.60	14.34	0.00	0.00	0.00	97.87
CKT	400kV BINA-BINA(MPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV BINA-BINA(MPPTCL)-3	SRMT	04-02-2025	07:37:00	04-02-2025	15:28:00	0.33	7.85	0.00	0.00	0.00	
							0.33	7.85	0.00	0.00	0.00	98.83
CKT	400kV BINA-BINA(MPPTCL)-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV BINA-SAGAR(MPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV BINA-SHUJALPUR-1	LART	03-02-2025	04:17:00	03-02-2025	04:17:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV BINA-SHUJALPUR-2	LART	09-02-2025	05:22:00	09-02-2025	05:22:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV BOISAR- AURANGABAD-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV BOISAR- AURANGABAD-2	LMAC	17-02-2025	19:19:00	17-02-2025	20:21:00	0.04	0.00	0.00	1.03	0.00	
							0.04	0.00	0.00	1.03	0.00	100.00
CKT	400kV BOISAR-PADGE(MSETCL)	LMAC	15-02-2025	15:04:00	15-02-2025	15:48:00	0.03	0.00	0.00	0.73	0.00	
							0.03	0.00	0.00	0.73	0.00	100.00
CKT	400kV BIRSINGHPUR(MPPTCL)-DAMOH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV BIRSINGHPUR(MPPTCL)-DAMOH-2	LART	01-02-2025	19:57:00	01-02-2025	19:57:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV MAGARWADA-BOISAR-1	LPRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00	
							28.00	0.00	0.00	0.00	672.00	100.00
CKT	400kV MAGARWADA-BOISAR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	
							0.00	0.00	0.00	0.00	0.00	100.00
CKT	400kV MAGARWADA-NAVSARI-1	OSPD	23-02-2025	07:48:00	23-02-2025	19:20:00	0.48	0.00	0.00	0.00	11.53	
CKT	400kV MAGARWADA-NAVSARI-1	OSPD	22-02-2025	11:15:00	22-02-2025	21:02:00	0.41	0.00	0.00	0.00	9.78	
							0.89	0.00	0.00	0.00	21.31	100.00
CKT	400kV MAGARWADA-NAVSARI-2	LMAC	07-02-2025	16:09:00	07-02-2025	17:17:00	0.05	0.00	0.00	1.13	0.00	
CKT	400kV MAGARWADA-NAVSARI-2	OSPT	04-02-2025	11:01:00	05-02-2025	02:00:00	0.62	14.98	0.00	0.00	0.00	
CKT	400kV MAGARWADA-NAVSARI-2	OSPD	23-02-2025	07:51:00	23-02-2025	19:12:00	0.47	0.00	0.00	0.00	11.35	
CKT	400kV MAGARWADA-NAVSARI-2	OSPD	22-02-2025	11:17:00	22-02-2025	21:04:00	0.41	0.00	0.00	0.00	9.78	
							1.55	14.98	0.00	1.13	21.13	97.77
CKT	400kV DAMOH-BHOPAL(MPPTCL)-1	OSFT	10-02-2025	14:11:00	10-02-2025	18:39:00	0.19	4.47	0.00	0.00	0.00	
CKT	400kV DAMOH-BHOPAL(MPPTCL)-1	LEFT	09-02-2025	20:41:00	09-02-2025	21:21:00	0.03	0.67	0.00	0.00	0.00	
							0.22	5.14	0.00	0.00	0.00	99.24

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

CKT	400kV DAMOH-BHOPAL(MPPTCL)-2	LART	08-02-2025	03:19:00	08-02-2025	03:19:00	0.00	0.00	0.00	0.00	0.00		* A/R successful of 400kV Damoh - Bhopal #2 on Y-ph/E fault at 03:19hrs/08.02.2025* Damoh end:-* M1- 139.08KM/2.62KA* M2- 117.63KM/2.62KA* Bhopal end:-* M1- 92.8KM/3.91KA* M2-93.87KM/3.91KA* 27.02.2025 18:14:21 INDIA (60002986)* Flashover marks found on Arcing Hron, Hardwares yoke plate in conductor end and also at tower end at location 323.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MANSAR(GETCO)-LIMBDI(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV INDORE(MPPCTL)-ASOJ(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV INDORE(MPPCTL)-ASOJ(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV INDORE -INDORE(MPPCTL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV INDORE -INDORE(MPPCTL)-2	OSPT	03-02-2025	09:57:00	03-02-2025	18:27:00	0.35	8.50	0.00	0.00	0.00		* H/T 400KV-Indore(PG)-Indore(MP)-2 at 09:57 hrs /03.02.2025 for attending S/D nature defect work
							0.35	8.50	0.00	0.00	0.00	98.74	
CKT	400kV ITARSI-INDORE(MPPCTL)-1	LART	14-02-2025	13:25:00	14-02-2025	13:25:00	0.00	0.00	0.00	0.00	0.00		* Dear Sir,** A/R Successful of 400KV Itarsi-Indore(MP)#1 line at 13:25Hrs/14.02.2025 on Y-E fault:** Itarsi end: * M1: 158.56KM, 2.33KA* M2: 159.4KM, 2.24KA** Indore(MP) end:* 34KM,7.61KA* Regards,* 27.02.2025 19:00:13 INDIA (60002986)* AUTO RECLOSURE DUE TO NH CONSTRUCTION WORKS SPAN 468-469
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ITARSI-INDORE(MPPCTL)-2	SCSD	25-02-2025	12:59:00	26-02-2025	22:18:00	1.39	0.00	0.00	0.00	33.32		* H/T 400KV-ITARSI-INDORE-MP-2 at 12:59 hrs /25.02.2025 for Erection, Testing <*><*> Commissioning of Indore#2 LR under ADD CAP at It= arsi.Regards
CKT	400kV ITARSI-INDORE(MPPCTL)-2	LCSD	28-02-2025	16:05:00	28-02-2025	23:59:00	0.33	0.00	0.00	0.00	7.90		* H/T of 400KV Itarsi - Indore (MP) 2 at 16:05hrs/28.02.2025 for Taking LR into Service After Erection, Testing <*><*> Commissioning of Indore#2 LR Under Add Cap at Itarsi.
CKT	400kV ITARSI-INDORE(MPPCTL)-2	LCSD	13-02-2025	10:41:00	13-02-2025	20:14:00	0.40	0.00	0.00	0.00	9.55		* H/T of 400KV Itarsi - Indore (MP) 2 at 10:41Hrs/13.02.2025 For Erection, Testing <*><*> Commissioning of LR Under Add Cap at Itarsi SS.
							2.12	0.00	0.00	0.00	50.77	100.00	
CKT	400kV ITARSI-KHANDWA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ITARSI-KHANDWA-2	OSFT	23-02-2025	17:05:00	23-02-2025	21:12:00	0.17	4.12	0.00	0.00	0.00		* H/T 400kV ITARSI-KHANDWA # 2 lines at 17:05Hrs/23.02.2025 on emergency basis to replace melted Isolator contact finger of 42589L (R Phase) line Isolator at Khandwa end.* Regards
CKT	400kV ITARSI-KHANDWA-2	LCSD	22-02-2025	09:41:00	22-02-2025	19:58:00	0.43	0.00	0.00	0.00	10.28		* H/T 400KV Itarsi - Khandwa 2 at 09:41Hrs/22.02.2025 to drop down the Main Bay Jumper of Isolator (424-89A) for Isolator replacement works under ADD CAP at Itarsi end.
							0.60	4.12	0.00	0.00	10.28	99.39	
CKT	400KV JAMKLIYA (ADANI)-JAMNGR (RIL)#1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV JAMKLIYA (ADANI)-JAMNGR (RIL)#2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kv JABALPUR PS-JABALPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00			

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

CKT	400kV KALA- VAPI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV_KHANDWA(PG)-CHHEGAON(MPPTCL) LINE	OSPT	25-02-2025	09:44:00	25-02-2025	20:22:00	0.44	10.63	0.00	0.00	0.00		* H/T 400KV Chhegaon Khandwa-1 at 09:44 hrs /25.02.2025 for Insulator replacement work based of PID.
							0.44	10.63	0.00	0.00	0.00	98.42	
CKT	400kV KHANDWA-DHULE(MSETCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KHANDWA-DHULE(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KHANDWA-INDORE-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KHANDWA-INDORE-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KHANDWA-KHARGONE(NTPC)	OSPT	24-02-2025	10:02:00	24-02-2025	19:47:00	0.41	9.75	0.00	0.00	0.00		* H/T 400KV-KHANDWA-KHARGONE-1 line at 10:02Hrs/24.02.2025 for Insulator replacement work <>&<> Terminal Equipment AMP work.
							0.41	9.75	0.00	0.00	0.00	98.55	
CKT	400KV_LAKADIA(ADANI)-JAMKHAMBALIYA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV_LAKADIA(ADANI)-JAMKHAMBALIYA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MAUDA(NTPC)-BETUL-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MAUDA(NTPC)-BETUL-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU-MUNDRA(CGPL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU-MUNDRA(CGPL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MUNDRA(CGPL)-BHACHAU-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MUNDRA(CGPL)-BHACHAU-4	OSPD	06-02-2025	09:54:00	06-02-2025	18:48:00	0.37	0.00	0.00	0.00	8.90		* H/T of 400KV Bhachau - CGPL 4 at 09:54Hrs/06.02.2025, S/D Aavailed by CGPL for Line isolator PM <>&<> Testing works at CGPL end.
							0.37	0.00	0.00	0.00	8.90	100.00	
CKT	400kV BHUJ-MUNDRA(CGPL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHUJ-MUNDRA(CGPL)-2	OSPD	22-02-2025	09:13:00	22-02-2025	19:15:00	0.42	0.00	0.00	0.00	10.03		* H/T 400KV Bhuj - CGPL 2 at 09:13Hrs/22.02.2025. S/D Aailed by CGPL.
							0.42	0.00	0.00	0.00	10.03	100.00	
CKT	400kV MUNDRA(CGPL)-JETPUR(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MUNDRA(CGPL)-JETPUR(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGDA(MPPTCL)-DEGHAM-1	LMAC	28-02-2025	09:56:00	28-02-2025	20:48:00	0.45	0.00	0.00	10.87	0.00		* H/T for kite thread removal work
CKT	400kV NAGDA(MPPTCL)-DEGHAM-1	LART	01-02-2025	06:18:00	01-02-2025	06:18:00	0.00	0.00	0.00	0.00	0.00		* A/R Successful of 400KV Nagda - Dehgam 1 at 06:18 hrs/01.02.2025 due to B ph-E fault.* Dehgam end(AFAS).* M1- 331km/1.37ka* Nagda end : M1- 0.32KM/2.73KA* 27.02.2025 18:02:07 INDIA (60002986)* Flashover marks found on Jumper and tower body at location 02
							0.45	0.00	0.00	10.87	0.00	100.00	
CKT	400kV NAGDA(MPPTCL)-DEGHAM-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGDA(MPPTCL)-SHUJALPUR-1	LART	10-02-2025	04:59:00	10-02-2025	04:59:00	0.00	0.00	0.00	0.00	0.00		* A/R successful on B-ph/E fault Shujalpur:- M1-31.96 KM/7.42KA* M2- 31.42KM/7.34KA* Nagda:- M1- 122.25KM/3.07KA* M2- 112.7KM/3.02KA* 27.02.2025 18:39:21 INDIA (60002986)* Falshover marks found on Hardware fittings and D- Shackle and Grading ring at location 554.
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAGDA(MPPTCL)-SHUJALPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-D/C-NEW NAVSARI-MAGARWADA-ACL-C1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-D/C-NEW NAVSARI-MAGARWADA-ACL-C2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV NAVSARI-VAV(GETCO)	OSPD	05-02-2025	09:40:00	05-02-2025	17:56:00	0.34	0.00	0.00	0.00	8.27		* H/T of 400KV Navsari - Vav(GETCO) 1 at 09:40Hrs/05.02.2025 for for PMM work (availed by Getco).
							0.34	0.00	0.00	0.00	8.27	100.00	
CKT	400kV PIRANA-NICOL(TORRENT)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAJGARH-BADNAWAR(MPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAJGARH-BADNAWAR(MPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV_RAJGARH (PG)-CHHEGAON(MPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RAJGARH-KHARGONE(NTPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV RNCHHDPURA(GETCO)-NICOL(TPGL) #1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400 KV RANCHHODPURA-PIRANA LINE	OSPD	05-02-2025	10:49:00	05-02-2025	17:46:00	0.29	0.00	0.00	0.00	6.95		* H/T of 400KV Pirana - Ranchodpura 1 at 10:49Hrs/05.02.2025 for for PMM work (availed by Getco).
							0.29	0.00	0.00	0.00	6.95	100.00	
CKT	400kV SASAN(RELIANCE)-REWA	LCSD	28-02-2025	13:06:00	28-02-2025	23:59:59	0.45	0.00	0.00	0.00	10.90		* H/T for railway diversion work.
							0.45	0.00	0.00	0.00	10.90	100.00	
CKT	400kV SATNA-BINA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SATNA-BINA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SATNA-BINA-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV SATNA-SAGAR(MPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

CKT	400kV SATPURA(MPPTCL)-ITARSI-1		OSFT	08-02-2025	13:49:00	08-02-2025	20:02:00	0.00	0.00	0.00	0.00	0.00	100.00	
								0.26	6.22	0.00	0.00	0.00		* 400kv Satpura- Itarsi Line at hrs13:49 hrs./08.02.2025 on emergency basis to attend snaped earth wire between tower no 152-153.
CKT	400KV SEONI-KHANDWA-1		LMAC	28-02-2025	18:17:00	28-02-2025	19:48:00	0.06	0.00	0.00	1.52	0.00		* H/T of 400KV Khandwa - Seoni 1 at 18:17hrs/28.02.2025 on emergency to remove kite thread in line bay at Khandwa end.
CKT	400KV SEONI-KHANDWA-1		OSPT	05-02-2025	09:03:00	05-02-2025	21:07:00	0.50	12.07	0.00	0.00	0.00		* H/T of 400KV Khandwa - Seoni 1 at 09:03Hrs/05.02.2025 for attending S/D nature defects work in line.
								0.56	12.07	0.00	1.52	0.00	98.20	
CKT	400KV SEONI-KHANDWA-2		OSPT	06-02-2025	09:06:00	06-02-2025	20:29:00	0.47	11.38	0.00	0.00	0.00		* H/T of 400KV Khandwa - Seoni 2 at 09:06Hrs/06.02.2025 for attending S/D nature defects work in line.* Regards.
								0.47	11.38	0.00	0.00	0.00	98.31	
CKT	400KV SARDAR SAROVAR(SSNNL)-RAJGARH-1				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV SARDAR SAROVAR(SSNNL)-RAJGARH-2		LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* Kept under V/R
								28.00	0.00	0.00	0.00	672.00	100.00	
CKT	400kv SUGEN(TORRENT)-VAPI				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kv TARAPUR(NPCIL)-BOISAR-1				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TARAPUR(NPCIL)-BOISAR-2				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TARAPUR(NPCIL)-PADGE(MSETCL)-1				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV TARAPUR(NPCIL)-PADGE(MSETCL)-2				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV VADODARA-ASOJ(GETCO)-1				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV VADODARA-ASOJ(GETCO)-2				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV VADODARA-PIRANA-1				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV VADODARA-PIRANA-2				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV VAPI-BOISAR				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-VAPI(PG)-VAPI2(STERLITE)-C1				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV-VAPI(PG)-VAPI2(STERLITE)-C2				00:00:00		00:00:00							

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

CKT	765KV BINA-INDORE	OSPT	10-02-2025	11:42:00	10-02-2025	21:57:00	0.43	10.25	0.00	0.00	0.00	98.47	* 1. H/T 765kV S/C Bina -Indore at 11:42 hrs./10.02.2025 for attending shutdown nature defects.
							0.43	10.25	0.00	0.00	0.00		
CKT	765kV GWALIOR-AGRA-1	OSFT	08-02-2025	13:08:00	08-02-2025	15:25:00	0.10	2.28	0.00	0.00	0.00		* H/T 765 KV Gwalior-Agra # 1 Line at 13:08 hrs./08.02.2025 on emergency basis* to attend at loc. No. T0052 Y- phase Right Side 01 sub conductor of Jumper Detached from "I" suspension Pilot fitting from suspension clamp.
							0.10	2.28	0.00	0.00	0.00	99.66	
CKT	765kV GWALIOR-AGRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV GWALIOR-ORAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV INDORE-VADODARA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JAIPUR(RRVPNL)-GWALIOR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JAIPUR(RRVPNL)-GWALIOR-2	OSFT	28-02-2025	15:08:00	28-02-2025	17:54:00	0.12	2.77	0.00	0.00	0.00		* H/T of 765KV Gwalior - Jaipur 2 at 15:08hrs/28.02.2025 on emergency basis S/D Aailed by NR1.
							0.12	2.77	0.00	0.00	0.00	99.59	
CKT	765kV JABALPUR PS-BINA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JABALPUR PS-BINA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JABALPUR PS-DHARAMJAYGARH-1	SVRD	28-02-2025	22:00:00	28-02-2025	23:59:59	0.08	0.00	0.00	0.00	2.00		* H/T on VR
CKT	765kV JABALPUR PS-DHARAMJAYGARH-1	LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* KEPT OPEN on Voltage regulation vide WRDC code on system constraints
							28.08	0.00	0.00	0.00	674.00	100.00	
CKT	765kV JABALPUR PS-DHARAMJAYGARH-2	LVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* H/T on Voltage regulation vide WRDC code on system constraints <=> L/R CONVERT AS B/R
							28.00	0.00	0.00	0.00	672.00	100.00	
CKT	765kV JABALPUR-ORAI-1	OSPT	28-02-2025	09:37:00	28-02-2025	21:33:00	0.50	11.93	0.00	0.00	0.00		* H/T to attend s/d nature defects and normalization of spare reactor work.
							0.50	11.93	0.00	0.00	0.00	98.22	
CKT	765kV JABALPUR-ORAI-2	OSPT	06-02-2025	10:44:00	06-02-2025	20:40:00	0.41	9.93	0.00	0.00	0.00		* H/T of 765KV Jabalpur - Orai 2 at 10:44Hrs/06.02.2025 for attending S/D nature defect in line.
CKT	765kV JABALPUR-ORAI-2	OMSU	28-02-2025	15:53:00	28-02-2025	16:45:00	0.04	0.00	0.87	0.00	0.00		* A/T of 765KV Jabalpur - Orai 2 at 15:33hrs/28.02.2025 at Jabalpur end only due to DT receipt from Orai end and the said line synchronised at 16:45Hrs/28.02.2025 from Jabalpur end.
							0.45	9.93	0.87	0.00	0.00	98.52	
CKT	400kV RIHAND(NTPC)-VINDHYACHAL PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RIHAND(NTPC)-VINDHYACHAL PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SASAN(RELIANCE)-SATNA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SASAN(RELIANCE)-SATNA-2	LART	27-02-2025	05:43:00	27-02-2025	05:43:00	0.00	0.00	0.00	0.00	0.00		* A/R successful of 765kV SASAN-SATNA 2 line at 05:43Hrs./27.02.2025 on R Phase to earth fault:** Satna end:** AFAS M1: 116.52KM, 5.036KA* AFAS M2: 117.52KM, 5KA* Relay M1: 116.4KM, 5KA* Relay M2: 4.99KA, F/L not recorded* TWFL: 119.27km** Sasan (Reliance) end: 117.5Km, 5.388KA
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV VINDHYACHAL PS-SASAN(RELIANCE)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SATNA-BINA-1	OSPT	11-02-2025	08:47:00	11-02-2025	20:04:00	0.47	11.28	0.00	0.00	0.00		* H/T 765KV Satna - Bina 1 at 08:47Hrs/11.02.2025 for attending shutdown nature defects.
							0.47	11.28	0.00	0.00	0.00	98.32	
CKT	765kV SATNA-BINA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SATNA-GWALIOR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SATNA-ORAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SATNA-VINDHYACHAL PS-1	OSPT	01-02-2025	00:00:01	01-02-2025	20:33:00	0.86	20.55	0.00	0.00	0.00		* H/T 765KV-SATNA-VINDHYACHAL(PS)-1 Line at 08:54Hrs/31.01.2025 for Line Reactor CB Healthiness check by OEM at Vindhychal(PS) and attending Line S/D nature defects
							0.86	20.55	0.00	0.00	0.00	96.94	
CKT	765kV SATNA-VINDHYACHAL PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SEONI-BINA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF AURANGABAD-1@ BOISAR	SVRD	01-02-2025	00:00:01	28-02-2025	23:59:59	28.00	0.00	0.00	0.00	672.00		* H/T UNDER V/R
							28.00	0.00	0.00	0.00	672.00	100.00	
LNR	330MVAR,SWLR OF CHITORGARH2 AT BANSKANTA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF CHITORGARH1 AT BANSKANTA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BHUJ-1 AT BANASKANTHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BHUJ-2 AT BANASKANTHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KHNADWA-1 AT BETUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KHANDWA-2 AT BETUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF LAKADIA(ADANI)-1@ BHACHAU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF LAKADIA(ADANI)-2@ BHACHAU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BANASKANTHA-2 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BANASKANTHA-1 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the month of Feb-2025

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

LNR	50MVAR,SWLR OF SAGAR AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SHUJALPUR-1 AT BINA	OMSU	03-02-2025	04:17:00	03-02-2025	04:49:00	0.02	0.00	0.53	0.00	0.00		* A/R successful of 400kV Bina- Shujalpur#1 on B-ph/E fault at 04:17hrs/03.02.2025* Bina:-* M1- 3.0 kA/141.80km, M2- 2.63 kA /134.40km* Shujalpur:-* M1- 8.48kA, M2-6.69kA/53.9km* L/R tripped during A/R successful on B-ph/E fault as per ferroresonance scheme
							0.02	0.00	0.53	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SHUJALPUR-2 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF INDORE AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF GWALIOR-3 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF JAIPUR-2 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF JAIPUR-1 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-1 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF ORAI-1 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-2 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF ITARSI-1 AT INDORE(MP)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF ITARSI-2 AT INDORE(MP)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF KHANDWA-1 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	80MVAR,SWLR OF KHANDWA-2 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF KHANDWA-1 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF VADODARA AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF KHANDWA-2 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-1 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-2 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-3 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHOPAL AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SHUJALPUR-2 AT NAGDA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SHUJALPUR-1 AT NAGDA	SCSD	17-02-2025	12:14:00	17-02-2025	16:57:00	0.20	0.00	0.00	0.00	4.72		* FOR REATCOR AMP WORK AND DIFFERENTIAL RELAY RETROFITTING WORK
							0.20	0.00	0.00	0.00	4.72	100.00	
LNR	63MVAR,SWLR OF SR. SAROVAR-1 AT RAJGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF KHARGONE AT RAJGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SR. SAROVAR-2 AT RAJGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-1 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-2 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF ORAI-1 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,LR OF GWALIOR AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF BINA-1 AT SHUJALPUR	OSPT	20-02-2025	10:15:00	20-02-2025	20:35:00	0.43	10.33	0.00	0.00	0.00		* H/T 400kV-Bina-Shujalpur-1 L/R@ Shujalpur - 400kv at 10:15 hrs./20.02.2025 for AMP Works.
							0.43	10.33	0.00	0.00	0.00	98.46	
LNR	50MVAR,SWLR OF BINA-2 AT SHUJALPUR	OSPT	07-02-2025	10:13:00	07-02-2025	20:20:00	0.42	10.12	0.00	0.00	0.00		* 400KV-BINA-SHUJALPUR-2 SWITCHABLE L/R@ SHUJALPUR SS at 10:13Hrs/07.02.2025 for AMP works.
LNR	50MVAR,SWLR OF BINA-2 AT SHUJALPUR	OMSU	09-02-2025	05:22:00	09-02-2025	06:55:00	0.07	0.00	1.55	0.00	0.00		* A/R 400kV Bina- Shujalpur#2 on Y-ph/E fault at 05:22hrs/09.02.2025
							0.49	10.12	1.55	0.00	0.00	98.49	
LNR	240MVAR,SWLR OF SATNA-1 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF SATNA-2 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	423MVA, 400/32KV, COUPLING TRANSFORMER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-200/+200 MVAR STATCOM AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	COUPLING TRANSFORMER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BOISAR	SCSD	17-02-2025	23:55:00	18-02-2025	07:30:00	0.32	0.00	0.00	0.00	7.58		* H/T FOR BUS-BAR RELAY RETROFITTING WORKS
XMER	315MVA,400/220kV ICT-1 AT BOISAR	SCSD	06-02-2025	23:16:00	07-02-2025	09:43:00	0.44	0.00	0.00	0.00	10.45		* HT for BB/LBB retrofitting
							0.76	0.00	0.00	0.00	18.03	100.00	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

XMER	315MVA,400/220kV ICT-2 AT BOISAR	SCSD	20-02-2025	23:26:00	21-02-2025	04:47:00	0.22	0.00	0.00	0.00	5.35		* for busbar relay retrofitting and testing.Regards
XMER	315MVA,400/220kV ICT-2 AT BOISAR	SCSD	08-02-2025	23:43:00	09-02-2025	08:08:00	0.35	0.00	0.00	0.00	8.42		* H/T 400/220KV ICT # 2 of Boisar ss at 23:43Hrs/08.02.2025 for busbar/LBB retrofittings works.
							0.57	0.00	0.00	0.00	13.77	100.00	
XMER	500MVA,400/220kV ICT-3 AT BOISAR	SCSD	07-02-2025	23:24:00	08-02-2025	08:14:00	0.37	0.00	0.00	0.00	8.83		* H/T 400/220KV ICT # 3 of Boisar ss at 23:24Hrs/07.02.2025 for busbar/LBB retrofittings works.
XMER	500MVA,400/220kV ICT-3 AT BOISAR	SCSD	19-02-2025	23:31:00	20-02-2025	10:42:00	0.47	0.00	0.00	0.00	11.18		* H/T 400KV/220KV BOISAR-ICT-3 at 23:31 hrs./19.02.2025 for busbar relay retrofitting and testing.Regards
							0.84	0.00	0.00	0.00	20.01	100.00	
XMER	500MVA,400/220kV ICT-4 AT BOISAR	SCSD	10-02-2025	00:56:00	10-02-2025	08:05:00	0.30	0.00	0.00	0.00	7.15		* H/T FOR BUSBAR/LBB RETROFITTING WORKS
XMER	500MVA,400/220kV ICT-4 AT BOISAR	SCSD	19-02-2025	00:42:00	19-02-2025	05:21:00	0.19	0.00	0.00	0.00	4.65		* H/T FOR BUS-BAR RELAY RETROFITTING WORKS
							0.49	0.00	0.00	0.00	11.80	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BANASKANTHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BANASKANTHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT BANASKANTHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BETUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BETUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BHACHAU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHACHAU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT BHUJ			00:00:00		00							

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

XMER	1500MVA,765/400kV ICT-2 AT INDORE	SCSD	11-02-2025	10:22:00	11-02-2025	19:00:00	0.36	0.00	0.00	0.00	8.63		* H/T of 765/400KV ICT 2 at Indore SS at 10:22Hrs/11.02.2025 for construction works.
							0.36	0.00	0.00	0.00	8.63		
XMER	500MVA,400/220kV ICT-3 AT INDORE PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT ITARSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT ITARSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT ITARSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT JABALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT JABALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT JABALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT KALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KALA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KALA	SCSD	11-02-2025	13:18:00	19-02-2025	20:20:00	8.29	0.00	0.00	0.00	199.03		* H/T 400/220KV ICT 3 at Kala SS at 13:18Hrs/11.02.2025 for construction works.
							8.29	0.00	0.00	0.00	199.03	100.00	
XMER	315MVA,400/220kV ICT-1 AT KHANDWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT KHANDWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT KHANDWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT MAGARWADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT MAGARWADA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT MORENA SS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT NAVSARI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT NAVSARI	OSPT	27-02-2025	11:20:00	27-02-2025	23:33:00	0.51	12.22	0.00	0.00	0.00		* H/T for AMP work
							0.51	12.22	0.00	0.00	0.00	98.18	
XMER	500MVA,400/220kV ICT-3 AT NAVSARI	OSPT	28-02-2025	11:32:00	28-02-2025	21:33:00	0.42	10.02	0.00	0.00	0.00		* H/T for AMP Work.
							0.42	10.02	0.00	0.00	0.00	98.51	
XMER	315MVA,400/220kV ICT-1 AT PIRANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT PIRANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT RAJGARH	OSPT	28-02-2025	11:37:00	28-02-2025	18:15:00	0.28	6.63	0.00	0.00	0.00		* H/T for AMP work
							0.28	6.63	0.00	0.00	0.00	99.01	
XMER	315MVA,400/220kV ICT-2 AT RAJGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT REWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT REWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT REWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1000MVA,765/400kV ICT-1 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1000MVA,765/400kV ICT-2 AT SATNA	OSFT	20-02-2025	12:46:00	20-02-2025	15:43:00	0.12	2.95	0.00	0.00	0.00		* . H/T 765/400kV ICT#2 at Satna SS at 12:46 hrs./20.02.2025 on emergency basis to attend disconnected NCT ground plate .
							0.12	2.95	0.00	0.00	0.00	99.56	
XMER	315MVA,400/220kV ICT-1 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT SHUJALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT SHUJALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT SHUJALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT VADODARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT VADODARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT VADODARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT VADODARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-2

XMER	1500MVA,765/400kV ICT-3 AT VADODARA				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-1 AT VAPI				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
								0.00	0.00	0.00	0.00	0.00		
XMER	315MVA,400/220kV ICT-2 AT VAPI	OSPT	21-02-2025	10:15:00	21-02-2025	19:55:00	0.40	9.67	0.00	0.00	0.00	0.00		* H/T of 400/220KV ICT-2 at Vapi SS at 10:15hrs/21.02.2025 for AMP works.
							0.40	9.67	0.00	0.00	0.00	0.00	98.56	
XMER	315MVA,400/220kV ICT-3 AT VAPI				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT VAV GIS				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT VAV GIS				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT VINDHYACHAL				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT VINDHYACHAL				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT VINDHYACHAL				00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
								0.00	0.00	0.00	0.00	0.00	100.00	