

SN	UNIQUE ID OF TRANSMISSION ELEMENT	NAME OF LINE/CT	Description (Length/Nos./MVA/MVA/M Wetc.)	REGION	Type of failure	OUTAGE		RESTORATION		Details of Outage					Total outage in days (1)	Duration of outage attributable to (in Hrs)				Restoration Time as per Regulation 5(b) (in days) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency
						TRIPPING DATE	TRIPPING TIME	RESTORATION DATE	RESTORATION TIME	no. of insulator failed	No. of towers damaged	Snapping of phase conductor	Failure of earth wire	Failure of Bushing		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available						
56	WR2L56	400kV BINA-SHUJALPUR 2 400kV BINA-SHUJALPUR 2 Total	199.94	WR-II	-	11/09/2020	10:15	11/09/2020	19:39	-	-	-	-	-	9.40	0.00	0.00	0.00	0.00	-	-	-	LINE H/T FOR AMP WORKS	WRPC	98.69%
57	WR2L57	400kV SHUJALPUR-NAGDA 1 400kV SHUJALPUR-NAGDA 1 Total	152.23	WR-II	-	28/09/2020	10:25	30/09/2020	03:09	-	-	-	-	-	0.00	0.00	0.00	40.73	0.00	-	-	-	LINE H/T S/D AVAILED BY MPPTCL FOR OVERHEAD CROSSING /STRINGING OF UNDER CONSTRUCTION OF 400KV NAGDA -MANDSOUR (SITAMAU) LINE	WRPC	100.00%
58	WR2L58	400kV SHUJALPUR-NAGDA 2 400kV SHUJALPUR-NAGDA 2 Total	152.23	WR-II	-	15/09/2020	14:49	15/09/2020	19:50	-	-	-	-	-	5.02	0.00	0.00	0.00	0.00	-	-	-	LINE H/T ON EMERGENCY BASIS TO ATTEND HOT SPOT ON MIDDLE PHASE JUMPER OF DEAD END TOWER AT SHUJALPUR	WRPC	99.30%
59	WR2L59	400kV NAGDA-DEHGAM 2 400kV NAGDA-DEHGAM 2 Total	331.44	WR-II	-	23/09/2020	21:22	23/09/2020	21:22	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	LINE A/R SUCCESSFUL Y PHASE TO E/F: DEHGAM END: FL=120KM, F/C=3.03KA AND NAGDA_END: FL=203.1KM, F/C=1.8KA	WRPC	100.00%
60	WR2L60	400kV NAGDA-DEHGAM 1 400kV NAGDA-DEHGAM 1 Total	331.44	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
61	WR2L61	400kV SEONI-KHANDWA 1 400kV SEONI-KHANDWA 1 Total	351.73	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
62	WR2L62	400kV SEONI-KHANDWA 2 400kV SEONI-KHANDWA 2 Total	351.73	WR-II	-	13/09/2020	16:49	13/09/2020	17:08	-	-	-	-	-	0.00	0.00	0.32	0.00	0.00	-	-	-	LINE A/T ON Y PHASE TO E/F : KHANDWA END: FL=99.32KM, F/C=3.7KA SEONI END: FL=242.43KM, F/C=2.38KA TRIPPING DUE TO HEAVY WINDS AND RAINS. NEWSPAPER CUTTING ATTACHED FOR REFERENCE	WRPC	100.00%
63	WR2L63	400kV KHANDWA-RAJGARH 2 400kV KHANDWA-RAJGARH 2 Total	220.59	WR-II	-	10/09/2020	16:04	10/09/2020	16:04	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	LINE A/R SUCCESSFUL ON Y PHASE TO E/ KHANDWA END: FL=83.28KM, F/C=4.25KA AND RAJGARH END: FL=64.5KM, F/C=3.48KA	WRPC	100.00%
64	WR2L64	400kV SARDAR SAROVAR-RAJGARH 1(LILO) 400kV SARDAR SAROVAR-RAJGARH 1(LILO) Total	4.01	WR-II	-	12/09/2020	12:13	12/09/2020	20:07	-	-	-	-	-	0.00	7.90	0.00	0.00	0.00	-	-	-	LINE A/T ON B PHASE TO E/F: RAJGARH END: FL=135KM, F/C=2.09KA SSP END: FL=1.4KM, F/C=5.58KA FAULT BEYOND POWERGRID JURISDICTION (WHICH IS LILO PORTION OF 4.01KM OF RAJGARH END)	WRPC	100.00%
65	WR2L65	400kV SARDAR SAROVAR-RAJGARH 2(LILO) 400kV SARDAR SAROVAR-RAJGARH 2(LILO) Total	4.01	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
66	WR2L66	400kV RAJGARH-BADNAWAR 1(LILO) 400kV RAJGARH-BADNAWAR 1(LILO) Total	4.12	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
67	WR2L67	400kV RAJGARH-BADNAWAR 2(LILO) 400kV RAJGARH-BADNAWAR 2(LILO) Total	4.12	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
68	WR2L68	400kV KHANDWA-KHARGONE(NTPC) 400kV KHANDWA-KHARGONE(NTPC) Total	75.00	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
69	WR2L69	400kV KHARGONE(NTPC)-RAJGARH 400kV KHARGONE(NTPC)-RAJGARH Total	146.00	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
70	WR2L70	220kV VAPI-MAGARWADA 1 220kV VAPI-MAGARWADA 1 Total	25.71	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
71	WR2L71	220kV VAPI-MAGARWADA 2 220kV VAPI-MAGARWADA 2 Total	25.71	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
72	WR2L72	220kV VAPI-KHARADPARA 1 220kV VAPI-KHARADPARA 1 Total	29.66	WR-II	-	29/09/2020	06:35	29/09/2020	15:32	-	-	-	-	-	0.00	8.95	0.00	0.00	0.00	-	-	-	LINE A/R SUCCESSFUL AT VAPI END AND A/T AT KHARADPARA DNH END ON B PHASE TO E/F: VAPI END: FL=9.6KM, F/C=11.14KA DR FILE ATTACHED FOR REFERENCE	WRPC	100.00%
73	WR2L73	220kV VAPI-BHILOSA 220kV VAPI-BHILOSA Total	28.35	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	8.95	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
74	WR2L74	220kV BHILOSA-KHARADPARA 220kV BHILOSA-KHARADPARA Total	1.61	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
75	WR2L75	765kV BINA-GWALIOR 2 765kV BINA-GWALIOR 2 Total	233.65	WR-II	-	24/09/2020	09:05	24/09/2020	10:01	-	-	-	-	-	0.00	0.00	0.93	0.00	0.00	-	-	-	LINE A/T ON R PHASE TO E/F: GWALIOR END: FL=128.9KM, F/C=4.9KA AND BINA END: FL=102KM, F/C=6.06KA HEAVY WIND & RAIN REPORTED AT SITE. NEWSPAPER CUTTING ATTACHED FOR REFERENCE	WRPC	100.00%
76	WR2L76	765kV SEONI-BINA 1 765kV SEONI-BINA 1 Total	292.05	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
77	WR2L77	400kV DAMOH-BHOPAL 1 400kV DAMOH-BHOPAL 1 Total	214.47	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
78	WR2L78	400kV DAMOH-BHOPAL 2 400kV DAMOH-BHOPAL 2 Total	213.80	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
81	WR2L81	220kV VAPI-VAGCHIPA 1 220kV VAPI-VAGCHIPA 1 Total	10.00	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
82	WR2L82	220kV VAGCHIPA-KHADOLI 220kV VAGCHIPA-KHADOLI Total	19.70	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
83	WR2L83	220kV VAPI-VAGCHIPA 2 220kV VAPI-VAGCHIPA 2 Total	10.00	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
84	WR2L84	220kV VAGCHIPA-SAYALI 220kV VAGCHIPA-SAYALI Total	9.00	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
85	WR2L85	220kV SAYALH-KHADOLI 220kV SAYALH-KHADOLI Total	12.24	WR-II	-	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	0.00	0.00	-	-	-	-	WRPC	100.00%
86	WR2L86	400kV DAMOH-BIRSINGPUR 1 400kV DAMOH-BIRSINGPUR 1 Total	228.47	WR-II	-	12/09/2020	05:33	12/09/2020	06:03	-	-	-	-	-	0.50	0.00	0.00	0.00	0.00	-	-	-	LINE A/T ON Y PHASE TO E/F: DAMOH END: FL=155KM, F/C=2.01 AND BIRSINGPUR END: FL=80.2KM, F/C=1.53KA	WRPC	99.30%
87	WR2L87	400kV DAMOH-BIRSINGPUR 2 400kV DAMOH-BIRSINGPUR 2 Total	228.47	WR-II	-	29/09/2020	11:55	29/09/2020	16:27	-	-	-	-	-	5.03	0.00	0.00	0.00	0.00	-	-	-	LINE H/T FOR ATTENDING HOTSPOT ON Y PHASE CT TERMINAL PAD AT BIRSINGPUR END	WRPC	100.00%
88	WR2L88	400kV DEHGAM-PIRANA 1 400kV DEHGAM-PIRANA 1 Total	46.66	WR-II	-	15/09/2020	08:19	30/09/2020	00:00	-	-	-	-	-	0.00	0.00	0.00	375.68	0.00	-	-	-	LINE H/T FOR BULLET TRAIN LINE DIVERSION WORKS	WRPC	100.00%

SN	UNIQUE ID OF TRANSMISSION ELEMENT	NAME OF LINE/CT	Description (Length/Nos./MVA/MVAR/M Wetc.)	REGION	Type of failure	OUTAGE		RESTORATION		Details of Outage						Total outage in days (f)	Duration of outage attributable to (in Hrs)				Restoration Time as per Regulation 5(b) (in days) (z)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency		
						TRIPPING DATE	TRIPPING TIME	RESTORATION DATE	RESTORATION TIME	no. of insulator failed	No. of towers damaged	Snapping of phase conductor	Failure of earth wire	Failure of Bushing	ISTS Licensee		OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available									
		BUS REACTOR 1 KHANDWA 400kV 125MVAR Total																	0	0	0	0						
273	WR2R13	BUS REACTOR 2 DEHGAM 400kV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
274	WR2R14	BUS REACTOR 1 BHACHAU 400kV 63MVAR Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
275	WR2R15	BUS REACTOR 1 SHUJALPUR 400kV 63MVAR Total	63.00	WR-II	-	15/09/2020	16:42	15/09/2020	19:51	-	-	-	-	-	-	-	-	-	3.15	0.00	0.00	0.00				WRPC	99.56%	
		BUS REACTOR 1 SHUJALPUR 400kV 63MVAR Total																	3.15	0.00	0.00	0.00						
276	WR2R16	BUS REACTOR 1 RAJGARH 400kV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
277	WR2R17	BUS REACTOR 1 NAVSARI(GIS) 400kV 63MVAR Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
278	WR2R18	BUS REACTOR 2 SATNA 400kV 63MVAR Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
279	WR2R19	SWITCHABLE LR SHUJALPUR 1 400kV 63MVAR AT NAGDA Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
280	WR2R20	SWITCHABLE LR SHUJALPUR 2 400kV 63MVAR AT NAGDA Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
281	WR2R21	BUS REACTOR 2 GWALIOR 400kV 125MVAR	125.00	WR-II	-	08/09/2020	11:20	13/09/2020	06:14	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	114.90				WRPC	100.00%	
281	WR2R21	BUS REACTOR 2 GWALIOR 400kV 125MVAR Total	125.00	WR-II	-	13/09/2020	22:52	23/09/2020	13:19	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	230.45				WRPC	100.00%	
		BUS REACTOR 2 GWALIOR 400kV 125MVAR Total																	0.00	0.00	0.00	345.35						
282	WR2R22	BUS REACTOR 3 GWALIOR 400kV 125MVAR	125.00	WR-II	-	08/09/2020	15:05	13/09/2020	06:13	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	111.13				WRPC	100.00%	
282	WR2R22	BUS REACTOR 3 GWALIOR 400kV 125MVAR Total	125.00	WR-II	-	13/09/2020	22:53	20/09/2020	08:06	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	153.22				WRPC	100.00%	
282	WR2R22	BUS REACTOR 3 GWALIOR 400kV 125MVAR	125.00	WR-II	-	20/09/2020	20:08	30/09/2020	00:00	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	243.87				WRPC	100.00%	
		BUS REACTOR 3 GWALIOR 400kV 125MVAR Total																	0.00	0.00	0.00	508.22						
283	WR2R23	BUS REACTOR 2 INDORE(PPOOLING) 400kV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
284	WR2R24	SWITCHABLE LR SHUJALPUR 2 400kV 63MVAR AT BINA Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
285	WR2R25	SWITCHABLE LR SHUJALPUR 1 400kV 63MVAR AT BINA Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
286	WR2R26	BUS REACTOR 1 JABALPUR(PPOOLING) 400kV 125MVAR Total	125.00	WR-II	-	24/09/2020	10:14	24/09/2020	17:34	-	-	-	-	-	-	-	-	-	7.33	0.00	0.00	0.00				WRPC	98.96%	
287	WR2R27	BUS REACTOR 2 KHANDWA 400kV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	7.33	0.00	0.00	0.00				WRPC	100.00%	
288	WR2R28	BUS REACTOR 2 JABALPUR 400kV 125MVAR Total	125.00	WR-II	-	18/09/2020	09:56	18/09/2020	14:59	-	-	-	-	-	-	-	-	-	5.05	0.00	0.00	0.00				WRPC	99.30%	
289	WR2R29	BUS REACTOR 1 SATNA 765kV 240MVAR Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
290	WR2R30	SWITCHABLE LR BINA 1 765kV 240MVAR AT SATNA Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
291	WR2R31	SWITCHABLE LR BINA 2 765kV 240MVAR AT SATNA Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	
292	WR2R32	BUS REACTOR 1 INDORE(PPOOLING) 765kV 240MVAR	240.00	WR-II	-	07/09/2020	19:43	12/09/2020	00:13	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	100.50				WRPC	100.00%	
292	WR2R32	BUS REACTOR 1 INDORE(PPOOLING) 765kV 240MVAR Total	240.00	WR-II	-	16/09/2020	09:58	21/09/2020	02:34	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	112.60				WRPC	100.00%	
292	WR2R32	BUS REACTOR 1 INDORE(PPOOLING) 765kV 240MVAR	240.00	WR-II	-	30/09/2020	11:45	30/09/2020	00:00	-	-	-	-	-	-	-	-	-	0.00	0.00	0.00	12.25				WRPC	100.00%	
		BUS REACTOR 1 INDORE(PPOOLING) 765kV 240MVAR Total																	0.00	0.00	0.00	225.35						
293	WR2R33	SWITCHABLE LR BINA 1 765kV 240MVAR AT GWALIOR Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0				WRPC	100.00%	

SN	UNIQUE ID OF TRANSMISSION ELEMENT	NAME OF LINE/CT	Description (Length/Nos./MVA/MVAR/M Wetc.)	REGION	Type of failure	OUTAGE		RESTORATION		Details of Outage					Total outage in days (f)	Duration of outage attributable to (in Hrs)				Restoration Time as per Regulation 5(b) (in days) (z)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency		
						TRIPPING DATE	TRIPPING TIME	RESTORATION DATE	RESTORATION TIME	no. of insulator failed	No. of towers damaged	Snapping of phase conductor	Failure of earth wire	Failure of Bushing		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available								
294	WR2R34	SWITCHABLE LR BINA 2 765KV 240MVAR AT GWALIOR SWITCHABLE LR BINA 2 765KV 240MVAR AT GWALIOR Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
295	WR2R35	SWITCHABLE LR INDORE(PPOOLING) 1 765KV 240MVAR AT BINA SWITCHABLE LR INDORE(PPOOLING) 1 765KV 240MVAR AT BINA Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
296	WR2R36	SWITCHABLE LR BINA 1 765KV 240MVAR AT JABALPUR(PPOOLING) SWITCHABLE LR BINA 1 765KV 240MVAR AT JABALPUR(PPOOLING) Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
297	WR2R37	BUS REACTOR 1 BINA 765KV 240MVAR BUS REACTOR 1 BINA 765KV 240MVAR Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
298	WR2R38	SWITCHABLE LR BINA 2 765KV 240MVAR AT JABALPUR(PPOOLING) SWITCHABLE LR BINA 2 765KV 240MVAR AT JABALPUR(PPOOLING) Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
299	WR2R39	BUS REACTOR 2 JABALPUR(PPOOLING) 765KV 240MVAR BUS REACTOR 2 JABALPUR(PPOOLING) 765KV 240MVAR Total	240.00	WR-II	-	21/09/2020	09:47	21/09/2020	18:28	-	-	-	-	-	-	-	8.68	0.00	0.00	0.00	-	-	-	-	REACTOR H/T FOR AMP WORKS	WRPC	98.79%
300	WR2R40	SWITCHABLE LR GWALIOR 3 765KV 240MVAR AT BINA SWITCHABLE LR GWALIOR 3 765KV 240MVAR AT BINA Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
301	WR2R41	SWITCHABLE LR ORAI 1 765KV 240MVAR AT SATNA SWITCHABLE LR ORAI 1 765KV 240MVAR AT SATNA Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
302	WR2R42	BUS REACTOR 1 KALAGIS 400KV 80MVAR BUS REACTOR 1 KALAGIS 400KV 80MVAR Total	80.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
303	WR2R43	BUS REACTOR 1 INDORE(PPOOLING) 400KV 63MVAR BUS REACTOR 1 INDORE(PPOOLING) 400KV 63MVAR Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
304	WR2R44	BUS REACTOR 2 INDORE(PPOOLING) 765KV 240MVAR BUS REACTOR 2 INDORE(PPOOLING) 765KV 240MVAR Total	240.00	WR-II	-	08/09/2020	10:30	15/09/2020	09:24	-	-	-	-	-	-	-	0.00	0.00	0.00	166.90	-	-	-	-	REACTOR H/T ON VOLTAGE REGULATION AS PER WRDLC INSTRUCTION	WRPC	100.00%
305	WR2R45	BUS REACTOR 2 SHUJALPUR 400KV 125MVAR BUS REACTOR 2 SHUJALPUR 400KV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
306	WR2R46	SWITCHABLE LR GWALIOR 2 765KV 240MVAR AT SATNA SWITCHABLE LR GWALIOR 2 765KV 240MVAR AT SATNA Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
307	WR2R47	BUS REACTOR 1 GWALIOR 765KV 240MVAR BUS REACTOR 1 GWALIOR 765KV 240MVAR Total	240.00	WR-II	-	12/09/2020	22:44	13/09/2020	04:26	-	-	-	-	-	-	-	0.00	0.00	0.00	5.70	-	-	-	-	REACTOR H/T ON VOLTAGE REGULATION AS PER WRDLC INSTRUCTION	WRPC	100.00%
307	WR2R47	BUS REACTOR 1 GWALIOR 765KV 240MVAR BUS REACTOR 1 GWALIOR 765KV 240MVAR Total	240.00	WR-II	-	19/09/2020	23:23	20/09/2020	02:32	-	-	-	-	-	-	-	0.00	0.00	0.00	3.15	-	-	-	-	REACTOR H/T ON VOLTAGE REGULATION AS PER WRDLC INSTRUCTION	WRPC	100.00%
308	WR2R48	BUS REACTOR 2 DAMOH 400KV 125MVAR BUS REACTOR 2 DAMOH 400KV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
309	WR2R49	BUS REACTOR 1 PIRANA 400KV 125MVAR BUS REACTOR 1 PIRANA 400KV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
310	WR2R50	SWITCHABLE LR BINA 3 (IPTC) 765KV 240MVAR AT JABALPUR(PPOOLING) SWITCHABLE LR BINA 3 (IPTC) 765KV 240MVAR AT JABALPUR(PPOOLING) Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
311	WR2R51	SWITCHABLE LR BHOPAL 1 765KV 240MVAR AT JABALPUR(PPOOLING) SWITCHABLE LR BHOPAL 1 765KV 240MVAR AT JABALPUR(PPOOLING) Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
312	WR2R52	BUS REACTOR 2 BHACHAU 400KV 125MVAR BUS REACTOR 2 BHACHAU 400KV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
313	WR2R53	BUS REACTOR 2 JABALPUR(PPOOLING) 400KV 125MVAR BUS REACTOR 2 JABALPUR(PPOOLING) 400KV 125MVAR Total	125.00	WR-II	-	25/09/2020	10:51	25/09/2020	18:49	-	-	-	-	-	-	-	7.97	0.00	0.00	0.00	-	-	-	-	REACTOR H/T FOR AMP WORKS	WRPC	98.89%
314	WR2R54	BUS REACTOR 1 MAGARWADA 400KV 80MVAR BUS REACTOR 1 MAGARWADA 400KV 80MVAR Total	80.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
315	WR2R55	BUS REACTOR 2 BINA 765KV 240MVAR BUS REACTOR 2 BINA 765KV 240MVAR Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
316	WR2R56	SWITCHABLE LR SATNA 1 765KV 240MVAR AT VINDHYACHAL(PPOOLING) SWITCHABLE LR SATNA 1 765KV 240MVAR AT VINDHYACHAL(PPOOLING) Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
317	WR2R57	BUS REACTOR 1 JABALPUR(PPOOLING) 765KV 240MVAR BUS REACTOR 1 JABALPUR(PPOOLING) 765KV 240MVAR Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
318	WR2R58	BUS REACTOR 2 SATNA 765KV 240MVAR BUS REACTOR 2 SATNA 765KV 240MVAR Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	

SN	UNIQUE ID OF TRANSMISSION ELEMENT	NAME OF LINE/CT	Description (Length/Nos./MVA/MVAR/M Wetc.)	REGION	Type of failure	OUTAGE		RESTORATION		Details of Outage					Total outage in days (f)	Duration of outage attributable to (in Hrs)				Restoration Time as per Regulation 5(b) (in days) (z)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by certifying agency		
						TRIPPING DATE	TRIPPING TIME	RESTORATION DATE	RESTORATION TIME	no. of insulator failed	No. of towers damaged	Snapping of phase conductor	Failure of earth wire	Failure of Bushing		ISTS Licensee	OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available								
319	WR2R59	SWITCHABLE LR SATNA 2 765kV 240MVAR AT VINDHYACHAL(PPOOLING) SWITCHABLE LR SATNA 2 765kV 240MVAR AT VINDHYACHAL(PPOOLING) Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
320	WR2R60	BUS REACTOR 1 VINDHYACHAL(PPOOLING) 765kV 240MVAR BUS REACTOR 1 VINDHYACHAL(PPOOLING) 765kV 240MVAR Total	240.00	WR-II	-	07/09/2020	10:08	07/09/2020	17:22	-	-	-	-	-	-	-	7.23	0.00	0.00	0.00	-	-	-	-	REACTOR H/T FOR AMP WORKS	WRPC	99.00%
321	WR2R61	BUS REACTOR 1 VADODARA(GIS) 765kV 240MVAR BUS REACTOR 1 VADODARA(GIS) 765kV 240MVAR Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
322	WR2R62	BUS REACTOR 1 VINDHYACHAL(PPOOLING) 400kV 63MVAR BUS REACTOR 1 VINDHYACHAL(PPOOLING) 400kV 63MVAR Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
323	WR2R63	SWITCHABLE LR SSP 1 400kV 63MVAR AT RAJGARH SWITCHABLE LR SSP 1 400kV 63MVAR AT RAJGARH Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
324	WR2R64	SWITCHABLE LR SSP 2 400kV 63MVAR AT RAJGARH SWITCHABLE LR SSP 2 400kV 63MVAR AT RAJGARH Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
325	WR2R65	SWITCHABLE LR KHANDWA 1 400kV 80MVAR AT INDORE(PPOOLING) SWITCHABLE LR KHANDWA 1 400kV 80MVAR AT INDORE(PPOOLING) Total	80.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
326	WR2R66	SWITCHABLE LR KHANDWA 2 400kV 80MVAR AT INDORE(PPOOLING) SWITCHABLE LR KHANDWA 2 400kV 80MVAR AT INDORE(PPOOLING) Total	80.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
327	WR2R67	SWITCHABLE LR ORAI 1 765kV 240MVAR AT GWALIOR SWITCHABLE LR ORAI 1 765kV 240MVAR AT GWALIOR Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
328	WR2R68	BUS REACTOR 1 BETUL(GIS) 400kV 125MVAR BUS REACTOR 1 BETUL(GIS) 400kV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
329	WR2R69	SWITCHABLE LR KHANDWA 1 400kV 50MVAR AT BETUL(GIS) SWITCHABLE LR KHANDWA 1 400kV 50MVAR AT BETUL(GIS) Total	50.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
330	WR2R70	SWITCHABLE LR KHANDWA 2 400kV 50MVAR AT BETUL(GIS) SWITCHABLE LR KHANDWA 2 400kV 50MVAR AT BETUL(GIS) Total	50.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
331	WR2R71	SWITCHABLE LR VADODARA(GIS) 1 765kV 240MVAR AT INDORE(PPOOLING) SWITCHABLE LR VADODARA(GIS) 1 765kV 240MVAR AT INDORE(PPOOLING) Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
332	WR2R72	SWITCHABLE LR KHARGONE(NTPC) 1 400kV 63MVAR AT RAJGARH SWITCHABLE LR KHARGONE(NTPC) 1 400kV 63MVAR AT RAJGARH Total	63.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
333	WR2R73	SWITCHABLE LR JAIPUR 1 765kV 240MVAR AT GWALIOR SWITCHABLE LR JAIPUR 1 765kV 240MVAR AT GWALIOR Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
334	WR2R74	SWITCHABLE LR JAIPUR 2 765kV 240MVAR AT GWALIOR SWITCHABLE LR JAIPUR 2 765kV 240MVAR AT GWALIOR Total	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
335	WR2R75	SWITCHABLE LR BINA 1 400kV 50MVAR AT SHUJALPUR SWITCHABLE LR BINA 1 400kV 50MVAR AT SHUJALPUR Total	50.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
336	WR2R76	SWITCHABLE LR BINA 2 400kV 50MVAR AT SHUJALPUR SWITCHABLE LR BINA 2 400kV 50MVAR AT SHUJALPUR Total	50.00	WR-II	-	11/09/2020	10:15	11/09/2020	19:39	-	-	-	-	-	-	-	9.40	0.00	0.00	0.00	-	-	-	-	REACTOR H/T FOR AMP WORKS	WRPC	98.69%
337	WR2R77	BUS REACTOR 1 REWA(PPOOLING) 400kV 125MVAR BUS REACTOR 1 REWA(PPOOLING) 400kV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
338	WR2R78	BUS REACTOR 1 VADODARA(GIS) 400kV 125MVAR BUS REACTOR 1 VADODARA(GIS) 400kV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
339	WR2R79	SWITCHABLE LR ITARSI 1 400kV 50MVAR AT INDORE(MPTCL) SWITCHABLE LR ITARSI 1 400kV 50MVAR AT INDORE(MPTCL) Total	50.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
340	WR2R80	SWITCHABLE LR ITARSI 2 400kV 50MVAR AT INDORE(MPTCL) SWITCHABLE LR ITARSI 2 400kV 50MVAR AT INDORE(MPTCL) Total	50.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
341	WR2R81	BUS REACTOR 1 BANASKANTHA 400kV 125MVAR BUS REACTOR 1 BANASKANTHA 400kV 125MVAR Total	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	
342	WR2R82	BUS REACTOR 1 BANASKANTHA 765kV 330MVAR	330.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	0	0	0	0	-	-	-	-	WRPC	100.00%	

SN	UNIQUE ID OF TRANSMISSION ELEMENT	NAME OF LINE/CT	Description (Length/Nos./MVA/MVar/M Wetc.)	REGION	Type of failure	OUTAGE		RESTORATION		Details of Outage						Total outage in days (1)	Duration of outage attributable to (in Hrs)				Restoration Time as per Regulation 5(b) (in days) (2)	Whether Restoration Time more than normative (Y/N)	Difference between Actual and Norm 1-2	Detailed Reason(s) for Outage	Outage Certifying Agency and Reference Document	% Availability as certified by agency	
						TRIPPING DATE	TRIPPING TIME	RESTORATION DATE	RESTORATION TIME	no. of insulator failed	No. of towers damaged	Snapping of phase conductor	Failure of earth wire	Failure of Bushing	ISTS Licensee		OTHERS	System Constraints/ Natural calamity / Militancy	Deemed Available								
		BUS REACTOR 1 BANASKANTHA 765kV 330MVAR Total																0	0	0	0						
343	WR2R83	SWITCHABLE LR CHITTORGARH 1 765kV 330MVAR AT BANASKANTHA	330.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%
		SWITCHABLE LR CHITTORGARH 1 765kV 330MVAR AT BANASKANTHA Total																0	0	0	0						
344	WR2R84	SWITCHABLE LR CHITTORGARH 2 765kV 330MVAR AT BANASKANTHA	330.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%
		SWITCHABLE LR CHITTORGARH 2 765kV 330MVAR AT BANASKANTHA Total																0	0	0	0						
345	WR2R85	SWITCHABLE LR BANASKANTHA 1 765kV 240MVAR AT CHITTORGARH	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%
		SWITCHABLE LR BANASKANTHA 1 765kV 240MVAR AT CHITTORGARH Total																0	0	0	0						
346	WR2R86	SWITCHABLE LR BANASKANTHA 2 765kV 240MVAR AT CHITTORGARH	240.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%
		SWITCHABLE LR BANASKANTHA 2 765kV 240MVAR AT CHITTORGARH Total																0	0	0	0						
347	WR2R87	BUS REACTOR 1 BHUJ 400kV 125MVAR	125.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%
		BUS REACTOR 1 BHUJ 400kV 125MVAR Total																0	0	0	0						
348	WR2R88	BUS REACTOR 1 BHUJ 765kV 330MVAR	330.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%
		BUS REACTOR 1 BHUJ 765kV 330MVAR Total																0	0	0	0						
349	WR2R89	SWITCHABLE LR BHUJ 1 765kV 330MVAR AT BANASKANTHA	330.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%
		SWITCHABLE LR BHUJ 1 765kV 330MVAR AT BANASKANTHA Total																0	0	0	0						
350	WR2R90	SWITCHABLE LR BHUJ 2 765kV 330MVAR AT BANASKANTHA	330.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%
		SWITCHABLE LR BHUJ 2 765kV 330MVAR AT BANASKANTHA Total																0	0	0	0						
351	WR2R91	SWITCHABLE LR BANASKANTHA 1 765kV 330MVAR AT BHUJ	330.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%
		SWITCHABLE LR BANASKANTHA 1 765kV 330MVAR AT BHUJ Total																0	0	0	0						
352	WR2R92	SWITCHABLE LR BANASKANTHA 2 765kV 330MVAR AT BHUJ	330.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%
		SWITCHABLE LR BANASKANTHA 2 765kV 330MVAR AT BHUJ Total																0	0	0	0						
353	WR2S1	STATCOM AT SATNA	975.00	WR-II	-	07/09/2020	01:02	08/09/2020	23:30	1	-	-	-	-	1.9363	46.47	0.00	0.00	0.00	1	Y	0.94	STATCOM AT DUE TO FAILURE OF BUS POST INSULATOR OF LV BUS	WRPC	93.55%		
		STATCOM AT SATNA Total														46.47	0.00	0.00	0.00								
354	WR2S2	STATCOM AT GWALIOR	775.00	WR-II	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	WRPC	100.00%	
		STATCOM AT GWALIOR Total														0	0	0	0								
		Grand Total														358.35	82.13	135.75	4829.82								