

Standard of Performance data for the Month of May-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	125MVAR,BUS REACTOR-1 AT BANASKANTHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	330MVAR,BUS REACTOR-1 AT BANASKANTHA	SCSD	28-05-2024	09:44:00	28-05-2024	12:44:00	0.13	0.00	0.00	0.00	3.00		* Switching of Spare Reactor with R Phase Reactor (spare out RPH in)
BSR	330MVAR,BUS REACTOR-1 AT BANASKANTHA	OSPT	28-05-2024	12:44:00	28-05-2024	16:08:00	0.14	3.40	0.00	0.00	0.00		* 28.05.2024 11:32:10 INDIA (60016679)* Switching of Spare Reactor with R Phase Reactor (spare out RPH in)
BSR	125MVAR,BUS REACTOR-1 AT BETUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.54	
BSR	63MVAR,BUS REACTOR-1 AT BHACHAU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT BHACHAU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT BHUJ	OSPT	02-05-2024	10:16:00	02-05-2024	15:34:00	0.22	5.30	0.00	0.00	0.00		* H/T of 400KV BR 1 at BHui SS at 10:16Hrs/02.05.2024. for attending hotspot in 41589R Isolator.
BSR	330MVAR,BUS REACTOR-1 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.29	
BSR	125MVAR,BUS REACTOR-1 AT BINA	OSFT	22-05-2024	09:37:00	22-05-2024	09:45:00	0.01	0.13	0.00	0.00	0.00		* Reactor H/T ON EMERGENCY BASIS TO ISOLATE TIE CB
BSR	240MVAR,BUS REACTOR-1 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.98	
BSR	240MVAR,BUS REACTOR-2 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT DAMOH	OSPT	15-05-2024	09:06:00	15-05-2024	19:31:00	0.43	10.42	0.00	0.00	0.00		* H/T 400kv B/R-1 of Damoh SS at 09:06 Hrs / 15.05.2024 for AMP work
BSR	125MVAR,BUS REACTOR-2 AT DAMOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	98.60	
BSR	63MVAR,BUS REACTOR-1 AT DEHGAM	SCSD	23-05-2024	10:16:00	23-05-2024	19:42:00	0.39	0.00	0.00	0.00	9.43		* H/T OF DEHGAM - 400KV B/R 1 AT 10:16 HRS FOR MAIN BAY 401 LBB RELAY RETROFITTING WORK.
BSR	63MVAR,BUS REACTOR-1 AT DEHGAM	SCSD	21-05-2024	09:32:00	21-05-2024	20:14:00	0.45	0.00	0.00	0.00	10.70		* H/T DEHGAM - 400KV B/R 1 at 09:32hrs/21.05.2024 for Tie Bay 402 LBB relay retrofitting work.
BSR	125MVAR,BUS REACTOR-2 AT DEHGAM	SCSD	29-05-2024	10:20:00	29-05-2024	17:51:00	0.31	0.00	0.00	0.00	7.52		* FOR LBB relay retrofitting work,
BSR	125MVAR,BUS REACTOR-1 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT GWALIOR	SVRD	07-05-2024	22:49:00	10-05-2024	09:54:00	2.46	0.00	0.00	0.00	59.08		* H/T ON V/R AS PER WRLDC INSTRUCTION
BSR	240MVAR,BUS REACTOR-1 AT GWALIOR	SVRD	26-05-2024	23:45:00	28-05-2024	18:36:00	1.79	0.00	0.00	0.00	42.85		* H/T 765KV BUS REACTOR-1 AT GWALIOR SS ON V/R
BSR	125MVAR,BUS REACTOR-2 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	101.93	
BSR	125MVAR,BUS REACTOR-3 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT INDORE	SVRD	01-05-2024	00:00:01	03-05-2024	20:37:00	2.86	0.00	0.00	0.00	68.62		* H/T on V/R on system constraints
BSR	125MVAR,BUS REACTOR-2 AT INDORE	OSPT	15-05-2024	10:30:00	15-05-2024	17:29:00	0.29	6.98	0.00	0.00	0.00		* H/T OF INDORE - 400KV B/R 2 AT 10:30 HRS / 15.05.2024 FOR ATTENDING OF HOT SPOTS TOWARD BUS CONNECTING RE
BSR	240MVAR,BUS REACTOR-2 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.06	
BSR	125MVAR,BUS REACTOR-1 AT ITARSI	SCSD	13-05-2024	09:11:00	16-05-2024	19:58:00	3.45	0.00	0.00	0.00	82.78		* H/T for 416 bay CT replacement work
BSR	125MVAR,BUS REACTOR-2 AT ITARSI	SCSD	08-05-2024	10:22:00	11-05-2024	19:53:00	3.40	0.00	0.00	0.00	81.52		* H/T 400KV ITARSI - 400KV B/R 2 at 10:22 hrs/08.05.2024 FOR CT REPLACEMENT WORKS UNDER ADD CAP.
BSR	50MVAR,BUS REACTOR-3 AT ITARSI	SCSD	01-05-2024	00:00:01	01-05-2024	19:48:00	0.83	0.00	0.00	0.00	19.80		* Replacement of CT, Dia to be kept open
BSR	125MVAR,BUS REACTOR-1 AT JABALPUR PS	OSPT	20-05-2024	09:42:00	20-05-2024	17:07:00	0.31	7.42	0.00	0.00	0.00		* H/T FOR AMP WORKS
BSR	240MVAR,BUS REACTOR-1 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.00	
BSR	125MVAR,BUS REACTOR-2 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT JABALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT JABALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	25MVAR,33kV BUS REACTOR-1 AT JABALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
BSR	25MVAR,33kV BUS REACTOR-2 AT JABALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of May-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
BSR	80MVAR,BUS REACTOR-1 AT KALA	SVRD	01-05-2024	00:00:01	31-05-2024	23:59:59	0.00	0.00	0.00	0.00	0.00	100.00	* H/T on Voltage regulation vide WRDLC code on system constraints
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT KHANDWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT KHANDWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-3 AT KHANDWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	80MVAR,BUS REACTOR-1 AT MAGARWADA	SVRD	01-05-2024	00:00:01	01-05-2024	08:51:00	0.37	0.00	0.00	0.00	8.85	100.00	* H/T ON V/R
BSR	80MVAR,BUS REACTOR-1 AT MAGARWADA	SVRD	08-05-2024	16:29:00	31-05-2024	23:59:59	23.31	0.00	0.00	0.00	559.52	100.00	* H/T UNDER V/R
							23.68	0.00	0.00	0.00	568.37	100.00	
BSR	63MVAR,BUS REACTOR-1 AT NAVSARI	SVRD	11-05-2024	15:02:28	31-05-2024	23:59:59	20.37	0.00	0.00	0.00	488.96	100.00	* H/T on voltage regulation as per RLDC instruction
							20.37	0.00	0.00	0.00	488.96	100.00	
BSR	125MVAR,BUS REACTOR-1 AT PIRANA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT RAJGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT RAJGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT REWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-2 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	50MVAR,BUS REACTOR-1 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-2 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT SHUJALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-2 AT SHUJALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT VADODARA	SVRD	01-05-2024	00:00:01	31-05-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* H/T ON V/R
							31.00	0.00	0.00	0.00	744.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT VADODARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	125MVAR,BUS REACTOR-1 AT VAV GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	63MVAR,BUS REACTOR-1 AT VINDHYACHAL P			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
BSR	240MVAR,BUS REACTOR-1 AT VINDHYACHAL P			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV BHILOSA(DNH)-KHARADPARA(DNH)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV GANDHAR(NTPC)-HALDARWA(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV GANDHAR(NTPC)-HALDARWA(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAKRAPAR(NPCIL)-HALDARWA(GETCO)	OSPD	16-05-2024	08:21:00	16-05-2024	19:58:00	0.48	0.00	0.00	0.00	11.62	100.00	* H/T OF 220KV-KAKRAPAR 1<(>&<)-2-HALDARWA-1at 08:21 Hrs/16.05.2024(AVAILED BY NPCIL FOR RTV COATING AT THEIR
							0.48	0.00	0.00	0.00	11.62	100.00	
CKT	220kV KAKRAPAR(NPCIL)-HALDARWA(GETCO)	OSPD	17-05-2024	06:45:00	17-05-2024	19:34:00	0.53	0.00	0.00	0.00	12.82	100.00	* H/T OF 220KV-KAKRAPAR 1<(>&<)-2-HALDARWA-2 at 06:45 Hrs/17.05.2024(AVAILED BY NPCIL FOR RTV COATING AT THEIR
							0.53	0.00	0.00	0.00	12.82	100.00	
CKT	220kV KAKRAPAR(NPCIL)-VAPI(GETCO)-1	OSPD	21-05-2024	06:43:00	21-05-2024	19:53:00	0.55	0.00	0.00	0.00	13.17	100.00	* H/T 220KV-KAKRAPAR 1<(>&<)-2-VAPI-1 at 06:43 hrs./21.05.2024 for RTV coating of string insulator and Bay APM check (S/D ave
							0.55	0.00	0.00	0.00	13.17	100.00	
CKT	220kV KAKRAPAR(NPCIL)-VAPI(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAKRAPAR(NPCIL)-VAV(GETCO)-1	OSPD	18-05-2024	06:35:00	18-05-2024	19:32:00	0.54	0.00	0.00	0.00	12.95	100.00	* H/T OF 220KV-KAKRAPAR 1<(>&<)-2-VAV-1 AT 06:35 HRS / 18.05.2024 FOR RTV COATING OF STRING INSULATOR AND BAY
							0.54	0.00	0.00	0.00	12.95	100.00	
CKT	220kV KAKRAPAR(NPCIL)-VAV(GETCO)-2	OSPD	19-05-2024	06:19:00	19-05-2024	19:51:00	0.56	0.00	0.00	0.00	13.53	100.00	* H/T OF 220KV-KAKRAPAR 1<(>&<)-2-VAV-2 AT 06:19 HRS / 19.05.2024 FOR RTV COATING OF STRING INSULATOR AND BAY
							0.56	0.00	0.00	0.00	13.53	100.00	
CKT	220kV KAWAS(NTPC)-HALDARWA(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAWAS(NTPC)-HALDARWA(GETCO)-2	OSFD	12-05-2024	10:57:00	12-05-2024	13:28:00	0.11	0.00	0.00	0.00	2.52	100.00	* H/t on emergency bais to attend flashover insulator at Loc- 134(B-ph)
							0.11	0.00	0.00	0.00	2.52	100.00	
CKT	220kV KAWAS(NTPC)-NAVSARI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of May-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	220kV KAWAS(NTPC)-NAVSARI-2	OSPD	18-05-2024	09:18:00	18-05-2024	21:39:00	0.52	0.00	0.00	0.00	12.35	100.00	* H/T OF 220kV Kawas - Navsari 2 at 09:18 HRS / 18.05.2024 For AMP works at Kawas end. (S/D Availed by NTPC).
CKT	220kV KAWAS(NTPC)-VAV(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KAWAS(NTPC)-VAV(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV KHADOLI(DNH)-VAGCHIPA(DNH)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV NAVSARI GIS-BHESTAN#1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV NAVSARI GIS-BHESTAN#2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV NAVSARI-NAVSARI (GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV NAVSARI-NAVSARI (GETCO)-2	LCSD	01-05-2024	09:37:00	02-05-2024	19:13:00	1.40	0.00	0.00	0.00	33.60	100.00	* H/T 220KV-NAVSARI-NAVSARI-GETCO-2 at 09:37Hrs/01.05.2024 For CVT and Wave Trap replacement under Add-Cap at Navsari (
CKT	220kV SAYALI(DNH)-KHADOLI(DNH)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV SAYALI(DNH)-VAGCHIPA(DNH)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV TARAPUR(NPCIL)-BOISAR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV VAPI-BHILOSA(DNH)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV VAPI-KHARADPADA(DNH)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV VAPI-MAGARWADA(DAMAN)-1	OSPD	30-05-2024	10:06:00	31-05-2024	23:59:59	1.58	0.00	0.00	0.00	37.90	100.00	* H/T 220KV-VAPI-MAGARWADA-1at 10:06 hrs./30.05.2024 for 220KV CVT REPLACEMENT, RELAY AND 220KV EQUIPMENTS TE
CKT	220kV VAPI-MAGARWADA(DAMAN)-2	OSPD	31-05-2024	09:09:00	31-05-2024	18:27:00	0.39	0.00	0.00	0.00	9.30	100.00	* RELAY AND 220KV EQUIPMENTS TESTING AT MAGARWADA(DD) END.
CKT	220kV VAPI -VAGCHIPA(DNH)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	220kV VAPI -VAGCHIPA(DNH)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV ANUPPUR(MB POWER)-JABALPUR PS-1	LART	14-05-2024	14:24:00	14-05-2024	14:24:00	0.00	0.00	0.00	0.00	0.00	100.00	* A/R Successful of 400kV ANUPPUR(MB Power)-JABALPUR(Pooling) - 1 on R-ph/E fault at 14:24 hrs/14.05.2024** At Jabalpur end
CKT	400kV ANUPPUR(MB POWER)-JABALPUR PS-2	LART	14-05-2024	13:38:00	14-05-2024	13:38:00	0.00	0.00	0.00	0.00	0.00	100.00	* A/R Successful of 400kV ANUPPUR-JABALPUR(Pooling) 2 on B-ph/E fault at 13:38 hrs/14.05.2024** At Jabalpur end AFAS:-* M1
CKT	400kV BANASKANTHA-SANKHARI(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANASKANTHA-SANKHARI(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANASKANTHA-VAV(RADHANESDA)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BANASKANTHA-VAV(RADHANESDA)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BETUL-KHANDWA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BETUL-KHANDWA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU-HALVAD(GETCO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU-LIMBDI(GETCO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU(PG)-LAKADIA(ADANI)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU(PG)-LAKADIA(ADANI)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU-RANCHHODPURA(GETCO)-1	LMAC	06-05-2024	14:11:00	06-05-2024	15:26:00	0.05	0.00	0.00	1.25	0.00	100.00	* A/T 400kV Bhachau- Ranchodpura#1 Line on Rph-Y ph fault at 14:11 hrs/06.05.2024* Bhachau:-* M1-240.7km/lr:-2.76kA/ly:-2.20kA*
CKT	400kV BHACHAU-RANCHHODPURA(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU-VARSANA(GETCO)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BHACHAU-VARSANA(GETCO)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV BINA-BINA(MPPTCL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of May-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400KV BINA-BINA(MPPTCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV BINA-BINA(MPPTCL)-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV BINA-BINA(MPPTCL)-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV BINA-SAGAR(MPPTCL)	OSPD	08-05-2024	09:40:00	08-05-2024	19:32:00	0.41	0.00	0.00	0.00	9.87	100.00	* H/T 400KV-SAGAR-BINA-1 at 09:40 hrs/08.05.2024 FOR LINE MAINTENANCE WORK (SD taken by MPSLDC).
CKT	400KV BINA-SHUJALPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV BINA-SHUJALPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV BOISAR- AURANGABAD-1	LPRD	09-05-2024	11:53:00	10-05-2024	11:23:00	0.98	0.00	0.00	0.00	23.50	100.00	* H/T UNDER P/R
CKT	400KV BOISAR- AURANGABAD-1	LPRD	16-05-2024	13:41:00	16-05-2024	16:14:00	0.11	0.00	0.00	0.00	2.55	100.00	* H/T UNDER P/R
CKT	400KV BOISAR- AURANGABAD-1	LART	14-05-2024	01:17:00	14-05-2024	01:17:00	0.00	0.00	0.00	0.00	0.00	100.00	* Dear Sir,* A/R Successful of 400 KV Aurangabad-Boisar#1 on B-ph/E fault at 01:17hrs/14.05.2024** At Boisar end:-* M1-166.27km/2
CKT	400KV BOISAR- AURANGABAD-1	OSPT	24-05-2024	10:51:00	24-05-2024	18:56:00	0.34	8.08	0.00	0.00	0.00	98.91	* H/T OF 400KV-AURANGABAD-BOISAR-1 AT 10:51 HRS / 24.05.2024 FOR REPLACEMENT OF Y-PH INSULATOR.
CKT	400KV BOISAR- AURANGABAD-2	LART	14-05-2024	02:28:00	14-05-2024	02:28:00	0.00	0.00	0.00	0.00	0.00	100.00	* A/R Successful of 400 KV Aurangabad-Boisar#2 on Y-ph/E fault at 2:28hrs/14.05.2024** At Boisar end:-* M1-148.72km/2.63kA* M2-1
CKT	400KV BOISAR- AURANGABAD-2	LART	14-05-2024	15:55:00	14-05-2024	15:55:00	0.00	0.00	0.00	0.00	0.00	100.00	* A/R Successful of 400 KV Aurangabad-Boisar#2 on B-ph/E fault at 15:55hrs/14.05.2024** At Boisar end:-* M1-91.8km/3.9kA* M2-91.
CKT	400KV BOISAR-PADGE(MSETCL)	LMAC	04-05-2024	11:48:00	04-05-2024	12:45:00	0.04	0.00	0.00	0.95	0.00	100.00	* Dear Sir,* A/T 400kv Boisar-Padghe Line on Rph/E fault at 11:48hrs/04.05.2024* Boisar:-* M1- 57.92km/4.89kA* M2- 60.0km/4.70kA*
CKT	400KV BOISAR-PADGE(MSETCL)	LMAC	16-05-2024	17:45:00	16-05-2024	19:08:00	0.06	0.00	0.00	1.38	0.00	100.00	* A/T of 400 KV Boisar - Padghe line on B-ph/E fault at 17:45hrs/16.05.2024** At Boisar end:-* M1-86.6KM/2.96kA* M2-85.43KM/3.81K
CKT	400KV BIRSINGHPUR(MPPTCL)-DAMOH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV BIRSINGHPUR(MPPTCL)-DAMOH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV MAGARWADA-BOISAR-1	OSFT	16-05-2024	17:24:00	16-05-2024	20:42:00	0.14	3.30	0.00	0.00	0.00	99.56	* H/T of 400KV Boisar - Magarwada 1 at 17:24 Hrs / 16.05.2024 on emergency to replace broken insulator at loc no: 27.
CKT	400KV MAGARWADA-BOISAR-2	LNCC	16-05-2024	16:18:00	16-05-2024	20:45:00	0.19	0.00	0.00	4.45	0.00	100.00	* A/T of 400 KV Boisar - Magarwada # 2 on B-ph/E fault at 16:18hrs/16.05.2024** At Boisar end:-* M1-28KM/8.41KA* M2-28.5KM/8.7K
CKT	400KV MAGARWADA-NAVSARI-1	OMSU	23-05-2024	12:42:00	23-05-2024	17:23:00	0.20	0.00	4.68	0.00	0.00	100.00	* H/T OF 400KV NAVSARI-MAGARWADA #1 <(>&<)> 2 AT 12:42 HRS/23.05.2024 <(>&<)> 12:45 HRS/23.05.2024 respectively FC
CKT	400KV MAGARWADA-NAVSARI-2	LEFT	22-05-2024	21:00:00	22-05-2024	21:43:00	0.03	0.72	0.00	0.00	0.00	100.00	* A/T on R Ph-E/fault.* At NAVSARI end:-* M1: 104km/3 Ka, M2:120.4km/3.4kA* At MAGARWADA end:-* M1: 15.68 km/7.8kA, M
CKT	400KV MAGARWADA-NAVSARI-2	OSFT	23-05-2024	12:45:00	23-05-2024	17:25:00	0.19	4.67	0.00	0.00	0.00	100.00	* H/T OF 400KV NAVSARI-MAGARWADA #1 <(>&<)> 2 AT 12:42 HRS/23.05.2024 <(>&<)> 12:45 HRS/23.05.2024 respectively FC
CKT	400KV MAGARWADA-NAVSARI-2	LMAC	18-05-2024	11:36:00	18-05-2024	14:28:00	0.12	0.00	0.00	2.87	0.00	99.27	* A/T of 400KV Navsari - Magarwada 2 on RY-ph fault at 11:36hrs/18.05.2024** At Navsari end:-* M1-4.3KM/21.12KA* M2-4.49KM/2
CKT	400KV DAMOH-BHOPAL(MPPTCL)-1	LMAC	19-05-2024	16:56:00	19-05-2024	18:47:00	0.08	0.00	0.00	1.85	0.00	100.00	* A/T 400KV Damoh-Bhopal-1 on R-ph/E fault at 16:56 hrs/19.05.2024 * Bhopal End : 176.0KM/1.73 KA. * Damoh End:-* M1: 35.9KM/4.3
CKT	400KV DAMOH-BHOPAL(MPPTCL)-1	OSPT	26-05-2024	08:35:00	26-05-2024	20:47:00	0.51	12.20	0.00	0.00	0.00	96.37	* H/T of 400KV Damoh - Bhopal 1 at 08:35Hrs/26.05.2024 for Insulator replacement.
CKT	400KV DAMOH-BHOPAL(MPPTCL)-1	OSPT	28-05-2024	06:48:00	28-05-2024	21:32:00	0.61	14.73	0.00	0.00	0.00	96.32	* H/T OF 400KV-BHOPAL-MP-DAMOH-1 AT 06:48 HRS / 28.05.2024 FOR INSULATOR REPLACEMENT WORK.
CKT	400KV DAMOH-BHOPAL(MPPTCL)-2	OSPT	29-05-2024	07:06:00	29-05-2024	20:40:00	0.57	13.57	0.00	0.00	0.00	96.32	* H/T FOR INSULATOR REPLACEMENT WORK.
CKT	400KV DAMOH-BHOPAL(MPPTCL)-2	OSPT	27-05-2024	06:45:00	27-05-2024	20:34:00	0.58	13.82	0.00	0.00	0.00	96.32	* H/T OF 400KV-BHOPAL-MP-DAMOH-2 AT 06:45 HRS / 27.05.2024 FOR INSULATOR REPLACEMENT WORK.
CKT	400KV MANSAR(GETCO)-LIMBDI(GETCO)-1	OSPD	17-05-2024	07:38:00	17-05-2024	19:18:00	0.49	0.00	0.00	0.00	11.67	100.00	* H/T of 400KV Mansar - Choraniya line at 07:38Hrs/17.05.2024 for AMP works. (S/D Availed by GETCO)
CKT	400KV INDORE(MPPCTL)-ASOJ(GETCO)-1	OSPT	08-05-2024	11:12:00	08-05-2024	12:14:00	0.04	1.03	0.00	0.00	0.00	99.74	* H/T 400KV INDORE-MP-ASOJ-1 at 11:12 hrs/08.05.2024 TO TAKE LINE REACTOR OUT FOR FDS TESTING at INDORE MP end.*
CKT	400KV INDORE(MPPCTL)-ASOJ(GETCO)-1	OSPT	08-05-2024	16:30:00	08-05-2024	17:22:00	0.04	0.87	0.00	0.00	0.00	99.74	* H/T 400KV INDORE-MP-ASOJ-1 at 16:30 hrs/08.05.2024 to take L/R into service at INDORE MP end.* Same line taken into service
CKT	400KV INDORE(MPPCTL)-ASOJ(GETCO)-2	OSPT	09-05-2024	11:19:00	09-05-2024	12:14:00	0.04	0.92	0.00	0.00	0.00	99.84	* H/T 400KV INDORE-MP-ASOJ-2 at 11:19 hrs/09.05.2024 TO TAKE LINE REACTOR OUT FOR FDS TESTING at INDORE MP end.*
CKT	400KV INDORE(MPPCTL)-ASOJ(GETCO)-2	OSPT	09-05-2024	15:40:00	09-05-2024	15:58:00	0.01	0.30	0.00	0.00	0.00	99.84	* Dear Sir,** H/T 400KV INDORE-MP-ASOJ-2 at 15:40hrs/09.05.2024 TO TAKE LINE REACTOR IN SERVICE at INDORE MP end.* S
CKT	400KV INDORE -INDORE(MPPCTL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV INDORE -INDORE(MPPCTL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV ITARSI-INDORE(MPPCTL)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV ITARSI-INDORE(MPPCTL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV ITARSI-KHANDWA-1	LCSD	06-05-2024	10:12:00	07-05-2024	00:38:00	0.60	0.00	0.00	0.00	14.43	100.00	* H/T FOR LBB RETROFITTING WORK AT KHANDWA SS
CKT	400KV ITARSI-KHANDWA-2	LCSD	02-05-2024	10:04:00	04-05-2024	22:35:00	2.52	0.00	0.00	0.00	60.52	100.00	* H/T of 400KV Itarsi - Khandwa 2 at 10:04 Hrs / 02.05.2024 for CT <(>&<)> Isolator replacement work at Itarsi end under ADD CAP.
CKT	400KV JAMK'LIYA (ADANI)-JAMNGR (RIL)#1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV JAMK'LIYA (ADANI)-JAMNGR (RIL)#2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of May-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV JABALPUR PS-JABALPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JABALPUR PS-JABALPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JABALPUR-ITARSI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JABALPUR-ITARSI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JABALPUR-ITARSI-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JABALPUR-ITARSI-4			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JABALPUR-REWA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV JABALPUR-REWA-2	LART	22-05-2024	16:52:00	22-05-2024	16:52:00	0.00	0.00	0.00	0.00	0.00	100.00	* A/R Successful on Y-ph/E fault* Jabalpur end details:* M1- 53.6KM, 5.21KA, M2- 51.94KM, 5.473KA* REWA end details:* M1- 183.5K
CKT	400kV GANDHAR(NTPC)-DEHGAM-1	LCSD	20-05-2024	09:32:00	20-05-2024	22:16:00	0.53	0.00	0.00	0.00	12.73		* H/T for Main Bay 403 LBB relay retrofitting work
CKT	400kV GANDHAR(NTPC)-DEHGAM-1	LCSD	21-05-2024	09:31:00	21-05-2024	20:39:00	0.46	0.00	0.00	0.00	11.13		* 400KV-DEHGAM-GANDHAR-1 at 09:310hrs/21.05.2024 For Tie Bay 402 LBB relay retrofitting work
CKT	400kV GANDHAR(NTPC)-DEHGAM-1	OMST	28-05-2024	11:07:00	28-05-2024	12:44:00	0.07	1.62	0.00	0.00	0.00		* A/T due to DC leakage at Dehgam end.
CKT	400kV GANDHAR(NTPC)-DEHGAM-2	LCSD	22-05-2024	09:41:00	22-05-2024	20:52:00	0.47	0.00	0.00	0.00	11.18		* H/T 400KV-DEHGAM-GANDHAR-2 at 09:41 hrs./22.05.2024 FOR MAIN BAY 404 LBB RELAY RETROFITTING WORK.
CKT	400kV GANDHAR(NTPC)-DEHGAM-2	LCSD	24-05-2024	09:09:00	24-05-2024	20:00:00	0.45	0.00	0.00	0.00	10.85		* H/T OF 400KV-DEHGAM-GANDHAR-2 AT 09:06 HRS / 24.05.2024 FOR LBB RELAY RETROFITTING IN TIE BAY 405.
CKT	400kV GANDHAR(NTPC)-GANDHAR(GTEC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GANDHAR(NTPC)-NAVSARI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV GANDHAR(NTPC)-SUGEN(TORRENT)-1	OSPD	09-05-2024	08:35:00	09-05-2024	14:31:00	0.25	0.00	0.00	0.00	5.93		* H/T of 400kV Gandhar - Sugen line at 08:35Hrs/09.05.2024 for off line gantry water washing works at sugen end. S/D Availed by Su
CKT	400kV GANDHAR(NTPC)-VAV(GETCO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAKRAPAR(NPCIL)-NAVSARI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAKRAPAR(NPCIL)-NAVSARI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAKRAPAR(NPCIL)-VAPI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KAKRAPAR(NPCIL)-VAPI-2	OSFD	21-05-2024	10:33:00	21-05-2024	19:12:00	0.36	0.00	0.00	0.00	8.65		* H/T 400kV KAKRAPAR-VAPI 2 at 10:33 hrs./21.05.2024 on emergency basis (one out of two Line connection between LA and CVT
CKT	400kV KALA-KUDUS(MSETCL)-1	OSFT	03-05-2024	07:00:00	03-05-2024	08:49:00	0.08	1.82	0.00	0.00	0.00		* H/T FOR ATTENDING SF6 LEAKAGE at Kala end
CKT	400kV KALA-KUDUS(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KALA- VAPI-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KALA- VAPI-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KHANDWA(PG)-CHHEGAON(MPPTCL) L			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KHANDWA-DHULE(MSETCL)-1	LCSD	21-05-2024	08:39:00	21-05-2024	22:10:00	0.56	0.00	0.00	0.00	13.52		* 400KV-KHANDWA-DHULE-MS-1 at 08:39hrs/21.05.2024 for LBB retrofitting work.
CKT	400kV KHANDWA-DHULE(MSETCL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV KHANDWA-INDORE-1	LMAC	19-05-2024	17:57:00	19-05-2024	20:14:00	0.10	0.00	0.00	2.28	0.00		* H/T 400kV Indore-Khandwa-1 on emergency basis for removing of steel poles under 400kv indore-khandwa-1 at loc. no.383-384 at 1
CKT	400kV KHANDWA-INDORE-1	LMAC	17-05-2024	13:58:00	17-05-2024	14:59:00	0.04	0.00	0.00	1.02	0.00		* A/T of 400kV Khandwa - Indore 1 on R-ph/E fault at 13:58hrs/17.05.2024** At Khandwa end:* M1-133.4KM/2.72KA* M2-134.7KM/2.7
CKT	400kV KHANDWA-INDORE-1	LMAC	19-05-2024	14:51:00	19-05-2024	15:15:00	0.02	0.00	0.00	0.40	0.00		* A/T due to R-ph/E fault* Indore end details:* M1- 31.2KM, 9.726KA* M2- 31.0KM, 9.35KA* Khandwa end details:* M1- 133.81KM, 2.73
CKT	400kV KHANDWA-INDORE-1	LART	19-05-2024	14:21:00	19-05-2024	14:21:00	0.00	0.00	0.00	0.00	0.00		* A/R Successful due to R-ph/E fault.* Indore end details:* M1- 31.2KM, 9.402KA* M2- 31.2KM, 9.35KA* Khandwa end details:* M1- 133
CKT	400kV KHANDWA-INDORE-2	LMAC	20-05-2024	15:14:00	20-05-2024	17:39:00	0.10	0.00	0.00	2.42	0.00		* H/T 400kV Indore-Khandwa-2 on emergency basis for removing of steel poles under 400kv indore-khandwa-2 at loc. no.383-384 at 1
CKT	400kV KHANDWA-KHARGONE(NTPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV LAKADIA(ADANI)-JAMKAMBALIYA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400KV LAKADIA(ADANI)-JAMKAMBALIYA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MAUDA(NTPC)-BETUL-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of May-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO IISTS Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV MAUDA(NTPC)-BETUL-2	LMAC	25-05-2024	11:57:00	25-05-2024	15:58:00	0.17	0.00	0.00	4.02	0.00		* H/T of 400 Mauda - Betul 2 at 11:57Hrs/25.05.2024 on emergency to remove rope at loc no: 71 (S/D Availed by WR1).* 27.05.2024
CKT	400kV MAUDA(NTPC)-BETUL-2	LART	10-05-2024	20:35:00	10-05-2024	20:35:00	0.00	0.00	0.00	0.00	0.00	100.00	* A/R successful of 400 kV Mauda-Betul #2 at 20:35 Hrs / 10.05.2024 on Yph-E/fault** Indication:* @ Betul :.* M1-92.6km / 3.47KA** @T
CKT	400kV BHACHAU-MUNDRA(CGPL)-1	OSPD	20-05-2024	09:05:00	20-05-2024	18:49:00	0.41	0.00	0.00	0.00	9.73		* S/D TAKEN BY CGPL
CKT	400kV BHACHAU-MUNDRA(CGPL)-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV MUNDRA(CGPL)-BHACHAU-3	OSPD	21-05-2024	10:08:00	21-05-2024	19:49:00	0.40	0.00	0.00	0.00	9.68		* H/T 400KV-CGPL-BACHAU-3 at 10:08hrs/21.05.2024. S/D availed by CGPL for terminal equipment testing.
CKT	400kV MUNDRA(CGPL)-BHACHAU-4	OSPD	23-05-2024	09:13:00	23-05-2024	18:32:00	0.39	0.00	0.00	0.00	9.32		* H/T 400KV-CGPL-BACHAU-4 AT 09:12 HRS / 23.05.2024 FOR TERMINAL EQUIPMENT TESTING (S/D AVAILED BY CGPL)
CKT	400kV BHUJ-MUNDRA(CGPL)-1	OSPD	17-05-2024	09:05:00	18-05-2024	00:39:00	0.65	0.00	0.00	0.00	15.57		* H/T OF 400KV-BHUJ-CGPL-1 AT 09:05 HRS / 17.05.2024 FOR CT AND IPS TUBE ERECTION, CONNECTION AT CGPL END- AV
CKT	400kV BHUJ-MUNDRA(CGPL)-1	OSPD	13-05-2024	09:08:00	13-05-2024	19:51:00	0.45	0.00	0.00	0.00	10.72		* S/D availed by CGPL for dismantling of IPS tubes of BP
CKT	400kV BHUJ-MUNDRA(CGPL)-1	OMSU	16-05-2024	09:04:00	16-05-2024	21:38:00	0.52	0.00	12.57	0.00	0.00		* H/T OF 400KV-BHUJ-CGPL-1 AT 09:04 HRS / 16.05.2024 FOR CT AND IPS TUBE ERECTION, CONNECTION AT CGPL END- AV
CKT	400kV BHUJ-MUNDRA(CGPL)-2	LART	15-05-2024	16:33:00	15-05-2024	16:33:00	1.62	0.00	12.57	0.00	26.29	100.00	* A/R Successful of 400 KV Bhuj - Mundra # 2 on R-ph/E fault at 16:33hrs/15.05.2024** At Bhuj end:.* M1-20.5KM/14.53KA* M2-20.2K
CKT	400kV MUNDRA(CGPL)-JETPUR(GETCO)-1	OSPT	03-05-2024	09:09:00	03-05-2024	19:39:00	0.44	10.50	0.00	0.00	0.00		* Dear Sir,* H/T 400kv CGPL-Jetpur#1 at 9:09hrs/03.05.2024 for rectification of pending defects in line.* Regards,
CKT	400kV MUNDRA(CGPL)-JETPUR(GETCO)-2	OSPT	04-05-2024	09:20:00	04-05-2024	18:45:00	0.39	9.42	0.00	0.00	0.00		** Dear Sir,* H/T 400kv CGPL-Jetpur#2 at 09:20hrs/04.05.2024 for rectification of pending defects in line.* Regards,
CKT	400kV NAGDA(MPPTCL)-DEHGAM-1	LCSD	16-05-2024	10:28:00	16-05-2024	20:16:00	0.41	0.00	0.00	0.00	9.80		* H/T FOR TIE LBB RETROFITTING WORKS AT DEHGAM END
CKT	400kV NAGDA(MPPTCL)-DEHGAM-1	LCSD	18-05-2024	10:21:00	18-05-2024	20:17:00	0.41	0.00	0.00	0.00	9.93		* H/T OF 400KV-NAGDA-DEHGAM-1 at 10:21 HRS / 18.05.2024 For Main Bay 429-LBB, A/R relay retrofitting work at DEHGAM END
CKT	400kV NAGDA(MPPTCL)-DEHGAM-2	LCSD	17-05-2024	11:36:00	17-05-2024	22:00:00	0.43	0.00	0.00	0.00	10.40		* H/T OF 400KV-NAGDA-DEHGAM-2 11:36 HRS / 17.05.2024 FOR MAIN LBB RETROFITTING WORKS AT DEHGAM END.
CKT	400kV NAGDA(MPPTCL)-DEHGAM-2	SRET	22-05-2024	18:44:00	22-05-2024	20:46:00	0.09	2.03	0.00	0.00	0.00		** Dear Sir,* A/T of 400kv Nagda-Dehgam ckt 2 at 18:44 Hrs / 22.05.2024 due to reactor protection operated at Nagda end and trouble
CKT	400kV NAGDA(MPPTCL)-DEHGAM-2	OMSU	23-05-2024	10:28:00	23-05-2024	11:25:00	0.04	0.00	0.95	0.00	0.00		* H/T OF 400KV NAGDA-DEHGAM #2 AT 10:28 HRS/23.05.2024 FOR TAKING L/R ON SERVICE AT NAGDA END. SAME LINE TA
CKT	400kV NAGDA(MPPTCL)-SHUJALPUR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV NAGDA(MPPTCL)-SHUJALPUR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV NAVSARI-VAV(GETCO)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV PIRANA-NICOL(TORRENT)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV RAJGARH-BADNAWAR(MPPTCL)-1	OSFD	31-05-2024	11:29:00	31-05-2024	19:52:00	0.35	0.00	0.00	0.00	8.38		* ESD TAKEN BY MPPTCL FOR TREE CUTTING WORK UNDER THEIR LILO SECTION.
CKT	400kV RAJGARH-BADNAWAR(MPPTCL)-1	OSPD	26-05-2024	09:47:00	26-05-2024	20:05:00	0.43	0.00	0.00	0.00	10.30		* H/T of 400KV Rajgarh - Badnawar 2 at 09:47Hrs/26.05.2024 to provide bird flappers. (S/D Availed by MPPTCL).
CKT	400kV RAJGARH-BADNAWAR(MPPTCL)-2	OMSU	20-05-2024	13:20:00	20-05-2024	13:20:00	0.00	0.00	0.00	0.00	0.00		* Dear Sir,* A/R Successful of 400KV Rajgarh-Badnawar#2 on Y-ph/E fault at 13:20hrs/20.05.2024* Rajgarh:.* M1- 34.9km/4.7kA* M2-
CKT	400kV RAJGARH (PG)-CHHEGAON(MPPTCL)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV RAJGARH-KHARGONE(NTPC)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV RNCHHDPURA(GETCO)-NICOL(TPGL) #1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400 KV RANCHHODPURA-PIRANA LINE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV SASAN(RELIANCE)-REWA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
CKT	400kV SATNA-BINA-1	OSPT	21-05-2024	07:46:00	21-05-2024	20:56:00	0.55	13.17	0.00	0.00	0.00		* H/T 400KV-SATNA-BINA-1 at 07:46hrs/21.05.2024 for Insulator Replacement Work.
CKT	400kV SATNA-BINA-1	LHWT	09-05-2024	15:49:00	09-05-2024	21:00:00	0.22	5.18	0.00	0.00	0.00		** A/T 400kv Satna- Bina#1 on R-ph/E fault at 15:49hrs/09.05.204* Satna:.* M1- 73km/4.55kA* M2-96.1km/3.96kA* AFAS(Double End):
CKT	400kV SATNA-BINA-1	OSPT	20-05-2024	08:15:00	20-05-2024	20:25:00	0.51	12.17	0.00	0.00	0.00		* H/T for Insulator replacement works
CKT	400kV SATNA-BINA-1	OSFT	10-05-2024	06:00:00	10-05-2024	20:42:00	0.61	14.70	0.00	0.00	0.00		* 05.06.2024 11:49:17 INDIA (60002986)* 09.05.2024 20:15:15 INDIA (60016679)** A/T 400KV Satna- Bina#1 on R-ph/E fault at 15:49h
CKT	400kV SATNA-BINA-1	OSPT	22-05-2024	09:04:00	22-05-2024	21:45:00	0.53	12.68	0.00	0.00	0.00		* H/T 400KV-SATNA-BINA-1 AT 09:04 hrs /22.05.20 24FOR INSULATOR REPLACEMENT WORK.
CKT	400kV SATNA-BINA-1	OMSU	09-05-2024	21:00:00	10-05-2024	06:00:00	0.38	0.00	9.00	0.00	0.00		* 09.05.2024 20:15:15 INDIA (60016679)** A/T 400KV Satna- Bina#1 on R-ph/E fault at 15:49hrs/09.05.204* Satna:.* M1- 73km/4.55kA*
CKT	400kV SATNA-BINA-2	OSPT	19-05-2024	07:37:00	19-05-2024	20:51:00	0.55	13.23	0.00	0.00	0.00		* H/T for Insulator replacement works.
CKT	400kV SATNA-BINA-2	OSPT	18-05-2024	09:54:00	18-05-2024	20:57:00	0.46	11.05	0.00	0.00	0.00		* H/T of 400KV Satna - Bina 2 at 09:54Hrs/18.05.2024 for Insulator replacement work in line.
CKT	400kV SATNA-BINA-2	OSPT	17-05-2024	11:06:00	17-05-2024	20:42:00	0.40	9.60	0.00	0.00	0.00		* H/T of 400KV Satna - Bina 2 at 11:06Hrs/17.05.2024 for Insulator replacement work in line.
CKT	400kV SATNA-BINA-4	OSPT	06-05-2024	07:29:00	06-05-2024	20:23:00	0.54	12.90	0.00	0.00	0.00		* H/T for line AMP <(>&<)> insulator replacement work
CKT	400kV SATNA-BINA-4	OSPT	05-05-2024	07:46:00	05-05-2024	19:58:00	0.51	12.20	0.00	0.00	0.00		* H/T for line AMP <(>&<)> insulator replacement work
CKT	400kV SATNA-SAGAR(MPPTCL)	OSPT	03-05-2024	08:13:00	03-05-2024	20:17:00	1.05	25.10	0.00	0.00	0.00		
CKT	400kV SATNA-SAGAR(MPPTCL)	OSPT	04-05-2024	07:43:00	04-05-2024	19:57:00	0.51	12.23	0.00	0.00	0.00		* H/T 400kv Sagar Satna Line at 08:13hrs/03.05.2024 for AMP and insulator replacement works.
CKT	400kV SATNA-SAGAR(MPPTCL)	OSPT	04-05-2024	07:43:00	04-05-2024	19:57:00	0.51	12.23	0.00	0.00	0.00		** H/T 400kv Sagar Satna Line at 07:43hrs/04.05.2024 for AMP and insulator replacement works.
							1.01	24.30	0.00	0.00	0.00		

Standard of Performance data for the Month of May-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	400kV ZERDA(GETCO)-KANKROLI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BANASKANTHA-BHUJ-1	OSPT	27-05-2024	13:12:00	27-05-2024	19:48:00	0.28	6.60	0.00	0.00	0.00		* 27.05.2024 11:36:31 INDIA (60016679)* H/T OF 765KV-BHUJ-BANASKANTHA-1 AT 10:11 HRS/27.05.2024 for Line AMP works, For
CKT	765kV BANASKANTHA-BHUJ-1	SCSD	27-05-2024	10:12:00	27-05-2024	13:12:00	0.13	0.00	0.00	0.00	3.00		* H/T OF 765KV-BHUJ-BANASKANTHA-1 AT 10:11 HRS/27.05.2024 for Line AMP works, For Switching in Line reactor at Banaskantha
CKT	765kV BANASKANTHA-BHUJ-1	LART	16-05-2024	17:02:00	16-05-2024	17:02:00	0.00	0.00	0.00	0.00	0.00		* A/R Successful of 765KV Bhuj - Banaskantha # 1 on R-ph/E fault at 17:02hrs/16.05.2024** At Bhuj end:- M1-40.26KM/8.57KA* M2-
CKT	765kV BANASKANTHA-BHUJ-2			00:00:00		00:00:00	0.41	6.60	0.00	0.00	3.00	99.11	
CKT	765kV BANASKANTHA-CHITTORGARH-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BANASKANTHA-CHITTORGARH-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BINA-GWALIOR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BINA-GWALIOR-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BINA-GWALIOR-3			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV BINA-INDORE	LCSD	01-05-2024	00:00:01	10-05-2024	22:19:00	9.93	0.00	0.00	0.00	238.32		* For Erection and Stringing of Diversion Portion of 765 KV Bina Indore Line under WCR-BPL Diversion Work. DIA TO BE KEPT OPEN
CKT	765kV GWALIOR-AGRA-1			00:00:00		00:00:00	9.93	0.00	0.00	0.00	238.32	100.00	
CKT	765kV GWALIOR-AGRA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV GWALIOR-ORAI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV INDORE-VAODARA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JAIPUR(RRVPNL)-GWALIOR-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JAIPUR(RRVPNL)-GWALIOR-2	OSPT	19-05-2024	09:44:00	19-05-2024	21:04:00	0.47	11.33	0.00	0.00	0.00		* H/T of 765KV-GWALIOR-JAIPUR-2 at 09:44Hrs/19.05.2024 for AMP works of Line
CKT	765kV JAIPUR(RRVPNL)-GWALIOR-2	LMAC	17-05-2024	15:13:00	17-05-2024	20:03:00	0.20	0.00	0.00	4.83	0.00		* A/T of 765KV Gwalior - Phagi 2 on B-ph/E fault at 15:13hrs/17.05.2024** At Gwalior end:- M1-24.79/14.60KA* M2-24.2km/14.07ka* /
CKT	765kV JAIPUR(RRVPNL)-GWALIOR-2	LMAC	17-05-2024	12:59:00	17-05-2024	15:01:00	0.09	0.00	0.00	2.03	0.00		* A/T of 765KV Gwalior - Phagi 2 on B-ph/E fault at 12:59hrs/17.05.2024** At Gwalior end:- M1-26.6KM/2.23KA* M2-NIL** At Phagi er
CKT	765kV JABALPUR PS-BINA-1			00:00:00		00:00:00	0.76	11.33	0.00	6.86	0.00	98.46	
CKT	765kV JABALPUR PS-BINA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV JABALPUR PS-DHARAMJAYGARH-1	LVRD	01-05-2024	00:00:01	31-05-2024	23:59:59	31.00	0.00	0.00	0.00	744.00		* KEPT OPEN on Voltage regulation vide WRLDC code on system constraints
CKT	765kV JABALPUR PS-DHARAMJAYGARH-1	LVRD	25-05-2024	08:10:00	31-05-2024	23:59:59	6.66	0.00	0.00	0.00	159.83		* H/T UNDER V/R
CKT	765kV JABALPUR PS-DHARAMJAYGARH-2			00:00:00		00:00:00	37.66	0.00	0.00	0.00	903.83	100.00	
CKT	765kV JABALPUR-ORAI-1	LCSD	04-05-2024	17:28:00	04-05-2024	21:15:00	0.16	0.00	0.00	0.00	3.78		* H/T on emergency to remove hanging support pulley from top Ph jumper at loc no 476 which was fell during OPGW installation work.
CKT	765kV JABALPUR-ORAI-2			00:00:00		00:00:00	0.16	0.00	0.00	0.00	3.78	100.00	
CKT	400kV RIHAND(NTPC)-VINDHYACHAL PS-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	400kV RIHAND(NTPC)-VINDHYACHAL PS-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SASAN(RELIANCE)-SATNA-1	OSPT	19-05-2024	08:11:00	19-05-2024	20:17:00	0.50	12.10	0.00	0.00	0.00		* H/T of 765KV-SASAN-SATNA-1 at 08:11Hrs/19.05.2024 for rectification of shutdown nature defects
CKT	765kV SASAN(RELIANCE)-SATNA-2			00:00:00		00:00:00	0.50	12.10	0.00	0.00	0.00	98.37	
CKT	765kV VINDHYACHAL PS-SASAN(RELIANCE)-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SATNA-BINA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SATNA-BINA-2			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
CKT	765kV SATNA-GWALIOR-2	GOVC	20-05-2024	18:04:00	20-05-2024	19:35:00	0.06	0.00	0.00	1.52	0.00		* A/T of 765 KV Satna-Gwalior at 16:02 Hrs / 20.05.2024 on B Ph-E/fault.* Test charge attempt taken at 18:04 from gwalior end ,over vr
CKT	765kV SATNA-GWALIOR-2	LEFT	20-05-2024	16:02:00	20-05-2024	18:04:00	0.09	2.03	0.00	0.00	0.00		* A/T of 765 KV Satna-Gwalior at 16:02 Hrs / 20.05.2024 on B Ph-E/fault.* Indication:* At Satna end: - M1: 5.5 km /19.47 kA* - M2-5.5Km
CKT	765kV SATNA-ORAI	LART	31-05-2024	13:31:00	31-05-2024	13:31:00	0.15	2.03	0.00	1.52	0.00	99.73	
CKT	765kV SATNA-ORAI	LMAC	26-05-2024	11:05:00	26-05-2024	12:45:00	0.07	0.00	0.00	1.67	0.00		* A/R Successful of 765KV Satna - Orai on Y-ph/E fault at 13:31 Hrs / 31.05.2024.* Indication:* At Satna end: - M1 :-111.3KM/5.64K
CKT	765kV SATNA-ORAI						0.07	0.00	0.00	1.67	0.00	100.00	* A/T of 765KV Satna - Orai line at 11:05 Hrs / 26.05.2024 on Y Ph-E/fault.* Indication:* At Satna end: - M1: 188KM/3.2KA* M2:19C

Standard of Performance data for the Month of May-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE TO System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
CKT	765KV SATNA-VINDHYACHAL PS-1	LART	08-05-2024	15:25:00	08-05-2024	15:25:00	0.00	0.00	0.00	0.00	0.00		* A/R Successful of 765 KV Satna - Vindhyachal - 1 at 15:25 Hrs/08.05.2024 on Bph-E/fault:** @Satna end : M1- 15.3KM/15.38KA*
CKT	765KV SATNA-VINDHYACHAL PS-1	LMAC	02-05-2024	06:20:00	02-05-2024	07:33:00	0.05	0.00	0.00	1.22	0.00	100.00	* **SUBSTATION: VindhyachalPS* EQUIPMENT: 765KV SATNA-VINDHYACHAL PS-1* DATE <-&-> TIME: 02/05/2024 06:20:2
CKT	765KV SATNA-VINDHYACHAL PS-2	LNCC	11-05-2024	13:12:00	11-05-2024	14:06:00	0.04	0.00	0.00	0.90	0.00		* Dear Sir,* A/T 765kv Satna- V'chal#2 at 13:12hrs/11.05.2024 on Y-ph/E fault* Satna:-* M1- 53.53km/8.3kA* M2-53.6km/8.8kA* TWFL:
CKT	765KV SATNA-VINDHYACHAL PS-2	LART	15-05-2024	14:18:00	15-05-2024	14:18:00	0.00	0.00	0.00	0.00	0.00		* A/R Successful of 765kv Satna- V'chal#2 at 14:18hrs/15.05.2024 on B-ph/E fault* Satna:-* M1- 56.43KM/8.54KA* M2-55.3KM/8.15K
CKT	765KV SATNA-VINDHYACHAL PS-2	OSFT	25-05-2024	10:53:00	25-05-2024	17:44:00	0.29	6.85	0.00	0.00	0.00		* H/T of 765KV Satna - Vindhyachal 2 at 10:53Hrs/25.05.2024 on emergency to attend slipped earth wire from tower peak at loc no: 61C
CKT	765kv SEONI-BINA-1			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.08	
LNR	80MVAR,SWLR OF AURANGABAD-1 @ BOISAR	SVRD	01-05-2024	00:00:01	31-05-2024	23:59:59	31.00	0.00	0.00	0.00	744.00	100.00	* H/T UNDER V/R
LNR	330MVAR,SWLR OF CHITORGARH2 AT BANSKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF CHITORGARH1 AT BANSKA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BHUJ-1 AT BANASKANTHA	SCSD	27-05-2024	10:12:00	27-05-2024	13:12:00	0.13	0.00	0.00	0.00	3.00		* 27.05.2024 11:36:31 INDIA (60016679)* H/T OF 765KV-BHUJ-BANASKANTHA-1 AT 10:11 HRS/27.05.2024 for Line AMP works, For
LNR	330MVAR,SWLR OF BHUJ-1 AT BANASKANTHA	OSPT	27-05-2024	13:12:00	27-05-2024	19:48:00	0.28	6.60	0.00	0.00	0.00		* 02.06.2024 17:18:38 INDIA (60002986)* 27.05.2024 11:36:31 INDIA (60016679)* H/T OF 765KV-BHUJ-BANASKANTHA-1 AT 10:11 H
LNR	330MVAR,SWLR OF BHUJ-2 AT BANASKANTHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.11	
LNR	50MVAR,SWLR OF KHNADWA-1 AT BETUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF KHANDWA-2 AT BETUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF LAKADIA(ADANI)-1 @ BHACH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF LAKADIA(ADANI)-2 @ BHACH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BANASKANTHA-2 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	330MVAR,SWLR OF BANASKANTHA-1 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF SAGAR AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SHUJALPUR-1 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SHUJALPUR-2 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF INDORE AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF GWALIOR-3 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF JAIPUR-2 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF JAIPUR-1 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-1 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF ORAI-1 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-2 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF ITARSI-1 AT INDORE(MP)			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF ITARSI-2 AT INDORE(MP)	OSPT	07-05-2024	10:55:00	07-05-2024	17:40:00	0.28	6.75	0.00	0.00	0.00		* H/T 400KV-ITARSI-INDORE-MP-2 L/R @ INDORE-MP at 10:55hrs/07.05.2024 for FDS testing (switchable LR)
LNR	80MVAR,SWLR OF KHANDWA-1 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	99.09	
LNR	80MVAR,SWLR OF KHANDWA-2 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF KHANDWA-1 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF VADODARA AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF KHANDWA-2 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-1 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of May-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
LNR	240MVAR,SWLR OF BINA-2 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-3 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BHOPAL AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SHUJALPUR-2 AT NAGDA	OSFT	25-05-2024	12:56:00	25-05-2024	18:48:00	0.24	5.87	0.00	0.00	0.00	99.21	* H/T of Switchable L/R of 400kV Nagda - Shujalpur 2 at 12:56Hrs/25.05.2024 on emergency to replace faulty MOG at Nagda end.
LNR	63MVAR,SWLR OF SHUJALPUR-1 AT NAGDA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SR. SAROVAR-1 AT RAJGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF KHARGONE AT RAJGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	63MVAR,SWLR OF SR. SAROVAR-2 AT RAJGARH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-1 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF BINA-2 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF ORAI-1 AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,LR OF GWALIOR AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF BINA-1 AT SHUJALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	50MVAR,SWLR OF BINA-2 AT SHUJALPUR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF SATNA-1 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
LNR	240MVAR,SWLR OF SATNA-2 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	423MVA, 400/32kV, COUPLING TRANSFORMER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-200/+200 MVAR STATCOM AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	COUPLING TRANSFORMER			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
STATCOM	-300/+300 MVAR STATCOM AT SATNA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BOISAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BOISAR	OSFT	16-05-2024	22:37:00	17-05-2024	02:11:00	0.15	3.57	0.00	0.00	0.00	99.52	* H/T ICT2 BOISAR 400/220kV at 22:37 hrs. /16.05.2024 on emergency basis to attend misalignment of 400 kV side 89T B ph isolator.
XMER	500MVA,400/220kV ICT-3 AT BOISAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT BOISAR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BANASKANTHA	OSFT	14-05-2024	19:59:00	14-05-2024	22:01:00	0.09	2.03	0.00	0.00	0.00	99.73	* H/T of 765 / 400 kV Banakantha ICT-1 at 19:58 Hrs / 14.05.2024 for attending hot spot in Neutral jumper of B-Phase. under emergency
XMER	1500MVA,765/400kV ICT-2 AT BANASKANTHA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BETUL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BETUL	OSFT	14-05-2024	11:33:00	14-05-2024	16:28:00	0.21	4.92	0.00	0.00	0.00	99.34	* H/T ICT2 BETUL(GIS) 400/220kV at 11:33 hrs /14.05.2024 on emergency basis to check cause of leakage and top-up the compartment
XMER	315MVA,400/220kV ICT-1 AT BHACHAU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT BHACHAU			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of May-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO Licensee	OUTAGE ATTRIBUTABLE TO Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	500MVA,400/220kV ICT-3 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00		
XMER	1500MVA,765/400kV ICT-3 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-4 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-4 AT BHUJ	OSPT	14-05-2024	09:52:00	14-05-2024	22:19:00	0.52	12.45	0.00	0.00	0.00	98.33	* H/H 765KV/400KV BHUJ-ICT-4 at 09:52 hrs./14.05.2024 for PRV modification Work
XMER	500MVA,400/220kV ICT-5 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-6 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-7 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-8 AT BHUJ			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1000MVA,765/400kV ICT-1 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1000MVA,765/400kV ICT-2 AT BINA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT DAMOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT DAMOH			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT DAMOH	OSPT	17-05-2024	09:37:00	17-05-2024	19:22:00	0.41	9.75	0.00	0.00	0.00	98.69	* H/T of 400/220KV ICT 3 at Damoh SS at 09:37Hrs/17.05.2024 for AMP works.
XMER	315MVA,400/220kV ICT-1 AT DEHGAM	SCSD	14-05-2024	10:33:00	14-05-2024	16:01:00	0.23	0.00	0.00	0.00	5.47		* H/T 400KV/220KV DEHGAM-ICT-1 at 10:33 hrs./14.05.2024 for Disconnecting tertiary Transformer overhead connection from ICT#1
XMER	315MVA,400/220kV ICT-1 AT DEHGAM	SCSD	24-05-2024	09:06:00	24-05-2024	19:02:00	0.41	0.00	0.00	0.00	9.93		* H/T OF 400KV/220KV DEHGAM-ICT-1 AT 09:09 HRS / 24.05.2024 FOR LBB RELAY RETROFITTING IN TIE BAY 405.
XMER	315MVA,400/220kV ICT-1 AT DEHGAM	SCSD	27-05-2024	10:35:00	27-05-2024	17:11:00	0.28	0.00	0.00	0.00	6.60		* H/T OF 400KV/220KV DEHGAM-ICT-1 at 10:35 HRS / 27.05.2024 For Main Bay 406 LBB relay retrofitting work.
XMER	315MVA,400/220kV ICT-2 AT DEHGAM	SCSD	01-05-2024	00:00:01	09-05-2024	21:43:00	8.91	0.00	0.00	0.00	213.72		* H/T FOR OIL REPLACEMENT WORK UNDER ADD C
XMER	315MVA,400/220kV ICT-2 AT DEHGAM	SCSD	14-05-2024	16:36:00	14-05-2024	19:24:00	0.12	0.00	0.00	0.00	2.80		* H/T of 400/220 kV DEHGAM-ICT-2 at 16:36 Hrs / 14.05.2024 for Connection of tertiary Transformer from ICT#2* 05.06.2024 12:06:5
XMER	315MVA,400/220kV ICT-2 AT DEHGAM	SCSD	25-05-2024	10:29:00	25-05-2024	17:47:00	0.30	0.00	0.00	0.00	7.30		* H/T OF 400KV/220KV DEHGAM-ICT-2 at 10:29 HRS / 25.05.2024 for LBB RELAY RETROFITTING IN MAIN BAY 407.
XMER	500MVA,400/220kV ICT-3 AT DEHGAM	SCSD	30-05-2024	09:33:00	30-05-2024	20:36:00	0.46	0.00	0.00	0.00	11.05		* H/T 400KV/220KV DEHGAM-ICT-3 at 09:33 hrs./30.05.2024 at Dehgam ss For Backup Impedance relay Installation work.
XMER	315MVA,400/220kV ICT-1 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT GWALIOR			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT GWALIOR	OSPT	08-05-2024	10:36:00	08-05-2024	20:42:00	0.42	10.10	0.00	0.00	0.00	98.64	* H/T 400/220KV GWALIOR-ICT-3 at 10:36 hrs/08.05.2024 FOR AMP WORKS.
XMER	500MVA,400/220kV ICT-1 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT INDORE			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT INDORE PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT ITARSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT ITARSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-3 AT ITARSI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT JABALPUR PS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	

Standard of Performance data for the Month of May-2024

Name of Transmission Licensee : POWER GRID CORPORATION OF INDIA LTD., WESTERN REGION-II

Object Type	Element Name	Type of failure	Outage Date	Outage Time	Restoration Date	Restoration Time	Total Outage in Days	OUTAGE ATTRIBUTABLE TO ISTS Licensee	OUTAGE ATTRIBUTABLE To Others	OUTAGE ATTRIBUTABLE To System Constraint	OUTAGE ATTRIBUTABLE To Deemed Available	% Availability as certified by certifyin	Detailed Reasons for Outage
XMER	1500MVA,765/400kV ICT-3 AT VADODARA			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-1 AT VAPI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-2 AT VAPI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	315MVA,400/220kV ICT-3 AT VAPI			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-1 AT VAV GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	500MVA,400/220kV ICT-2 AT VAV GIS			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-1 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-2 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	
XMER	1500MVA,765/400kV ICT-3 AT VINDHYACHAL			00:00:00		00:00:00	0.00	0.00	0.00	0.00	0.00	100.00	
							0.00	0.00	0.00	0.00	0.00	100.00	