"Supply and retrofitting of 420kV & 245kV Isolators at Malerkotla substation" (through PRANIT portal)".

| Query | Reply |
|--|---|
| 1. As per latest REV 13 Specification Clause | The isolators (as per BOQ SI no 3 & 4) are not required to |
| No.2.0.f), 220 kV Bus Isolators shall be capable of Bus Transfer Switch duty. | perform Bus transfer switching duty. |
| In view of the above we request you to confirm whether 220 kV Isolators in your BOQ Sl.No.3 & 4 shall be ' with Bus Transfer Switch or not . | |