

पावर ग्रिड कारपोरेशन ऑफ इंडिया लिमिटेड
(भारत सरकार का उद्यम)
POWER GRID CORPORATION OF INDIA LIMITED
(A Government of India Enterprise)



Plot No. 4, Unit-41, Niladri Vihar, Chandrasekarpur, Bhubaneswar -751021

दूरभाष / Phone: + 91-0674-2720794

Eastern Region Transmission System-II, Odisha Projects

E-mail: cnmodisha@powergrid.co.in

BY SPEED POST/HAND/COURIER

संदर्भ: ODP/BB/C&M-1719/I-1046/NIT-06/Clarification

दिनांक: 27/09/2019

To (On Individual Basis)

M/s

.....

.....

Sub: Clarification in respect of "Package-A: Supply & Commissioning of Spring-Spring Operated 420KV, SF6 Circuit Breakers by Replacing Old BHEL Circuit Breakers at POWERGRID, Baripada Sub-Station (under RE 2019-20) [Spn no. ODP/BB/C&M-1719/I-1046]

Ref no.:

- 1) NIT Ref no.: ODP/BB/C&M-1719/I-1046/NIT-06/19-20/ Dated 29/08/2019
- 2) Bid documents issued to you.

Dear Sir,

- 1.0 This has reference to above.
- 2.0 One of the bidder has sought some clarification. In this regard please find clarification attached herewith as Annexure-I along with this letter. This clarification shall form integral part of bidding documents.
- 3.0 This is for information and submission of bids accordingly.

Thanking you,

Yours faithfully,

नेहा सिन्हा
27/09/19

(Neha Sinha)

Asst. Manager (C&M)

स्वहित एवं राष्ट्रहित में ऊर्जा बचाये / Save Energy for Self and Nation

पंजीकृत कार्यालय: बी, 9-कुतुब इंस्टीट्यूशनल एरिया, कटवरिया सराय, नई दिल्ली - 110016

Registered Office: B-9, Qutub Institutional Area, Katwaria Sarai, New Delhi - 110016,

दूरभाष /Tel :91-11-26560112 / 26560121. फैक्स /Fax: 91-11-22571848/ 571760. तार -'नेटग्रिड' Gram: 'NATGRID'

Annexure-I

Clarification to NIT for "Package-A: Supply & Commissioning of Spring-Spring Operated 420KV, SF6 Circuit Breakers by Replacing Old BHEL Circuit Breakers at POWERGRID, Baripada Sub-Station (under RE 2019-20) [Spn no. ODP/BB/C&M-1719/I-1046]"

The clarification requested and reply from POWERGRID is as under:

Sl.no.	Clarification Requested	POWERGRID's Reply
1	VOL-II, Scope of Work Point 7 Please confirm the IPS Tube thickness whether is it 4 inch or 4.5 inch. Please confirm the type of terminal connector.	The Diameter of the Existing Al. Tube is 114.3mm. The Terminal Connector to be supplied accordingly.
2	VOL-II, GTP Bidder shall supply the CB as per the approved GTP of PGCIL, Please confirm.	Bidder shall supply the Circuit breaker as per Technical Specification, GTP and any other document of the bid.
3	Guest House Accommodation We would request you to provide the guest house accommodation to our engineer in charge on chargeable basis.	Guest House accommodations shall be subject to availability and chargeable basis.

अतः फाईल