

Clarification No III dated 17.04.2026 for Rate Contract for Control and Protection Panels Package: CRP-02 consisting of CRP, SAS & PMU associated with Rate Contract for Substation Equipment's for implementation of Bay Extension works. Spec. No. CC/NT/W-MISC/DOM/A00/26/03365

Sr. No.	Clause reference	Provision in Specification	Bidders's Query	POWERGRID'S Clarifications
1	Clause 2.7f of Section Project, Vol II of Bidding Documents	400kV Line – PRP Though the BPS Items are specified for 400kV, the same may be operated for 765kV also.	Please confirm that the same implies to 765kV Line bay only and not for any ICT, Reactor bays. Also, we understand that in case the same is for 765kV Line bay, there shall be no requirement for standalone DR.	The bidder's understanding is generally in order