

Date: 28/02/2025

<< Issued to all bidders through portal [<https://etender.powergrid.in>](https://etender.powergrid.in)>>

Subject: Clarification-III to the Bidding Documents for 400kV GIS SUBSTATION PACKAGE SS-144 for (i) Augmentation of transformation capacity at 400/220kV Bidadi (GIS) S/s in Karnataka by 1x500 MVA, 400/220kV ICT (3rd), (ii) Augmentation of Transformation capacity at 400/220kV Yelahanka (GIS) S/s (POWERGRID) in Karnataka by 400/220kV, 1X500MVA ICT (3rd). Spec. No.: CC/NT/W-GIS/DOM/A10/24/15640

Dear Sir,

- 1.0 This has reference to the Bidding Documents for the subject Package which was uploaded on the portal <https://etender.powergrid.in>.
- 2.0 Please find enclosed herewith **Clarification-III** to the Bidding Documents. **Clarification-III** shall be read in conjunction with the Bidding Documents, referred to at para 1.0 above, and shall become an integral part thereof as though it has occurred therein.
- 3.0 Save and Except for the changes brought-out in the above mentioned **Clarification-III** all other terms and conditions of the original Bidding Documents, shall remain unaltered.

Yours faithfully,

28-02-2025

X 

Signed by: AKHILESH KUMAR SINGH

A K Singh
Ch. Manager (CS)

Clarification-III dated 28/02/2025 to the Bidding Documents for 400kV GIS SUBSTATION PACKAGE SS-144 for (i) Augmentation of transformation capacity at 400/220kV Bidadi (GIS) S/s in Karnataka by 1x500 MVA, 400/220kV ICT (3rd), (ii) Augmentation of Transformation capacity at 400/220kV Yelahanka (GIS) S/s (POWERGRID) in Karnataka by 400/220kV, 1X500MVA ICT (3rd). Spec. No.: CC/NT/W-GIS/DOM/A10/24/15640

| S.No. | Document Volume / Section & Page no. | Reference Clause | Query Description | POWERGRID's Reply |
|-------|--------------------------------------|------------------|---|--|
| 1 | REV 5A | Typ SLD | Passive continuous type busbar design is already accepted by PGCIL in recent past. Refer enclosed addendums/clarifications issued by PGCIL. So, request you to please provide your acceptance for the same. | Acceptable provided other requirements of Technical Specifications are fulfilled for offered design of GIS. |
| 2 | Section project | | Kindly arrange to provide the following information for Bidadi substation- 1. Photos of existing GIS busbar where present GIS will be extended. 2. Approved SLD, Section and Plan drawings 3. End module details, rating plates, end module gas pressure details and density monitor photos. | SLD & GA is already provided. Other drawings shall be shared to bidder in the event of award during detailed engineering. Please refer Clarification-I |
