

Bid Corrigendum

GEM/2025/B/6180680-C13

Following terms and conditions supersede all existing "Buyer added Bid Specific Terms and conditions" given in the bid document or any previous corrigendum. Prospective bidders are advised to bid as per following Terms and Conditions:

Buyer Added Bid Specific Additional Terms and Conditions

1. Bidder shall submit the following documents along with their bid for Vendor Code Creation:
 - a. Copy of PAN Card.
 - b. Copy of GSTIN.
 - c. Copy of Cancelled Cheque.
 - d. Copy of EFT Mandate duly certified by Bank.
2. Buyer Organization specific Integrity Pact shall have to be complied by all bidders. Bidders shall have to upload scanned copy of signed integrity pact as per Buyer organizations policy along with bid. [Click here to view the file](#)
3. **Manufacturer Authorization:** Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid
4. Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller, if:
 - i) The Seller fails to comply with any material term of the Contract.
 - ii) The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent.
 - iii) The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period and/or to replace/rectify any rejected or defective Material(s) promptly.
 - iv) The Seller becomes bankrupt or goes into liquidation.
 - v) The Seller makes a general assignment for the benefit of creditors.
 - vi) A receiver is appointed for any substantial property owned by the Seller.
 - vii) The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.
5. Scope of supply (Bid price to include all cost components) : Only supply of Goods
6. Bidders can also submit the EMD with Account Payee Demand Draft in favour of Power Grid Corporation of India Limited payable at Lucknow.
.
Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.
7. Bidders can also submit the EMD with Banker's Cheque in favour of Power Grid Corporation of India Limited payable at Lucknow.
.
Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy

Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of Power Grid Corporation of India Limited payable at Lucknow

9. Buyer Added text based ATC clauses

[illegible]

Specification. No.: NCN0155

GEM BID REF. NO. GEM/2025/B/6180680 Dated: 07-05-2025

2 / 8

4.	TS	Please elaborate the requirement for 3 sides and 4 sides equipment of teed differential.	Revised annexure mentioning CT and VT inputs is attached As Annexure-1
5.	TS	We understood that 2 Sets. of all the relevant software for offered relays like communication software, relay settings & configuration software, DR Downloading & Evaluation software etc. along with their licenses are to be supplied for the complete package not per substation. Kindly confirm.	All the software shall be submitted by way of two sets of original/licensed CDs for each location.

Annexure-1 is uploaded in Buyer Uploaded ATC.

This corrigendum shall form an integral part of the bid documents and shall be read in conjunction with the same

CORRIGENDUM-II Dated 11.06.2025

GEM BID REF. NO. GEM/2025/B/6180680 Dated: 07-05-2025

Sl. No.	Clause No.	Bidder's Query	Reply
---------	------------	----------------	-------

This

1.	<p>Sl. No. 24 of Buyer Added Additional Terms and Conditions (BATC)</p> <p>Quantity Variation:</p> <p>During placement of the Award, the Purchaser reserves the right to increase or decrease the tendered quantity by 25 (Twenty-Five) percent for ordering, if so warranted, without any change in the unit prices quoted by the bidder.</p> <p>Subsequent to the award, the Purchaser reserves the right to increase or decrease the quantity of Goods & Related Services specified to the extent of 25 (Twenty-Five)% of the Contract Price as originally set forth in Contract Order, without any change in unit price or other terms and conditions during the execution of the Contract. However, the quantities of individual items and services may vary to any extent.</p>	<p>Any change in the quantity at the time of order placement will be acceptable.</p> <p>Although increase in quantity during execution of contract will be checked and may be accepted. However, decrease in the quantity later to order placement will not be accepted. Kindly accept this change in this clause.</p>	<p>Bidders are requested to quote as per BATC of the GeM bid.</p>
2.	<p>Point No #7 of Gem Corrigendum-I</p>	<p>The relay shall be capable of supporting IEC 61850 protocol. Bidder shall provide both RJ45 and FO ports.</p>	<p>The relay shall be capable of supporting IEC 61850 protocol. Bidder shall provide FO port with the relay.</p>
3.	<p>Buyer Added Bid Specific Additional Terms and Conditions / Serial No : 3</p> <p>Manufacturer Authorization: Wherever Authorized Distributors/service providers are submitting the bid, Authorization Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid</p>	<p>Kindly Confirm if OEM is planning to BID directly, If Manufacturer Authorization allowed to Dealer/ multiple Distributors ?</p>	<p>Dealer/Multiple distributors may participate in bid and submit Manufacturer Authorization Form /Certificate with OEM as per GeM Bid.</p>

corrigendum shall form an integral part of the bid documents and shall be read in conjunction with the same.

CORRIGENDUM-I**GEM BID REF. NO. GEM/2025/B/6180680 Dated: 07-05-2025**

Sl. No.	Clause No.	Bidder's Query	Reply
1.	BOQ	As per the Specification of TEE D differential Protection, point 3.1 says TEE -1 is low impedance differential & Point 3.2 says TEE-2 is High impedance differential. But in BOQ, it is not mentioned that which feeder should have TEED Low Impedance and TEED High impedance protection. Please clarify.	<p><i>In BOQ line-item number 11 "Teed Relay as per TS and usage details attached in Bid Document" mentioned quantity is 22 nos.</i></p> <p><i>Out of these 22, 11 nos. are Low Impedance Relay and 11 nos. are High impedance Relay to be supplied under this line item. Bidders may quote the rates accordingly for this item.</i></p> <p><i>In BOQ line-item number 12 "Teed Relay as per TS and usage details attached in bid document) mentioned quantity is 17 nos. Out of these 17, 09 nos. are Low Impedance Relay and 08 nos. are High impedance Relay to be supplied under this line item. Bidders may quote the rates accordingly for this item.</i></p> <p><i>Price break-up for Low Impedance Relay and High Impedance Relay for item no. 11 and item no. 12 must be provided by the bidder along with submitted bid as per attached format.</i></p>
2.	BOQ	In the BOQ, point no 17 & 18 (Orai and Fatehpur), you have simply mentioned Numerical relay, but you have not specified the application or Protections/DI requirement. Kindly provide	<i>These relays are being procured for creation of soft logic (Mechanical protection of ICT/Reactor) and extend tripping to Group relay. Details of required Input and output cards have been mentioned in Bid Document. No CT-PT card is required, Relays to meet out the above conditions with any protection application is required.</i>
3.	BOQ	Regarding Line-Item Numbers 17 and 18 of the tenders, there is a requirement for numerical relays at Orai and Fatehpur of NR-III. In Annexure II, point b states "Nil/Minimum number of Protection functions."-kindly elaborate on the specific protection functions required in the relays to be quoted and offered.	<i>These relays are being procured for creation of logic in soft (Mechanical protection of ICT/Reactor) and extend tripping to Group relay. Details of required Input and output cards have been mentioned in Bid Document. No CT-PT card is required, Relays to meet out the above condition with any protection application is required.</i>
4.	TS	No. of required BI & BO are clear for all Relays. However, details of CT & VT are not clear. Please confirm the requirement of CT & VT.	<i>Details of CT and VT inputs is already provided in Specification Document (page 04-05) of GeM Bid.</i>

This

5.	TS	Kindly confirm if specification of Teed-1 or Teed-2 need to be considered for this requirement .	<p>Teed Relay with 3 CT input-22 no's (Ref-BOQ line item-11) (which is bifurcated as 11 no's Low impedance Relay and 11 no's High impedance Relay).</p> <p>Teed relay with 4 CT input-17 Nos (BOQ Line item 12) (which is to be bifurcated as 9 number Low impedance Relay and 8 number High impedance relay).</p> <p>In BOQ line-item number 11 "Teed Relay as per TS and usage details attached in Bid Document" mentioned quantity is 22 nos.</p> <p>Out of these 22, 11 nos. are Low Impedance Relay and 11 nos. are High impedance Relay to be supplied under this line item. Bidders may quote the rates accordingly for this item.</p> <p>In BOQ line-item number 12 "Teed Relay as per TS and usage details attached in bid document) mentioned quantity is 17 nos. Out of these 17, 09 nos. are Low Impedance Relay and 08 nos. are High impedance Relay to be supplied under this line item. Bidders may quote the rates accordingly for this item.</p> <p>Price break-up for Low Impedance Relay and High Impedance Relay for item no. 11 and item no. 12 must be provided by the bidder along with submitted bid as per attached format.</p>
6.	TS	Kindly confirm the use of this Numerical relays. Also confirm the CT & VT requirement. (Specification Document Page No. 05)	These relays are being procured for creation of soft logic (Mechanical protection of ICT/Reactor) and extend tripping to Group relay. Details of required Input and output cards have been mentioned in Bid Document. No CT-PT card is required, Relays to meet out the above conditions with any protection application is required
7.	TS	Kindly confirm the port requirement for future SCADA connectivity. RJ45 or FO?	The relay shall be capable of supporting IEC 61850 protocol. Bidder shall provide both RJ45 and FO ports
8.	TS	As the Specification contain the complete scheme requirement of Transformer feeder. Kindly confirm if any other protection like overflux, backup, REF will be part of differential relay or only differential protection need to be considered.	Only differential protection needs to be considered.

9.	TS	We understood that our scope is limited to supply of loose relays as per the BOQ along with software and communication cable. No other material or service is in scope of vendor. Kindly confirm.	<i>Relays as per the TS along with software and communication cable is required to be supplied. No other material or service is required</i>
10.	TS	We understood that 2 nos. of licensed software need to be supplied for the complete package. Kindly confirm.	<i>It is to be clarified that all the relevant software for offered relays like communication software, relay settings & configuration software, DR Downloading & Evaluation software etc. along with their licenses are to be supplied as well as two sets of original/licensed CDs are to be provided for these software's.</i>
11.	TS	We understood that our scope is limited to supply of loose relays. Offered relays can be synchronized with substation clock on SNTP. Any additional hardware for time synchronization is not in scope of supply. Kindly confirm.	<i>Required relays shall be synchronized with substation clock on SNTP. No additional hardware for time synchronization is required.</i>
12.	TS	We understood that our scope is limited to supply of loose relays. Kindly confirm the protection need to be considered for said Numerical relays.	<i>There is no specific protection need. The relays are procured for LOGIC implementation at Orai & Fatehpur Substation which requires the use of BI & BO only.</i>

corrigendum shall form an integral part of the bid documents and shall be read in conjunction with the same.

10. Buyer uploaded ATC document [Click here to view the file.](#)

Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.

6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

*This document shall overwrite all previous versions of Bid Specific Additional Terms and Conditions.

[This Bid is also governed by the General Terms and Conditions](#)