

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	12-08-2024 17:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	12-08-2024 17:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	180 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Power
Department Name/विभाग का नाम	Power Grid Corporation Of India Limited
Organisation Name/संगठन का नाम	Power Grid Corporation Of India Limited
Office Name/कार्यालय का नाम	Corporate Office Gurgaon
Total Quantity/कुल मात्रा	10
Item Category/मद केटेगरी	Distribution Transformer, 3 Phase, 11 kV > 200 KVA up to and Including 2500 KVA (Q3) , Distribution Transformer, 3 Phase, 33 KV, > 200 KVA Up to and including 2500 KVA (Q3)
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	Yes
RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	Distribution Transformer, 3 Phase, 33 KV, > 200 KVA Up to and including 2500 KVA
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	7 Days

Bid Details/बिड विवरण	
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation

EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
EMD Amount/ईएमडी राशि	611000

ePBG Detail/ईपीबीजी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	5.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	27

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

POWER GRID Corporation OF INDIA Limited
Corporate Office Gurgaon, POWER GRID Corporation OF INDIA Limited, POWER GRID Corporation OF INDIA Limited, Ministry of Power
(Power Grid Corporation Of India Ltd.)

Splitting/विभाजन

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

Reserved for Make In India products

Reserved for Make In India products	Yes
-------------------------------------	-----

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. Bid reserved for Make In India products: : Procurement under this bid is reserved for purchase from Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. However, eligible micro and small enterprises will be allowed to participate. The minimum local content to qualify as a class 1 local supplier is denoted in the bid document. All bidders must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which the bid is liable to be rejected. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020 . In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.

2. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 100% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

3. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

4. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

Excel Upload Required/एक्सेल में अपलोड किए जाने की आवश्यकता :

Price Breakup - [1721127690.xlsx](#)

Pre Bid Detail(s)

Pre-Bid Date and Time	Pre-Bid Venue
26-07-2024 11:00:00	Power Grid Corporation of India Limited Saudamini Plot No 2 Sector 29 Gurgaon Haryana 122001

Distribution Transformer, 3 Phase, 11 KV > 200 KVA Up To And Including 2500 KVA (3 pieces)

(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Whether Price variation applicable?	Price Variation Clause/मूल्य परिवर्तन खंड(पीवीसी)	Price variation clause document
Yes	Appendix – 2 of Section – VI: Samples Forms and Procedures	57224c704af58c0c21ea7d9c739797bb.pdf

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Energy efficiency level	2
	BEE Star Rating	1, 2, 3, 4, 5
	Installation, Testing and Demonstration	Yes . Excluding Civil work, No
	Minimum warranty on receipt of stores (in Months)	30, 42, 54, 66, 78
	Minimum warranty from the date of installation (in Months)	24, 36, 48, 60, 72
RATINGS	Nominal system voltage, HV (in kV)	11
	Nominal system voltage, LV (in V)	415
	Standard ratings (in kVA)	800
	Minimum basic insulation level (in kVP)	75
	No load voltage ratios (in Volts)	11000/433-250
	Highest system voltage for equipment (in kV)	12
	Rated lightning impulse withstand voltage (in kV Peak) (Refer IS:1180 (Part 1):2014 Annex-D)	60, 75, 95
CONSTRUCTION	Core material	CRGO (as per IS:3024 latest)
	Conductor (Winding) material	Copper
	Vector Group	Dyn1
	Type of Mounting	Ground Mounted

Specification	Specification Name/विशिष्ट का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Noise level at rated voltage and frequency, Maximum (in dB)	45, 48, 51, 55
TRANSFORMER TANK	Transformer tank cover construction	Non-sealed, Bolted
	Tank configuration with	With radiator fins
	Material of transformer tank	Mild Steel
	Minimum thickness of top and bottom material of transformer tank (in mm)	5, 6, 7, 8, 9, 10
	Minimum thickness of side material of transformer tank (in mm)	3.15, 4, 4.5, 5, 6
	Material of Bolts/Nuts/Wahers exposed to atmosphere	Stainless steel (for upto 12 mm size), Brass (for upto 12 mm size), Electro Galvanized (for above 12 mm size), Hot Dip Galvanized (for above 12 mm size)
	Gaskets wherever used shall conform to	Type IV (as per IS:11149) NBR
	Provision of conservator	Yes , for Non sealed type with Plain tank construction
Painting	Type of painting on inside of tank (hint: Refer Table 12 of IS:1180 (Pt.1):2014)	Oil resistant paint
	Type of painting on External surface of tank (hint: Refer Table 12 of IS:1180 (Pt.1):2014)	Epoxy (Primer)
TAP CHANGER	Winding tapped	HV
	No. of positions (in Nos.)	7
	Voltage variation	+5% to -10% in steps of 2.5% for variation of HV
TERMINAL ARRANGEMENT	Transformer fitted with bushings of appropriate voltage and current ratings on HV side	Yes. 3 Nos. (Conforming to IS:2099)
	Transformer fitted with bushings of appropriate voltage and current ratings on LV side	Yes. 4 Nos. (Conforming to IS:7421)
	Suitable provision for adoption of cables of suitable size on LV side	Yes. For PVC/XLPE Cables
	Cable End Box on HV side	Yes, No
	Cable End Box on LV side	Yes
MARKING	Material of rating plate	Stainless steel

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Marking method on rating plate	Etching, Engraved, Stamped
	Rating and terminal marking plates combined into one plate	Yes, No
OPTIONAL FITTINGS	Suitable rating lightning arrestors	HT Side, 1 No. per phase, No
	Bird guard	No
	Terminal connectors	No
	Oil temperature indicator and winding temperature indicator	Yes
	Jacking pads	Yes
	Buchholz relay	Yes
	Magnetic oil level gauge with low oil level alarm contact	Yes
	Non return valve	Yes, No
	Protection relay for sealed type transformers for internal parameters that is pressure, temperature, oil level and gas detection	No
	Unidirectional flat rollers	Yes
	Drain cum sampling valve	Yes
	Self protection / disconnection devices	No
	Expulsion fuse as disconnection device	No
SERVICE CONDITION	Maximum altitude	<1000 m
TEST REPORTS & CERTIFICATIONS	Availability of type test reports to prove the conformity of the specification from	NABL Accredited
	Agreed for stage Inspection as required by buyer	Yes
SPECIAL TEST REPORTS	Availability of test report for Determination of sound level test	Yes, No
	Availability of test report for short circuit withstand test	Yes

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Availability of test report for No load current at 112.5 % Voltage	Yes
	Availability of test report for Paint adhesion test	Yes for all units
	BDV and moisture content of oil in the transformer	Yes for all units
	Other requirements	Losses and Impedance values as per Cl.7.8 and Table 6 of IS:1180 (Part 1):2014 latest, Limits of temeptrature-rise as per Cl.7.10 of IS:1180 (Part 1):2014 latest

Additional Specification Parameters - Distribution Transformer, 3 Phase, 11 KV > 200 KVA Up To And Including 2500 KVA (3 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Nominal system voltage LV (in V) & Power Frequency Test Level- HV & Power Frequency Test Level- LV & HV Bushing - Rated Voltage & HV Bushing - Rated Current	433 V & 28kV & 2kV & 12kV & 100A
Creepage & Wet & Dry Power Frequency & LV Bushing - Rated Voltage & LV Bushing - Rated Current & Creepage & Wet & Dry Power Frequency & Type Test & Routine Test as per TS	25mm/Kv & 28kV rms & 1kV & 2000A & 25mm/Kv & 5kV rms & Yes

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Anurag	342307, POWERGRID 765/400/220kV Bhadla Substation, Noore Ki Bhurj, Bap, Phalodi, 342307	3	180

Distribution Transformer, 3 Phase, 33 KV, > 200 KVA Up To And Including 2500 KVA (7 pieces)**(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Whether Price variation applicable?	Price Variation Clause/मूल्य परिवर्तन खंड(पीवीसी)	Price variation clause document
Yes	Appendix – 2 of Section – VI: Samples Forms and Procedures	d85c9725c63f70967bab344e5374404c.pdf

Technical Specifications/तकनीकी विशिष्टियाँ* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Energy efficiency level	2
	BEE Star Rating	1, 2, 3, 4, 5
	Installation, Testing and Demonstration	Yes . Excluding Civil work, No
	Minimum warranty on receipt of stores (in Months)	30, 42, 54, 66, 78
	Minimum warranty from the date of installation (in Months)	24, 36, 48, 60, 72
RATINGS	Nominal system voltage, HV (in kV)	33
	Nominal system voltage, LV (in V)	415
	Standard ratings (in kVA)	800
	Minimum basic insulation level (in kVP)	170
	No load voltage ratios (in Volts)	33000/433-250
	Highest system voltage for equipment (in kV)	36
	Rated lightning impulse withstand voltage (in kV Peak) (Refer IS:1180 (Part 1):2014 Annex-D)	145, 170
CONSTRUCTION	Core material	CRGO (as per IS:3024 latest)
	Conductor (Winding) material	Copper
	Vector Group	Dyn1
	Type of Mounting	Ground Mounted

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Noise level at rated voltage and frequency, Maximum (in dB)	45, 48, 51, 55
TRANSFORMER TANK	Transformer tank cover construction	Non-sealed, Bolted
	Tank configuration with	With radiator fins
	Material of transformer tank	Mild Steel
	Minimum thickness of top and bottom material of transformer tank (in mm)	5, 6, 7, 8, 9, 10
	Minimum thickness of side material of transformer tank (in mm)	31.5, 4, 4.5, 5, 6
	Material of Bolts/Nuts/Wahers exposed to atmosphere	Stainless steel (for upto 12 mm size), Brass (for upto 12 mm size), Electro Galvanized (for above 12 mm size), Hot Dip Galvanized (for above 12 mm size)
	Gaskets wherever used shall conform to	Type IV (as per IS:11149) NBR
	Provision of conservator	Yes , for Non sealed type with Plain tank construction
PAINTING	Type of painting on inside of tank (hint: Refer Table 12 of IS:1180 (Pt.1):2014)	Oil resistant paint
TAP CHANGER	Tap changing arrangement	Off circuit , externally operated switch with mechanical locking device and a position indicator
	Winding tapped	HV
	No. of positions (in Nos.)	7
	Voltage variation	+5% to -10% in steps of 2.5% for variation of HV
TERMINAL ARRANGEMENT	Transformer fitted with bushings of appropriate voltage and current ratings on HV side	Yes. 3 Nos. (Conforming to IS:2099)
	Transformer fitted with bushings of appropriate voltage and current ratings on LV side	Yes. 4 Nos. (Conforming to IS:7421)
	Cable End Box on HV side	Yes, No
	Cable End Box on LV side	Yes
MARKING	Material of rating plate	Stainless steel
	Marking method on rating plate	Etching, Engraved, Stamped
OPTIONAL FITTINGS	Suitable rating lightning arrestors	HT Side, 1 No. per phase, No

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Bird guard	No
	Terminal connectors	No
	Oil temperature indicator and winding temperature indicator	Yes
	Jacking pads	Yes
	Buchholz relay	Yes
	Magnetic oil level gauge with low oil level alarm contact	Yes
	Non return valve	Yes, No
	Protection relay for sealed type transformers for internal parameters that is pressure, temperature, oil level and gas detection	No
	Unidirectional flat rollers	Yes
	Drain cum sampling valve	Yes with steel plug (for transformers upto 500 KVA), No, Yes
	Self protection / disconnection devices	No
	Expulsion fuse as disconnection device	No
SERVICE CONDITION	Maximum altitude	<1000 m
TEST REPORTS & CERTIFICATIONS	Availability of type test reports to prove the conformity of the specification from	NABL Accredited
	Agreed for stage Inspection as required by buyer	Yes
SPECIAL TEST REPORTS	Availability of test report for Determination of sound level test	Yes, No
	Availability of test report for short circuit withstand test	Yes
	BDV and moisture content of oil in the transformer	Yes for all units
	Other requirements	Losses and Impedance values as per Cl.7.8 and Table 6 of IS:1180 (Part 1):2014 latest, Limits of temperature-rise as per Cl.7.10 of IS:1180 (Part 1):2014 latest

Additional Specification Parameters - Distribution Transformer, 3 Phase, 33 KV, > 200 KVA Up To And Including 2500 KVA (7 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Nominal system voltage LV (in V) & Minimum basic insulation level (in kVP) & Highest system voltage for equipment (in kV) & Rated lightning impulse withstand voltage (in kV Peak)	433V & 250kVP & 52kV & 250kV
Power Frequency Test Level-HV & Power Frequency Test Level-LV & HV Bushing - Rated Voltage & HV Bushing - Rated Current & Creepage & Basic Impulse Level & Wet & Dry Power Frequency	95kV & 2kV & 52kV & 100A & 25mm/Kv & 250kVp & 95kV
LV Bushing - Rated Voltage & LV Bushing - Rated Current & Creepage & Wet & Dry Power Frequency & Type Test & Routine Test as per TS	1kV & 2000A & 25mm/Kv & 5kV rms & Yes

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Pushpendra Kumar Jaiswal	370001,POWER GRID CORPORATION OF INDIA LIMITED, 765/400/220 KV Bhuj Pooling Substation, Village-Palanpur (Badi), Taluka-Nakhatrana, Dist-Kutch, Gujarat 370001	7	180

Buyer added Bid Specific Additional Specification - Drawings

S.No./क्र. सं.	Document Title	Description	Applicable/रिवर्स प्रभार के अनुसार जीएसटी i.r.o. Items
1	Drawing View	Drawing	Distribution Transformer, 3 Phase, 11 KV > 200 KVA Up To And Including 2500 KVA(3)

S.No./क्र.सं.	Document Title	Description	Applicable/रिवर्स प्रभार के अनुसार जीएसटी i.r.o. Items
2	Drawing View	Drawing	Distribution Transformer, 3 Phase, 33 KV, > 200 KVA Up To And Including 2500 KVA(7)

Buyer added Bid Specific Additional Scope of Work

S.No.क्र.सं.	Document Title	Description	Applicable/रिवर्स प्रभार के अनुसार जीएसटी i.r.o. Items
1	GTR View	GTR	Distribution Transformer, 3 Phase, 11 KV > 200 KVA Up To And Including 2500 KVA(3)
2	Section Project View	Section Project	Distribution Transformer, 3 Phase, 11 KV > 200 KVA Up To And Including 2500 KVA(3)
3	TS View	TS	Distribution Transformer, 3 Phase, 11 KV > 200 KVA Up To And Including 2500 KVA(3)
4	GTR View	GTR	Distribution Transformer, 3 Phase, 33 KV, > 200 KVA Up To And Including 2500 KVA(7)
5	Section Project View	Section Project	Distribution Transformer, 3 Phase, 33 KV, > 200 KVA Up To And Including 2500 KVA(7)
6	TS View	TS	Distribution Transformer, 3 Phase, 33 KV, > 200 KVA Up To And Including 2500 KVA(7)

The uploaded document only contains Buyer specific Additional Scope of Work and / or Drawings for the bid items added with due approval of Buyer's competent authority. Buyer has certified that these additional scope and drawings are generalized and would not lead to any restrictive bidding.

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

- Terms and conditions of the Bidding Documents uploaded under BuyerATC on GeM portal and provisions mentioned hereinbelow, will supersede the GeM GTC and the provisions mentioned above.
- Local Content of 60% for Class-I Local Supplier indicated above against each of the BOQ item is for the entire package and not for the respective individual item. The percentage of Minimum Local content to qualify as Class-I Local Supplier is 60% as defined in BuyerATC.
- Purchase preference to Class-I Local Supplier shall be governed as per the provisions of BuyerATC, which shall supersede the above indicated provisions related to MII Policy.
- Delivery Period indicated above against each of the BOQ item is total Contract duration for the sub

ect package. Delivery period requirement shall be in line with BuyerATC.

- (v) Primary product appearing above is for indicative purpose only. The relevant provisions regarding the same shall be governed as per BuyerATC.
- (vi) Document required from seller shall be governed as per the provisions of the documents enclosed in BuyerATC.
- (vii) Exemption to Start-Ups / MSEs and requirement of e-PBG/CPG shall be governed as per the provisions of the documents enclosed in BuyerATC.
- (viii) Bidders are requested to quote the price in GeM portal itself. The prices (including taxes and duties) Quoted by Bidders on GeM portal shall be final and shall be considered for evaluation and award purposes.
- (ix) Further, Bidders shall quote their all-inclusive Prices against each item (i.e., Unit Price, F&I, Dynamic short circuit test of one each of 33KV & 11 KV class Transformers and applicable GST) against the Category Bid in the financial portion of the bid.

It may be noted that Dynamic short circuit test is to be carried out only for one transformer each of 33KV & 11 KV class (i.e. Dynamic short circuit test for one 33kV transformer and Dynamic short circuit test for one 11 KV transformer). Considering the same, bidders are required to quote on GeM Portal. Further, breakup of charges quoted is to be furnished.

- (x) Warranty/Defect Liability Period of Equipments to be procured under subject package shall be in line with Clause GCC 22.1 in SCC enclosed in BuyerATC.
- (xi) All bids must be accompanied by a bid security of **Rs. 6,11,000/-** (Rupees Six Lakh and Eleven Thousand only) and the same shall be valid upto **19/04/2025**.

2. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file](#).

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)

9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।

---Thank You/धन्यवाद---