

Clarification -III dated 20.04.2023 for to the Bidding Documents for “Transmission Line Tower Package TW01 for (i) 400kV D/c (Triple HTLS Conductor) line from Pot Head Yard of Kiru HE Project - Kishtwar Pooling Station, (ii) LILO of one ckt. of 400 kV D/c (Triple HTLS Conductor) Kiru - Kishtwar line at Pot Head Yard of Kwar & Pakal Dul HE Projects and (iii) Extension of Kishtwar (GIS) pooling station under Consultancy Works to M/S CVPPPL”; Spec. No.: CC/NT/W-TW/DOM/A06/23/00495

Sl. No.	Clause ref	Clause Description	Queries asked by the bidder	POWERGRID's clarification
1.	General	General	Request to please provide us the GTP format for HTLS conductor as per Sag & Tension Conditions mentioned in 01_1 Section IA (standard) Scope Rev-6 (Feb'2023)	Bidder may refer GTP format of HTLS conductor attached with the technical specification. However, it is a sample format and technical requirement shall be modified as per technical particulars given in Section-IA.
2.	L. Section-Air Conditioning Rev-04 4. New Annexure-S2	SPECIFIC REQUIREMENT'S (SectionProject) C/ENGG/SPEC/SECPROJECT/SPECIFIC REQUIREMENT REV NO 07	Each Local Control room inside GIS hall shall be provided with temperature transducer to monitor the temperature of the Local Control rooms in the GIS halls. But in price Schdule there is no such line item in avaiable. Please clarify	Air conditioning for LCR room is not envisage under subject package
3.	J. Section Fire Protection Rev 06 2. New Clause no.2.01.02	SPECIFIC REQUIREMENT'S (SectionProject) C/ENGG/SPEC/SECPROJECT/SPECIFIC REQUIREMENT REV NO 07	Hydrant posts and Fire extinguishers (CO2 and DCP type) shall also be provided for GIS Building also. But in price Schdule there is no such line item in avaiable. Please clarify. We have not considered any hydrant system for Extn of 400kv GIS Building .Please confirm	Bidder's understanding is correct.
4.	'Extension of Kishtwar (GIS) pooling station Sl.No 45	Price Schedule	We have considered only 4.5 kg Co2 Type Portable fire extinguisher as per Price Schedule. We have not considered any other extinguisher. Please confirm	Bidder shall quote as per provision of Bidding document.