

Amendment – 2 to Bidding Documents for “DISMANTLING AND BUYBACK OF DISMANTLED AC SYSTEM, SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF CENTRALISED AIR CONDITIONING SYSTEM AT HVDC RIHAND and HVDC DADRI S/s”

(Specification No.: Package A: 2002000171/OTHERS/DOM/K00 - NR3 RHQ -1 and Package B: 2002000172/OTHERS/DOM/K00 - NR3 RHQ -1)

S. No.	Clause Ref No	Existing Clause/Description	Amended as
1.	Technical Specification, Volume-II of bidding document	Following documents comprise part of Technical Specification - i) i) ‘Scope of work of HVAC Work.pdf’ ii) ‘Drawings of existing AC system.pdf’ iii) AHU Room Layout.pdf iv) Duct Layout Control room.pdf v) Duct layout other area.pdf vi) Equipment and ducting layout.pdf vii) Layout of AC and Ventilation system.pdf	Following documents are added to Technical Specification - 1. Heat Load and design consideration of existing HVAC.pdf 2. Photographs All the above documents are enclosed as Annexure-A to this Amendment-02. Also, as already specified in tender documents, it is complete responsibility of the bidder solely to make himself familiar with the site and site conditions before bidding and undertake a site visit to draw any technical conclusions. Sharing drawings shall in no way relieve the bidder of such responsibility. POWERGRID shall in no way be responsible of any inaccurate conclusions drawn from such drawings.
2.	Item no. 0008 of BoQ on the e-tendering portal (RFx - 2002000171)	MINIMUM 18000 CFM DOUBLE SKIN AHU	Item no. 0020 on e-tendering portal MINIMUM 18000 CMH DOUBLE SKIN AHU
3.	Item no. 0009 of BoQ on the e-tendering portal (RFx - 2002000171)	MINIMUM 28000 CFM DOUBLE SKIN AHU	Item no. 0021 on e-tendering portal MINIMUM 28000 CMH DOUBLE SKIN AHU
4.	Item no. 0007 of BoQ on the e-tendering portal (RFx - 2002000172)	MINIMUM 18000 CFM DOUBLE SKIN AHU	Item no. 0020 on e-tendering portal MINIMUM 18000 CMH DOUBLE SKIN AHU
5.	Item no. 0008 of BoQ on the e-tendering portal (RFx - 2002000172)	MINIMUM 28000 CFM DOUBLE SKIN AHU	Item no. 0021 on e-tendering portal MINIMUM 28000 CMH DOUBLE SKIN AHU

Enclosures -

1. Annexure-A comprising of Heat Load and design consideration of existing HVAC.pdf and Photographs.