



Bid Number/बोली क्रमांक (बिड संख्या):
GEM/2024/B/5243337
Dated/दिनांक : 13-08-2024

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	28-08-2024 11:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	28-08-2024 11:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	180 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Power
Department Name/विभाग का नाम	Power Grid Corporation Of India Limited
Organisation Name/संगठन का नाम	Power Grid Corporation Of India Limited
Office Name/कार्यालय का नाम	Corporate Office Gurgaon
Total Quantity/कुल मात्रा	215
Item Category/मद केटेगरी	ACSR CONDUCTOR - TYPE: ZEBRA (Q3) , ACSR Conductor - Type Moose (Q3)
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	Yes
RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	ACSR CONDUCTOR - TYPE: ZEBRA
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	3 Days

Bid Details/बिड विवरण

Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Estimated Bid Value/अनुमानित बिड मूल्य	94664007
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation

EMD Detail/ईएमडी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
EMD Amount/ईएमडी राशि	1893000

ePBG Detail/ईपीबीजी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	5.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	17

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

Lucknow
Power Grid Corporation of India Ltd., Centralized Procurement Cell, NR-III-RHQ, Plot No 2A/INS02, Awadh Vihar Yojana, Amar Shaheed Path, Lucknow - 226002, Uttar Pradesh
(Cpc)

Splitting/विभाजन

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

Reserved for Make In India products

Reserved for Make In India products	Yes
-------------------------------------	-----

MSE Purchase Preference/एमएसई खरीद वरीयता

1. Bid reserved for Make In India products: : Procurement under this bid is reserved for purchase from Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. However, eligible micro and small enterprises will be allowed to participate. The minimum local content to qualify as a class 1 local supplier is denoted in the bid document. All bidders must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which the bid is liable to be rejected. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020 . In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.

2. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

3. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

4. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

Excel Upload Required/एक्सेल में अपलोड किए जाने की आवश्यकता :

BOQ Price breakup for ACSR Conductor - [1723526048.xlsx](#)

ACSR CONDUCTOR - TYPE: ZEBRA (187 kilometer)

(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Standards	Conformity of the specification for Aluminium conductors for overhead transmission purposes	Generally as per IS : 398 (Part 2) latest and with additional requirement as mentioned below
	ISI Marked (If Yes Select 2 If No select 1)	2, 1 Or higher
	Govt. Organization with which seller is registered	POWERGRID
	Aluminium wires :Properties and characteristics	as per IS:398 (Part 2):1996 latest
	Steel Wire: Properties and characteristics as prescribed for regular strength steel wire	as per IS:398 (Part 2):1996 latest
	Testing and Inspection protocol	as per Annexure-A attached for POWERGRID
	Type Test, Acceptance test, Routine Tests parameters, test methods and requirements	as per Annexure-B attached for POWERGRID
	Packing and marking	as per Annexure C attached for POWERGRID
	Steel Drums for packing of finished conductor	as per Annexure D attached for POWERGRID
	Wooden Drums for packing of finished conductor	as per Annexure E attached for POWERGRID
	Price variation	as per Annexure F attached for POWERGRID
	Agreed to obtain approval of manufacturing quality plan from buyer before commencement of manufacturing and agreed to follow the same	Yes
	All the Annexures attached above are seen and under stood	Yes
Transmission Line Parameters	Voltage rating	765 KV
	Bundle Configuration	Six Conductor
Construction	Shape of conductor	Stranded
	No. of Aluminium wires in conductor (in Nos.)	54

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Aluminium wire diameter, Nominal (in mm)	3.18 (Minimum: 3.16 mm, Maximum: 3.20 mm)
	No.of Steel wires in conductor (in Nos.)	7
	Steel wire diameter, Nominal (in mm)	3.18 (Minimum: 3.12 mm, Maximum: 3.24 mm)
	Steel Core (in Nos.)	1
	No. of of wires on 1st steel layer (in Nos.)	6
	No. of of wires on 1st Aluminium layer (in Nos.)	12
	No. of of wires on 2nd Aluminium layer (in Nos.)	18
Chemical Composition - Aluminium	Minimum Purity of aluminium (in %)	99.5
	Maximum copper content (in %)	0.04
Chemical Composition - Steel wires / Rods	Carbon (in %)	0.50 to 0.85
	Manganese (in %)	0.50 to 1.10
	Phosphorous (in %)	</=0.035
	Sulphur (in %)	</=0.045
	Silicon (in %)	0.10 to 0.35
	Minimum purity of zinc (in %)	99.95
Breaking load	Minimum breaking load of strand: Aluminium: Before stranding (in KN)	1.29
	Minimum breaking load of strand: Aluminium: After stranding (in KN)	1.23
	Minimum breaking load of strand: Steel: Before stranding (in KN)	10.43
	Minimum breaking load of strand: Steel: After stranding (in KN)	9.91
	Method for tensile testing of steel wire	as per IS:1521:1972 latest
Galvanizing	Zinc used for galvanizing shall be electrolyte high grade zinc	as per IS:209:1992 latet

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Methods for testing uniformity of coating of zinc coated articles	as per IS:2633:1986 latest
	Hot-Dipped Galvanized Coatings on Round Steel Wire	as per IS:4826:1979 latest
	Method for determination of mass of zinc coating on zinc coated iron and steel articles	as per IS:6745:1972 latest
	Minimum weight of zinc coating per Sq.mm (in gm)	250
	Minimum number of dips that the galvanised strand can with stand in the standard preece test	2 of one minute and 1 of half minute
	Recommended Practice for Hot-Dip Galvanizing of Iron and Steel	as per IS:2629:1985 latest
	Minimum no. of twists in gauge length equal 100 times the dia., of wire which the strand can withstand in the torsion test (after stranding)	16
Stranded Conductor	Overall diameter (in mm)	28.62
	Sectional area of aluminium (in Sq.mm)	428.9
	Total sectional area (in Sq.mm)	484.5
	Minimum UTS of the conductor (in KN)	130.32
	Maximum DC resistance of the conductor at 20 deg. C (in Ohm/Km)	0.06868
Standard Length	Standard length of the conductor (in m)	2200+/-5% as per Annexure A attached for POWERGRID
	Linear mass of the conductor, Standard (in Kg/Km)	1621 (Minimum: 1589 Kg/Km, Maximum: 1653 Kg/Km)
Lay Length of Outer Steel Wire	Minimum Lay length, 1st Steel layer (in mm)	13 to 18
	Minimum Lay length, 1st Aluminium layer (in mm)	10 to 17
	Minimum Lay length, 2nd Aluminium layer (in mm)	10 to 16

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
JOINTS IN WIRES	Aluminium wires: Individual wires in the inner layers of the finished conductor	Joints permitted (But not more than 4 per conductor length and shall not be closer than 15 meters from joint in the same wire or in any other aluminium wire of the completed conductor
	Aluminium wires: Cold pressure butt welding withstand a stress of	Not less than the breaking strength of individual strand as per relevant IS/IEC specifications
PACKING	Finished Conductor shall be supplied with	Painted steel drum
	Sealing of finished conductor	Both end of the conductor sealed.
	Drums are returnable	96% of total drums returnable
	Protection for conductor against all damage and displacement during transit, storage and subsequent handling and stringing operations in the field	Protected.
	Outer Covering material on the conductor after packing on drums	Covered with Solid Polypropylene sheet with minimum 5mm thickness, Covered wooden lagging with minimum 50 mm thickness
	Supplier shall be responsible for any loss or damage during transportation, handling and storage due to improper packing.	Yes

Additional Specification Parameters - ACSR CONDUCTOR - TYPE: ZEBRA (187 kilometer)

Specification Parameter Name	Bid Requirement (Allowed Values)
ISI Marked (If Yes Select 2 If No select 1)	2 Or higher
POWERGRID Technical specification of ACSR Conductor	The offered conductor should also comply with Parameters of POWERGRID technical Specification (TS) - Section-VIIA Conductor attached in Buyer added ATC as "Annexure TS" . In case of any discrepancy between (i) "GeM golden parameters, Additional specification parameter with Sl. no 1. above, Additional Applicable Specification Document attached in the GeM Bid" and (ii) POWERGRID TS, then POWERGRID technical specification (Section-VIIA Conductor) as attached with Buyer added ATC shall supersede.

* Bidders offering must also comply with the additional specification parameters mentioned above.

Additional Specification Documents/अतिरिक्त विशिष्टि दस्तावेज़

Applicable Specification Document	View
-----------------------------------	----------------------

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Jeethesh S	441206,Power Grid Corporation of India Limited, C/O RP Kawle, Behind Taj Guest House, MSEB Colony, Bramhapuri, Dist: Chandrapur-441206	55	90
2	Sabbavarapu Naveen	496111,Powergrid corporation of India Ltd, Near Tamnar, Village:Bhendra, Raigarh Road,Gharghoda, (Opp. Gharghoda Bypass Point), Dist. Raigarh, Chhattisgarh-496111 "	132	90

ACSR Conductor - Type Moose (28 kilometer)**(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)****Technical Specifications/तकनीकी विशिष्टियाँ**[* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Standards	Conformity of the specification for Aluminium conductors for overhead transmission purposes	Generally as per IS : 398 (Part 5) latest and with additional requirement as mentioned below
	ISI Marked (If "Yes" Select 2 If "No" select 1)	2 Or higher
	Govt. Organization with which seller is registered	POWERGRID
	Aluminium wires :Properties and characteristics	as per IS:398 (Part 5):1996 latest
	Steel Wire: Properties and characteristics as prescribed for regular strength steel wire	as per IS:398 (Part 5):1996 latest
	Testing and Inspection protocol	as per IS:398 (Part 5):1996 latest

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Type Test, Acceptance test, Routine Tests parameters, test methods and requirements	as per Cl. 14 of IS:398 (Part 5):1996 latest
	Packing and marking	as per Section 4 of IS:398 (Part 5):1996 latest, as per Annexure C attached for POWERGRID
	Steel Drums for packing of finished conductor	as per Annexure D attached for POWERGRID
	Wooden Drums for packing of finished conductor	as per Annexure E attached for POWERGRID
	Price variation	as per Annexure F attached for POWERGRID
	Agreed to obtain approval of manufacturing quality plan from buyer before commencement of manufacturing and agreed to follow the same	Yes
	All the Annexures attached above are seen and under stood	Yes
Transmission Line Parameters	Voltage rating	400KV
	Bundle Configuration	Two Conductor, Four Conductor
Construction	Shape of conductor	Stranded
	No. of Aluminium wires in conductor (in Nos.)	54
	Aluminium wire diameter, Nominal (in mm)	3.53 (Minimum: 3.51 mm, Maximum: 3.55 mm)
	No. of Steel wires in conductor (in Nos.)	7
	Steel wire diameter, Nominal (in mm)	3.53 (Minimum: 3.47 mm, Maximum: 3.59 mm)
	Steel Core (in Nos.)	1
	No. of of wires on 1st steel layer (in Nos.)	6
	No. of of wires on 1st Aluminium layer (in Nos.)	12
	No. of of wires on 2nd Aluminium layer (in Nos.)	18
Chemical Composition - Aluminium	Minimum Purity of aluminium (in %)	99.5
	Maximum copper content (in %)	0.04

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Chemical Composition - Steel wires / Rods	Carbon (in %)	0.50 to 0.85
	Manganese (in %)	0.50 to 1.10
	Phosphorous (in %)	</=0.035
	Sulphur (in %)	</=0.045
	Silicon (in %)	0.10 to 0.35
	Minimum purity of zinc (in %)	99.95
Breaking load	Minimum breaking load of strand: Aluminium: Before stranding (in KN)	1.57
	Minimum breaking load of strand: Aluminium: After stranding (in KN)	1.49
	Minimum breaking load of strand: Steel: Before stranding (in KN)	12.86
	Minimum breaking load of strand: Steel: After stranding (in KN)	12.22
	Method for tensile testing of steel wire	as per IS:1521:1972 latest
Galvanizing	Zinc used for galvanizing shall be electrolyte high grade zinc	as per IS:209:1992 latest
	Methods for testing uniformity of coating of zinc coated articles	as per IS:2633:1986 latest
	Hot-Dipped Galvanized Coatings on Round Steel Wire	as per IS:4826:1979 latest
	Method for determination of mass of zinc coating on zinc coated iron and steel articles	as per IS:6745:1972 latest
	Minimum weight of zinc coating per Sq.mm (in gm)	250
	Minimum number of dips that the galvanised strand can with stand in the standard preece test	2 of one minute and 1 of half minute
	Recommended Practice for Hot-Dip Galvanizing of Iron and Steel	as per IS:2629:1985 latest

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Minimum no. of twists in gauge length equal 100 times the dia., of wire which the strand can withstand in the torsion test (after stranding)	16
Stranded Conductor	Overall diameter (in mm)	31.77
	Sectional area of aluminium (in Sq.mm)	528.5
	Total sectional area (in Sq.mm)	597
	Minimum UTS of the conductor (in KN)	161.2
	Maximum DC resistance of the conductor at 20 deg. C (in Ohm/Km)	0.05552
Standard Length	Standard length of the conductor (in m)	2100+/-5% as per Annexure A attached for POWERGRID
	Linear mass of the conductor, Standard (in Kg/Km)	2004 (Minimum: 1969 Kg/Km, Maximum: 2040 Kg/Km)
Lay Length of Outer Steel Wire	Minimum Lay length, 1st Steel layer (in mm)	16 to 18
	Minimum Lay length, 1st Aluminium layer (in mm)	12 to 14
	Minimum Lay length, 2nd Aluminium layer (in mm)	11 to 13
JOINTS IN WIRES	Aluminium wires: Individual wires in the inner layers of the finished conductor	Joints permitted (But not more than 4 per conductor length and shall not be closer than 15 meters from joint in the same wire or in any other aluminium wire of the completed conductor.)
	Aluminium wires: Cold pressure butt welding withstand a stress of	Not less than the breaking strength of individual strand as per relevant IS/IEC specifications
PACKING	Finished Conductor shall be supplied with	Painted steel drum
	Sealing of finished conductor	Both end of the conductor to be sealed.
	Drums are returnable	96% of total drums returnable
	Protection for conductor against all damage and displacement during transit, storage and subsequent handling and stringing operations in the field	Protected

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Outer Covering material on the conductor after packing on drums	Covered with Solid Polypropylene sheet with minimum 5mm thickness
	Supplier shall be responsible for any loss or damage during transportation, handling and storage due to improper packing.	Yes

Additional Specification Parameters - ACSR Conductor - Type Moose (28 kilometer)

Specification Parameter Name	Bid Requirement (Allowed Values)
Packing and marking	as per Section 4 of IS:398 (Part 5):1996 latest,
Bundle Configuration	Two Conductor
POWERGRID Technical specification of ACSR Conductor	The offered conductor should also comply with Parameters of POWERGRID technical Specification (TS) - Section-VIIA Conductor attached in Buyer added ATC as "Annexure TS" . In case of any discrepancy between (i) "GeM golden parameters, Additional specification parameter with Sl. no 1,2 above, Additional Applicable Specification Document attached in the GeM Bid" and (ii) POWERGRID TS, then POWERGRID technical specification (Section-VIIA Conductor) as attached with Buyer added ATC shall supersede.

* Bidders offering must also comply with the additional specification parameters mentioned above.

Additional Specification Documents/अतिरिक्त विशिष्टि दस्तावेज़

Applicable Specification Document	View
-----------------------------------	----------------------

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Jeethesh S	441206,Power Grid Corporation of India Limited, C/O RP Kawle, Behind Taj Guest House, MSEB Colony, Bramhapuri, Dist: Chandrapur-441206	28	90

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Forms of EMD and PBG

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

Power Grid Corporation of India Limited
payable at
Lucknow

Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

2. Forms of EMD and PBG

Bidders can also submit the EMD with Banker's Cheque in favour of

Power Grid Corporation of India Limited
payable at
Lucknow

Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

3. Generic

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

4. Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- a. Copy of PAN Card.
- b. Copy of GSTIN.
- c. Copy of Cancelled Cheque.
- d. Copy of EFT Mandate duly certified by Bank.

5. Generic

Manufacturer Authorization: Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

6. Scope of Supply

Scope of supply (Bid price to include all cost components) : Only supply of Goods

7. Generic

Supplier shall ensure that the Invoice is raised in the name of Consignee with GSTIN of Consignee only.

8. Generic

Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller,

if:

- i) The Seller fails to comply with any material term of the Contract.
- ii) The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent.
- iii) The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period and/or to replace/rectify any rejected or defective Material(s) promptly.
- iv) The Seller becomes bankrupt or goes into liquidation.
- v) The Seller makes a general assignment for the benefit of creditors.
- vi) A receiver is appointed for any substantial property owned by the Seller.
- vii) The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.

9. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

10. **Purchase Preference (Centre)**

Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.

11. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

12. **Generic**

Buyer Organization specific Integrity Pact shall have to be complied by all bidders. Bidders shall have to upload scanned copy of signed integrity pact as per Buyer organizations policy along with bid. [Click here to view the file](#)

13. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

“Supply of ACSR Zebra Conductor and ACSR Moose Conductor for various Consultancy work in Western Region-I, POWERGRID”.

Specification. No.: NCN0023

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent

Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---