

Package Name	Residual Life assessment of 220 KV D/C Bairasuil – Pong Transmission Line.
Package No.	N2JM/C&M/CS/35(23)
Specification utility Number	NR2/NT/S-MISC/DOM/J01/23/01884

Corrigendum No. 1**to the Invitation For Bids (IFB)/RfX Number : 5006004355**

S.No	Query	PGCIL's Reply
1	As per the Technical Specification it is written that there will be Rebound Hammer Test of 72 Points on one Leg of individual tower. In S.No. 5 of detailed modalities it has been mentioned that 6 No. of points of observation shall be taken of each Grid of 300 mm x 300 mm. We would like to draw to your attention towards the Clause 6.4 of IS: 516 Part-5 Section-4 where it is clearly written that around each point of observation there will be 6 Rebound hammer test and average of these 6 will be considered as one reading as per your technical specification. Please Clarify whether you are considering 6 reading as individual reading. Hence individual reading means average of 6 reading as mentioned in clause 6.4 of IS: 516 Part-5 Section-4.	In the Technical Specifications (TS) attached as part of Volume-II with the tender documents, it has been clearly mentioned in S no 1 (specifications for Rebound Hammer test) that there will be twelve grids in total for each leg and further 06 nos. of points of rebound hammer observations are to be taken per grid (making 72 points of rebound hammer points of observations or readings per leg). Therefore, whether we do average of six readings taken in a single grid and call this average of six readings an individual reading would not change the scope as the scope of work speaks about 72 points of rebound hammer points of observations or readings in total as per the TS.
2	Further in SCC at serial no. 16 we do not agree with this clause terms and conditions hence it should be deleted	In the Cl. 16 of SCC attached as part of Volume-I in the tender documents, it has been clearly mentioned in the last sub-para that, "Contract Performance Guarantee and Additional Performance Guarantee shall not be applicable to this package". Therefore, the Cl. 16 of SCC is self-explanatory vis a vis the query raised
3	The GCC and SCC framed are not in accordance with intended service requirement hence it should be amended as per service requirement.	GCC and SCC which are part of the bidding documents shall remain applicable without any amendment.
4	For the work as defined in the Technical Specification and bill of material there will	Excavation (excavation is understood to include providing surface for testing to the

For Web-Uploading

	be requirement of 3-4 Labour at each site of work to execute the test in accordance with scope of work hence Labour has to be provide by PGCIL	contractor) and Backfilling has been included in the scope of work of POWERGRID and as such the labour requirement for only these two activities (excavation and backfilling) are to be provided by POWERGRID.
5	Excavation of foundation, preparation of surface, Provision of necessary scaffolding, Water & Electricity will be in the scope of PGCIL	Except excavation and backfilling, all other activities including transportation/lodging of the men/material/machinery required for tests are all to be arranged by the contractor as per the scope of work
6	Appendix I of SCC regarding Environmental Management Plan are also not applicable to us, please delete this clause.	Appendix -I to SCC attached in Volume-I of tender documents shall remain applicable in this work package.