| | SPECIAL CONDITIONS (Refer Sr. No. 15 of notesheet) |
|---|---|
| **Sr.No.** | **Conditions** |
| 1 | The agency should have at least one civil engineer on his pay roll, having experience of atleast 03 yrs. of civil sites. Necessary proof to be given with EPF compliance. |
| 2 | One civil engineer having experience of minimum 03 years to be depolyed for the full duration of the contract till the handing over of the site. |
| 3 | Minimum T&P to be brought at the time of start of work i.e. 10 wire brushes, 200 nos. emery papers for scrapping , cloth hand gloves 10 pairs , eye goggles 10 pairs , safety shoes 10 pairs , First Aid Box ( 01 nos) having standard medicines, cotton waste (cloth) for cleaning of FFPL (fire fightening pipe line) etc. |
| 4 | Consumption of paint will be verified as per CPWD DAR-2021. Asian paint -Apcolite (prmium enamel paint ) OR Berger -equivalent paint to be used. |
| 5 | Rust remover chemical to be used for fencing angles only. Consumption of Qty. will be verified as per Brochure of the chemical. Subsequently application of Primer and two coats of SEP. |
| 6 | Fire fightening pipes to be painted with SEP of one or more coat item. Scrapping and Cleaning pipes with emery papers and removing all dust and foreign particles with cotton cloth etc. |
| 7 | Fire fightening pipes : wherever corrossion has started , only that portion to be scrapped with emery papers, wire brush and cleaning the puipes with cotton cloth and then aaplication of primer etc. and two coats of SEP . |
| | |