

Amendment No.-II dated 23.06.2025 to the Bidding Documents for AIS Bay extension works (SS-02)

i) Under NERES-XXIII

a) Extension of 132kV Pasighat (DoP, Arunachal Pradesh) S/s.

b) Extension 132kV Roing (POWERGRID) S/s.

c) Extension 132kV Tezu (POWERGRID) S/s.

d) Extension of 132kV Namsai (POWERGRID) S/s

ii) Under NERES-29A

a) Installation of new 1x50MVA, 132/33kV (3rd) ICT at Namsai (POWERGRID) S/s

(Specification No. NER/NT/W-AIS/DOM/H00/25/08534)

| S No. | Volume/ Section/ Clause No. | Existing Provision/ Bidder's Queries | Amended as/ POWERGRID's Reply |
|--------------|-----------------------------------------------------|-------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Volume III- First Envelope Attachments and Bid Form | Existing Provision: a) Attach 12- (Price Adjustment Data) "The Prices are Firm and Fixed" | Amended as New Documents: a) Attach 12- (Price Adjustment Data) "As per Appendix-2 of Sample forms and procedure" Note: Corrected First Envelope Attachments and Bid Form is uploaded in the tender. Bidders are kindly requested to |

| | | | |
|---|------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| | | | submit their offer in the correct First Envelope Attachments and Bid Form. |
| 2 | Volume II- Price_Schedule | <p>Bidder's Queries: <i>Please refer the Civil BOQ part for Namsai, Pasighat, Roing & Tezu wherein the following item Unit is differently mentioned in all the respective sites BOQ.</i> <i>"Providing & Laying non-woven Geosynthetics fabric of minimum 200 GSM in separation layer between sub-grade and stone spreading in switchyard as per technical specification and direction of Engineer in Charge."</i></p> <ol style="list-style-type: none"> 1) 1. Namsai Transformer Bay - M2. 2) 2. Namsai Line Bay - M3. 3) 3. Pasighat - M2. 4) 4. Roing - M3. 5) 5. Tezu - M2. | <p>POWERGRID's Reply: The Unit shall be "M2" for the line item "Providing & Laying non-woven Geosynthetics fabric of minimum 200 GSM in separation layer between sub-grade and stone spreading in switchyard as per technical specification and direction of Engineer in Charge." (Approved BOQ attached in local reference Dated 30.07.2025)</p> <ol style="list-style-type: none"> 1) Namsai Transformer Bay - M2. 2) Namsai Line Bay - M2. 3) Pasighat - M2. 4) Roing - M2. 5) Tezu - M2. <p>Note: Corrected Price_Schedule is uploaded in the tender. Bidders are kindly requested to submit their offer in the correct Price_Schedule.</p> |