

L&T CONSTRUCTION, PT&D IC																	
OWNER: POWER GRID CORPORATION OF INDIA LTD.																	
PROJECT: TRANSMISSION LINE TOWER PACKAGE FOR TW26 FOR 132KV S/C LINE (ON D/C TOWER) UNDER COMPREHENSIVE SCHEME FOR STRENGTHENING OF TRANSMISSION & DISTRIBUTION SYSTEM IN NER & SIKKIM: INTRA-STATE: ARUNACHAL PRADESH															O21002-T-11-45-TS		DATE
LINE: 1. 132KV S/C (on D/C tower) Yingkong - Tuting (Route length: 125km)															Prepared		Checked
TITLE: TOWER SCHEDULE FROM DE TO AP239															AY		TRAMS
SLNo	Loc. No.	Type of Tower	RAISED CHIMNEY/BENCHING	Easting X (m)	Northing Y (m)	Elevation Z (m)	Deviation Angle (Deg)	Span (m)	Section Length (m)	Wind Span (m)	Weight Span in Mtr (Cold)			Weight Span in Mtr (Hot)			Remarks & Crossings.
											Left	Right	Total	Left	Right	Total	
1	DEAD END	DD+25		697203.14	3173892.05	462.67	3° 10' 15" RT			87.71	0.00	189.00	189.00	0.00	134.00	134.00	
								175.42	175.42								ROAD
2	AP1	DD+18		697134.73	3174053.58	463.62	43° 24' 44" RT			158.67	-12.00	-152.00	-164.00	44.00	-17.00	27.00	
								141.92	141.92								
3	AP2	DBN+3		697184.33	3174186.54	489.54	14° 2' 24" LT			145.56	296.00	-678.00	-382.00	161.00	-224.00	-63.00	STRENGTHENING CHECK REQUIRED
								149.20	149.20								ROAD
4	AP3	DD+3		697201.01	3174334.81	528.46	43° 4' 2" LT			174.69	830.00	-1279.00	-449.00	376.00	-532.00	-156.00	STRENGTHENING CHECK REQUIRED
								200.16	200.16								
5	AP3A	DBN+9		697081.54	3174495.41	630.41	5° 43' 2" LT			271.10	1504.00	-456.00	1048.00	757.00	-233.00	524.00	STRENGTHENING CHECK REQUIRED
								342.03	342.03								
6	AP4	DC+18		696851.06	3174748.12	702.46	11° 22' 27" LT			291.74	807.00	-333.00	474.00	585.00	-120.00	465.00	STRENGTHENING CHECK REQUIRED
								241.44	241.44								
7	AP5	DBN+9		696656.38	3174890.92	749.25	4° 0' 49" RT			186.51	577.00	-520.00	57.00	364.00	-153.00	211.00	
								131.58	131.58								
8	AP5A	DBN+9		696555.99	3174975.98	776.06				120.32	655.00	640.00	1295.00	287.00	250.00	537.00	STRENGTHENING CHECK REQUIRED
								109.07	109.07								
9	AP6	DBN+9		696472.78	3175046.48	754.02	0° 36' 51" RT			220.23	-528.00	1037.00	509.00	-139.00	720.00	581.00	STRENGTHENING CHECK REQUIRED
								331.39	331.39								
10	AP7	DC+9	1.5	696222.26	3175263.40	644.36	17° 52' 58" LT			325.01	-689.00	1265.00	576.00	-372.00	846.00	474.00	STRENGTHENING CHECK REQUIRED
								318.63	318.63								
11	AP8	DD+9		695928.96	3175387.93	512.19	42° 28' 11" RT			371.29	-919.00	339.00	-590.00	-499.00	312.00	-187.00	STRENGTHENING CHECK REQUIRED
								423.93	423.93								NALA
12	AP9	DD+9		695752.99	3175773.62	485.87	42° 41' 29" LT			355.84	87.00	-574.00	-487.00	114.00	-270.00	-156.00	
								287.74	287.74								ROAD, POND
13	AP10	DD+18	1.5	695487.70	3175885.04	547.74	25° 41' 55" LT			219.36	868.00	-704.00	164.00	564.00	-237.00	327.00	
								150.97	150.97								

SKS
(L&T L&T)

राकेश चिल्का RAKESH CHILKA
उप प्रबंधक / DY MANAGER
शक्ति संचयन विभाग POWER GRID YINGKONG
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार का उद्योग)

ज्योत्सोम देव JYOTSMOY DEV
DEPUTY GENERAL MANAGER
POWERGRID, YINGKONG, A.P.
(Government of India Enterprise)

14	AP11	DC-9	1.5	693336.93	3175877.37	596.25	22° 24' 43" RT		188.01	860.00	151.00	799.00	394.00	22.00	172.00	STRENGTHENING CHECK REQUIRED
								223.04	223.04							
15	AP12	DC-9		693124.79	3175992.48	626.25	17° 33' 33" RT		223.86	378.00	64.00	442.00	256.00	88.00	138.00	
								222.67	222.67							
16	AP13	DC-9		694047.09	3176086.66	623.86	16° 8' 27" RT		245.68	160.00	167.00	327.00	137.00	153.00	290.00	
								268.69	268.69							
17	AP14	DC-18		694786.13	3176301.80	611.87	10° 6' 40" LT		218.45	102.00	-192.00	-90.00	116.00	-36.00	80.00	
								168.21	168.21							
18	AP15	DC-25	1.5	694663.28	3176416.70	619.16	3° 39' 31" RT		212.10	360.00	25.00	385.00	205.00	72.00	277.00	
								255.98	255.98							
19	AP16	DC-18	3	694487.87	3176603.13	633.62	8° 50' 39" RT		257.66	231.00	294.00	525.00	185.00	221.00	406.00	
								259.34	259.34							
20	AP17	DBN-9		694341.32	3176817.09	631.19	0° 34' 40" RT		248.26	-34.00	69.00	35.00	40.00	92.00	132.00	
								237.18	237.18							
21	AP18	DBN-9		694209.26	3177014.10	635.16	10° 11' 47" LT		284.10	168.00	-151.00	17.00	145.00	-34.00	111.00	
								331.02	331.02							CART TRACK, NALA
22	AP19	DC-18		693979.19	3177252.10	663.71	17° 4' 40" LT		251.10	483.00	1396.00	1879.00	367.00	648.00	1015.00	STRENGTHENING CHECK REQUIRED
								171.17	171.17							
23	AP20	DBN-9		693829.33	3177334.81	587.64	5° 8' 13" RT		233.06	-1205.00	432.00	-773.00	-458.00	315.00	-142.00	STRENGTHENING CHECK REQUIRED
								294.95	294.95							
24	AP21	DBN-3		693584.89	3177499.87	565.05	14° 35' 28" RT		255.91	-135.00	188.00	53.00	-19.00	149.00	130.00	
								216.86	216.86							
25	AP22	DBN-3		693441.54	3177662.59	559.18	9° 53' 25" LT		251.01	29.00	532.00	561.00	69.00	369.00	438.00	
								285.16	285.16							
26	AP23	DBN-9		693219.08	3177841.00	515.22	2° 18' 60" RT		260.36	-245.00	189.00	-56.00	-81.00	155.00	74.00	
								235.56	235.56							
27	AP24	DBN-6		693041.43	3177995.69	512.54	1° 7' 12" LT		273.96	47.00	270.00	317.00	81.00	226.00	307.00	
								312.35	312.35							
28	AP25	DD-6		692801.90	3178196.16	500.56	51° 5' 22" RT		252.79	45.00	367.00	412.00	89.00	226.00	315.00	
								193.22	193.22							
29	AP26	DC-3		692805.33	3178389.35	485.68	21° 16' 5" LT		284.37	-172.00	182.00	10.00	-30.00	183.00	153.00	
								375.51	375.51							NALA
30	AP27	DD-6		692675.35	3178741.64	483.34	56° 5' 36" LT		261.47	190.00	244.00	434.00	189.00	141.00	330.00	
								147.42	147.42							

Sumit
(SKS)
(L&T Ltd)

राकेश चिल्का
रूप प्रबन्धक / DY MANAGER
पॉवरग्रिड यिङ्कियॉङ्ग
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार का उद्यम)

JYOTIRMOY DEV
DEPUTY GENERAL MANAGER
POWERGRID, YINGKIONG A.P.
(Government of India Enterprise)

31	AP28	DBN+0		692532.10	3178776.45	481.00	4' 27' 56"LT			194.65	-99.00	-545.00	-644.00	4.00	-231.00	-227.00	
								241.87	241.87								
32	AP29	DBN+6		692293.33	3178815.08	531.54	5' 12' 59"LT			234.09	793.00	182.00	975.00	479.00	149.00	128.00	STRENGTHENING CHECK REQUIRED DUE TO ONE SIDE WT. SPAN VIOLATION
								226.30	226.30								CART TRACK
33	AP30	DC+9		692067.58	3178830.76	523.28	14' 2' 6"RT			360.77	45.00	461.00	506.00	78.00	431.00	509.00	
								495.24	495.24								CART TRACK
34	AP31	DD+3		691596.60	3178983.86	470.72	30' 8' 52"RT			363.40	41.00	948.00	909.00	72.00	552.00	624.00	STRENGTHENING CHECK REQUIRED
								231.56	231.56								
35	AP32	DBN+0		691444.09	3179158.11	404.93	14' 57' 28"RT			222.89	-705.00	94.00	-611.00	-308.00	100.00	-208.00	STRENGTHENING CHECK REQUIRED
								214.21	214.21								
36	AP33	DC+0		691349.39	3179350.25	405.90	20' 23' 3"LT			229.80	121.00	-56.00	65.00	114.00	27.00	141.00	
								245.39	245.39								
37	AP34	DBN+3		691171.04	3179518.79	417.72	9' 8' 56"RT			231.40	301.00	-497.00	-196.00	219.00	-194.00	25.00	
								217.40	217.40								
38	AP35	DC+6		691038.78	3179691.33	460.64	16' 51' 23"LT			340.60	719.00	256.00	975.00	416.00	252.00	668.00	STRENGTHENING CHECK REQUIRED
								463.80	463.80								
39	AP36	DBN+0		690662.01	3179961.79	460.86	3' 47' 52"RT			354.12	209.00	-82.00	127.00	213.00	13.00	226.00	
								244.44	244.44								
40	AP37	DBN+9	3	690473.32	3180117.17	465.91	14' 49' 18"RT			246.84	328.00	-500.00	-172.00	233.00	-211.00	22.00	
								249.24	249.24								
41	AP38	DC+9		690327.84	3180319.55	523.41	27' 6' 11"LT			250.85	755.00	373.00	1128.00	466.00	261.00	727.00	STRENGTHENING CHECK REQUIRED
								252.45	252.45								
42	AP39	DD+9		690103.29	3180434.90	502.24	31' 33' 51"RT			175.37	-119.00	-63.00	-182.00	-7.00	14.00	7.00	
								98.29	98.29								
43	AP39A	DBN+0		690052.30	3180518.94	515.06				124.22	163.00	980.00	1143.00	86.00	436.00	522.00	STRENGTHENING CHECK REQUIRED
								150.15	150.15								
44	AP40	DD+9		689974.41	3180647.31	458.35	52' 26' 41"LT			188.33	-825.00	-202.00	-1027.00	-281.00	-49.00	-330.00	
								226.50	226.50								NALA
45	AP41	DC+3		689749.29	3180672.19	488.61	29' 43' 31"RT			254.82	429.00	-649.00	-220.00	275.00	-313.00	-38.00	STRENGTHENING CHECK REQUIRED
								283.14	283.14								
46	AP42	DD+18		689520.32	3180838.75	554.74	26' 58' 35"RT			240.96	946.00	-455.00	491.00	611.00	-165.00	446.00	STRENGTHENING CHECK REQUIRED
								198.78	198.78								
47	AP42a	DBN+9		689430.11	3181015.88	602.34				168.43	659.00	422.00	1081.00	369.00	207.00	576.00	STRENGTHENING CHECK REQUIRED
								138.08	138.08								

Sushil
(SKS)
(L&T Ltd)

रकेश चिल्का / RAKESH CHILKA
उप प्रबंधक / DY MANAGER
पावरग्रिड विभाग / POWERGRID YINKIONG
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार का उद्यम)

सुरमोय देव / SURMOY DEV
DEPUTY GENERAL MANAGER
POWERGRID, YINKIONG, A.P.
(Government of India Enterprise)

48	AP43	DC+18		689367.44	3181138.92	576.11	17° 51' 15" RT		195.98	-282.00	-30.00	-312.00	-67.00	41.00	-26.00	
								253.88	253.88							
49	AP44	DD+3		689327.13	3181389.58	605.07	47° 10' 50" LT		262.81	283.00	255.00	538.00	212.00	202.00	414.00	
								271.73	271.73							NALA
50	AP45	DD+9		689101.02	3181540.29	588.06	34° 53' 51" LT		215.65	13.00	34.00	47.00	66.00	60.00	126.00	
								159.56	159.56							LAND BOUNDARY
51	AP46	DD+6		688941.50	3181536.90	593.37	44° 14' 31" LT		179.26	122.00	-542.00	-420.00	96.00	-204.00	-108.00	
								198.96	198.96							
52	AP46A	DBN+0		688801.94	3181395.11	643.48			177.73	744.00	-52.00	692.00	406.00	24.00	430.00	STRENGTHENING CHECK REQUIRED
								156.51	156.51							
53	AP47	DC+18		688692.15	3181283.56	632.44	21° 8' 50" RT		152.55	209.00	1277.00	1486.00	134.00	554.00	688.00	STRENGTHENING CHECK REQUIRED
								148.60	148.60							
54	AP48	DC+25		688556.73	3181222.39	558.13	22° 30' 15" RT		240.17	-1112.00	602.00	-510.00	-390.00	446.00	56.00	STRENGTHENING CHECK REQUIRED
								331.73	331.73							
55	AP49	DD+18		688225.17	3181211.94	512.46	24° 20' 15" RT		288.86	-264.00	-94.00	-358.00	-107.00	6.00	-101.00	
								245.99	245.99							
56	AP49A	DBN+3		687997.96	3181306.21	545.79			191.35	342.00	203.00	545.00	242.00	120.00	362.00	
								136.72	136.72							
57	AP50	DC+18		687871.68	3181358.60	524.58	5° 44' 59" RT		234.06	-66.00	618.00	552.00	17.00	454.00	471.00	STRENGTHENING CHECK REQUIRED
								331.41	331.41							
58	AP51	DC+18		687579.84	3181515.63	470.48	18° 28' 18" RT		165.71	-281.00	164.00	-117.00	-117.00	162.00	45.00	
								318.94	318.94							
59	AP52	DBN+9	1.5	687361.33	3181747.95	477.49	8° 57' 59" LT		262.12	155.00	523.00	678.00	157.00	309.00	466.00	
								205.30	205.30							
60	AP53	DC+9		687199.09	3181873.75	449.18	22° 8' 28" RT		205.06	-316.00	-2.00	-318.00	-101.00	52.00	-49.00	
								204.82	204.82							
61	AP54	DBN+9	3	687096.46	3182051.00	453.47	6° 53' 9" LT		241.74	208.00	135.00	343.00	154.00	137.00	291.00	
								278.66	278.66							
62	AP55	DC+18		686928.93	3182273.68	447.87	7° 9' 47" LT		231.88	143.00	141.00	284.00	142.00	115.00	257.00	
								185.09	185.09							FENCING
63	AP56	DC+18		686800.08	3182406.55	444.86	2° 9' 54" LT		278.25	44.00	125.00	169.00	70.00	143.00	213.00	
								371.40	371.40							
64	AP57	DC+9		686531.64	3182663.22	463.36	24° 56' 14" LT		309.24	246.00	424.00	670.00	229.00	286.00	515.00	
								247.07	247.07							

Sumit
(SKS)
(LAT LK)

राकेश चिल्का RAKESH CHILKA
उप प्रबंधक / DY MANAGER
पॉवरग्रिड यिंगकिंग POWERGRID YINGKIONG
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार का उद्यम)

JYOTIRMOY DEV
DEPUTY GENERAL MANAGER
POWERGRID, YINGKIONG, A.P.
(Government of India Enterprise)

65	AP58	DC+9	1.5	686297.72	3182742.76	436.00	22° 37' 13" RT			308.67	-176.00	11.00	-45.00	-37.00	133.00	96.00	
								370.26	370.26								
66	AP59	DBN+9		686019.98	3182987.61	449.85	5° 41' 59" LT			326.70	261.00	254.00	515.00	239.00	207.00	446.00	
								283.14	283.14								
67	AP60	DC+18		685790.04	3183152.83	430.08	3° 24' 49" RT			258.57	23.00	399.00	428.00	77.00	266.00	349.00	
								234.00	234.00								
68	AP61	DD+25		685608.40	3183300.45	400.60	15° 24' 27" RT			248.16	-163.00	-464.00	-627.00	-29.00	-197.00	-226.00	
								262.31	262.31								
69	AP62	DD+3		685456.23	3183514.06	476.97	38° 40' 2" LT			299.15	731.00	848.00	1579.00	465.00	603.00	1068.00	STRENGTHENING CHECK REQUIRED
								335.99	335.99								
70	AP63	DBN+9		685133.02	3183605.84	387.09	4° 41' 49" RT			314.87	-503.00	-184.00	-687.00	-258.00	-48.00	-306.00	
								293.74	293.74								
71	AP64	DBN+9	1.5	684857.96	3183708.95	418.97	0° 35' 30" LT			278.35	480.00	-602.00	-122.00	344.00	-273.00	71.00	
								262.95	262.95								
72	AP65	DD+3		684610.80	3183798.71	494.50	39° 41' 13" LT			294.08	872.00	843.00	1713.00	543.00	586.00	1129.00	STRENGTHENING CHECK REQUIRED
								325.21	325.21								
73	AP66	DD+0		684304.69	3183688.93	418.95	32° 49' 37" LT			309.94	-512.00	211.00	-301.00	-254.00	184.00	-70.00	
								294.66	294.66								NALA
74	AP67	DC+0		684125.54	3183454.99	412.55	23° 12' 26" LT			289.06	81.00	153.00	234.00	108.00	149.00	257.00	
								283.46	283.46								
75	AP68	DD+0		684055.82	3183180.24	411.50	49° 11' 44" RT			283.97	131.00	152.00	283.00	136.00	148.00	284.00	
								284.49	284.49								
76	AP69	DBN+0		683801.38	3183053.00	410.70	4° 45' 4" LT			270.10	135.00	-70.00	65.00	139.00	20.00	159.00	
								255.71	255.71								NALA
77	AP70	DBN+6		683582.93	3182920.09	421.85	1° 54' 7" LT			249.43	326.00	-851.00	-525.00	237.00	-389.00	-152.00	STRENGTHENING CHECK REQUIRED
								243.14	243.14								
78	AP71	DC+6		683379.52	3182786.88	508.21	18° 59' 35" LT			286.66	1108.00	436.00	1544.00	547.00	337.00	584.00	STRENGTHENING CHECK REQUIRED
								330.17	330.17								
79	AP72	DBN+9	3	683177.22	3182525.95	470.15	10° 17' 57" RT			297.35	-105.00	674.00	569.00	-6.00	436.00	430.00	STRENGTHENING CHECK REQUIRED
								264.53	264.53								ROAD, CART TRACK, 33KV LINE
80	AP73	DD+25		682980.37	3182349.24	407.45	24° 32' 44" LT			507.73	-406.00	303.00	-103.00	-167.00	306.00	139.00	STRENGTHENING CHECK REQUIRED
								750.92	750.92								BRAHAMAPUTRA RIVER
81	AP74	DD+25		682680.46	3181660.81	454.02	58° 26' 15" RT			629.18	463.00	-38.00	425.00	460.00	-12.00	448.00	STRENGTHENING CHECK REQUIRED
								507.42	507.42								River, GROUND CLEARANCE VIOLATION

Sush
(SKS)

(2 & T Ltd)

राकेश चिल्का RAKESH CHILKA
रथ प्रबन्धक / DY MANAGER
पावरग्रिड यिङ्किंग POWERGRID YINGKIONG
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार का उद्यम)

JYOTIRMOY DEV
DEPUTY GENERAL MANAGER
POWERGRID, YINGKIONG, A.P.
(Government of India Enterprise)

82	AP75	DD+18	3	682178.00	3181590.00	580	45° 13' 35" RT		313.67	568.00	1330.00	-762.00	543.00	-405.00	138.00	STRENGTHENING CHECK REQUIRED
								119.90	119.90							
83	AP-76	DD+25		682082.50	3181662.50	643.70	13° 50' 23" RT		211.05	1443.00	369.00	1812.00	540.00	286.00	826.00	STRENGTHENING CHECK REQUIRED
								302.20	302.20							
84	AP-77	DBN+6		681892.50	3181897.50	638.21	9° 51' 30" LT		257.40	-65.00	-478.00	-543.00	18.00	-181.00	-163.00	
								212.60	212.60							
85	AP-78	DC+6		681732.50	3182037.50	681.30	16° 29' 1" LT		243.89	694.00	-286.00	408.00	398.00	-105.00	293.00	STRENGTHENING CHECK REQUIRED
								275.18	275.18							
86	AP-79	DD+9		681482.50	3182152.50	719.63	35° 29' 0" RT		394.03	565.00	293.00	858.00	384.00	291.00	675.00	
								512.88	512.88							CANAL, BT ROAD
87	AP-80	DD+9		681227.50	3182597.50	707.18	48° 59' 36" RT		378.20	227.00	-846.00	-619.00	230.00	-399.00	-168.00	
								243.52	243.52							
88	AP-81	DD+0		681307.50	3182827.50	808.56	22° 33' 2" RT		245.70	1110.00	980.00	2090.00	662.00	594.00	1256.00	STRENGTHENING CHECK REQUIRED
								247.89	247.89							
89	AP-82	DD+9		681472.50	3183012.50	719.75	45° 44' 1" LT		374.56	-721.00	-115.00	-836.00	-334.00	-75.00	-409.00	
								501.22	501.22							
90	AP-83	DD+25		681437.50	3183512.50	834.35	45° 26' 58" LT		505.59	632.00	430.00	1062.00	592.00	413.00	1005.00	STRENGTHENING CHECK REQUIRED
								509.95	509.95							
91	AP-84	DD+9		681050.00	3183844.00	788.80	50° 19' 59" RT		499.25	87.00	-155.00	-68.00	104.00	-105.00	-2.00	STRENGTHENING CHECK REQUIRED
								488.56	488.56							
92	AP-85	DD+9		681057.50	3184332.50	924.10	20° 39' 7" LT		366.22	665.00	911.00	1576.00	617.00	544.00	1161.00	STRENGTHENING CHECK REQUIRED
								243.88	243.88							
93	AP-86	DBN+9	3	680975.00	3184562.00	853.12	11° 47' 55" RT		329.19	-659.00	-133.00	-792.00	-291.00	-66.00	-357.00	STRENGTHENING CHECK REQUIRED
								414.51	414.51							CANAL
94	AP-87	DD+0		680917.50	3184972.50	944.83	42° 8' 0" RT		291.85	558.00	-1225.00	-667.00	492.00	-479.00	13.00	STRENGTHENING CHECK REQUIRED
								169.19	169.19							
95	AP-88	DD+6_1000M		681012.50	3185112.50	1036.28	27° 46' 4" RT		212.09	1424.00	589.00	2013.00	678.00	381.00	1059.00	STRENGTHENING CHECK REQUIRED
								255.00	255.00							
96	AP-89	DC+9		681237.50	3185232.50	993.08	28° 50' 34" LT		324.43	-330.00	-94.00	-424.00	-123.00	-27.00	-150.00	
								393.86	393.86							
97	AP-90	DD+18_1000M		681452.50	3185562.50	1042.12	55° 15' 4" LT		269.82	489.00	799.00	1288.00	422.00	356.00	778.00	STRENGTHENING CHECK REQUIRED
								145.77	145.77							
98	AP-91	DC+0		681397.50	3185697.50	1024.23	29° 23' 52" LT		202.79	-652.00	-383.00	-1035.00	-210.00	-152.00	-362.00	STRENGTHENING CHECK REQUIRED
								259.80	259.80							
99	AP-92	DBN+6_1000M		681194.00	3185859.00	1063.96	2° 6' 48" LT		286.91	645.00	-730.00	-85.00	415.00	-378.00	37.00	STRENGTHENING CHECK REQUIRED
								314.01	314.01							
100	AP-93	DD+6_1000M	1.5	680941.00	3186045.00	1163.91	34° 47' 42" LT		269.55	1058.00	-50.00	1008.00	706.00	29.00	735.00	STRENGTHENING CHECK REQUIRED

Sunilk
(SKS)
(L&T Ltd)

रकेश चिल्का RAKESH CHILKA
उप प्रबंधक / DY MANAGER
पावरग्रिड यिंगकिंग POWERGRID YINGKIONG
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार का अधीन)

JYOTIRMOY DEV
DEPUTY GENERAL MANAGER
POWERGRID, YINGKIONG, A.P.
(Government of India Enterprise)

								225.08	225.08										
101	AP-94	DBN+6_1000M		680716.00	3186051.00	1177.74	9° 13' 13" RT			222.47	275.00	537.00	812.00	195.00	328.00	523.00			
								219.86	219.86										
102	AP-95	DD+3_1000M		680500.00	3186092.00	1148.34	24° 25' 59" RT			184.56	-313.00	778.00	465.00	-104.00	362.00	258.00			
								149.27	149.27										
103	AP-96	DBN+3_1000M		680378.00	3186178.00	1111.10	8° 39' 15" RT			178.95	-623.00	-439.00	-1062.00	-206.00	-162.00	-368.00			STRENGTHENING CHECK REQUIRED
								208.64	208.64										CANAL
104	AP-97	DD+18_1000M	3	680227.50	3186322.50	1132.97	31° 5' 48" RT			171.63	654.00	-920.00	-266.00	377.00	-308.00	69.00			STRENGTHENING CHECK REQUIRED
								134.63	134.63										
105	AP-98	DD+18_1000M		680192.50	3186452.50	1191.14	25° 33' 36" RT			135.96	1068.00	-148.00	920.00	456.00	-15.00	441.00			STRENGTHENING CHECK REQUIRED
								137.30	137.30										
106	AP-99	DD+6_1000M		680217.50	3186587.50	1213.31	32° 17' 34" LT			189.81	286.00	482.00	768.00	153.00	313.00	466.00			
								242.33	242.33										
107	AP-100	DD+0		680127.50	3186812.50	1189.59	36° 17' 34" LT			319.36	-241.00	605.00	364.00	-72.00	513.00	441.00			
								396.39	396.39										
108	AP-101	DBN+6_1000M		679791.00	3187022.00	1101.83	9° 38' 57" RT			304.10	-201.00	-147.00	-348.00	-109.00	-20.00	-129.00			
								211.81	211.81										
109	AP-102	DC+6		679632.50	3187162.50	1120.35	21° 57' 55" LT			270.69	359.00	614.00	973.00	232.00	450.00	682.00			STRENGTHENING CHECK REQUIRED
								329.58	329.58										
110	AP-103	DC+9_1000M	1.5	679322.00	3187273.00	1062.09	15° 45' 24" RT			231.23	-280.00	149.00	-131.00	-116.00	99.00	-17.00			
								132.87	132.87										
111	AP-104	DD+9_1000M		679213.62	3187349.87	1059.63	0° 0' 0"			139.15	-16.00	1527.00	1511.00	35.00	624.00	659.00			STRENGTHENING CHECK REQUIRED
								145.42	145.42										
112	AP-105	DD+9	1.5	679095.00	3187434.00	977.15	49° 41' 44" LT			183.67	-1362.00	1536.00	174.00	-459.00	820.00	361.00			STRENGTHENING CHECK REQUIRED
								221.92	221.92										
113	AP-106	DD+9		678880.00	3187379.00	856.75	5° 17' 31" LT			264.64	-1285.00	305.00	-980.00	-569.00	246.00	-323.00			STRENGTHENING CHECK REQUIRED
								307.36	307.36										
114	AP-107	DBN+6		678590.52	3187275.69	843.62	14° 42' 58" RT			230.48	4.00	419.00	423.00	63.00	218.00	281.00			
								153.59	153.59										
115	AP-108	DD+0	1.5	678437.50	3187262.50	830.33	34° 6' 37" LT			195.88	-266.00	843.00	577.00	-64.00	501.00	437.00			
								238.17	238.17										
116	AP-109	DC+3		678252.50	3187112.50	767.86	14° 58' 9" LT			348.55	-599.00	113.00	-486.00	-257.00	129.00	-128.00			
								458.93	458.93										CANAL
117	AP-110	DC+9		677982.78	3186741.19	796.10	10° 56' 58" LT			424.67	348.00	239.00	587.00	332.00	229.00	561.00			
								390.40	390.40										
118	AP-111	DC+9	3	677817.50	3186387.50	784.49	23° 38' 39" LT			348.50	151.00	258.00	419.00	161.00	222.00	383.00			
								306.59	306.59										

Sumit
(SKS)
(L&T Ltd)

राकेश चिल्का RAKESH CHILKA
उप प्रबंधक / DY. MANAGER
पौवरागिड रिगकिंग पावर ग्रिड यिङ्किङ्ग
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार का उद्यम)

JYOTIRMOY DEV
DEPUTY GENERAL MANAGER
POWERGRID, YINGKIONG, A.P.
(Government of India Enterprise)

119	AP-112	DD+9	3	677810.00	3186081.00	772.00	6° 40' 22" RT			299.24	39.00	-1111.00	1220.00	85.00	759.00	844.00	STRENGTHENING CHECK REQUIRED
								291.89	291.89								
120	AP-113	DD+9		677769.00	3185792.00	664.38	48° 46' 15" RT			338.85	-866.00	128.00	-738.00	-444.00	144.00	-300.00	CANAL, MUD ROAD
								385.81	385.81								
121	AP-114	DBN+3		677446.00	3185581.00	683.10	7° 54' 55" LT			332.18	260.00	-527.00	-267.00	245.00	-240.00	5.00	
								278.55	278.55								
122	AP-115	DD+9	3	677236.00	3185398.00	739.78	10° 32' 6" LT			274.52	812.00	75.00	887.00	526.00	102.00	628.00	
								270.50	270.50								
123	AP-116	DD+18		677068.00	3185186.00	739.35	33° 45' 32" RT			242.93	196.00	1225.00	1421.00	170.00	664.00	834.00	STRENGTHENING CHECK REQUIRED
								215.36	215.36								
124	AP-117	DD+18		676863.00	3185120.00	650.51	21° 22' 0" LT			212.87	-992.00	1344.00	352.00	-431.00	712.00	281.00	STRENGTHENING CHECK REQUIRED
								210.38	210.38								CANAL
125	AP-118	DD+3		676700.00	3184987.00	567.24	35° 17' 40" RT			251.53	-1111.00	230.00	-881.00	-479.00	197.00	-282.00	STRENGTHENING CHECK REQUIRED
								292.68	292.68								MUD ROAD, BT ROAD, RIVER
126	AP-119	DD+0		676408.00	3184967.00	562.07	52° 16' 41" RT			327.32	67.00	-525.00	-458.00	101.00	-304.00	-203.00	
								361.95	361.95								
127	AP-120	DD+0		676167.50	3185237.50	672.81	57° 3' 57" RT			383.72	909.00	27.00	936.00	688.00	64.00	752.00	STRENGTHENING CHECK REQUIRED
								405.48	405.48								
128	AP-121	DD+0		676275.35	3185628.38	712.35	38° 27' 9" RT			360.24	385.00	350.00	735.00	350.00	285.00	635.00	
								314.99	314.99								
129	AP-122	DD+3		676529.79	3185814.07	683.60	34° 57' 12" LT			299.65	-33.00	-178.00	-211.00	32.00	-43.00	-11.00	
								284.30	284.30								
130	AP-123	DBN+0		676622.00	3186083.00	717.67	6° 50' 41" LT			346.42	463.00	169.00	632.00	327.00	176.00	503.00	
								408.55	408.55								
131	AP-124	DC+9		676707.50	3186482.50	716.48	14° 14' 28" LT			336.87	240.00	-542.00	-302.00	233.00	-240.00	-7.00	
								265.19	265.19								
132	AP-125	DD+9		676697.50	3186747.50	778.66	57° 17' 56" LT			318.08	811.00	871.00	1682.00	510.00	672.00	1182.00	STRENGTHENING CHECK REQUIRED
								370.96	370.96								
133	AP-126	DBN+9		676378.00	3186936.00	668.02	7° 56' 1" RT			309.68	-486.00	-441.00	-927.00	-287.00	-180.00	-467.00	
								248.40	248.40								
134	AP-127	DC+3		676183.53	3187090.54	722.91	20° 42' 31" LT			239.52	694.00	183.00	877.00	433.00	151.00	584.00	STRENGTHENING CHECK REQUIRED
								230.65	230.65								
135	AP-128	DD+0		675963.88	3187160.92	720.65	39° 52' 44" RT			228.73	49.00	-656.00	-607.00	81.00	-279.00	-198.00	
								226.80	226.80								
136	AP-129	DD+9	3	675842.50	3187352.50	771.01	27° 27' 45" LT			212.46	892.00	-957.00	-65.00	515.00	-391.00	124.00	STRENGTHENING CHECK REQUIRED
								198.13	198.13								
137	AP-130	DD+9	3	675671.23	3187452.11	847.49	15° 9' 46" LT			331.36	1167.00	-249.00	918.00	602.00	-186.00	416.00	STRENGTHENING CHECK REQUIRED

Smith
(SKS)

(L&T Ltd)

राकेश चिल्का / RAKESH CHILKA
उप प्रबंधक / DY MANAGER
पावरग्रिड सिस्टम / POWER GRID - YINGKIONG
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार का उद्यम)

JYOTIRMOY DEV
DEPUTY GENERAL MANAGER
POWER GRID, YINGKIONG, A.P.
(Government of India Enterprise)

								464.60	464.60									
138	AP-131	DD+9_1000M	3	675222.50	3187572.50	1007.71	20° 17' 32"LT			285.04	741.00	-187.00	594.00	679.00	-27.00	652.00		STRENGTHENING CHECK REQUIRED
								105.48	105.48									
139	AP-132	DD+1_1000M		675117.50	3187562.50	1026.51	5° 25' 16"LT			106.24	292.00	964.00	1256.00	132.00	350.00	482.00		STRENGTHENING CHECK REQUIRED
								107.00	107.00									
140	AP-133	DD+0		675012.42	3187542.34	994.71	0° 0' 0"			112.77	-852.00	1313.00	461.00	-237.00	486.00	249.00		STRENGTHENING CHECK REQUIRED
								118.54	118.54									
141	AP-134	DD+9		674896.00	3187520.00	929.86	0° 14' 13"LT			351.49	-1182.00	536.00	-646.00	-355.00	521.00	166.00		STRENGTHENING CHECK REQUIRED
								584.43	584.43									
142	AP-135	DD+18	3	674322.50	3187407.50	810.14	48° 12' 6"LT			385.25	61.00	209.00	270.00	77.00	146.00	223.00		STRENGTHENING CHECK REQUIRED
								186.08	186.08									
143	AP-136	DD+25		674227.50	3187247.50	798.74	14° 55' 8"LT			212.54	-26.00	1353.00	1327.00	38.00	768.00	806.00		STRENGTHENING CHECK REQUIRED
								239.01	239.01									
144	AP-137	DD+9		674162.50	3187017.50	704.02	18° 5' 24"RT			339.31	-1089.00	178.00	-911.00	-504.00	185.00	-319.00		STRENGTHENING CHECK REQUIRED
								439.60	439.60									
145	AP-138	DBN+9		673917.50	3186652.50	715.50	5° 56' 5"LT			473.55	264.00	558.00	822.00	258.00	529.00	787.00		
								507.49	507.49									
146	AP-139	DD+0		673679.75	3186204.15	617.78	28° 46' 2"RT			446.51	-36.00	-150.00	-186.00	-6.00	-66.00	-72.00		UPDATED FROM TOWER TYPE DC TO DD TO AVOID WIND SPAN VIOILLATION
								385.54	385.54									
147	AP-140	DD+9		673357.50	3185992.50	674.35	39° 40' 54"LT			285.74	542.00	529.00	1071.00	457.00	295.00	752.00		
								185.93	185.93									
148	AP-141	DBN+9		673303.07	3185814.71	645.88	3° 19' 47"RT			208.80	-343.00	678.00	335.00	-108.00	409.00	301.00		STRENGTHENING CHECK REQUIRED
								231.67	231.67									AGRICULTURAL LAND
149	AP-142	DBN+3		673222.50	3185597.50	606.86	3° 21' 38"LT			209.94	-442.00	-42.00	-484.00	-173.00	31.00	-142.00		
								188.22	188.22									
150	AP-143	DBN+3		673167.50	3185417.50	615.65	7° 37' 58"RT			160.11	231.00	-164.00	67.00	158.00	-21.00	137.00		
								132.00	132.00									
151	AP-144	DBN+6		673112.50	3185297.50	622.97	13° 18' 49"LT			231.72	286.00	-97.00	199.00	153.00	-2.00	151.00		
								331.44	331.44									
152	AP-145	DBN+3		673047.50	3184972.50	658.16	9° 36' 49"LT			275.52	429.00	-22.00	407.00	335.00	43.00	378.00		
								219.60	219.60									
153	AP-146	DD+0		673041.00	3184753.00	671.11	31° 58' 30"RT			320.38	243.00	86.00	329.00	178.00	109.00	287.00		
								421.16	421.16									
154	AP-147	DD+6		672807.50	3184402.50	696.04	36° 11' 5"RT			385.53	341.00	1015.00	1356.00	319.00	739.00	1058.00		STRENGTHENING CHECK REQUIRED
								349.90	349.90									RIVER
155	AP-148	DD+0		672479.00	3184282.00	584.47	53° 22' 33"RT			330.97	-641.00	-877.00	-1518.00	-365.00	-470.00	-835.00		STRENGTHENING CHECK REQUIRED
								312.03	312.03									ARICULTURAL ROAD

Sush
(SKS)

(L&T LH)

राकेश चिल्का RAKESH CHILKA
उप प्रबंधक / DY MANAGER
पॉवरग्रिड यिंगकिंग POWERGRID YINGKIONG
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार का उद्यम)

JYOTIRMOY DEV
DEPUTY GENERAL MANAGER
POWERGRID, YINGKIONG, A.P.
(Government of India Enterprise)

156	AP-149	DD+9		672218.00	3184453.00	700	49° 11' 32" RT			309.61	1218.00	-1126.00	92.00	811.00	-613.00	198.00	STRENGTHENING CHECK REQUIRED
								307.18	307.18								
157	AP-150	DD+6		672177.50	3184757.50	866.19	20° 45' 26" RT			354.89	1477.00	-33.00	1444.00	964.00	11.00	975.00	STRENGTHENING CHECK REQUIRED
								402.80	402.80								
158	AP-151	DBN+6		672269.30	3185149.49	922.89	3° 1' 47" RT			276.30	442.00	681.00	1123.00	399.00	322.00	721.00	STRENGTHENING CHECK REQUIRED
								150.00	150.00								
159	AP-152	DBN+0	1.5	672311.18	3185293.52	895.79	9° 9' 41" RT			304.08	-527.00	511.00	-16.00	-168.00	472.00	304.00	
								458.17	458.17								
160	AP-153	DBN+0		672507.50	3185707.50	816.76	1° 28' 7" RT			461.64	-44.00	415.00	371.00	-5.00	392.00	387.00	
								465.11	465.11								CANAL
161	AP-154	DC+0		672717.50	3186122.50	761.43	18° 48' 39" LT			392.55	55.00	285.00	340.00	78.00	238.00	316.00	
								319.98	319.98								
162	AP-155	DC+0		672762.20	3186439.35	747.58	23° 7' 58" RT			334.21	35.00	-694.00	-659.00	83.00	-399.00	-316.00	STRENGTHENING CHECK REQUIRED
								348.43	348.43								CANAL
163	AP-156	DD+3		672942.50	3186737.50	870.08	13° 46' 58" LT			406.05	1064.00	112.00	1176.00	770.00	128.00	898.00	STRENGTHENING CHECK REQUIRED
								463.67	463.67								
164	AP-157	DD+18		673081.00	3187180.00	890.60	47° 57' 17" LT			277.87	352.00	-655.00	-303.00	336.00	-159.00	177.00	STRENGTHENING CHECK REQUIRED
								92.06	92.06								
165	AP-158	DD+9		673034.17	3187259.26	921.90	0° 0' 0"			126.31	748.00	1237.00	1985.00	252.00	564.00	816.00	STRENGTHENING CHECK REQUIRED
								160.56	160.56								
166	AP-159	DD+3		672952.50	3187397.50	858.69	8° 15' 19" RT			337.02	-1062.00	94.00	-968.00	-388.00	110.00	-278.00	STRENGTHENING CHECK REQUIRED
								513.47	513.47								
167	AP-160	DC+6		672757.50	3187872.50	916.02	14° 0' 27" LT			362.24	426.00	-700.00	-274.00	410.00	-287.00	123.00	STRENGTHENING CHECK REQUIRED
								211.01	211.01								
168	AP-161	DD+9		672632.50	3188042.50	973.35	8° 33' 14" LT			275.21	918.00	555.00	1473.00	506.00	424.00	930.00	STRENGTHENING CHECK REQUIRED
								339.41	339.41								
169	AP-162	DC+0		672393.00	3188283.00	932.22	25° 40' 35" RT			395.29	-211.00	14.00	-197.00	-79.00	45.00	-34.00	
								451.18	451.18								
170	AP-163	DC+6		672244.59	3188709.07	986.64	15° 23' 21" LT			283.09	443.00	106.00	549.00	412.00	75.00	487.00	
								115.00	115.00								
171	AP-164	DD+0		672179.30	3188803.74	990.70	36° 5' 28" RT			207.53	10.00	166.00	176.00	41.00	160.00	201.00	
								300.06	300.06								
172	AP-165	DC+0		672187.15	3189103.69	989.16	13° 43' 50" RT			370.84	136.00	-79.00	57.00	142.00	-31.00	111.00	
								441.62	441.62								
173	AP-166	DD+9_1000M		672303.16	3189529.79	1060.95	43° 22' 56" LT			290.39	528.00	173.00	701.00	480.00	108.00	588.00	
								139.17	139.17								
174	AP-167	DD+9_1000M		672237.50	3189652.50	1056.08	35° 38' 47" LT			159.03	-38.00	518.00	480.00	27.00	282.00	309.00	

Sumit
(SKS)

(LAT LH)

रकेश चिल्का RAKESH CHILKA
उप प्रबंधक / Dy. Manager
पॉवरग्रिड यिङ्किंग POWERGRID, YINGKIONG
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सर. प्रा. क. ए. ए. ए.)

ज्योतिर्मय देव JYOTIRMOY DEV
उप-प्रबंधक / Deputy General Manager
पॉवरग्रिड यिङ्किंग POWERGRID, YINGKIONG, A.P.
(Government of India Enterprise)

								178.90	179.90										
175	AP-168	DBN+6_1000M		672076.99	3189731.49	1032.47													
								461.88	461.88										BT ROAD
176	AP-169	DD+3_1000M		671651.00	3189910.00	1017.14													
								230.87	230.87										
177	AP-170	DD+0_1000M		671581.00	3190130.00	1072.36													
								197.10	756.00	-653.00	103.00	453.00	-257.00	196.00					STRENGTHENING CHECK REQUIRED
								163.34	163.34										
178	AP-171	DD+0_1000M		671597.50	3190292.50	1129.79													
								177.18	827.00	-501.00	326.00	431.00	-182.00	249.00					
								191.03	191.03										
179	AP-172	DBN+0_1000M		671612.74	3190482.92	1169.47													
								184.84	696.00	74.00	770.00	377.00	82.00	459.00					STRENGTHENING CHECK REQUIRED
								178.65	178.65										
180	AP-173	DC+6_1000M		671627.00	3190661.00	1164.40													
								269.91	104.00	672.00	776.00	96.00	526.00	622.00					STRENGTHENING CHECK REQUIRED
								361.16	361.16										
181	AP-174	DD+9_1000M		671517.00	3191005.00	1085.36													
								318.24	-302.00	-51.00	-353.00	-156.00	30.00	-126.00					
								275.31	275.31										
182	AP-175	DC+9_1000M	3	671588.00	3191271.00	1100.35													
								284.48	330.00	-345.00	-16.00	248.00	-142.00	106.00					
								293.64	293.64										
183	AP-176	DD+9_1000M		671768.00	3191503.00	1153.86													
								256.98	645.00	-1137.00	-492.00	442.00	-502.00	-60.00					STRENGTHENING CHECK REQUIRED
								220.32	220.32										
184	AP-177	DD+9_1000M		671902.50	3191677.50	1259.39													
								334.88	1381.00	222.00	1603.00	746.00	223.00	969.00					STRENGTHENING CHECK REQUIRED
								449.44	443.44										
185	AP-178	DD+18_1000M		672062.50	3192097.50	1251.25													
								323.52	228.00	138.00	366.00	228.00	117.00	345.00					
								197.60	197.60										
186	AP-179	DD+18_1000M	3	672115.00	3192288.00	1245.58													
								205.68	58.00	1890.00	1948.00	79.00	965.00	1044.00					STRENGTHENING CHECK REQUIRED
								213.77	213.77										
187	AP-180	DD+9_1000M	1.5	672072.50	3192497.50	1093.08													
								381.71	-1623.00	1025.00	-598.00	-697.00	955.00	258.00					BT ROAD
								549.66	549.66										STRENGTHENING CHECK REQUIRED
188	AP-181	DD+25		671787.50	3192967.50	794.40													
								445.19	-406.00	1371.00	965.00	-335.00	952.00	617.00					STRENGTHENING CHECK REQUIRED
								340.73	340.73										
189	AP-182	DD+25		671451.00	3193021.00	626.86													
								372.81	-993.00	700.00	-284.00	-574.00	600.00	26.00					STRENGTHENING CHECK REQUIRED
								404.89	404.89										
190	AP-183	DC+0		671047.49	3192987.62	545.72													
								457.96	-291.00	44.00	-247.00	-181.00	66.00	-115.00					
								511.03	511.03										
191	AP-184	DD+3		670557.50	3192842.50	619.90													
								339.58	477.00	980.00	1466.00	456.00	483.00	939.00					STRENGTHENING CHECK REQUIRED
								168.13	168.13										
192	AP-185	DD+6		670411.00	3192925.00	561.34													
								251.70	-807.00	856.00	49.00	-301.00	615.00	314.00					
								335.27	335.27										RIVER

Sumit
(SKS)

(LAT Ltd)

राकेश चिल्का / RAKESH CHILKA
उप प्रबंधक / DY. MANAGER
पावरग्रिड सिस्टीम / POWERGRID, YINGKIONG
(GOVERNMENT OF INDIA ENTERPRISE,
भारत सरकार का अधिनियम)

JYOTIRMOY DEV
DEPUTY GENERAL MANAGER
POWERGRID, YINGKIONG, A.P.
(Government of India Enterprise)

193	AP-186	DD+9	670337.00	3193252.00	471.32	49° 16' 22" RT		282.74	-505.00	1516.00	-2021.00	-264.00	-698.00	-962.00	STRENGTHENING CHECK REQUIRED
							230.20	230.20							
194	AP-187	DD+9	670474.00	3193437.00	637.32	34° 32' 48" RT		169.81	-1804.00	-1236.00	568.00	985.00	-356.00	629.00	STRENGTHENING CHECK REQUIRED
							109.42	109.42							
195	AP-188	DD+3	670577.50	3193472.50	698.38	2° 59' 11" RT		127.51	1360.00	-667.00	693.00	480.00	-222.00	258.00	STRENGTHENING CHECK REQUIRED
							145.60	145.60							
196	AP-189	DD+6	670717.50	3193512.50	736.68	34° 4' 11" LT		178.02	817.00	575.00	1392.00	372.00	337.00	709.00	
							210.44	210.44							
197	AP-190	DBN+3	670852.73	3193673.74	705.84	0° 0' 0"		173.91	-363.00	565.00	202.00	-125.00	260.00	135.00	
							137.38	137.38							
198	AP-191	DD+6	670941.00	3193779.00	679.42	17° 21' 14" LT		168.09	-427.00	1367.00	940.00	-121.00	695.00	574.00	STRENGTHENING CHECK REQUIRED
							198.81	198.81							
199	AP-192	DD+3	671017.50	3193962.50	587.84	9° 9' 57" LT		281.92	-1148.00	131.00	-1017.00	-476.00	145.00	-331.00	STRENGTHENING CHECK REQUIRED
							365.03	365.03							
200	AP-193	DD+9	671102.50	3194317.50	590.15	28° 35' 21" LT		374.15	233.00	432.00	665.00	219.00	373.00	592.00	UPDATED FROM TOWER TYPE DC TO DD TO AVOID WIND SPAN VILATION
							383.28	383.28							
201	AP-194	DBN+0	671002.50	3194687.50	554.43	13° 53' 25" LT		341.07	-47.00	-620.00	-667.00	12.00	-305.00	-293.00	STRENGTHENING CHECK REQUIRED
							298.86	298.86							
202	AP-195	DD+0	670857.55	3194948.85	636.98	20° 34' 28" RT		406.79	931.00	135.00	1066.00	615.00	147.00	762.00	STRENGTHENING CHECK REQUIRED
							514.72	514.72							BT ROAD, AGRICULTURAL LAND
203	AP-196	DD+3	670782.00	3195458.00	679.14	40° 48' 44" LT		352.73	383.00	129.00	512.00	372.00	111.00	483.00	
							190.74	190.74							
204	AP-197	DD+3	670637.50	3195582.50	676.91	45° 32' 12" RT		288.27	62.00	538.00	600.00	80.00	457.00	537.00	
							385.81	385.81							CANAL
205	AP-198	DD+0	670612.50	3195967.50	614.47	50° 21' 28" RT		291.59	-142.00	-792.00	-934.00	-60.00	-326.00	-386.00	
							197.36	197.36							
206	AP-199	DD+3	670756.00	3196103.00	679.05	19° 52' 38" RT		192.17	1004.00	-612.00	392.00	538.00	-230.00	308.00	STRENGTHENING CHECK REQUIRED
							186.98	186.98							
207	AP-200	DD+3	670927.50	3196177.50	725.84	1° 29' 21" RT		233.69	806.00	790.00	1396.00	424.00	514.00	938.00	STRENGTHENING CHECK REQUIRED
							280.40	280.40							
208	AP-201	DD+0	671187.50	3196282.50	665.72	39° 42' 29" LT		250.94	-504.00	-206.00	-710.00	-228.00	-50.00	-278.00	
							221.47	221.47							BT ROAD
209	AP-202	DBN+3	671292.50	3196477.50	686.53	11° 26' 3" RT		278.43	427.00	362.00	789.00	271.00	295.00	566.00	
							335.39	335.39							BT ROAD
210	AP-203	DBN+0	671506.90	3196735.42	664.88	8° 24' 49" RT		319.13	-25.00	455.00	430.00	43.00	336.00	379.00	
							302.88	302.88							AGRICULTURAL LAND
211	AP-204	DD+0	671732.50	3196937.50	632.65	43° 15' 41" RT		263.22	-148.00	-322.00	-470.00	-29.00	-109.00	-138.00	

Sumit
(SKS)
(LAT Ltd)

रकेश चिल्का RAKESH CHILKA
उप प्रबंधक / DY. MANAGER
पॉवरग्रिड यिंकांग POWERGRID YINGKONG
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार की उद्यम)

ज्योतिर्मोय देव JYOTIRMOY DEV
DEPUTY GENERAL MANAGER
POWERGRID, YINGKONG, A.P.
(Government of India Enterprise)

							223.57	223.57												AGRICULTURAL LAND
212	AP-205	DD+6	671956.00	3196932.00	660.24	33° 42' 51" LT			177.74	549.00	-797.00	-248.00	336.00	-249.00	87.00					
							131.92	131.92												
213	AP-206	DD+0	672067.50	3197002.50	706.42	32° 28' 7" LT			214.36	932.00	994.00	1926.00	384.00	649.00	1033.00					STRENGTHENING CHECK REQUIRED
							296.81	296.81												
214	AP-207	DBN+3	672194.00	3197271.00	614.26	5° 1' 47" RT			294.27	-685.00	-60.00	-745.00	-340.00	26.00	-314.00					STRENGTHENING CHECK REQUIRED
							291.74	291.74												AGRICULTURAL LAND
215	AP-208	DD+9	672341.00	3197523.00	628.38	54° 22' 28" LT			211.34	350.00	-36.00	314.00	265.00	27.00	292.00					
							130.93	130.93												
216	AP-209	DD+3	672287.50	3197642.50	638.89	51° 21' 35" RT			349.47	166.00	230.00	396.00	104.00	235.00	339.00					STRENGTHENING CHECK REQUIRED
							568.00	568.00												
217	AP-210	DD+6	672547.50	3198147.50	661.05	30° 22' 29" RT			384.36	347.00	1049.00	1396.00	343.00	553.00	896.00					STRENGTHENING CHECK REQUIRED
							200.72	200.72												
218	AP-211	DD+9	672717.00	3198255.00	590.07	55° 8' 9" LT			238.99	-638.00	363.00	-475.00	-342.00	266.00	-76.00					
							277.26	277.26												AGRICULTURAL LAND
219	AP-212	DBN+0	672729.00	3198532.00	578.06	3° 33' 17" RT			252.76	-87.00	176.00	89.00	10.00	146.00	156.00					
							228.27	228.27												
220	AP-213	DBN+3	672753.00	3198759.00	570.28	0° 39' 40" RT			176.31	52.00	355.00	407.00	82.00	169.00	251.00					
							124.35	124.35												
221	AP-214	DBN+6	672767.50	3198882.50	554.52	1° 2' 53" LT			290.78	-230.00	441.00	211.00	-44.00	413.00	369.00					
							457.22	457.22												BT ROAD,RIVER
222	AP-215	DD+0	672812.50	3199337.50	499.79	24° 55' 52" RT			292.49	23.00	-1363.00	-1340.00	52.00	-427.00	-375.00					STRENGTHENING CHECK REQUIRED
							127.77	127.77												
223	AP-216	DD+6	672877.50	3199447.50	565.90	21° 7' 1" LT			185.54	1509.00	-321.00	1188.00	574.00	-114.00	460.00					STRENGTHENING CHECK REQUIRED
							243.31	243.31												
224	AP-217	DC+3	672917.50	3199687.50	605.79	19° 19' 54" LT			289.39	565.00	401.00	966.00	358.00	320.00	678.00					
							335.47	335.47												
225	AP-218	DC+3	672860.00	3200018.00	576.30	15° 2' 33" RT			289.73	-54.00	25.00	-39.00	17.00	70.00	87.00					
							243.99	243.99												
226	AP-219	DBN+9	672882.00	3200261.00	578.39	4° 38' 33" RT			268.64	220.00	198.00	418.00	175.00	177.00	352.00					
							293.29	293.29												
227	AP-220	DBN+9	672932.00	3200550.00	573.28	3° 28' 16" RT			310.46	95.00	218.00	313.00	117.00	198.00	315.00					
							327.63	327.63												
228	AP-221	DBN+3	673007.30	3200868.86	572.90	7° 10' 8" RT			307.18	110.00	194.00	304.00	130.00	173.00	303.00					
							286.72	286.72												
229	AP-222	DC+3	673107.50	3201137.50	567.98	21° 42' 3" RT			250.27	94.00	264.00	358.00	115.00	186.00	301.00					
							213.81	213.81												AGRICULTURAL LAND

Sunsh
(SKS)
(L&T Ltd)

रकेश चिल्का RAKESH CHILKA
उप-प्रबन्धक / DY MANAGER
पॉवरग्रिड यिङ्किंग POWERGRID YINGKIONG
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार का उद्यम)

मोर्चमोय देव MOYMOY DEV
DEPUTY GENERAL MANAGER
POWERGRID, YINGKIONG, A.P.
(Government of India Enterprise)

230	AP-223	DBN+9		673251.00	3201296.00	550	2° 47' 29"LT		261.17	-49.00	50.00	1.00	29.00	92.00	121.00	
									308.52	308.52						
231	AP-224	DBN+3		673446.68	3201534.53	567.56	13° 13' 49"RT		255.49	259.00	-104.00	155.00	218.00	2.00	220.00	
									202.45	202.45						
232	AP-225	DBN+3		673607.50	3201657.50	581.70	12° 54' 36"LT		253.91	307.00	191.00	498.00	201.00	176.00	377.00	
									305.37	305.37						CANAL
233	AP-226	DC+0		673802.50	3201892.50	580.59	22° 18' 19"RT		285.77	115.00	-438.00	-323.00	130.00	-186.00	-56.00	
									266.18	266.18						
234	AP-227	DBN+3		674037.50	3202017.50	630.93	4° 15' 59"LT		245.45	711.00	-162.00	549.00	458.00	-28.00	430.00	STRENGTHENING CHECK REQUIRED
									224.72	224.72						
235	AP-228	DD+9	3	674227.50	3202137.50	642.81	23° 26' 23"LT		236.80	386.00	-1079.00	-693.00	253.00	-509.00	-256.00	STRENGTHENING CHECK REQUIRED
									248.87	248.87						
236	AP-229	DD+9	3	674367.69	3202343.13	756.30	23° 12' 5"LT		213.57	1350.00	979.00	2329.00	780.00	491.00	1271.00	STRENGTHENING CHECK REQUIRED
									178.28	178.28						
237	AP-230	DD+9		674401.96	3202518.08	701.44	42° 45' 44"RT		284.85	-790.00	91.00	-699.00	-302.00	119.00	-183.00	
									391.41	391.41						CANAL
238	AP-231	DD+9		674718.00	3202749.00	720.60	41° 21' 23"RT		276.26	305.00	-539.00	-234.00	278.00	-184.00	94.00	
									161.11	161.11						
239	AP-232	DBN+6		674878.45	3202734.39	760.88	1° 47' 56"LT		222.83	706.00	68.00	774.00	352.00	98.00	450.00	STRENGTHENING CHECK REQUIRED
									284.55	284.55						
240	AP-233	DBN+9		675162.50	3202717.50	765.65	8° 47' 41"LT		311.79	217.00	373.00	590.00	187.00	303.00	490.00	
									339.03	339.03						
241	AP-234	DC+0		675500.03	3202749.36	748.09	19° 19' 56"LT		341.24	-33.00	93.00	60.00	36.00	119.00	155.00	
									343.45	343.45						CANAL
242	AP-235	DD+0		675812.00	3202893.00	758.78	10° 33' 35"LT		276.46	250.00	-1076.00	-826.00	224.00	-457.00	-233.00	STRENGTHENING CHECK REQUIRED
									209.48	209.48						
243	AP-236	DD+6		675983.00	3203014.00	845.17	48° 44' 18"LT		155.30	1302.00	-712.00	590.00	684.00	-184.00	500.00	STRENGTHENING CHECK REQUIRED
									101.12	101.12						
244	AP-237	DD+0		675993.53	3203114.57	877.15	27° 42' 10"LT		202.57	813.00	-132.00	681.00	285.00	-19.00	266.00	
									304.03	304.03						
245	AP-238	DD+9		675881.00	3203397.00	898.05	21° 43' 27"RT		277.51	438.00	205.00	643.00	324.00	170.00	494.00	
									251.00	251.00						
246	AP-239	DD+9 (ICE)		675881.00	3203648.00	888.14	40° 10' 33"RT		125.50	50.00	0.00	50.00	85.00	0.00	85.00	
							Total Length=		67220.790							

Sumit
(SKS)
(LAT LAL)

राकेश चिल्का / RAKESH CHILKA
रूप प्रबंधक / DY. MANAGER
पावरग्रिड यिङ्किंग / POWERGRID YINGKIONG
(GOVERNMENT OF INDIA ENTERPRISE)
(भारत सरकार का उद्यम)

श्री. मोर्तमोय देव
DEPUTY GENERAL MANAGER
POWERGRID, YINGKIONG, A.P.
(Government of India Enterprise)