

Clarifications for the Queries raised

Tender: RFX No.5002004796

Project : 400 kV AIS Substation Extension Package of Kurnool-3 PS due to re arrangement in Electrical Layout in Kurnool - III Pooling Station

Ref : Section Project, Annexure IV & Schedule of Prices 1 & 3.

S. No.	Item Description	Bidder Query	POWERGRID Clarification
1	Section Project – Civil Works – D (iii) (Page No. 6)	Dismantling & re erection of chain link fencing work is included in the scope whereas there is no mention of this item in the price schedule no. 3	In case of execution of this item as per site conditions, suitable amendment shall be issued.
2	Section Project – Civil Works – E (Page No. 7), 3-g (Specific Exclusions) (Page No. 9)	This referred clauses specifies, chain link fencing is covered under separate package and are excluded. This is contradicting your clause D(iii) referred above.	
3	Section Project – Civil Works – E (iii) (Page No. 7)	Fire resistant wall. There is no separate item in price schedule. Please clarify under which item no. in price schedule 3 this work is covered.	Items required for the construction of firewall are already included in the Civil works BOQ items (PCC, RCC, Reinforcement steel, etc.,).
4	Section Project – Item F (Page No. 4)	As per this 1.1 kV Grade Power & Control Cables are included in the scope, however there is no mention of supply of this item in price schedule 1 and neither it's covered under erection hard wares or any other heading in SOW & Section Project. In case we need to supply this cable, please let us know what these cables are for and where to be used.	All the required power & control cables shall be provided by the owner and laying of Power and control cables as per section technical specifications is to be done by the agency.
5	Annexure - IV	The Column 5 heading is misleading as it says qty of deferred scope which are already available at site / to be supplied in existing (this) package and your column 6 heading says additional supply quantity required for deferred scope. Suggest remove the sentence “to be supplied in existing (this) package” from column 5 heading.	Column-5 heading of the Annexure-IV is updated.
6	Annexure - IV	As per item nos. 23, 24 & 25 the qty required for this project are 10, 12 & 12 respectively to be supplied whereas as per price schedule 1, item nos. 5, 6 & 7 and price schedule 3 item nos. 23, 24 & 25, the qty are 12, 42 & 42. Please clarify	Quantity of item nos. 23, 24 & 25 in the Annexure-IV is updated as 12, 42 & 42 (In line with BOQ quantities).

S. No.	Item Description	Bidder Query	POWERGRID Clarification
7	Annexure - IV	Item no. 45 specifies Line Current Differential Relay is 10 Nos. Whereas there is no mention of this in your erection price schedule 3. We presume we need not have to do anything pertaining to this item installation. Please confirm.	Installation of line differential relay is the part of installation & commissioning of 220KV line protection panel.
8	Price Schedule No. 3	As per item nos. 48, 49 & 50, We have to lay 1.1 kV grade Control Cables, PVC Power Cables and XLPE power Cables on LS basis. However there is no supply of these cables in price schedule 1.	Item no. 48,49 & 50 are deleted in the Price schedule and updated price schedule is attached as Price_Schedule_R2.
9	Price Schedule No. 3	Item No. 86 to 97 , various type of cables laying. We have noted that these cables are already available with you as per Annexure -IV, Item Nos. 50 to 59, 61to 63. Please clarify what is the difference between these cables and item no. 48,49 & 50 cables mentioned in Lump Sum qty.	